



earth wind and fire

BLDG ID #0696

Name of Client: KERRISDALE STATION LTD.		Name of Building or Site: KERRISDALE STATION NORTH	
Billing Address: C/O HATHSTAUWK PROPERTY MANAGEMENT LTD. 200 - 4580 COWLEY CRESCENT RICHMOND, B.C. V7B 1B8		Site Address: 2052 WEST 41ST AVE VANCOUVER, B.C. V6M 1Y8	
#	Contact Names:	Contact Phone:	Email:
	WINNIE NG (PM)	604-272-7494	WNG@HATHSTAUWK.COM
	HARRY DHALI WAL	604-219-2723	HDHALIWAL@HATHSTAUWK.COM
	RONI	236-858-8944	KSCARETAKER@HATHSTAUWK.COM
			Position:
			Property Manager
			Property Manager
			Caretaker

Estimate of Servicing hours:	7.00		
Building year:	1980'S	Class:	
Repair Budget:	\$700	Stories:	

SERVICE ITEMS

Items:	No:
Fire Alarm	1
Fire Extinguishers	10
Number of In-suites	
Emergency Lighting	14
Cross Connections / Backflows	3
Wet Sprinkler system	4
Dry Sprinkler system	2
Quantity of Low Points	16
Standpipe	1
Fire Hydrant	
Kitchen Systems	

Locations

Fire Panel	GROUND FLOOR LOBBY
Booster	
Sprinkler System	PARKADE MECHANICAL
Signal Disconnect	FACP
Relay Disconnect	FACP

FOR OFFICE USE:

File #	#0696
Acquired date:	May 1, 2021
Fire Safety Plan:	
Keys:	11B
Agreement Expires	2026

SPECIAL REQUESTS:

Credit status:	current
-----------------------	---------

Monitoring

Company:	CHUBB	Acct #:	181443
Phone Number:	604-685-4274	Password:	COLLIERS

Elevator Company

RICHMOND

Technician notes:

FACP 'SILENT TEST' TIMES OUT AND SELF RESTORES
MUST RESET MAGLOCKS IN P1 ELEC ROOM (KEY SWITCH LIGHT SHOULD BE RED) BEFORE FINISHING
DBO

15 LP"s + 1 IN ELEVATOR PIT

WET SPRINKLER TAMPER LED's ARE BEHIND MAIN PANEL

Scheduling notes:

CRU 2050 OPENS @ 11AM

Service Schedule:	Est. time
JANUARY: ANNUAL	7
SPRING: APR/MAY	3
WINTER: OCT/NOV	1.5