



earth wind and fire

BLDG ID #0515

Name of Client:

BCS 2591

Name of Building or Site:

THE EMPORIO BCS 2591

Billing Address:

C/O RANCHO MANAGEMENT SERVICES
8TH FLOOR - 1125 HOWE STREET
VANCOUVER, BC V6Z 2K8

Site Address:

6351 BUSWELL STREET
RICHMOND, BC V6B 5P2

Contact Names:

SUBE YOUNG

DOMINIC

Contact Phone:

604-684-4508 D:604-331-4230

604-250-9217

Email:

sube.young@ranchogroup.com

emporio@ranchogroup.com

Position:

PROPERTY MANAGER

CARETAKER

Estimate of Servicing hours:

2.5 DAYS 2 TECHS

Building year:

2007

Class:

Repair Budget:

800

Stories:

SERVICE ITEMS

Items:

No:

Fire Alarm	1
Fire Extinguishers	30
Number of In-suites	93
Emergency Lighting	4
Cross Connections / Backflows	1 of 3
Wet Sprinkler system	1
Dry Sprinkler system	3
Quantity of Low Points	33
Standpipe	Yes
Fire Pump (RICHTEK)	Yes
Generator (FRONTIER)	Yes

Locations

Fire Panel	CACF - LOBBY / PANEL- ED RM
Booster	
Sprinkler System	DPV SERVICE ROOM SOUTH
Signal Disconnect	
Relay Disconnect	

FOR OFFICE USE:

File #	#0515
Acquired date:	October 1, 2017
Fire Safety Plan:	
Keys:	#17B
Agreement Expires	2026

SPECIAL REQUESTS:

Credit status:

current

Monitoring

Company:

TYCO

Acct #:

G272101937

Phone Number:

1-800-289-2647

Password:

SUSHI

Elevator Company

WEBB

WEBB ELEVATOR PHONE - 2X 12V 1.3A

Technician notes:

FRONT DOOR REMAINS OPEN WHEN PANEL GOES INTO ALARM
RESET SEC.PANEL IN TELEPHONE ROOM TO LOCK DOORS
BD/RD (NEW 2018)
MAY NEED TO ENABLE THESE DEVICES BEFORE JUMPING
BD/RD OM CACF
1020146
1E+07
(PWD: 2222)
TRY JUMPERS FIRST WHEN DONE, REPLACE RESISTORS AND RESET

GENERATOR - FRONTIER 1-877-946-5531

Service Schedule:

Est. time

SPRING: APRIL/MAY DRY ONLY	
NOVEMBER: ANNUAL, WINTER AND WET	