



earth wind and fire

BLDG ID #0660

Name of Client:		Name of Building or Site:	
LMS 3460 - THE ANSONIA		THE ANSONIA	
Billing Address:		Site Address:	
C/O TRIBE MANAGEMENT		2268 REDBUD LANE	
#400 - 11950 80TH AVENUE		VANCOUVER, BC	
DELTA, BC V4C 1Y2		V6K 4S6	
#	Contact Names:	Contact Phone:	Email:
	ROB MARTIN	604-635-5000 x 5087	rob.martin@tribemgmt.com
	WARD & LYNN STENDAHL	604-739-6022 cell: 604-355-5569	ward@inscript.ca
			Position:
			PROPERTY MANAGER
			STRATA PRESIDENT

Estimate of Servicing hours:	2 DAYS 2 TECHS		
Building year:	1998	Class:	
Repair Budget:		Stories:	

SERVICE ITEMS

Items:	1
Fire Alarm	12
Fire Extinguishers	81
Number of In-suites	23
Emergency Lighting	1 & 1
Cross Connections / Backflows	1
Wet Sprinkler system	2
Dry Sprinkler system	15
Quantity of Low Points	
Standpipe	
Fire Hydrant	
Kitchen Systems	

Locations

Fire Panel	LOBBY
Booster	
Sprinkler System	P1
Signal Disconnect	
Relay Disconnect	

FOR OFFICE USE:

File #	0660
Acquired date:	July 1, 2022
Fire Safety Plan:	YES
Keys:	
Agreement Expires	2026

SPECIAL REQUESTS:

Credit status:	current
-----------------------	---------

Monitoring

Company:	CHUBB	Acct #:	159002
Phone Number:	1-800-387-0771	Password:	5057

Elevator Company

Technician notes:

(NO EQUIPMENT TO BE TESTED IN SHAFT)
EL BREAKERS P2 ELECTRICAL ROOM/BELL DISCONNECT
IS ON PAGING SYSTEMS/ EG. PAGING 1 SIG 12 CIRCUITS
CCN: 7J46-Q5XN

CRITICAL DETAILS FOR TECH SUMMARY!!

***MUST RESET KEY IN THE ELECTRICAL ROOM SO ALL DOORS CAN
LOCKED. MUST BE RESET EACH TIME AN ALARM IS CAUSED.

***SUMP ALARMS MUST BE CLEARED BEFORE FA WILL CLEAR, LOWER EAST
P2 AREA. OPEN BOX AND MANUALLY RUN 2 PUMPS TILL RED LIGHT GOES AW

SPECIAL NOTE: RESET DOOR RELEASE ON P2 COMM ROOM

Scheduling notes:

Service Schedule:	Est. time
JULY: ANNUAL	
WINTER: OCT/NOV	