



earth wind and fire

BLDG ID #0309

Name of Client:	Name of Building or Site:			
S.U.C.C.E.S.S	SOLHEIM PLACE			
Billing Address:	Site Address:			
28 WEST PENDER STREET	251 UNION STREET			
VANCOUVER, BC	VANCOUVER, BC			
V6B 1R6				
#	Contact Names:	Contact Phone:	Email:	Position:
	LAWRENCE LAM	778-319-2826 X 1062	LAWRENCE.LAM@SUCCESS.BC.ca	
	FRANCOIS	604-785-0009	FRANCOIS.CADIEUX@SUCCESS.BC.ca	
	SUCCESS OFFICE	604-408-7234		

Estimate of Servicing hours:	13 HRS 2 TECHS
Building year:	Class:
Repair Budget:	Stories:
800	

SERVICE ITEMS

Items:	No:
Fire Alarm	
Fire Extinguishers	28
Number of In-suites	86
Emergency Lighting	4
Cross Connections / Backflows	3 DBO
Wet Sprinkler system	1
Dry Sprinkler system	1
Quantity of Low Points	3
Standpipe	1
Fire Hydrant	
Kitchen Systems	

Locations

Fire Panel	LOBBY
Booster	5 MAIN ELEC RM 1ST - 5 SET 12V
Sprinkler System	
Signal Disconnect	
Relay Disconnect	

DPV NE MECH RM 4" - RELIABLE

FOR OFFICE USE:

File #	#0309
Acquired date:	August 1, 2012
Fire Safety Plan:	
Keys:	#18A TAG COLOUR: ORANGE
Agreement Expires	2026

SPECIAL REQUESTS:

Monitoring

Company:	TELUS	Acct #:	TC-44-09-2689
Phone Number:	604-731-4126	Password:	

Elevator Company

RICHMOND

Technician notes:

LEAVE 1ST PULL STATION OPEN TO DEFEAT 1 MIN INHIBITER
*FOR BOILER BF TURN OFF BREAKER (NEXT TO BF-LABELLED) BEFORE TESTING SO DOESN'T OVERHEAT.
*WATER MUST BE SHUT DOWN FOR 5-15 MINS FOR SERVICING THE MAIN WATER SUPPLY BACKFLOW.

JIM KELLY 604-652-3971 TRAYNOR MECH SPKLR

Scheduling notes:

Service Schedule:

Est. time

MAY: ANNUAL, BF	
WINTER: OCT/NOV	



earth wind and fire

BLDG ID #0309

Credit status:

current