



B2 – BACnet / Modbus (Advanced)

Modbus - Workshop III

RTU

B2 - Modbus - Workshop III – RTU - Network



First define the network addresses within your group

Group 1: Modbus Addresses 10..19

Group 2: Modbus Addresses 20..29

Group 3: Modbus Addresses 30..39

Group 4: Modbus Addresses 40..49

Group 1: IP Adresses 192.168.0.10..19

Group 2: IP Adresses 192.168.0.20..29

Group 3: IP Adresses 192.168.0.30..39

Group 4: IP Adresses 192.168.0.40..49

— Serial network (RS485)

— IP Subnet 192.168.0.1 – 192.168.0.254

B2 - Modbus - Workshop III – RTU

1. **Start Modbus Poll.**
2. **Read out all the devices on the RTU network.**
3. **Add an additional device to the network.**
4. **Read it out.**