



Final Test - Solution

2019 Bus Basics B1 EN

Course/Class: B1

Name:

First Name:

Date:

Test duration: 20 minutes

Examiner: Benjamin Ott, Igor Malvone, Thorben Flach, Katrin Blattner-Kempin

Point maximum: 18 points reached:

Signature:..... Date:

Please write a cross in the square field for **all** correct statements.

Building Automation

1. Exercise

1 point

If I use communicative actuators instead of those with analogue control without feedback, I have in the project:

More cabling effort	☐
Knowledge of damper/valve position	☒
Status information of the device	☒

2. Exercise

1 point

Each fieldbus protocol has defined the following points:

Topology & Cabling	☒
Predefined addresses, worldwide unique	☐
Rules for transmission	☒
Address of the device	☒

Protocol MP-Bus

3. Exercise

1 point

Which tools can be used to parameterise the LMV-D3-MP?

PC tool	☒
ZTH EU	☒
NFC Assistant App	☒
Belimo CLOUD	☐

4. Exercise

1 point

Which actuators can be operated via MP-Bus?

LM24A-MP	☒
LR24A MOD	☒
PRCA-BAC	☒
CQ24A-BAC	☐

5. Exercise

1 point

What tools are available to analyse the MP-Bus?

PC tool	☒
ZTH EU	☒
NFC Assistant App	☐
ZIP-BT-NFC	☐

Protocol Modbus

6. Exercise

1 point

Is it true that ALL Belimo MOD-actuators and MOD-sensors support the hybrid mode?

Yes	☐
No	☒

7. Exercise

1 point

The Modbus slave (actuator or sensor) sends the following information back to the master in case of a READ Register command:

All available registers	☐
Only the value of the register	☒
Text and value of the register	☐
Only the description of the register	☐

8. Exercise

1 point

Can the customer change the Belimo Modbus register numbers and values (documented in the Register Description) for an existing product?

Yes	☐
No	☒
Partially	☐

Protocol BACnet

9. Exercise

1 point

Where do I find the BACnet objects and services available for a specific Belimo device:

In SAP	☐
In the data sheet	☐
In Register Descriptions	☐
In the PICS	☒

10. Exercise

1 point

If I use BACnet as protocol, which information can be read from a BACnet actuator?

Current Values	☒
Object Name, Device Name	☒
Unit of value	☒

11. Exercise

1 point

BACnet MS/TP is based on:

RS-485 (Serial) communication	☒
IP communication	☐
Cloud communication	☐

KNX bus protocol

12. Exercise

1 point

Does every KNX device manufacturer offer its own commissioning tool to the customers for configuration and commissioning?

Yes	☐
No	☒
Only partially possible	☐

13. Exercise

1 point

Is it possible that Belimo KNX actuators can be first time addressed with the manufacturer-independent ETS software via their KNX serial number for a location-independent commissioning (instead of having to press the commissioning button for each device on site)?

Yes	☒
No	☐
Only partially possible	☐

IT Basics and IoT

14. Exercise

1 point

What does a router do?

Forward packages	☒
Connecting end devices to each other	☐
Connecting networks	☒
De-modelling a signal	☐

15. Exercise

1 point

What does DNS do?

Connecting networks	☐
Connect end devices to each other	☐
Assign IP address	☐
Convert domain name to IP address	☒

16. Exercise

1 point

What do I need or have to do to connect the Belimo Energy Valve to the cloud?

Activate the Cloud in EV	☒
Register on the Belimo Cloud	☒
Download Certificate	☐
Internet Access	☒

Bus communication in the building

17. Exercise

1 point

The UK24-MOD gateway translates which of the following protocols?

KNX	☐
MP-Bus	☒
BACnet	☐
Modbus	☒

18. Exercise

1 point

How can I find out which products support which interfaces and features?

Bus Brochure	☒
Belimo App	☐
Website Product: System Integration	☒
Online Tool for Device Selection	☒