

OpenStudio Results

Model Summary

Building Summary

Information	Value	Units
Building Name	Building 1	building_name
Net Site Energy	12,020,236	kBtu
Total Building Area	120,556	ft^2
EUI (Based on Net Site Energy and Total Building Area)	99.71	kBtu/ft^2
OpenStudio Standards Building Type		

Weather Summary

	Value
Weather File	Ahmedabad Gujarat IND ISHRAE WMO#=426470
Latitude	23.07
Longitude	72.63
Elevation	180 (ft)
Time Zone	5.50
North Axis Angle	0.00
ASHRAE Climate Zone	

Sizing Period Design Days

	Maximum Dry Bulb (F)	Daily Temperature Range (R)	Humidity Value	Humidity Type	Wind Speed (mph)	Wind Direction
AHMEDABAD ANN CLG .4% CONDNS DB=>MWB	107.6	23.22	73.76	Wetbulb [F]	7.16	270.0
AHMEDABAD ANN CLG .4% CONDNS DP=>MDB	87.44	23.22	81.32	Dewpoint [F]	7.16	270.0
AHMEDABAD ANN CLG .4% CONDNS ENTH=>MDB	93.02	23.22	40.2	Enthalpy [Btu/lb]	7.16	270.0
AHMEDABAD ANN CLG .4% CONDNS WB=>MDB	93.02	23.22	83.48	Wetbulb [F]	7.16	270.0
AHMEDABAD ANN HTG 99.6% CONDNS DB	51.62	0.0	51.62	Wetbulb [F]	2.24	50.0
AHMEDABAD ANN HTG WIND 99.6% CONDNS WS=>MCDB	72.5	0.0	72.5	Wetbulb [F]	15.66	50.0
AHMEDABAD ANN HUM_N 99.6% CONDNS DP=>MCDB	74.66	0.0	26.96	Dewpoint [F]	2.24	50.0

Unmet Hours Summary

Time Setpoint Not Met	Time (hr)
During Heating	0.0
During Cooling	0.0
During Occupied Heating	0.0


During Occupied Cooling	0.0
-------------------------	-----

Unmet Hours Tolerance


Tolerance for Time Setpoint Not Met	Temperature (F)
Heating	0.36
Cooling	0.36

Annual Overview


End Use - view table



Energy Use - view table




EUI - Electricity - view table




EUI - Gas - view table

Monthly Overview


Electricity Consumption (kWh) - view table




District Cooling Consumption (MBtu) - view table




District Heating Consumption (MBtu) - view table




Electricity Peak Demand (kW) - view table



District Cooling Peak Demand (kBtu/hr) - view table



District Heating Peak Demand (kBtu/hr) - view table



Utility Bills/Rates

No Data to Show for Utility Bills/Rates

Envelope

Base Surface Constructions

Construction	Net Area (ft^2)	Surface Count	R Value (ft^2*h*R/Btu)
ASHRAE 189.1-2009 ExtRoof IEAD ClimateZone 2-5	30,139	3	24.73
ASHRAE 189.1-2009 ExtWall Mass ClimateZone 3	18,729	28	8.77

Sub Surface Constructions


Construction	Area (ft^2)	Surface Count	U-Factor (Btu/ft^2*h*R)
ASHRAE 189.1-2009 ExtWindow ClimateZone 3	9,688	24	

WWR & Skylight Ratio

Description	Total (%)	North (%)	East (%)	South (%)	West (%)
Gross Window-Wall Ratio	34.09	50.0	50.0	0.0	50.0
Gross Window-Wall Ratio (Conditioned)	34.09	50.0	50.0	0.0	50.0
Skylight-Roof Ratio	0.0				

Space Type Breakdown

Space Type Breakdown - view table



Space Type Summary

189.1-2009 - Office - BreakRoom - CZ1-3
 (4 spaces and 4 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - BreakRoom - CZ1-3 People Definition	0.0500	people/ft^2	1.0
189.1-2009 - Office - BreakRoom - CZ1-3 Electric Equipment Definition	4.4600	W/ft^2	1.0
189.1-2009 - Office - BreakRoom - CZ1-3 Lights Definition	1.0800	W/ft^2	1.0
189.1-2009 - Office - BreakRoom - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - BreakRoom - CZ1-3 Ventilation (outdoor air method Sum)	15.0000	cfm/person	

189.1-2009 - Office - Conference - CZ1-3
 (1 spaces and 1 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - Conference - CZ1-3 People Definition	0.0500	people/ft^2	1.0
189.1-2009 - Office - Conference - CZ1-3 Electric Equipment Definition	0.3700	W/ft^2	1.0
189.1-2009 - Office - Conference - CZ1-3 Lights Definition	1.1700	W/ft^2	1.0
189.1-2009 - Office - Conference - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - Conference - CZ1-3 Ventilation (outdoor air method Sum)	20.0000	cfm/person	

189.1-2009 - Office - Elec/MechRoom - CZ1-3
 (1 spaces and 1 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - Elec/MechRoom - CZ1-3 Electric Equipment Definition	0.2700	W/ft^2	1.0
189.1-2009 - Office - Elec/MechRoom - CZ1-3 Lights Definition	1.3500	W/ft^2	1.0
189.1-2009 - Office - Elec/MechRoom - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - Elec/MechRoom - CZ1-3 Ventilation (outdoor air method Sum)	20.0000	cfm/person	

189.1-2009 - Office - IT_Room - CZ1-3
 (1 spaces and 1 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - IT_Room - CZ1-3 People Definition	0.0050	people/ft^2	1.0
189.1-2009 - Office - IT_Room - CZ1-3 Electric Equipment Definition	1.5600	W/ft^2	1.0
189.1-2009 - Office - IT_Room - CZ1-3 Lights Definition	0.9900	W/ft^2	1.0
189.1-2009 - Office - IT_Room - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	

189.1-2009 - Office - IT_Room - CZ1-3 Ventilation (outdoor air method Sum)	0.0500	cfm/floor area ft^2	
--	--------	---------------------	--

189.1-2009 - Office - Lobby - CZ1-3
(1 spaces and 1 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - Lobby - CZ1-3 People Definition	0.0100	people/ft^2	1.0
189.1-2009 - Office - Lobby - CZ1-3 Electric Equipment Definition	0.0700	W/ft^2	1.0
189.1-2009 - Office - Lobby - CZ1-3 Lights Definition	1.1700	W/ft^2	1.0
189.1-2009 - Office - Lobby - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - Lobby - CZ1-3 Ventilation (outdoor air method Sum)	15.0000	cfm/person	

189.1-2009 - Office - OpenOffice - CZ1-3
(4 spaces and 4 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - OpenOffice - CZ1-3 People Definition	0.0052	people/ft^2	1.0
189.1-2009 - Office - OpenOffice - CZ1-3 Electric Equipment Definition	0.7100	W/ft^2	1.0
189.1-2009 - Office - OpenOffice - CZ1-3 Lights Definition	0.9900	W/ft^2	1.0
189.1-2009 - Office - OpenOffice - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - OpenOffice - CZ1-3 Ventilation (outdoor air method Sum)	20.0000	cfm/person	

Interior Lighting Summary

Interior Lighting Summary

	Zone	Lighting Power Density (W/ft^2)	Total Power (W)	Schedule Name	Scheduled Hours/Week (hr)	Actual Load Hours/Week (hr)	Return Air Fraction	Consumption (kWh)
THERMAL ZONE 5 189.1-2009 - OFFICE - BREAKROOM - CZ1-3 LIGHTS	THERMAL ZONE 5	1.08	6975.01	OFFICE BLDG LIGHT	61.85	61.85	0.0000	22494.45
THERMAL ZONE 6 189.1-2009 - OFFICE - BREAKROOM - CZ1-3 LIGHTS	THERMAL ZONE 6	1.08	6975.01	OFFICE BLDG LIGHT	61.85	61.85	0.0000	22494.45
THERMAL ZONE 7 189.1-2009 - OFFICE - BREAKROOM - CZ1-3 LIGHTS	THERMAL ZONE 7	1.08	6975.01	OFFICE BLDG LIGHT	61.85	61.85	0.0000	22494.45
THERMAL ZONE 8 189.1-2009 - OFFICE - BREAKROOM - CZ1-3 LIGHTS	THERMAL ZONE 8	1.08	6975.01	OFFICE BLDG LIGHT	61.85	61.85	0.0000	22494.45
THERMAL ZONE 11 189.1-2009 - OFFICE - CONFERENCE - CZ1-3 LIGHTS	THERMAL ZONE 11	1.17	10075.02	OFFICE BLDG LIGHT	61.85	61.85	0.0000	32494.45
THERMAL ZONE 9 189.1-2009 - OFFICE - ELEC/MECHROOM - CZ1-3 LIGHTS	THERMAL ZONE 9	1.35	11625.02	OFFICE BLDG LIGHT	61.85	61.85	0.0000	37491.67
THERMAL ZONE 10 189.1-2009 - OFFICE - IT_ROOM - CZ1-3 LIGHTS	THERMAL ZONE 10	0.99	8525.02	OFFICE BLDG LIGHT	61.85	61.85	0.0000	27494.45
THERMAL ZONE 12 189.1-2009 - OFFICE - LOBBY - CZ1-3 LIGHTS	THERMAL ZONE 12	1.17	10075.02	OFFICE BLDG LIGHT	61.85	61.85	0.0000	32494.45

THERMAL ZONE 1 189.1-2009 - OFFICE - OPENOFFICE - CZ1-3 LIGHTS	THERMAL ZONE 1	0.99	14918.78	OFFICE BLDG LIGHT	61.85	61.85	0.0000	48116.67
THERMAL ZONE 2 189.1-2009 - OFFICE - OPENOFFICE - CZ1-3 LIGHTS	THERMAL ZONE 2	0.99	14918.78	OFFICE BLDG LIGHT	61.85	61.85	0.0000	48116.67
THERMAL ZONE 3 189.1-2009 - OFFICE - OPENOFFICE - CZ1-3 LIGHTS	THERMAL ZONE 3	0.99	14918.78	OFFICE BLDG LIGHT	61.85	61.85	0.0000	48116.67
THERMAL ZONE 4 189.1-2009 - OFFICE - OPENOFFICE - CZ1-3 LIGHTS	THERMAL ZONE 4	0.99	14918.78	OFFICE BLDG LIGHT	61.85	61.85	0.0000	48116.67

Plug Loads Summary

Electric Plug Load Consumption

	Electricity Annual Value (kWh)
InteriorEquipment:Electricity:Zone:THERMAL ZONE 5	136433.33
InteriorEquipment:Electricity:Zone:THERMAL ZONE 6	136433.33
InteriorEquipment:Electricity:Zone:THERMAL ZONE 7	136433.33
InteriorEquipment:Electricity:Zone:THERMAL ZONE 8	136433.33
InteriorEquipment:Electricity:Zone:THERMAL ZONE 11	15091.67
InteriorEquipment:Electricity:Zone:THERMAL ZONE 9	11013.89
InteriorEquipment:Electricity:Zone:THERMAL ZONE 10	63627.78
InteriorEquipment:Electricity:Zone:THERMAL ZONE 12	2855.56
InteriorEquipment:Electricity:Zone:THERMAL ZONE 1	50677.78
InteriorEquipment:Electricity:Zone:THERMAL ZONE 2	50677.78
InteriorEquipment:Electricity:Zone:THERMAL ZONE 3	50677.78
InteriorEquipment:Electricity:Zone:THERMAL ZONE 4	50677.78

Exterior Lighting


No Data to Show for Exterior Lighting

Water Use Equipment

No Data to Show for Water Use Equipment

HVAC Load Profiles

Monthly Load Profiles - view table



Zone Conditions

Temperature (Table values represent hours spent in each temperature range)

Zone	Unmet Htg (hr)	Unmet Htg - Occ (hr)	< 56 (F)	56- 61 (F)	61- 66 (F)	66- 68 (F)	68- 70 (F)	70- 72 (F)	72- 74 (F)	74- 76 (F)	76- 78 (F)	78- 83 (F)	>= 88 (F)	Unmet Clg (hr)	Unmet Clg - Occ (hr)	Mean Temp (F)
THERMAL ZONE 1	0	0	0	0	0	0	48	1603	2791	4318	0	0	0	0	0	73.6 (F)
THERMAL ZONE 10	0	0	0	0	0	0	0	0	31	4976	563	3190	0	0	0	77.0 (F)
THERMAL ZONE 11	0	0	0	0	0	0	0	1	26	4951	707	3075	0	0	0	76.9 (F)
THERMAL ZONE 12	0	0	0	0	0	0	4	73	319	5154	550	2660	0	0	0	76.6 (F)
THERMAL ZONE 2	0	0	0	0	0	0	0	0	0	4801	931	3028	0	0	0	76.9 (F)
THERMAL ZONE 3	0	0	0	0	0	0	0	0	0	4784	222	3754	0	0	0	77.2 (F)
THERMAL ZONE 4	0	0	0	0	0	0	0	0	7	4921	485	3347	0	0	0	77.1 (F)
THERMAL ZONE 5	0	0	0	0	0	0	0	0	0	4784	319	3657	0	0	0	77.2 (F)
THERMAL ZONE 6	0	0	0	0	0	0	0	0	0	4784	0	3976	0	0	0	77.4 (F)
THERMAL ZONE 7	0	0	0	0	0	0	0	0	0	4784	0	3976	0	0	0	77.4 (F)
THERMAL ZONE 8	0	0	0	0	0	0	0	0	0	4784	0	3976	0	0	0	77.4 (F)
THERMAL ZONE 9	0	0	0	0	0	91	977	2371	1476	3845	0	0	0	0	0	72.9 (F)

Humidity (Table values represent hours spent in each Humidity range)

Zone	< 30 (%)	30-35 (%)	35-40 (%)	40-45 (%)	45-50 (%)	50-55 (%)	55-60 (%)	60-65 (%)	65-70 (%)	70-75 (%)	>= 80 (%)	Mean Relative Humidity (%)
THERMAL ZONE 1	0	30	26	627	1396	952	792	1071	847	588	399	65.8 (%)
THERMAL ZONE 10	52	281	697	2441	2225	858	647	679	520	220	81	49.5 (%)
THERMAL ZONE 11	28	47	383	1388	1776	996	792	917	1152	796	360	55.8 (%)

THERMAL ZONE 12	26	134	473	1642	2115	1098	902	1115	502	364	187	53.0 (%)
THERMAL ZONE 2	32	92	722	2348	1947	808	945	1224	369	122	60	50.5 (%)
THERMAL ZONE 3	32	230	1258	2776	2041	1045	739	590	47	2	0	46.6 (%)
THERMAL ZONE 4	69	304	679	2049	1955	714	982	1178	539	156	121	50.6 (%)
THERMAL ZONE 5	30	106	562	1618	2190	936	849	1416	833	153	41	52.2 (%)
THERMAL ZONE 6	34	368	3008	1352	1793	500	438	1000	256	11	0	45.7 (%)
THERMAL ZONE 7	33	383	3100	1362	1792	469	449	957	210	5	0	45.3 (%)
THERMAL ZONE 8	136	368	1246	1916	2059	1081	675	1031	243	5	0	47.8 (%)
THERMAL ZONE 9	13	109	397	2715	1205	920	731	521	451	422	338	55.6 (%)

Zone Overview

Zone Summary

	Area (ft^2)	Conditioned (Y/N)	Part of Total Floor Area (Y/N)	Volume (ft^3)	Multiplier	Gross Wall Area (ft^2)	Window Glass Area (ft^2)	Lighting (W/ft^2)	People (ft^2/person)	Plug and Process (W/ft^2)
THERMAL ZONE 1	15069.47	Yes	Yes	148321.6	1.00	3552.09	645.83	0.99	190.52	0.71
THERMAL ZONE 10	8611.13	Yes	Yes	84755.2	1.00	1937.5	968.75	0.99	199.99	1.56
THERMAL ZONE 11	8611.13	Yes	Yes	84755.2	1.00	1937.5	968.75	1.17	20.02	0.37
THERMAL ZONE 12	8611.13	Yes	Yes	84755.2	1.00	1937.5	968.75	1.17	100.0	0.07
THERMAL ZONE 2	15069.47	Yes	Yes	148321.6	1.00	3552.09	645.83	0.99	190.52	0.71
THERMAL ZONE 3	15069.47	Yes	Yes	148321.6	1.00	3552.09	645.83	0.99	190.52	0.71
THERMAL ZONE 4	15069.47	Yes	Yes	148321.6	1.00	3552.09	645.83	0.99	190.52	0.71
THERMAL ZONE 5	6458.35	Yes	Yes	63566.4	1.00	1614.59	807.29	1.08	20.02	4.46
THERMAL ZONE 6	6458.35	Yes	Yes	63566.4	1.00	1614.59	807.29	1.08	20.02	4.46
THERMAL ZONE 7	6458.35	Yes	Yes	63566.4	1.00	1614.59	807.29	1.08	20.02	4.46
THERMAL ZONE 8	6458.35	Yes	Yes	63566.4	1.00	1614.59	807.29	1.08	20.02	4.46
THERMAL ZONE 9	8611.13	Yes	Yes	84755.2	1.00	1937.5	968.75	1.35	0.0	0.27
Total	120555.8			1186572.8		28416.72	9687.52	1.06	55.65	1.47
Conditioned Total	120555.8			1186572.8		28416.72	9687.52	1.06	55.65	1.47
Unconditioned Total	0.0			0.0		0.0	0.0	0.0	0.0	0.0
Not Part of Total	0.0			0.0		0.0	0.0	0.0	0.0	0.0

Zone Sensible Cooling and Heating Sensible Sizing

	Heating/Cooling	Calculated Design Load	Design Load With Sizing Factor	Calculated Design Air Flow (ft^3/min)	Design Air Flow With Sizing Factor (ft^3/min)	Date/Time Of Peak	Outdoor Temperature at Peak Load (F)	Outdoor Humidity Ratio at Peak Load (lbWater/lbAir)
THERMAL ZONE 1	Cooling	10.65 (ton)	12.25 (ton)	6500.72	7475.41	5/21 15:30:00	106.9	0.01
THERMAL ZONE 1	Heating	34.13 (kBtu/h)	42.67 (kBtu/h)	915.36	1582.8	1/21 19:00:00	51.62	0.01
THERMAL ZONE 10	Cooling	9.96 (ton)	11.45 (ton)	6076.95	6988.07	5/21 15:10:00	107.37	0.01
THERMAL ZONE 10	Heating	23.0 (kBtu/h)	28.75 (kBtu/h)	616.59	769.15	1/21 19:00:00	51.62	0.01
THERMAL ZONE 11	Cooling	36.93 (ton)	42.47 (ton)	22568.19	25954.16	5/21 15:00:00	107.6	0.01
THERMAL ZONE 11	Heating	14.05 (kBtu/h)	17.56 (kBtu/h)	377.16	8611.13	1/21 19:00:00	51.62	0.01
THERMAL ZONE 12	Cooling	11.45 (ton)	13.17 (ton)	6992.3	8039.03	5/21 15:20:00	107.13	0.01
THERMAL ZONE 12	Heating	30.4 (kBtu/h)	38.0 (kBtu/h)	813.65	1292.52	1/21 19:00:00	51.62	0.01
THERMAL ZONE 2	Cooling	14.56 (ton)	16.74 (ton)	8886.58	10221.48	5/21 15:10:00	107.37	0.01
THERMAL ZONE 2	Heating	19.34 (kBtu/h)	24.18 (kBtu/h)	519.13	1582.8	1/21 19:00:00	51.62	0.01
THERMAL ZONE 3	Cooling	15.64 (ton)	17.99 (ton)	9547.67	10980.04	5/21 15:10:00	107.37	0.01
THERMAL ZONE 3	Heating	18.76 (kBtu/h)	23.44 (kBtu/h)	502.17	1582.8	1/21 19:00:00	51.62	0.01
THERMAL ZONE 4	Cooling	17.16 (ton)	19.74 (ton)	10475.74	12045.83	5/21 16:00:00	106.21	0.01
THERMAL ZONE 4	Heating	47.32 (kBtu/h)	59.15 (kBtu/h)	1267.09	1584.92	1/21 19:00:00	51.62	0.01
THERMAL ZONE 5	Cooling	28.05 (ton)	32.25 (ton)	17143.86	19716.18	5/21 15:00:00	107.6	0.01
THERMAL ZONE 5	Heating	17.41 (kBtu/h)	21.76 (kBtu/h)	466.15	4843.76	1/21 19:00:00	51.62	0.01
THERMAL ZONE 6	Cooling	30.53 (ton)	35.11 (ton)	18658.86	21457.9	5/21 15:10:00	107.37	0.01
THERMAL ZONE 6	Heating	11.62 (kBtu/h)	14.53 (kBtu/h)	311.48	4843.76	1/21 19:00:00	51.62	0.01
THERMAL ZONE 7	Cooling	31.08 (ton)	35.75 (ton)	18997.88	21845.65	5/21 15:10:00	107.37	0.01
THERMAL ZONE 7	Heating	11.47 (kBtu/h)	14.33 (kBtu/h)	307.24	4843.76	1/21 19:00:00	51.62	0.01
THERMAL ZONE 8	Cooling	31.73 (ton)	36.48 (ton)	19389.87	22296.97	5/21 15:20:00	107.13	0.01
THERMAL ZONE 8	Heating	23.76 (kBtu/h)	29.7 (kBtu/h)	635.66	4843.76	1/21 19:00:00	51.62	0.01
THERMAL ZONE 9	Cooling	3.95 (ton)	4.55 (ton)	2267.2	2608.34	5/21 07:00:00	86.47	0.01
THERMAL ZONE 9	Heating	22.08 (kBtu/h)	27.6 (kBtu/h)	591.17	739.49	1/21 19:00:00	51.62	0.01

Zone Equipment Detail

No Data to Show for Zone Equipment Detail

Air Loops Detail

No Data to Show for Air Loops Detail

Plant Loops Detail

No Data to Show for Plant Loops Detail

Outdoor Air

Average and Minimum Outdoor Air During Occupied Hours									
	Average Number of Occupants	Nominal Number of Occupants	Zone Volume (ft^3)	Avg. Mechanical Ventilation (ach)	Min. Mechanical Ventilation (ach)	Avg. Infiltration (ach)	Min. Infiltration (ach)	Avg. Simple Ventilation (ach)	Min. Simple Ventilation (ach)
THERMAL ZONE 1	44.18	79.11	148322	0.0	0.0	0.027	0.0	0.313	0.001
THERMAL ZONE 10	16.57	43.06	84755	0.0	0.0	0.026	0.0	0.3	0.005
THERMAL ZONE 11	165.7	430.56	84755	0.0	0.0	0.026	0.0	1.766	0.005
THERMAL ZONE 12	33.14	86.11	84755	0.0	0.0	0.143	0.002	0.265	0.001
THERMAL ZONE 2	44.18	79.11	148322	0.0	0.0	0.027	0.0	0.313	0.001
THERMAL ZONE 3	44.18	79.11	148322	0.0	0.0	0.027	0.0	0.313	0.001
THERMAL ZONE 4	44.18	79.11	148322	0.0	0.0	0.144	0.002	0.313	0.001
THERMAL ZONE 5	124.27	322.92	63566	0.0	0.0	0.029	0.0	1.324	0.004
THERMAL ZONE 6	124.27	322.92	63566	0.0	0.0	0.029	0.0	1.325	0.004
THERMAL ZONE 7	124.27	322.92	63566	0.0	0.0	0.029	0.0	1.325	0.004
THERMAL ZONE 8	124.27	322.92	63566	0.0	0.0	0.146	0.002	1.325	0.004

Cash Flow

No Data to Show for Cash Flow


Site and Source Summary

Site and Source Energy			
	Total Energy (kBtu)	Energy Per Total Building Area (kBtu/ft^2)	Energy Per Conditioned Building Area (kBtu/ft^2)
Total Site Energy	12020235.2	99.7	99.7
Net Site Energy	12020235.2	99.7	99.7
Total Source Energy	21720897.2	180.2	180.2
Net Source Energy	21720897.2	180.2	180.2


Site to Source Energy Conversion Factors	
	Site=>Source Conversion Factor
Electricity	3.167
Natural Gas	1.084
District Cooling	1.056
District Heating	3.613

Schedule Overview


Schedule Overview - view table




Office Bldg Light




Office Infil Quarter On




Office Misc Occ



Office Work Occ



Small Office ClgSetp



Small Office HtgSetp

