OpenStudio Results

Model Summary

Building Summary

Information	Value	Units
Building Name	Building 1	building_name
Net Site Energy	12,382,179	kBtu
Total Building Area	120,556	ft^2
EUI (Based on Net Site Energy and Total Building Area)	102.71	kBtu/ft^2
OpenStudio Standards Building Type		

Weather Summary

	Value
Weather File	Kolkata West Bengal IND ISHRAE WMO#=428090
Latitude	22.65
Longitude	88.45
Elevation	20 (ft)
Time Zone	5.50
North Axis Angle	0.00
ASHRAE Climate Zone	

Sizing Period Design Days

	Maximum Dry Bulb (F)	Daily Temperature Range (R)	Humidity Value	Humidity Type	Wind Speed (mph)	Wind Direction
KOLKATA ANN CLG .4% CONDNS DB=>MWB	98.96	16.38	80.24	Wetbulb [F]	6.04	180.0
KOLKATA ANN CLG .4% CONDNS DP=>MDB	89.6	16.38	82.94	Dewpoint [F]	6.04	180.0
KOLKATA ANN CLG .4% CONDNS ENTH=>MDB	94.28	16.38	42.05	Enthalpy [Btu/lb]	6.04	180.0
KOLKATA ANN CLG .4% CONDNS WB=>MDB	93.56	16.38	85.1	Wetbulb [F]	6.04	180.0
KOLKATA ANN HTG 99.6% CONDNS DB	52.88	0.0	52.88	Wetbulb [F]	0.67	0.0
KOLKATA ANN HTG WIND 99.6% CONDNS WS=>MCDB	73.76	0.0	73.76	Wetbulb [F]	10.96	0.0
KOLKATA ANN HUM_N 99.6% CONDNS DP=>MCDB	73.04	0.0	43.7	Dewpoint [F]	0.67	0.0


Unmet Hours Summary


Time Setpoint Not Met	Time (hr)
During Heating	0.0
During Cooling	0.0
During Occupied Heating	0.0
During Occupied Cooling	0.0


Unmet Hours Tolerance

Tolerance for Time Setpoint Not Met	Temperature (F)
Heating	0.36
Cooling	0.36


Annual Overview











EUI - Gas - view table














Utility Bills/Rates

No Data to Show for Utility Bills/Rates

Envelope

Base Surface Constructions

Construction	Net Area (ft^2)	Surface Count	R Value (ft^2*h*R/Btu)
ASHRAE 189.1-2009 ExtRoof IEAD ClimateZone 1	30,139	3	19.96
ASHRAE 189.1-2009 ExtWall Mass ClimateZone 3	18,729	28	8.77


Sub Surface Constructions

Construction	Area (ft^2)	Surface Count	U-Factor (Btu/ft^2*h*R)
ASHRAE 189.1-2009 ExtWindow ClimateZone 1	9,688	24	

WWR & Skylight Ratio

Description	Total (%)	North (%)	East (%)	South (%)	West (%)
Gross Window-Wall Ratio	34.09	50.0	50.0	0.0	50.0
Gross Window-Wall Ratio (Conditioned)	34.09	50.0	50.0	0.0	50.0
Skylight-Roof Ratio	0.0				

Space Type Breakdown



Space Type Summary

189.1-2009 - Office - BreakRoom - CZ1-3 (4 spaces and 4 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - BreakRoom - CZ1-3 People Definition	0.0500	people/ft^2	1.0
189.1-2009 - Office - BreakRoom - CZ1-3 Electric Equipment Definition	4.4600	W/ft^2	1.0
189.1-2009 - Office - BreakRoom - CZ1-3 Lights Definition	1.0800	W/ft^2	1.0
189.1-2009 - Office - BreakRoom - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - BreakRoom - CZ1-3 Ventilation (outdoor air method Sum)	15.0000	cfm/person	

189.1-2009 - Office - Conference - CZ1-3 (1 spaces and 1 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - Conference - CZ1-3 People Definition	0.0500	people/ft^2	1.0
189.1-2009 - Office - Conference - CZ1-3 Electric Equipment Definition	0.3700	W/ft^2	1.0
189.1-2009 - Office - Conference - CZ1-3 Lights Definition	1.1700	W/ft^2	1.0
189.1-2009 - Office - Conference - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - Conference - CZ1-3 Ventilation (outdoor air method Sum)	20.0000	cfm/person	

189.1-2009 - Office - Elec/MechRoom - CZ1-3 (1 spaces and 1 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - Elec/MechRoom - CZ1-3 Electric Equipment Definition	0.2700	W/ft^2	1.0
189.1-2009 - Office - Elec/MechRoom - CZ1-3 Lights Definition	1.3500	W/ft^2	1.0
189.1-2009 - Office - Elec/MechRoom - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - Elec/MechRoom - CZ1-3 Ventilation (outdoor air method Sum)	20.0000	cfm/person	

189.1-2009 - Office - IT_Room - CZ1-3 (1 spaces and 1 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - IT_Room - CZ1-3 People Definition	0.0050	people/ft^2	1.0
189.1-2009 - Office - IT_Room - CZ1-3 Electric Equipment Definition	1.5600	W/ft^2	1.0
189.1-2009 - Office - IT_Room - CZ1-3 Lights Definition	0.9900	W/ft^2	1.0
189.1-2009 - Office - IT_Room - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - IT_Room - CZ1-3 Ventilation (outdoor air method Sum)	0.0500	cfm/floor area ft^2	

189.1-2009 - Office - Lobby - CZ1-3 (1 spaces and 1 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - Lobby - CZ1-3 People Definition	0.0100	people/ft^2	1.0
189.1-2009 - Office - Lobby - CZ1-3 Electric Equipment Definition	0.0700	W/ft^2	1.0
189.1-2009 - Office - Lobby - CZ1-3 Lights Definition	1.1700	W/ft^2	1.0
189.1-2009 - Office - Lobby - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2	
189.1-2009 - Office - Lobby - CZ1-3 Ventilation (outdoor air method Sum)	15.0000	cfm/person	

189.1-2009 - Office - OpenOffice - CZ1-3 (4 spaces and 4 thermal zones)

Definition	Value	Unit	Inst. Multiplier
189.1-2009 - Office - OpenOffice - CZ1-3 People Definition	0.0052	people/ft^2	1.0
189.1-2009 - Office - OpenOffice - CZ1-3 Electric Equipment Definition	0.7100	W/ft^2	1.0
189.1-2009 - Office - OpenOffice - CZ1-3 Lights Definition	0.9900	W/ft^2	1.0

189.1-2009 - Office - OpenOffice - CZ1-3 Infiltration	0.0595	cfm/ext surf area ft^2
189.1-2009 - Office - OpenOffice - CZ1-3 Ventilation (outdoor air method Sum)	20.0000	cfm/person

Interior Lighting Summary

Interior Lighting Summary

	Zone	Lighting Power Density (W/ft^2)	Total Power (W)	Schedule Name	Scheduled Hours/Week (hr)	Actual Load Hours/Week (hr)	Return Air Fraction	Consumption (kWh)
THERMAL ZONE 5 189.1-2009 - OFFICE - BREAKROOM - CZ1-3 LIGHTS	THERMAL ZONE 5	1.08	6975.01	OFFICE BLDG LIGHT	61.85	61.85	0.0000	22494.45
THERMAL ZONE 6 189.1-2009 - OFFICE - BREAKROOM - CZ1-3 LIGHTS	THERMAL ZONE 6	1.08	6975.01	OFFICE BLDG LIGHT	61.85	61.85	0.0000	22494.45
THERMAL ZONE 7 189.1-2009 - OFFICE - BREAKROOM - CZ1-3 LIGHTS	THERMAL ZONE 7	1.08	6975.01	OFFICE BLDG LIGHT	61.85	61.85	0.0000	22494.45
THERMAL ZONE 8 189.1-2009 - OFFICE - BREAKROOM - CZ1-3 LIGHTS	THERMAL ZONE 8	1.08	6975.01	OFFICE BLDG LIGHT	61.85	61.85	0.0000	22494.45
THERMAL ZONE 11 189.1-2009 - OFFICE - CONFERENCE - CZ1-3 LIGHTS	THERMAL ZONE 11	1.17	10075.02	OFFICE BLDG LIGHT	61.85	61.85	0.0000	32494.45
THERMAL ZONE 9 189.1-2009 - OFFICE - ELEC/MECHROOM - CZ1-3 LIGHTS	THERMAL ZONE 9	1.35	11625.02	OFFICE BLDG LIGHT	61.85	61.85	0.0000	37491.67
THERMAL ZONE 10 189.1-2009 - OFFICE - IT_ROOM - CZ1-3 LIGHTS	THERMAL ZONE 10	0.99	8525.02	OFFICE BLDG LIGHT	61.85	61.85	0.0000	27494.45
THERMAL ZONE 12 189.1-2009 - OFFICE - LOBBY - CZ1-3 LIGHTS	THERMAL ZONE 12	1.17	10075.02	OFFICE BLDG LIGHT	61.85	61.85	0.0000	32494.45
THERMAL ZONE 1 189.1-2009 - OFFICE - OPENOFFICE - CZ1-3 LIGHTS	THERMAL ZONE 1	0.99	14918.78	OFFICE BLDG LIGHT	61.85	61.85	0.0000	48116.67
THERMAL ZONE 2 189.1-2009 - OFFICE - OPENOFFICE - CZ1-3 LIGHTS	THERMAL ZONE 2	0.99	14918.78	OFFICE BLDG LIGHT	61.85	61.85	0.0000	48116.67
THERMAL ZONE 3 189.1-2009 - OFFICE - OPENOFFICE - CZ1-3 LIGHTS	THERMAL ZONE 3	0.99	14918.78	OFFICE BLDG LIGHT	61.85	61.85	0.0000	48116.67
THERMAL ZONE 4 189.1-2009 - OFFICE - OPENOFFICE - CZ1-3 LIGHTS	THERMAL ZONE 4	0.99	14918.78	OFFICE BLDG LIGHT	61.85	61.85	0.0000	48116.67

Plug Loads Summary

Electric Plug Load Consumption

	Electricity Annual Value (kWh)
InteriorEquipment:Electricity:Zone:THERMAL ZONE 5	136433.33
InteriorEquipment:Electricity:Zone:THERMAL ZONE 6	136433.33
InteriorEquipment:Electricity:Zone:THERMAL ZONE 7	136433.33
InteriorEquipment:Electricity:Zone:THERMAL ZONE 8	136433.33
InteriorEquipment:Electricity:Zone:THERMAL ZONE 11	15091.67
InteriorEquipment:Electricity:Zone:THERMAL ZONE 9	11013.89

InteriorEquipment:Electricity:Zone:THERMAL ZONE 10	63627.78
InteriorEquipment:Electricity:Zone:THERMAL ZONE 12	2855.56
InteriorEquipment:Electricity:Zone:THERMAL ZONE 1	50677.78
InteriorEquipment:Electricity:Zone:THERMAL ZONE 2	50677.78
InteriorEquipment:Electricity:Zone:THERMAL ZONE 3	50677.78
InteriorEquipment:Electricity:Zone:THERMAL ZONE 4	50677.78


Exterior Lighting

No Data to Show for Exterior Lighting

Water Use Equipment

No Data to Show for Water Use Equipment

HVAC Load Profiles



Zone Conditions

Temperature (Table values represent hours spent in each temperature range)

Zone	Unmet Htg (hr)	Unmet Htg - Occ (hr)	< 56 (F)	56- 61 (F)	61- 66 (F)	66- 68 (F)	68- 70 (F)	70- 72 (F)	72- 74 (F)	74- 76 (F)	76- 78 (F)	78- 83 (F)	>= 88 (F)	Unmet Clg (hr)	Unmet Clg - Occ (hr)	Mean Temp (F)
THERMAL ZONE 1	0	0	0	0	0	0	236	1812	2507	4205	0	0	0	0	0	73.5 (F)
THERMAL ZONE 10	0	0	0	0	0	0	4	30	189	5111	508	2918	0	0	0	76.8 (F)
THERMAL ZONE 11	0	0	0	0	0	0	17	45	243	5141	544	2770	0	0	0	76.7 (F)
THERMAL ZONE 12	0	0	0	0	8	22	114	242	369	5035	498	2472	0	0	0	76.3 (F)
THERMAL ZONE 2	0	0	0	0	0	0	0	0	15	5073	1003	2669	0	0	0	76.6 (F)
THERMAL ZONE 3	0	0	0	0	0	0	0	0	0	4822	609	3329	0	0	0	77.1 (F)
THERMAL ZONE 4	0	0	0	0	0	0	0	24	157	5056	447	3076	0	0	0	76.9 (F)
THERMAL ZONE 5	0	0	0	0	0	0	0	0	0	4847	492	3421	0	0	0	77.1 (F)

THERMAL ZONE 6	0	0	0	0	0	0	0	0	0	4784	0	3976	0	0	0	77.4 (F)
THERMAL ZONE 7	0	0	0	0	0	0	0	0	0	4784	0	3976	0	0	0	77.4 (F)
THERMAL ZONE 8	0	0	0	0	0	0	0	0	0	4784	0	3976	0	0	0	77.4 (F)
THERMAL ZONE 9	0	0	0	0	9	308	874	2411	1352	3805	1	0	0	0	0	72.8 (F)

Humidity (Table values represent hours spent in each Humidity range)

Zone	< 30 (%)	30-35 (%)	35-40 (%)	40-45 (%)	45-50 (%)	50-55 (%)	55-60 (%)	60-65 (%)	65-70 (%)	70-75 (%)	>= 80 (%)	Mean Relative Humidity (%)
THERMAL ZONE 1	0	0	0	28	295	381	420	810	1132	1273	759	77.9 (%)
THERMAL ZONE 10	0	0	6	716	2408	1217	1009	863	840	882	531	58.0 (%)
THERMAL ZONE 11	0	0	3	86	320	649	1077	1321	1294	1744	1624	67.4 (%)
THERMAL ZONE 12	0	0	1	87	894	863	1094	2546	895	658	519	64.6 (%)
THERMAL ZONE 2	0	0	6	487	1667	967	1179	2345	1051	462	223	59.2 (%)
THERMAL ZONE 3	0	0	36	1047	2097	1392	1758	2239	190	1	0	53.9 (%)
THERMAL ZONE 4	0	3	8	340	1484	918	1163	2386	861	773	625	60.3 (%)
THERMAL ZONE 5	0	3	30	188	1100	1033	1459	1933	2097	583	223	60.6 (%)
THERMAL ZONE 6	0	24	2516	1015	1258	963	497	1364	1049	74	0	50.1 (%)
THERMAL ZONE 7	0	25	2935	681	1391	879	489	1417	912	31	0	49.5 (%)
THERMAL ZONE 8	3	19	346	1001	1511	1409	1766	1619	1063	23	0	54.5 (%)
THERMAL ZONE 9	0	0	5	2241	905	667	819	686	639	553	502	62.4 (%)

Zone Overview

Zone Summary

	Area (ft^2)	Conditioned (Y/N)	Part of Total Floor Area (Y/N)	Volume (ft^3)	Multiplier	Gross Wall Area (ft^2)	Window Glass Area (ft^2)	Lighting (W/ft^2)	People (ft^2/person)	Plug and Process (W/ft^2)
THERMAL ZONE 1	15069.47	Yes	Yes	148321.6	1.00	3552.09	645.83	0.99	190.52	0.71
THERMAL ZONE 10	8611.13	Yes	Yes	84755.2	1.00	1937.5	968.75	0.99	199.99	1.56
THERMAL ZONE 11	8611.13	Yes	Yes	84755.2	1.00	1937.5	968.75	1.17	20.02	0.37
THERMAL ZONE 12	8611.13	Yes	Yes	84755.2	1.00	1937.5	968.75	1.17	100.0	0.07
THERMAL ZONE 2	15069.47	Yes	Yes	148321.6	1.00	3552.09	645.83	0.99	190.52	0.71
THERMAL ZONE 3	15069.47	Yes	Yes	148321.6	1.00	3552.09	645.83	0.99	190.52	0.71

THERMAL ZONE 4	15069.47	Yes	Yes	148321.6	1.00	3552.09	645.83	0.99	190.52	0.71
THERMAL ZONE 5	6458.35	Yes	Yes	63566.4	1.00	1614.59	807.29	1.08	20.02	4.46
THERMAL ZONE 6	6458.35	Yes	Yes	63566.4	1.00	1614.59	807.29	1.08	20.02	4.46
THERMAL ZONE 7	6458.35	Yes	Yes	63566.4	1.00	1614.59	807.29	1.08	20.02	4.46
THERMAL ZONE 8	6458.35	Yes	Yes	63566.4	1.00	1614.59	807.29	1.08	20.02	4.46
THERMAL ZONE 9	8611.13	Yes	Yes	84755.2	1.00	1937.5	968.75	1.35	0.0	0.27
Total	120555.8			1186572.8		28416.72	9687.52	1.06	55.65	1.47
Conditioned Total	120555.8			1186572.8		28416.72	9687.52	1.06	55.65	1.47
Unconditioned Total	0.0			0.0		0.0	0.0	0.0	0.0	0.0
Not Part of Total	0.0			0.0		0.0	0.0	0.0	0.0	0.0

Zone Sensible Cooling and Heating Sensible Sizing

	Heating/Cooling	Calculated Design Load	Design Load With Sizing Factor	Calculated Design Air Flow (ft^3/min)	Design Air Flow With Sizing Factor (ft^3/min)	Date/Time Of Peak	Outdoor Temperature at Peak Load (F)	Outdoor Humidity Ratio at Peak Load (IbWater/IbAir)
THERMAL ZONE 1	Cooling	9.71 (ton)	11.17 (ton)	5896.84	6782.53	5/21 15:15:00	98.71	0.02
THERMAL ZONE 1	Heating	35.68 (kBtu/h)	44.6 (kBtu/h)	949.26	1582.8	1/21 19:00:00	52.88	0.01
THERMAL ZONE 10	Cooling	9.74 (ton)	11.21 (ton)	5915.91	6801.6	5/21 15:00:00	98.96	0.02
THERMAL ZONE 10	Heating	26.25 (kBtu/h)	32.81 (kBtu/h)	699.23	872.98	1/21 19:00:00	52.88	0.01
THERMAL ZONE 11	Cooling	31.08 (ton)	35.74 (ton)	18949.14	21792.68	5/21 15:00:00	98.96	0.02
THERMAL ZONE 11	Heating	18.3 (kBtu/h)	22.87 (kBtu/h)	487.34	8611.13	1/21 19:00:00	52.88	0.01
THERMAL ZONE 12	Cooling	10.86 (ton)	12.49 (ton)	6600.31	7589.83	5/21 15:45:00	98.22	0.02
THERMAL ZONE 12	Heating	36.11 (kBtu/h)	45.13 (kBtu/h)	961.97	1292.52	1/21 19:00:00	52.88	0.01
THERMAL ZONE 2	Cooling	13.56 (ton)	15.6 (ton)	8236.09	9471.39	5/21 15:15:00	98.71	0.02
THERMAL ZONE 2	Heating	21.72 (kBtu/h)	27.15 (kBtu/h)	578.45	1582.8	1/21 19:00:00	52.88	0.01
THERMAL ZONE 3	Cooling	14.62 (ton)	16.82 (ton)	8880.23	10213.0	5/21 15:15:00	98.71	0.02
THERMAL ZONE 3	Heating	21.79 (kBtu/h)	27.23 (kBtu/h)	580.57	1582.8	1/21 19:00:00	52.88	0.01
THERMAL ZONE 4	Cooling	16.63 (ton)	19.12 (ton)	10096.46	11611.46	5/21 16:15:00	97.65	0.02
THERMAL ZONE 4	Heating	53.05 (kBtu/h)	66.31 (kBtu/h)	1413.29	1765.03	1/21 19:00:00	52.88	0.01
THERMAL ZONE 5	Cooling	24.9 (ton)	28.64 (ton)	15190.25	17468.05	5/21 15:00:00	98.96	0.02
THERMAL ZONE 5	Heating	19.66 (kBtu/h)	24.58 (kBtu/h)	523.36	4843.76	1/21 19:00:00	52.88	0.01
THERMAL ZONE 6	Cooling	27.39 (ton)	31.5 (ton)	16698.89	19203.41	5/21 15:15:00	98.71	0.02

THERMAL ZONE 6	Heating	14.75 (kBtu/h)	18.44 (kBtu/h)	391.99	4843.76	1/21 19:00:00	52.88	0.01
THERMAL ZONE 7	Cooling	27.92 (ton)	32.1 (ton)	17018.84	19569.98	5/21 15:15:00	98.71	0.02
THERMAL ZONE 7	Heating	14.91 (kBtu/h)	18.64 (kBtu/h)	396.23	4843.76	1/21 19:00:00	52.88	0.01
THERMAL ZONE 8	Cooling	28.76 (ton)	33.08 (ton)	17533.73	20163.26	5/21 15:30:00	98.47	0.02
THERMAL ZONE 8	Heating	28.29 (kBtu/h)	35.36 (kBtu/h)	754.32	4843.76	1/21 19:00:00	52.88	0.01
THERMAL ZONE 9	Cooling	3.54 (ton)	4.07 (ton)	1989.63	2288.39	5/21 07:00:00	84.06	0.02
THERMAL ZONE 9	Heating	24.83 (kBtu/h)	31.04 (kBtu/h)	661.09	826.36	1/21 19:00:00	52.88	0.01

Zone Equipment Detail

No Data to Show for Zone Equipment Detail

Air Loops Detail

No Data to Show for Air Loops Detail

Plant Loops Detail

No Data to Show for Plant Loops Detail

Outdoor Air

Average and Minimum Outdoor Air During Occupied Hours

	Average Number of Occupants	Nominal Number of Occupants	Zone Volume (ft^3)	Avg. Mechanical Ventilation (ach)	Min. Mechanical Ventilation (ach)	Avg. Infiltration (ach)	Min. Infiltration (ach)	Avg. Simple Ventilation (ach)	Min. Simple Ventilation (ach)
THERMAL ZONE 1	44.18	79.11	148322	0.0	0.0	0.027	0.001	0.315	0.001
THERMAL ZONE 10	16.57	43.06	84755	0.0	0.0	0.026	0.001	0.302	0.008
THERMAL ZONE 11	165.68	430.56	84755	0.0	0.0	0.026	0.001	1.777	0.008
THERMAL ZONE 12	33.14	86.11	84755	0.0	0.0	0.143	0.003	0.267	0.001
THERMAL ZONE 2	44.18	79.11	148322	0.0	0.0	0.028	0.001	0.315	0.001
THERMAL ZONE 3	44.18	79.11	148322	0.0	0.0	0.028	0.001	0.315	0.001
THERMAL ZONE 4	44.18	79.11	148322	0.0	0.0	0.145	0.003	0.315	0.001
THERMAL ZONE 5	124.26	322.92	63566	0.0	0.0	0.029	0.001	1.333	0.006
THERMAL ZONE 6	124.26	322.92	63566	0.0	0.0	0.029	0.001	1.334	0.006
THERMAL ZONE 7	124.26	322.92	63566	0.0	0.0	0.029	0.001	1.334	0.006
THERMAL ZONE 8	124.26	322.92	63566	0.0	0.0	0.146	0.003	1.334	0.006

Cash Flow

No Data to Show for Cash Flow

Site and Source Summary

Site and Source Energy

	Total Energy (kBtu)	Energy Per Total Building Area (kBtu/ft^2)	Energy Per Conditioned Building Area (kBtu/ft^2)
Total Site Energy	12382178.3	102.7	102.7
Net Site Energy	12382178.3	102.7	102.7
Total Source Energy	22104052.3	183.4	183.4
Net Source Energy	22104052.3	183.4	183.4

Site to Source Energy Conversion Factors

	Site=>Source Conversion Factor	
Electricity	3.167	
Natural Gas	1.084	
District Cooling	1.056	
District Heating	3.613	

Schedule Overview

