

SECTION 09 29 00

GYPSUM BOARD

Riverside Mixed-Use Development
Project No. RMD-2025-001

PART 1 - GENERAL

1.01 REFERENCES

- ASTM C36 - Specification for Gypsum Wallboard
- ASTM C840 - Application and Finishing of Gypsum Board
- ASTM C645 - Steel Studs and Track for Screw Application
- GA-216 - Application and Finishing of Gypsum Panel Products
- UL Fire Resistance Ratings: Design Nos. U419, U465, U411
- ASTM C1396 - Gypsum Board
- ASTM C1629 - Abuse-Resistant Gypsum Board

1.02 SUBMITTALS

- A. Product data sheets for all gypsum board products.
- B. Fire-rated assembly documentation with UL listing.
- C. Sound transmission class (STC) test reports for rated assemblies.
- D. Installer qualifications: minimum 3 years commercial experience.

1.03 FIRE-RATED ASSEMBLIES

UL Design	Rating	Assembly Description	STC
U419	1-Hour	3-5/8 steel stud, 1-layer 5/8 Type X ea. side	45
U465	2-Hour	3-5/8 steel stud, 2-layer 5/8 Type X ea. side	55
U411	1-Hour	Floor-ceiling, 1-1/2 metal deck, 5/8 Type X ceiling	50

PART 2 - PRODUCTS

2.01 GYPSUM BOARD

- A. Standard: ASTM C36, 5/8-inch Type X for fire-rated assemblies.
- B. Moisture resistant: ASTM C1396, Type X, for wet areas.
- C. Abuse resistant: ASTM C1629, Level 3 for corridors and public areas.
- D. Manufacturer: Georgia-Pacific, CertainTeed, or National Gypsum.

2.02 FRAMING

- A. Steel studs: ASTM C645, 20 gauge min, 3-5/8 inch depth.
- B. Maximum spacing: 16 inches o.c. for single-layer 5/8-inch.
- C. Deflection track at top of partitions for structural movement.
- D. Resilient channel: 25 gauge, for STC-rated assemblies.

2.03 ACCESSORIES

- A. Joint compound: ASTM C475, setting type first coat, drying type finish.
- B. Joint tape: paper tape per ASTM C475.
- C. Corner bead: galvanized steel or vinyl.
- D. Control joints: zinc or PVC, maximum 30-foot spacing.

PART 3 - EXECUTION

3.01 FRAMING INSTALLATION

- A. Install studs plumb and true, secure to track at top and bottom.
- B. Frame openings with double studs and headers per design.
- C. Install backing for wall-mounted items (grab bars, cabinets).

3.02 BOARD APPLICATION

- A. Install board with long dimension perpendicular to framing.
- B. Screw spacing: 12 inches o.c. field, 8 inches o.c. edges.
- C. Stagger joints between layers in multi-layer assemblies.
- D. Leave 1/4-inch gap at floor; fire-stop per assembly requirements.

3.03 FINISHING

- A. Level 4 finish per GA-216 for painted surfaces.
- B. Level 5 finish for critical lighting and gloss paint.
- C. Apply joint tape and three coats of joint compound.
- D. Sand smooth between coats; final surface free of tool marks.

3.04 PAINTING

- A. Primer: one coat latex primer-sealer, Sherwin-Williams ProMar 200.
- B. Finish: two coats latex eggshell, Sherwin-Williams ProMar 200.
- C. Colors: per architect's color schedule.
- D. Minimum DFT: 1.5 mils per coat.

3.05 QUALITY CONTROL

- A. Flatness: 1/8 inch in 10 feet for board surfaces.
- B. Sound flanking test after installation per ASTM E336.
- C. Fire stopping inspection at all penetrations and joints.

END OF SECTION 09 29 00