

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD		NRCC-PRF-E
Nonresidential Performance Compliance Method		(Page 1 of 55)
Project Name:	MF88_IndSupply_CentralExhaust_SZHP	Date Prepared: 2026-09-23

A. General Information					
1	Project Name	MF88_IndSupply_CentralExhaust_SZHP			
2	Run Title	MF88 Individual Supply + Central Exhaust (SZHP)			
3	Project Location	Street			
4	City	Los Angeles	5	Standards Version	Compliance 2025
6	Zip code	95837	7	Compliance Software (version)	CBECC-CLI 2025.3.0 RC (1415)
8	Climate Zone	9	9	Building Orientation (deg)	0
10	Building Type(s)		11	Weather File	CA_Title24_2025_LOS-ANGELES-USC.epw
12	Project Scope	• New complete scope	13	Number of Dwelling Units	88
14	Total Conditioned Floor Area in Scope (ft²)	112641	15	Total # of hotel/motel rooms	0
16	Total Unconditioned Floor Area (ft²)	28284	17	Fuel Type	Natural gas
18	Is Natural Gas Available per Section 100.1?	Yes	19	Nonresidential Conditioned Floor Area	17613
20	Total # of Stories (Habitable Above Grade)	5	21	Residential Conditioned Floor Area	95028

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 2 of 55)

B1. PROJECT SUMMARY - Performance		
Table B1 shows which building components are included in the performance calculation. If indicated as not included, the project must show compliance prescriptively if within the permit application.		
Building Components Complying via Performance		
Envelope (See Table G)	Nonresidential	Included
	Multifamily	Included
Mechanical (See Table H)	Nonresidential	Included
	Multifamily	Included
Domestic Hot Water (See Table I)	Nonresidential	Included
	Multifamily	Included
Lighting (Indoor Conditioned, see Table K)	Nonresidential	Included
	Multifamily	Included
Solar Thermal Water Heating (See Table I3)		Not Included
Covered Process: Commercial Kitchens (see Table J)		Not Included
Covered Process: Laboratory Exhaust (see Table J)		Not Included
Photovoltaics (see Table F)		Included
Battery (see Table F)		Included

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 3 of 55)

B2. PROJECT SUMMARY - Prescriptive/Mandatory	
Building Components Not Supported via Performance Approach - Must Use the Following Certificate of Compliance Forms	
<i>The following building components are supported via the applicable Certificate of Compliance forms listed below when within the scope of the permit application.</i>	
Indoor Lighting - Unconditioned Spaces 140.6 & 141.0(b)2I & 170.2(e) & 180.2(b)4B	NRCC-LTI-01-E if any enclosed unconditioned spaces have new/alterd lighting
Indoor Lighting - Multifamily Dwelling Unit, Hotel/Motel Guest Room 160.5(a) & 130.0(b)	NRCC-LTI-01-E if dwelling units or guest rooms have new/alterd indoor lighting
Outdoor Lighting 140.7 & 141.0(b)2L & 170.2(e) & 180.2(b)4B	NRCC-LTO-01-E if any new/alterd outdoor lighting
Outdoor Lighting - Multifamily Dwelling Unit, Hotel/Motel Guest Room 160.5(a) & 130.0(b)	NRCC-LTO-01-E if dwelling units or guest rooms have new/alterd outdoor lighting
Illuminated Sign Lighting 140.8 & 141.0(b)2M & 170.2(e) & 180.2(b)4	NRCC-LTS-01-E if any new/alterd illuminated signs located indoors or outdoors
Electrical Power Distribution 130.5 & 141.0(b)2P & 170.2(e) & 180.2(b)4	NRCC-ELC-01-E if any new/alterd electrical power distribution components
Electrical Readiness for New Multifamily Buildings 160.9	NRCC-ELC-01-E if gas is used in dwelling unit heating, cooktop, clothes dryer or water heating systems
Design Review and Commissioning 120.8	NRCC-CXR-01-E if new building with conditioned nonresidential occupancy
Solar Readiness 110.10	NRCC-SAB-01-E if new conditioned building and no photovoltaic (PV) system is installed per the Energy Code
Covered Processes 120.6 & 140.9 & 141.1 & 160.7	NRCC-PRC-01-E if new/alterd Refrigerated Warehouse, Commercial Refrigeration, Enclosed Parking Garage, Process Boiler, Compressed Air, Elevator, Escalator, Moving Walkway, Controlled Environment Horticulture, Steam Trap, Computer/Data Room, Commercial Kitchen, Laboratory or Factory Exhaust

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 4 of 55)

C1. COMPLIANCE SUMMARY			
DOES NOT COMPLY *			
	Long-term System Cost (LSC) ¹		Source Energy Use
	Efficiency ² (\$/ft ² -yr)	Total ³ (\$/ft ² -yr)	Total ³ (kBtu/ft ² -yr)
Standard Design			
Proposed Design			
Compliance Margins			
¹ Long-term System Cost (LSC) is a 30-year present value cost to California's energy system. LSC is not a predicted utility bill. ² Efficiency measures include energy efficiency improvements such as better building envelope and more efficient mechanical equipment ³ Compliance Totals include efficiency, photovoltaics and batteries * New Construction: Building complies when Proposed Design is equal to or less than Standard Design in all compliance categories and unmet load hour limits are not exceeded. Complete Addition Scope and Existing, Addition and Alteration Scope: Building complies when efficiency compliance margin is greater than or equal to zero and unmet load hour limits are not exceeded.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 5 of 55)

C2. LSC ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual LSC Energy Use, \$/ft ² -yr)			
DOES NOT COMPLY			
Energy Component	Standard Design (LSC)	Proposed Design (LSC)	Compliance Margin (LSC) ¹
Space Heating	0.35	0.31	0.04
Space Cooling	3.93	3.95	-0.02
Indoor Fans	4.12	4.02	0.1
Heat Rejection	0	0	0
Pumps & Misc.	0.05	0.07	-0.02
Domestic Hot Water	6.26	6.72	-0.46
Indoor Lighting	7.02	6.9	0.12
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	21.73	21.97	-0.24 (-1.1%)
Photovoltaics	-19.91	-19.84	-0.07
Batteries	-0.48	-0.47	-0.01
TOTAL COMPLIANCE	1.34	1.66	-0.32 (-23.9%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 6 of 55)

C3. LSC ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (LSC)	Proposed Design (LSC)	Compliance Margin (LSC)²
Receptacle	11.42	11.42	---
Process	8.37	8.38	-0.01
Other Ltg	1.45	1.45	---
Process Motors	3.83	3.83	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	26.41	26.74	-0.33 (-1.2%)
¹ Notes: This table is not used for Energy Code Compliance.			
² Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

Not useable for compliance

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 7 of 55)

C4. SOURCE ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual SOURCE Energy Use, kBtu/ft ² /yr)			
DOES NOT COMPLY			
Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE) ¹
Space Heating	0.39	0.37	0.02
Space Cooling	0.56	0.56	0
Indoor Fans	0.97	0.95	0.02
Heat Rejection	0	0	0
Pumps & Misc.	0.03	0.03	0
Domestic Hot Water	1.61	1.68	-0.07
Indoor Lighting	1.69	1.67	0.02
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	5.25	5.26	-0.01 (-0.2%)
Photovoltaics	-2.1	-2.1	---
Batteries	-0.75	-0.75	---
TOTAL COMPLIANCE	2.4	2.41	-0.01 (-0.4%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 8 of 55)

C5. SOURCE ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE)²
Receptacle	2.89	2.89	---
Process	1.96	1.96	---
Other Ltg	0.42	0.42	---
Process Motors	0.97	0.97	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	8.64	8.65	-0.01 (-0.1%)
¹ Notes: This table is not used for Energy Code Compliance.			
² Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

C6. 'ABOVE CODE' QUALIFICATIONS	
☐ This project is pursuing CalGreen Tier 1	☐ This project is pursuing CalGreen Tier 2

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 9 of 55)

C7. ENERGY USE SUMMARY						
Energy Component	Standard Design Site (MWh)	Proposed Design Site (MWh)	Margin (MWh)	Standard Design Site (MBtu)	Proposed Design Site (MBtu)	Margin (MBtu)
Space Heating	1.7	1	0.7	41.5	41.6	-0.1
Space Cooling	81.7	81.9	-0.2	---	---	---
Indoor Fans	73.5	71.7	1.8	---	---	---
Heat Rejection	---	---	---	---	---	---
Pumps & Misc.	0.7	1.1	-0.4	---	---	---
Domestic Hot Water	113.3	121.3	-8	---	---	---
Indoor Lighting	134.9	131.7	3.2	---	---	---
Flexibility	---	---	---	---	---	---
EFFICIENCY TOTAL	405.8	408.7	-2.9	41.5	41.6	-0.1
Photovoltaics	-449.4	-447.4	-2	---	---	---
Batteries	5.5	5.4	0.1	---	---	---
ENERGY USE SUBTOTAL	-38.1	-33.3	-4.8	41.5	41.6	-0.1
Receptacle	207.5	207.5	0	---	---	---
Process	145	145	0	---	---	---
Other Ltg	22.8	22.8	0	---	---	---
Process Motors	64.2	64.2	0	---	---	---
ENERGY USE TOTAL	401.4	406.2	-4.8	41.5	41.6	-0.1

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 10 of 55)

C8. ENERGY USE INTENSITY (EUI)				
	Standard Design (kBtu/ft² / yr)	Proposed Design (kBtu/ft² / yr)	Margin (kBtu/ft² / yr)	Margin Percentage
GROSS EUI¹				
NET EUI¹				
¹ Notes: Gross EUI is Energy Use Total (not including PV)/Total Building Area. Net EUI is Energy Use Total (including PV)/Total Building Area.				

D1. EXCEPTIONAL CONDITIONS
• Verify project meets the requirements for Vestibules as per Section 120.7(e). • Verify that the project uses the JA18 Guideline 36 Library Version requirements as per Section 140.4(r). If applicable, a separate NRCC-MCH-E form must be completed. Refer to [https://www.energy.ca.gov/media/11605] to verify approved libraries by CEC.

D2. MULTIFAMILY REQUIRED SPECIAL FEATURES
• Battery System: 260.2 kWh • Indoor air quality, balanced fan • IAQ Ventilation System: as low as 0.186 W/CFM • IAQ Ventilation System: supply outside air inlet, filter, and H/ERV cores accessible per RACM Reference Manual • IAQ Ventilation System: fault indicator display • Cool roof • Non-standard duct location (any location other than attic) • Central Heat Pump Water Heater • Multifamily: Recirculating with no control (continuous pumping) • Northwest Energy Efficiency Alliance (NEEA) rated heat pump water heater; specific brand/model, or equivalent, must be installed • Domestic hot water central system piping sized in accordance with the California Plumbing Code Appendix M.

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 11 of 55)

E1. ECC FEATURE SUMMARY
The following is a summary of the features that must be field-verified by a certified ECC Rater as a condition for meeting the modeled energy performance for this computer analysis. Additional detail is provided in the building tables below. Registered LMCIs and LMCVs are required to be completed in the ECC Registry. Building-level Verifications: - Indoor air quality ventilation - Enclosure air leakage for each dwelling unit - Kitchen Exhaust Cooling System Verifications: - Minimum Airflow - Verified Refrigerant Charge - Fan Efficacy Watts/CFM Heating System Verifications: -- None -- HVAC Distribution System Verifications: - Duct leakage testing - Ducts located entirely in conditioned space confirmed by duct leakage testing Domestic Hot Water System Verifications: - Verified Pipe Insulation for Central Systems (RA3.6.3)

F1. REQUIRED PV SYSTEMS											
01	02	03	04	05	06	07	08	09	10	11	12
DC System Size (kWdc)	Exception¹	Module Type	Array Type	Power Electronics	CFI	Azimuth (deg)	Tilt Input	Array Angle (deg)	Tilt: (x in 12)	Inverter Eff. (%)	Annual Solar Access (%)
274.5		Standard (14-17%)	Fixed	none	true	150-270	n/a	n/a	<=7:12	96	98
¹ See Table D1 for any PV exceptions used.											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 12 of 55)

F1B. PV BATTERY BUILDING TYPE(S)		
01	02	03
Building Occupancy Type* (From Table 140.10-A/B and 170.2-U/V)	Conditioned Floor Area (ft²)	Unconditioned Floor Area (ft²)
Events and Exhibits	0	0
Library	0	0
Hotel/Motel	0	0
Office, Financial Institutions, Unleased Tenant Space, Medical Office Building/Clinic	414	0
Restaurants	0	0
Retail, Grocery	17613	0
School	0	0
Warehouse	0	0
Religious Worship	0	0
Sports and Recreation	4134	384
Multifamily greater than 3 stories	90480	0
None	0	27900
<i>*Building Occupancy Types are defined in Section 100.1 of the Energy Code</i>		

F2. BATTERY SYSTEMS¹						
01	02	03	04	05	06	07
Control	Capacity (kWh)	Charging Efficiency	Charging Rate (kW)	Discharging Efficiency	Discharging Rate (kW)	Round Trip Efficiency
TOU	260.2	N/A	65.04	N/A	65.04	0.9
¹ See Table D1 for any Battery exceptions used.						

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 13 of 55)

G1. ENVELOPE GENERAL INFORMATION (conditioned spaces only)			
01	02	03	04
Opaque Surfaces & Orientation	Total Gross Surface Area (ft ²)	Total Fenestration Area (ft ²)	Window to Wall Ratio (%)
North-Facing ¹	9530	2361.19	24.78
East-Facing ²	12210	3129.56	25.63
South-Facing ³	8470	2257.59	26.65
West-Facing ⁴	12090	3094.11	25.59
Total	42300	10842.4	25.63
Roof	22620	0	0
Notes ¹North-Facing is oriented to within 45 degrees of true north, including 4500'00" east of north (NE), but excluding 4500'00" west of north (NW), ²East-Facing is oriented to within 45 degrees of true east, including 4500'00" south of east (SE), but excluding 4500'00" north of east (NE), ³South-Facing is oriented to within 45 degrees of true south, including 4500'00" west of south (SW), but excluding 4500'00" east of south (SE), ⁴West-Facing is oriented to within 45 degrees of true west, including 4500'00" north of west (NW), but excluding 4500'00" south of west (SW),			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 14 of 55)

G2B. ROOFING PRODUCT SUMMARY (MULTIFAMILY AND COMMON AREAS)					
01	02	03	04	05	06
Name	Roof Pitch	Roof Rise (x in 12)	Aged Solar Reflectance	Thermal Emittance	SRI
F5 Res Zn E Court Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn E Perim Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn N Perim Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn NE Perim Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn NW Perim Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn S Court 1-Bed Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn S Court 2-Bed Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn SE Court Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn SW Court Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn SE Perim Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn SW Perim Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn W Court Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Res Zn W Perim Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Corridor Cathedral Ceiling	Low slope	1	0.63	0.75	N/A

G2B. ROOFING PRODUCT SUMMARY (MULTIFAMILY AND COMMON AREAS)					
01	02	03	04	05	06
Name	Roof Pitch	Roof Rise (x in 12)	Aged Solar Reflectance	Thermal Emittance	SRI
F5 Break Room Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Stairs E Cathedral Ceiling	Low slope	1	0.63	0.75	N/A
F5 Stairs W Cathedral Ceiling	Low slope	1	0.63	0.75	N/A

G4. NONRESIDENTIAL AIR BARRIER	
01	02
Building Story Name	Air Barrier
Building Story Nonresidential	Air barrier - not verified

Not useable for compliance

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 16 of 55)

G5. OPAQUE SURFACE ASSEMBLY SUMMARY										
01	02	03	04	05	06		07	08	09	10
Surface Name	Construction Type	Area (ft²)	Framing Type	Cavity R-Value	Continuous R-Value		Units	Value	Description of Assembly Layers	Status¹
					Interior	Exterior				
OtherFloorU07 1	Interior Floor	17,613	N/A	0	N/A	8.57	U-factor	0.0714	Concrete - 140 lb/ft3 - 10 in. Compliance Insulation R8.07 Compliance Insulation R0.50 Plywood - 5/8 in. Carpet - 3/4 in.	N
MetalFrameWal IU055	Exterior Wall	6,590	Metal	0	N/A	16.05	U-factor	0.055	Stucco - 7/8 in. Compliance Insulation R14.60 Compliance Insulation R1.41 Compliance Insulation R0.02 Compliance Insulation R0.02 Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 1/2 in.	N
MetalFrameWal Interior	Interior Wall	4,980	Metal	0	N/A	N/A	U-factor	0.3195	Gypsum Board - 5/8 in. Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 5/8 in.	N
Res Exterior Wall Cons	Exterior Walls	33,840	Wood Framed Wall	21	0	4	U-factor	0.0509	Inside Finish: Gypsum Board Cavity / Frame: R-21 / 2x6 Sheathing / Insulation: R-4 Sheathing Exterior Finish: Synthetic Stucco	N
Int Wall Cons	Interior Walls	49,570	Wood Framed Wall	0	0	0	U-factor	0.2662	Inside Finish: Gypsum Board Cavity / Frame: no insul. / 2x6 Other Side Finish: Gypsum Board	
Interior Floor Cons	Interior Floors	90,851	Wood Framed Floor	0	0	0.29	U-factor	0.1847	Floor Surface: Carpeted Floor Deck: Wood Siding/sheathing/decking Cavity / Frame: no insul. / 2x12 Sheathing / Insulation: R-0.3 Sheathing Ceiling Below Finish: Gypsum Board	N

¹ Status: N - New, A - Altered, E - Existing

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 17 of 55)

G5. OPAQUE SURFACE ASSEMBLY SUMMARY										
01	02	03	04	05	06		07	08	09	10
Surface Name	Construction Type	Area (ft²)	Framing Type	Cavity R-Value	Continuous R-Value		Units	Value	Description of Assembly Layers	Status¹
					Interior	Exterior				
Below Grade Wall Cons	Underground Walls	16,920	Concrete / ICF / Brick	0	0	0	U-factor	1.2	Mass Layer: 10 in. Concrete	N
Interior Mass Floor above Garage	Interior Floors	4,932	Concrete / ICF / Brick	0	0	4	U-factor	0.1395	Floor Surface: Hardwood Mass Layer: 6 in. Concrete Insulation/Furring: R-4 / no furring Ceiling Below Finish: Gypsum Board	N
NonRes Exterior Wall Cons	Exterior Walls	1,870	Concrete / ICF / Brick	0	13	0	U-factor	0.0771	Inside Finish: Gypsum Board Insulation/Furring: R-13 / 3.5in. wd Mass Layer: 6 in. Concrete	N
Cathedral Ceiling	Cathedral Ceilings	22,620	Wood Framed Ceiling	38	0	0	U-factor	0.0285	Roofing: 5 PSF (Normal Gravel) Roof Deck: Wood Siding/sheathing/decking Cavity / Frame: R-38 / 2x12 Inside Finish: Gypsum Board	N
Interior Wall adjacent Unconditioned	Interior Walls	800	Wood Framed Wall	11	0	0	U-factor	0.0993	Inside Finish: Gypsum Board Cavity / Frame: R-11 / 2x4 Other Side Finish: Gypsum Board	
Interior Framed Floor above Unconditioned	Interior Floors	384	Wood Framed Floor	18	0	0	U-factor	0.0492	Floor Surface: Carpeted Floor Deck: Wood Siding/sheathing/decking Cavity / Frame: R-19 in 5-1/2 in. (R-18) / 2x6 Ceiling Below Finish: Gypsum Board	N
¹ Status: N - New, A - Altered, E - Existing										

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 18 of 55)

G6B. OPAQUE DOOR SUMMARY (MULTIFAMILY AND COMMON AREAS)			
01	02	03	04
Name	Area (ft²)	Overall U-factor	Status¹
F1 Fitness Center Door Right	20	0.7	N
¹ Status: N - New, A - Altered, E - Existing			

G7A. FENESTRATION ASSEMBLY SUMMARY (NONRESIDENTIAL)								
01	02	03	04	05	06	07	08	09
Fenestration Assembly Name	Fenestration Type/ Product Type / Frame Type	Certification Method¹	Assembly Method	Area (ft²)	Overall U-factor	Overall SHGC	Overall VT	Status²
Nonres Fixed Window	Vertical fenestration Fixed window N/A	NFRC	Manufactured	659	0.34	0.22	0.42	N
¹ Notes: Newly installed fenestration shall have a certified NFRC Label Certificate or use the CEC default tables found in Table 110.6-A and Table 110.6-B. Center of Glass (COG) values are for the glass-only, determined by the manufacturer, and are shown for ease of verification. Site-built fenestration values are calculated per Nonresidential Appendix NA6 and are used in the analysis.								
² Status: N - New, A - Altered, E - Existing								

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 19 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F1 Business Center Win Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F1 Business Center Ext Wall Left	90	1.18	17.64	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F1 Corridor Win Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F1 Corridor Ext Wall Front	0	2.04	30.59	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F1 Corridor Glass Door Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F1 Corridor Ext Wall Front	0	2	40.02	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F1 Corridor Glass Door Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F1 Corridor Ext Wall Back	180	1	20.01	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F1 Fitness Center Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F1 Fitness Center Ext Wall Right	270	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F1 Leasing Office Glass Door Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F1 Leasing Office Ext Wall Left	90	1	20.01	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F1 Leasing Office Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F1 Leasing Office Ext Wall Left	90	0.47	7.06	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 20 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F1 Lobby Glass Door Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F1 Lobby Ext Wall Left	90	2	40.02	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F1 Lobby Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F1 Lobby Ext Wall Right	270	1.33	20	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn E Court Win Right Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn E Court Ext Wall Right	270	13.72	205.88	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn E Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn E Perim Ext Wall Right	270	14.12	211.77	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn N Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn N Perim Ext Wall Back	180	23.53	352.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn NE Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn NE Perim Ext Wall Back	180	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn NE Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn NE Perim Ext Wall Right	270	9.22	138.24	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 21 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F2 Res Zn NW Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn NW Perim Ext Wall Left	90	9.22	138.24	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn NW Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn NW Perim Ext Wall Back	180	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn S Court 1-Bed Win Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn S Court 1-Bed Ext Wall Front	0	4.71	70.59	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn S Court 2-Bed Win Front Court E	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn S Court 2-Bed Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn S Court 2-Bed Win Front Court W	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn S Court 2-Bed Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn SE Court Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn SE Court Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn SE Court Win Right Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn SE Court Ext Wall Right	270	3.53	52.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 22 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F2 Res Zn SW Court Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn SW Court Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn SW Court Win Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn SW Court Ext Wall Left	90	3.53	52.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn SE Perim Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn SE Perim Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn SE Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn SE Perim Ext Wall Right	270	7.06	105.89	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn SW Perim Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn SW Perim Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn SW Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn SW Perim Ext Wall Left	90	7.06	105.89	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Res Zn W Court Win Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn W Court Ext Wall Left	90	13.72	205.88	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 23 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F2 Res Zn W Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Res Zn W Perim Ext Wall Left	90	14.12	211.77	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F2 Break Room Win Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F2 Break Room Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn E Court Win Right Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn E Court Ext Wall Right	270	13.72	205.88	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn E Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn E Perim Ext Wall Right	270	14.12	211.77	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn N Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn N Perim Ext Wall Back	180	23.53	352.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn NE Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn NE Perim Ext Wall Back	180	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn NE Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn NE Perim Ext Wall Right	270	9.22	138.24	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 24 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F3 Res Zn NW Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn NW Perim Ext Wall Left	90	9.22	138.24	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn NW Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn NW Perim Ext Wall Back	180	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn S Court 1-Bed Win Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn S Court 1-Bed Ext Wall Front	0	4.71	70.59	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn S Court 2-Bed Win Front Court E	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn S Court 2-Bed Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn S Court 2-Bed Win Front Court W	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn S Court 2-Bed Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn SE Court Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn SE Court Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn SE Court Win Right Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn SE Court Ext Wall Right	270	3.53	52.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 25 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F3 Res Zn SW Court Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn SW Court Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn SW Court Win Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn SW Court Ext Wall Left	90	3.53	52.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn SE Perim Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn SE Perim Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn SE Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn SE Perim Ext Wall Right	270	7.06	105.89	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn SW Perim Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn SW Perim Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn SW Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn SW Perim Ext Wall Left	90	7.06	105.89	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Res Zn W Court Win Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn W Court Ext Wall Left	90	13.72	205.88	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 26 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F3 Res Zn W Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Res Zn W Perim Ext Wall Left	90	14.12	211.77	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F3 Break Room Win Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F3 Break Room Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn E Court Win Right Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn E Court Ext Wall Right	270	13.72	205.88	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn E Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn E Perim Ext Wall Right	270	14.12	211.77	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn N Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn N Perim Ext Wall Back	180	23.53	352.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn NE Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn NE Perim Ext Wall Back	180	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn NE Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn NE Perim Ext Wall Right	270	9.22	138.24	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 27 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F4 Res Zn NW Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn NW Perim Ext Wall Left	90	9.22	138.24	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn NW Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn NW Perim Ext Wall Back	180	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn S Court 1-Bed Win Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn S Court 1-Bed Ext Wall Front	0	4.71	70.59	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn S Court 2-Bed Win Front Court E	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn S Court 2-Bed Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn S Court 2-Bed Win Front Court W	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn S Court 2-Bed Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn SE Court Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn SE Court Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn SE Court Win Right Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn SE Court Ext Wall Right	270	3.53	52.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 28 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F4 Res Zn SW Court Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn SW Court Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn SW Court Win Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn SW Court Ext Wall Left	90	3.53	52.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn SE Perim Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn SE Perim Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn SE Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn SE Perim Ext Wall Right	270	7.06	105.89	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn SW Perim Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn SW Perim Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn SW Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn SW Perim Ext Wall Left	90	7.06	105.89	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Res Zn W Court Win Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn W Court Ext Wall Left	90	13.72	205.88	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 29 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F4 Res Zn W Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Res Zn W Perim Ext Wall Left	90	14.12	211.77	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F4 Break Room Win Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F4 Break Room Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn E Court Win Right Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn E Court Ext Wall Right	270	13.72	205.88	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn E Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn E Perim Ext Wall Right	270	14.12	211.77	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn N Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn N Perim Ext Wall Back	180	23.53	352.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn NE Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn NE Perim Ext Wall Back	180	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn NE Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn NE Perim Ext Wall Right	270	9.22	138.24	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 30 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F5 Res Zn NW Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn NW Perim Ext Wall Left	90	9.22	138.24	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn NW Perim Win Back Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn NW Perim Ext Wall Back	180	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn S Court 1-Bed Win Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn S Court 1-Bed Ext Wall Front	0	4.71	70.59	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn S Court 2-Bed Win Front Court E	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn S Court 2-Bed Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn S Court 2-Bed Win Front Court W	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn S Court 2-Bed Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn SE Court Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn SE Court Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn SE Court Win Right Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn SE Court Ext Wall Right	270	3.53	52.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 31 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status¹
F5 Res Zn SW Court Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn SW Court Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn SW Court Win Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn SW Court Ext Wall Left	90	3.53	52.94	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn SE Perim Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn SE Perim Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn SE Perim Win Right Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn SE Perim Ext Wall Right	270	7.06	105.89	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn SW Perim Win Front Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn SW Perim Ext Wall Front	0	5.88	88.23	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn SW Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn SW Perim Ext Wall Left	90	7.06	105.89	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Res Zn W Court Win Left Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn W Court Ext Wall Left	90	13.72	205.88	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 32 of 55)

G7B. FENESTRATION SUMMARY (MULTIFAMILY AND COMMON AREAS)												
01	02	03	04	05	06	07	08	09	10	11	12	13
Fenestration Name	Fenestration Type/ Product Type / Frame Type	Parent Surface	Azimuth	Multiplier	Area (ft²)	Overall U-factor	U-factor Source	Overall SHGC	SHGC Source	Overall VT	Exterior Shading	Status ¹
F5 Res Zn W Perim Win Left Perim	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Res Zn W Perim Ext Wall Left	90	14.12	211.77	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
F5 Break Room Win Front Court	Vertical fenestration Architectural Window - Operable (Multifamily only) N/A	F5 Break Room Ext Wall Front	0	2.35	35.3	0.3	NFRC	0.23	NFRC	N/A	Standard bug screens	N
¹ Status: N - New, A - Altered, E - Existing												

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
BaseSys5 F1	Package VAV Air System	1	441.93	0	N/A	NA - See Boiler	499.17	EER	9.8	Fixed DB	N
F1 Business Cent AirSys	Single Zone Heat Pump (SZHP) Air System	1	12.9	14.24	HSPF2	7.5	11.87	SEER2	14.3	No Economizer	N
F1 Corridor AirSys	Single Zone Heat Pump (SZHP) Air System	1	17.12	18.49	HSPF2	7.5	15.75	SEER2	14.3	No Economizer	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 33 of 55)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
F1 Fitness Cente AirSys	Single Zone Heat Pump (SZHP) Air System	1	16.28	14.93	HSPF2	7.5	14.98	SEER2	14.3	No Economizer	N
F1 Leasing Offic AirSys	Single Zone Heat Pump (SZHP) Air System	1	10	9.04	HSPF2	7.5	9.2	SEER2	14.3	No Economizer	N
F1 Lobby AirSys	Single Zone Heat Pump (SZHP) Air System	1	15.61	15.34	HSPF2	7.5	14.36	SEER2	14.3	No Economizer	N
F1 Stairs E AirSys	Single Zone Heat Pump (SZHP) Air System	1	4.57	3.85	HSPF2	7.5	4.21	SEER2	14.3	No Economizer	N
F1 Stairs W AirSys	Single Zone Heat Pump (SZHP) Air System	1	5.05	4.15	HSPF2	7.5	4.64	SEER2	14.3	No Economizer	N
F2 Corridor AirSys	Single Zone Heat Pump (SZHP) Air System	1	18.02	23	HSPF2	7.5	16.58	SEER2	14.3	No Economizer	N
F2 Break Room AirSys	Single Zone Heat Pump (SZHP) Air System	1	6.23	7	HSPF2	7.5	5.73	SEER2	14.3	No Economizer	N
F2 Stairs E AirSys	Single Zone Heat Pump (SZHP) Air System	1	1.39	1.77	HSPF2	7.5	1.28	SEER2	14.3	No Economizer	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 34 of 55)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
F2 Stairs W AirSys	Single Zone Heat Pump (SZHP) Air System	1	1.39	1.77	HSPF2	7.5	1.28	SEER2	14.3	No Economizer	N
F3 Corridor AirSys	Single Zone Heat Pump (SZHP) Air System	1	18.02	23	HSPF2	7.5	16.58	SEER2	14.3	No Economizer	N
F3 Break Room AirSys	Single Zone Heat Pump (SZHP) Air System	1	6.26	7.01	HSPF2	7.5	5.76	SEER2	14.3	No Economizer	N
F3 Stairs E AirSys	Single Zone Heat Pump (SZHP) Air System	1	1.39	1.77	HSPF2	7.5	1.28	SEER2	14.3	No Economizer	N
F3 Stairs W AirSys	Single Zone Heat Pump (SZHP) Air System	1	1.39	1.77	HSPF2	7.5	1.28	SEER2	14.3	No Economizer	N
F4 Corridor AirSys	Single Zone Heat Pump (SZHP) Air System	1	18.02	23	HSPF2	7.5	16.58	SEER2	14.3	No Economizer	N
F4 Break Room AirSys	Single Zone Heat Pump (SZHP) Air System	1	6.25	7.01	HSPF2	7.5	5.76	SEER2	14.3	No Economizer	N
F4 Stairs E AirSys	Single Zone Heat Pump (SZHP) Air System	1	1.39	1.77	HSPF2	7.5	1.28	SEER2	14.3	No Economizer	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 35 of 55)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
F4 Stairs W AirSys	Single Zone Heat Pump (SZHP) Air System	1	1.39	1.77	HSPF2	7.5	1.28	SEER2	14.3	No Economizer	N
F5 Corridor AirSys	Single Zone Heat Pump (SZHP) Air System	1	18.02	23	HSPF2	7.5	16.58	SEER2	14.3	No Economizer	N
F5 Break Room AirSys	Single Zone Heat Pump (SZHP) Air System	1	6.67	7.26	HSPF2	7.5	6.14	SEER2	14.3	No Economizer	N
F5 Stairs E AirSys	Single Zone Heat Pump (SZHP) Air System	1	2.32	2.4	HSPF2	7.5	2.13	SEER2	14.3	No Economizer	N
F5 Stairs W AirSys	Single Zone Heat Pump (SZHP) Air System	1	2.36	2.42	HSPF2	7.5	2.17	SEER2	14.3	No Economizer	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 36 of 55)

H2. DWELLING UNIT HVAC HEATING AND COOLING SYSTEMS														
01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
Dwelling Unit Type	Equipment Name	Equipment Type	Quantity	Air Distribution System Name	Fan System name	Heating					Cooling			
						Heat Output at 47	Heat Output at 17	Efficiency Unit	Efficiency	Backup	Total Cooling Output	Efficiency Unit	Efficiency	Variable Speed
1-Bed Type	Heat Pump System - Res	Central split HP N/A	40	Air Distribution System - Res	HVAC Fan - Heat Pump	36,000	22,536	HSPF2	7.5	Electric	N/A	EER2 SEER2	11.7 14.3	☐
2-Bed Type	Heat Pump System - Res	Central split HP N/A	32	Air Distribution System - Res	HVAC Fan - Heat Pump	36,000	22,536	HSPF2	7.5	Electric	N/A	EER2 SEER2	11.7 14.3	☐
3-Bed Type	Heat Pump System - Res	Central split HP N/A	8	Air Distribution System - Res	HVAC Fan - Heat Pump	36,000	22,536	HSPF2	7.5	Electric	N/A	EER2 SEER2	11.7 14.3	☐
Studio Type	Heat Pump System - Res	Central split HP N/A	8	Air Distribution System - Res	HVAC Fan - Heat Pump	36,000	22,536	HSPF2	7.5	Electric	N/A	EER2 SEER2	11.7 14.3	☐

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
BaseSys5 F1	1	4491.31	16,707.7	0.95	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 37 of 55)

01	14	15	16	17	18	19
Name or Item Tag	Supply Fan			Return / Relief Fan		
	Modeling Method	Fan Efficiency	Motor Efficiency	Modeling Method	Fan Efficiency	Motor Efficiency
BaseSys5 F1	Power Per Unit Flow	0.65	0.94	N/A	N/A	N/A

¹ Status: N - New, A - Altered, E - Existing

H3a. MULTIFAMILY / COMMON USE AREA FAN SYSTEMS SUMMARY				
01	02	03	04	05
Name	Type	Power	Power Units	Status
HVAC Fan - Heat Pump	Fixed speed	0.45	W/cfm	N/A

H3b. MULTIFAMILY / COMMON USE AREA IAQ FAN SYSTEMS SUMMARY					
01	02	03	04	05	06
Name	Type	Airflow (CFM)	Power	Power Units	Status
IAQ Exhaust Fan - Mech Room	Exhaust	57.6	0.19	W/cfm	N/A
Res Central Exhaust (All Units)	Exhaust	4048.8	0.3	W/cfm	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 38 of 55)

H4. MULTIFAMILY HVAC DISTRIBUTION							
01	02	03	04	05	06	07	08
Name	Type	Duct Ins. R-value Supply	Duct Ins. R-value Return	Duct Location Supply	Duct Location Return	Verified Duct Design Surface Area	
						Supply	Return
Air Distribution System - Res	Conditioned space-entirely (Non-Verified)	R-4.2	R-4.2	Conditioned Zone	Conditioned Zone	n/a	n/a
F1 Business Cent AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F1 Corridor AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F1 Fitness Cente AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F1 Leasing Offic AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F1 Lobby AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F1 Stairs E AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F1 Stairs W AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F2 Corridor AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F2 Break Room AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F2 Stairs E AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F2 Stairs W AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F3 Corridor AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 39 of 55)

H4. MULTIFAMILY HVAC DISTRIBUTION							
01	02	03	04	05	06	07	08
Name	Type	Duct Ins. R-value Supply	Duct Ins. R-value Return	Duct Location Supply	Duct Location Return	Verified Duct Design Surface Area	
						Supply	Return
F3 Break Room AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F3 Stairs E AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F3 Stairs W AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F4 Corridor AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F4 Break Room AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F4 Stairs E AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F4 Stairs W AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F5 Corridor AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F5 Break Room AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F5 Stairs E AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0
F5 Stairs W AirSys- Air Dist	Conditioned space-entirely (Non-Verified)	8	8	Conditioned Zone	Conditioned Zone	0	0

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 40 of 55)

H6. WET SYSTEM EQUIPMENT (boilers, chillers, cooling towers, etc.)									
01	02	03	04	05	06	07	08	09	10
Name or Item Tag	Equipment Type	Parent Fluid System Name	Qty	Vol (gal)	Rated Capacity	Capacity Unit	Rating	Rating Unit	Status ¹
GF Retail Boiler	Hot Water	GF Retail HW Loop	1	N/A	384.68	kBtu/Hr	0.84	TE	N
¹ Status: N - New, A - Altered, E - Existing									

H7. PUMPS							
01	02	03	04	05	06	07	08
Name or Item Tag	Parent Equipment	Qty	Power	Power Units	GPM	VSD	Status ¹
GF Retail HW Pump	GF Retail Boiler	1	0.5	BHP	19.23	☐	N
¹ Status: N - New, A - Altered, E - Existing							

H8. SYSTEM SPECIAL FEATURES			
01	02	03	04
System Name	Equipment Type	Interlocks per 140.4(n) ¹	Other Special Features and Controls
BaseSys5 F1	Package VAV Air System	N/A	Dual Maximum Reheat Controls Warmest Zone Supply Air Temp. Reset Optimum Start DDC Controls (ASHRAE Guideline 36) Fixed DB
Nonresidential Elec DHW System	Service Hot Water	N/A	Fixed Temperature Control
Nonresidential Gas DHW System	Service Hot Water	N/A	Fixed Temperature Control
GF Retail HW Loop	Hot Water System	N/A	Fixed Temperature Control
Notes: This table includes controls related to the performance path only. For projects using the prescriptive path, mandatory and prescriptive controls requirements are documented on the NRCC-MCH-E.			
¹ Yes = interlocks are provided, No = interlocks are not provided, NA means no operable openings.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 41 of 55)

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
Thermal Zone: F1 Retail N-NW	Retail - Sales	101.75	1526.17	0	5985	N/A
Thermal Zone: F1 Retail NE	Retail - Sales	73.44	1101.6	0	4320	N/A
Thermal Zone: F1 Retail SE	Retail - Sales	48.96	734.4	0	2880	N/A
Thermal Zone: F1 Retail SW	Retail - Sales	75.28	1129.14	0	4428	N/A
F1 Business Center	General - Conference/meeting	11.88	178.2	0	360	N/A
F1 Corridor	Residential - Common corridors	7.32	219.6	0	1464	N/A
F1 Fitness Center	Sports/Entertainment - Gym, sports arena (play area)	9	135	0	900	N/A
F1 Leasing Office	Office - Office space	2.07	62.1	0	414	N/A
F1 Lobby	Residential - Common corridors	5.25	157.5	0	1050	N/A
F1 Stairs E	Residential - Common corridors	0.9	27	0	180	N/A
F1 Stairs W	Residential - Common corridors	0.9	27	0	180	N/A
F2 Corridor	Residential - Common corridors	11.7	351	0	2340	N/A
F2 Break Room	General - Break rooms	5.94	89.1	0	180	N/A
F2 Stairs E	Residential - Common corridors	0.9	27	0	180	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 42 of 55)

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
F2 Stairs W	Residential - Common corridors	0.9	27	0	180	N/A
F3 Corridor	Residential - Common corridors	11.7	351	0	2340	N/A
F3 Break Room	General - Break rooms	5.94	89.1	0	180	N/A
F3 Stairs E	Residential - Common corridors	0.9	27	0	180	N/A
F3 Stairs W	Residential - Common corridors	0.9	27	0	180	N/A
F4 Corridor	Residential - Common corridors	11.7	351	0	2340	N/A
F4 Break Room	General - Break rooms	5.94	89.1	0	180	N/A
F4 Stairs E	Residential - Common corridors	0.9	27	0	180	N/A
F4 Stairs W	Residential - Common corridors	0.9	27	0	180	N/A
F5 Corridor	Residential - Common corridors	11.7	351	0	2340	N/A
F5 Break Room	General - Break rooms	5.94	89.1	0	180	N/A
F5 Stairs E	Residential - Common corridors	0.9	27	0	180	N/A
F5 Stairs W	Residential - Common corridors	0.9	27	0	180	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 43 of 55)

H10. MULTIFAMILY DWELLING UNIT TYPE CENTRAL / INDIVIDUAL VENTILATION												
01	02	03	04	05	06	07	08	09	10	11	12	13
Dwelling Unit Type	IAQ Option	Central Fan (If applicable)					Individual Fan (if applicable)					
		IAQ Fan Type	Supply Airflow CFM	Supply Fan Efficacy W/CFM	Exhaust CFM	Exhaust Fan Efficacy W/CFM	IAQ Fan Type	Count	Airflow CFM	Fan Efficacy W/CFM	Recovery Efficiency SRE	Recovery Efficiency ASRE
1-Bed Type	Exhaust Central / Individual Supply	Exhaust	N/A	N/A	36.6	0.3	Supply	1	36.6	0.35	N/A	N/A
2-Bed Type	Exhaust Central / Individual Supply	Exhaust	N/A	N/A	54.9	0.3	Supply	1	54.9	0.35	N/A	N/A
3-Bed Type	Exhaust Central / Individual Supply	Exhaust	N/A	N/A	72.3	0.3	Supply	1	72.3	0.35	N/A	N/A
Studio Type	Exhaust Central / Individual Supply	Exhaust	N/A	N/A	31.2	0.3	Supply	1	31.2	0.35	N/A	N/A

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
BaseVAV TrmlUnit-7	Variable Air Volume Reheat Box	1	100.31	N/A	4,880.93	1,526.17	0.31	N/A	N/A	N/A	☐
BaseVAV TrmlUnit-8	Variable Air Volume Reheat Box	1	78.78	N/A	3,670.75	1,101.6	0.3	N/A	N/A	N/A	☐
BaseVAV TrmlUnit-9	Variable Air Volume Reheat Box	1	66.3	N/A	2,435.01	734.4	0.3	N/A	N/A	N/A	☐
BaseVAV TrmlUnit-10	Variable Air Volume Reheat Box	1	95.61	N/A	3,807.57	1,129.14	0.3	N/A	N/A	N/A	☐
F1 Business Cent TrmlUnit	Uncontrolled	1	N/A	N/A	289.06	N/A	0	N/A	N/A	N/A	☐
F1 Corridor TrmlUnit	Uncontrolled	1	N/A	N/A	383.45	N/A	0	N/A	N/A	N/A	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 44 of 55)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	Min.	Min. Ratio	Power	Power Units	Cycles	
F1 Fitness Cente TrmlUnit	Uncontrolled	1	N/A	N/A	364.63	N/A	0	N/A	N/A	N/A	☐
F1 Leasing Offic TrmlUnit	Uncontrolled	1	N/A	N/A	247.65	N/A	0	N/A	N/A	N/A	☐
F1 Lobby TrmlUnit	Uncontrolled	1	N/A	N/A	349.68	N/A	0	N/A	N/A	N/A	☐
F1 Stairs E TrmlUnit	Uncontrolled	1	N/A	N/A	102.41	N/A	0	N/A	N/A	N/A	☐
F1 Stairs W TrmlUnit	Uncontrolled	1	N/A	N/A	113.06	N/A	0	N/A	N/A	N/A	☐
F2 Corridor TrmlUnit	Uncontrolled	1	N/A	N/A	403.65	N/A	0	N/A	N/A	N/A	☐
F2 Break Room TrmlUnit	Uncontrolled	1	N/A	N/A	139.58	N/A	0	N/A	N/A	N/A	☐
F2 Stairs E TrmlUnit	Uncontrolled	1	N/A	N/A	31.05	N/A	0	N/A	N/A	N/A	☐
F2 Stairs W TrmlUnit	Uncontrolled	1	N/A	N/A	31.05	N/A	0	N/A	N/A	N/A	☐
F3 Corridor TrmlUnit	Uncontrolled	1	N/A	N/A	403.65	N/A	0	N/A	N/A	N/A	☐
F3 Break Room TrmlUnit	Uncontrolled	1	N/A	N/A	140.13	N/A	0	N/A	N/A	N/A	☐
F3 Stairs E TrmlUnit	Uncontrolled	1	N/A	N/A	31.05	N/A	0	N/A	N/A	N/A	☐
F3 Stairs W TrmlUnit	Uncontrolled	1	N/A	N/A	31.05	N/A	0	N/A	N/A	N/A	☐
F4 Corridor TrmlUnit	Uncontrolled	1	N/A	N/A	403.65	N/A	0	N/A	N/A	N/A	☐
F4 Break Room TrmlUnit	Uncontrolled	1	N/A	N/A	140.11	N/A	0	N/A	N/A	N/A	☐
F4 Stairs E TrmlUnit	Uncontrolled	1	N/A	N/A	31.05	N/A	0	N/A	N/A	N/A	☐
F4 Stairs W TrmlUnit	Uncontrolled	1	N/A	N/A	31.05	N/A	0	N/A	N/A	N/A	☐
F5 Corridor TrmlUnit	Uncontrolled	1	N/A	N/A	403.65	N/A	0	N/A	N/A	N/A	☐
F5 Break Room TrmlUnit	Uncontrolled	1	N/A	N/A	149.36	N/A	0	N/A	N/A	N/A	☐
F5 Stairs E TrmlUnit	Uncontrolled	1	N/A	N/A	51.87	N/A	0	N/A	N/A	N/A	☐
F5 Stairs W TrmlUnit	Uncontrolled	1	N/A	N/A	52.77	N/A	0	N/A	N/A	N/A	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 45 of 55)

I1. WATER HEATER EQUIPMENT SUMMARY													
01	02	03	04	05	06	07	08	09	10	11	12	13	14
Name	Heater Element Type	Tank Type	Qty	Tank Vol (gal)	Rated Input	Rated Input Unit	Efficiency	Efficiency Unit	Tank Insulation R-value Int/Ext	Standby Loss Fraction	1st Hr. Rating or Flow Rate (gal)	Heat Pump Type	Tank Location or Ambient Condition
Heat Pump	Heat Pump	Storage	0	83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Residential (NEEA RATED) PRODUCT	Outside
Nonres Elec Water Heater	Electricity	Storage	1	30	8.7	kW	0.94	UEF	N/A	N/A	60	N/A	N/A
Nonres Gas Water Heater	Natural Gas	Storage	1	30	35.95	kBtu/Hr	0.56	UEF	N/A	N/A	80	N/A	N/A

I1A. WATER HEATERS - HEAT PUMP									
01	02	03	04	05	06	07	08	09	10
Name	# of Units	Tank Vol. (gal)	Heat Pump Brand	Heat Pump Model	Tank Location	Duct Inlet Air Source	Duct Outlet Air Source	UEF	JA13 Compliant
Heat Pump		83	SANCO2	GS3-45HPA-US & SAN-83SSAQA (83 gal)	Outside	Outside	Outside	0.59	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 46 of 55)

12. MULTI-FAMILY WATER HEATING SYSTEM DETAIL								
01	02	03	04	05	06	07	08	09
System Name	Configuration	Type	Qty in System	Dwelling Unit Distribution Type	Water Heater Name	Solar Heating System	Is Compact Distribution	Pipe Sizing as per CPC Appx. M.
DHW Heat Pump	Domestic Hot Water (DHW)	Central	1	Standard Distribution System	DHW Heat Pump - heater	N/A	N/A	Yes
DHW Heat Pump Indiv	Domestic Hot Water (DHW)	Unitary	1	Standard Distribution System	Heat Pump	N/A	No	N/A

13. MULTIFAMILY & HOTEL/MOTEL WATER HEATER EQUIPMENT SUMMARY - CHPWH							
01	02	03	04	05	06	07	08
Name	Brand/Model	Number of Compressors	Primary Tank Volume (gal)	Tank Count	Tank R-value	Tank Location	Air Source
DHW Heat Pump	Generic 20kW	6	750	1	16	Tank Zone	Outside

14. MULTIFAMILY & HOTEL/MOTEL WATER HEATER EQUIPMENT SUMMARY - CHPWH SECONDARY TANK								
01	02	03	04	05	06	07	08	09
Tank Type	Tank Configuration	Brand/Model	Count	Tank Volume (gal)	Tank Count	Tank R-value	Tank Location	Air Source
Electric Resistance	Series	N/A	1	120	1	16	F1 Mech Rm	N/A

15. RECIRCULATION LOOPS						
01	02	03	04	05	06	07
Water Heating System Name	Number of Recirculation Loops	Loop Insulation Thickness (in)	Recirculation Loop Location	Recirculation Pump Power	Recirculation Pump Power Units	Master Mixing Valve
DHW Heat Pump	1	1.5	Conditioned	48	Watts	None

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 47 of 55)

K1. INDOOR CONDITIONED LIGHTING GENERAL INFO					
01	02	03	04	05	06
Occupancy Type¹	Conditioned Floor Area² (ft²)	Installed Lighting Power (Watts)	Lighting Control Credits (Watts)	Additional (Custom) Allowance	
				Area Category Footnotes (Watts)	Area Category Footnotes (Watts)
Retail Merchandise Sales	17613	16732.3	0	0	0
Corridor	10824	4329.6	0	0	0
Exercise Center Gymnasium	900	450	0	0	0
Main Entry Lobby	1050	735	0	0	0
Lounge	720	396	0	0	0
Office (250 square feet)	414	248.4	0	0	0
Stairwell	1800	1080	0	0	0
Conference Multipurpose Meeting Center Area	360	270	0	0	0
Building Totals:	33681	24241.3	0	0	0
¹ See Table 140.6-C ² See NRCC-LTI-E for unconditioned spaces ³ Lighting information for existing spaces modeled is not included in this table					

K4. INDOOR CONDITIONED LIGHTING MANDATORY LIGHTING CONTROL
See NRCC-LTI-E for mandatory controls

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 48 of 55)

L. DWELLING UNIT INFORMATION			
01	02	03	04
Dwelling Unit Name	Dwelling Unit Type	Zone	Zone Group Multiplier
F2 1-Bed E Court-(1/2)	1-Bed Type	F2 Res Zn E Court	1
F2 1-Bed E Court-(2/2)	1-Bed Type	F2 Res Zn E Court	1
F2 2-Bed E Perim-(1/2)	2-Bed Type	F2 Res Zn E Perim	1
F2 2-Bed E Perim-(2/2)	2-Bed Type	F2 Res Zn E Perim	1
F2 1-Bed N Perim-(1/5)	1-Bed Type	F2 Res Zn N Perim	1
F2 1-Bed N Perim-(2/5)	1-Bed Type	F2 Res Zn N Perim	1
F2 1-Bed N Perim-(3/5)	1-Bed Type	F2 Res Zn N Perim	1
F2 1-Bed N Perim-(4/5)	1-Bed Type	F2 Res Zn N Perim	1
F2 1-Bed N Perim-(5/5)	1-Bed Type	F2 Res Zn N Perim	1
F2 3-Bed NE Perim-(1/1)	3-Bed Type	F2 Res Zn NE Perim	1
F2 3-Bed NW Perim-(1/1)	3-Bed Type	F2 Res Zn NW Perim	1
F2 1-Bed S Court-(1/1)	1-Bed Type	F2 Res Zn S Court 1-Bed	1
F2 2-Bed S Court-(1/2)	2-Bed Type	F2 Res Zn S Court 2-Bed	1
F2 2-Bed S Court-(2/2)	2-Bed Type	F2 Res Zn S Court 2-Bed	1
F2 Studio SE Court-(1/1)	Studio Type	F2 Res Zn SE Court	1
F2 Studio SW Court-(1/1)	Studio Type	F2 Res Zn SW Court	1
F2 2-Bed SE Perim-(1/1)	2-Bed Type	F2 Res Zn SE Perim	1
F2 2-Bed SW Perim-(1/1)	2-Bed Type	F2 Res Zn SW Perim	1
F2 1-Bed W Court-(1/2)	1-Bed Type	F2 Res Zn W Court	1
F2 1-Bed W Court-(2/2)	1-Bed Type	F2 Res Zn W Court	1
F2 2-Bed W Perim-(1/2)	2-Bed Type	F2 Res Zn W Perim	1
F2 2-Bed W Perim-(2/2)	2-Bed Type	F2 Res Zn W Perim	1
F3 1-Bed E Court-(1/2)	1-Bed Type	F3 Res Zn E Court	1
F3 1-Bed E Court-(2/2)	1-Bed Type	F3 Res Zn E Court	1
F3 2-Bed E Perim-(1/2)	2-Bed Type	F3 Res Zn E Perim	1
F3 2-Bed E Perim-(2/2)	2-Bed Type	F3 Res Zn E Perim	1

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 49 of 55)

L. DWELLING UNIT INFORMATION			
01	02	03	04
Dwelling Unit Name	Dwelling Unit Type	Zone	Zone Group Multiplier
F3 1-Bed N Perim-(1/5)	1-Bed Type	F3 Res Zn N Perim	1
F3 1-Bed N Perim-(2/5)	1-Bed Type	F3 Res Zn N Perim	1
F3 1-Bed N Perim-(3/5)	1-Bed Type	F3 Res Zn N Perim	1
F3 1-Bed N Perim-(4/5)	1-Bed Type	F3 Res Zn N Perim	1
F3 1-Bed N Perim-(5/5)	1-Bed Type	F3 Res Zn N Perim	1
F3 3-Bed NE Perim-(1/1)	3-Bed Type	F3 Res Zn NE Perim	1
F3 3-Bed NW Perim-(1/1)	3-Bed Type	F3 Res Zn NW Perim	1
F3 1-Bed S Court-(1/1)	1-Bed Type	F3 Res Zn S Court 1-Bed	1
F3 2-Bed S Court-(1/2)	2-Bed Type	F3 Res Zn S Court 2-Bed	1
F3 2-Bed S Court-(2/2)	2-Bed Type	F3 Res Zn S Court 2-Bed	1
F3 Studio SE Court-(1/1)	Studio Type	F3 Res Zn SE Court	1
F3 Studio SW Court-(1/1)	Studio Type	F3 Res Zn SW Court	1
F3 2-Bed SE Perim-(1/1)	2-Bed Type	F3 Res Zn SE Perim	1
F3 2-Bed SW Perim-(1/1)	2-Bed Type	F3 Res Zn SW Perim	1
F3 1-Bed W Court-(1/2)	1-Bed Type	F3 Res Zn W Court	1
F3 1-Bed W Court-(2/2)	1-Bed Type	F3 Res Zn W Court	1
F3 2-Bed W Perim-(1/2)	2-Bed Type	F3 Res Zn W Perim	1
F3 2-Bed W Perim-(2/2)	2-Bed Type	F3 Res Zn W Perim	1
F4 1-Bed E Court-(1/2)	1-Bed Type	F4 Res Zn E Court	1
F4 1-Bed E Court-(2/2)	1-Bed Type	F4 Res Zn E Court	1
F4 2-Bed E Perim-(1/2)	2-Bed Type	F4 Res Zn E Perim	1
F4 2-Bed E Perim-(2/2)	2-Bed Type	F4 Res Zn E Perim	1
F4 1-Bed N Perim-(1/5)	1-Bed Type	F4 Res Zn N Perim	1
F4 1-Bed N Perim-(2/5)	1-Bed Type	F4 Res Zn N Perim	1
F4 1-Bed N Perim-(3/5)	1-Bed Type	F4 Res Zn N Perim	1
F4 1-Bed N Perim-(4/5)	1-Bed Type	F4 Res Zn N Perim	1

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 50 of 55)

L. DWELLING UNIT INFORMATION			
01	02	03	04
Dwelling Unit Name	Dwelling Unit Type	Zone	Zone Group Multiplier
F4 1-Bed N Perim-(5/5)	1-Bed Type	F4 Res Zn N Perim	1
F4 3-Bed NE Perim-(1/1)	3-Bed Type	F4 Res Zn NE Perim	1
F4 3-Bed NW Perim-(1/1)	3-Bed Type	F4 Res Zn NW Perim	1
F4 1-Bed S Court-(1/1)	1-Bed Type	F4 Res Zn S Court 1-Bed	1
F4 2-Bed S Court-(1/2)	2-Bed Type	F4 Res Zn S Court 2-Bed	1
F4 2-Bed S Court-(2/2)	2-Bed Type	F4 Res Zn S Court 2-Bed	1
F4 Studio SE Court-(1/1)	Studio Type	F4 Res Zn SE Court	1
F4 Studio SW Court-(1/1)	Studio Type	F4 Res Zn SW Court	1
F4 2-Bed SE Perim-(1/1)	2-Bed Type	F4 Res Zn SE Perim	1
F4 2-Bed SW Perim-(1/1)	2-Bed Type	F4 Res Zn SW Perim	1
F4 1-Bed W Court-(1/2)	1-Bed Type	F4 Res Zn W Court	1
F4 1-Bed W Court-(2/2)	1-Bed Type	F4 Res Zn W Court	1
F4 2-Bed W Perim-(1/2)	2-Bed Type	F4 Res Zn W Perim	1
F4 2-Bed W Perim-(2/2)	2-Bed Type	F4 Res Zn W Perim	1
F5 1-Bed E Court-(1/2)	1-Bed Type	F5 Res Zn E Court	1
F5 1-Bed E Court-(2/2)	1-Bed Type	F5 Res Zn E Court	1
F5 2-Bed E Perim-(1/2)	2-Bed Type	F5 Res Zn E Perim	1
F5 2-Bed E Perim-(2/2)	2-Bed Type	F5 Res Zn E Perim	1
F5 1-Bed N Perim-(1/5)	1-Bed Type	F5 Res Zn N Perim	1
F5 1-Bed N Perim-(2/5)	1-Bed Type	F5 Res Zn N Perim	1
F5 1-Bed N Perim-(3/5)	1-Bed Type	F5 Res Zn N Perim	1
F5 1-Bed N Perim-(4/5)	1-Bed Type	F5 Res Zn N Perim	1
F5 1-Bed N Perim-(5/5)	1-Bed Type	F5 Res Zn N Perim	1
F5 3-Bed NE Perim-(1/1)	3-Bed Type	F5 Res Zn NE Perim	1
F5 3-Bed NW Perim-(1/1)	3-Bed Type	F5 Res Zn NW Perim	1
F5 1-Bed S Court-(1/1)	1-Bed Type	F5 Res Zn S Court 1-Bed	1

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 51 of 55)

L. DWELLING UNIT INFORMATION			
01	02	03	04
Dwelling Unit Name	Dwelling Unit Type	Zone	Zone Group Multiplier
F5 2-Bed S Court-(1/2)	2-Bed Type	F5 Res Zn S Court 2-Bed	1
F5 2-Bed S Court-(2/2)	2-Bed Type	F5 Res Zn S Court 2-Bed	1
F5 Studio SE Court-(1/1)	Studio Type	F5 Res Zn SE Court	1
F5 Studio SW Court-(1/1)	Studio Type	F5 Res Zn SW Court	1
F5 2-Bed SE Perim-(1/1)	2-Bed Type	F5 Res Zn SE Perim	1
F5 2-Bed SW Perim-(1/1)	2-Bed Type	F5 Res Zn SW Perim	1
F5 1-Bed W Court-(1/2)	1-Bed Type	F5 Res Zn W Court	1
F5 1-Bed W Court-(2/2)	1-Bed Type	F5 Res Zn W Court	1
F5 2-Bed W Perim-(1/2)	2-Bed Type	F5 Res Zn W Perim	1
F5 2-Bed W Perim-(2/2)	2-Bed Type	F5 Res Zn W Perim	1

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 52 of 55)

M. DWELLING UNIT TYPES						
01	02	03	04	05	06	07
Name	CFA (ft²)	Number of Bedrooms	Number in Building	Space Conditioning Systems Assigned	DHW System Name	IAQ Vent Fan Name
1-Bed Type	720	1	40	1-Bed Type :Heat Pump System - Res:Air Distribution System - Res:HVAC Fan - Heat Pump:2:3	DHW Heat Pump	Central Exhaust / Individual Supply
2-Bed Type	1080	2	32	2-Bed Type :Heat Pump System - Res:Air Distribution System - Res:HVAC Fan - Heat Pump:2:3	DHW Heat Pump	Central Exhaust / Individual Supply
3-Bed Type	1410	3	8	3-Bed Type :Heat Pump System - Res:Air Distribution System - Res:HVAC Fan - Heat Pump:2:3	DHW Heat Pump	Central Exhaust / Individual Supply
Studio Type	540	0	8	Studio Type :Heat Pump System - Res:Air Distribution System - Res:HVAC Fan - Heat Pump:2:3	DHW Heat Pump	Central Exhaust / Individual Supply

N. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION	
<i>Selections made by Documentation Author indicate which Certificates of Installation must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online</i>	
Building Component	Form/Title
Envelope	NRCI-ENV-E - Envelope (for all buildings)
Mechanical	NRCI-MCH-E - For all buildings with Mechanical Systems
Plumbing	NRCI-PLB-E - For all buildings with Plumbing Systems

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 53 of 55)

N. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION	
<i>Selections made by Documentation Author indicate which Certificates of Installation must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online</i>	
Building Component	Form/Title
Solar and Battery	NRCI-SAB-E - Solar Water Heating, PV and Battery Storage Systems
Indoor Lighting	NRCI-LTI-E - Indoor Lighting (for all buildings)

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
<i>Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction. Lighting controls and mechanical NRCA's must be completed through an Acceptance Test Technician Certification Provider (ATTCP).</i>	
Building Component ¹	Form/Title & System Name(s)
Envelope	NRCA-ENV-02-F - NRFC label verification for fenestration
Indoor Lighting	NRCA-LTI-02-A - Occupancy Sensors and Automatic Time Switch Controls.
Indoor Lighting	NRCA-LTI-03-A - Automatic Daylight Controls.
Indoor Lighting	NRCA-LTI-04-A - Demand Responsive Lighting Controls.
Mechanical	NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap
	BaseSys5 F1, F1 Business Cent AirSys, F1 Corridor AirSys, F1 Fitness Cente AirSys, F1 Leasing Offic AirSys, F1 Lobby AirSys, F1 Stairs E AirSys, F1 Stairs W AirSys, F2 Corridor AirSys, F2 Break Room AirSys, F2 Stairs E AirSys, F2 Stairs W AirSys, F3 Corridor AirSys, F3 Break Room AirSys, F3 Stairs E AirSys, F3 Stairs W AirSys, F4 Corridor AirSys, F4 Break Room AirSys, F4 Stairs E AirSys, F4 Stairs W AirSys, F5 Corridor AirSys, F5 Break Room AirSys, F5 Stairs E AirSys and F5 Stairs W AirSys.
Mechanical	NRCA-MCH-03-A - Constant Volume Single Zone HVAC
	F1 Business Cent AirSys, F1 Corridor AirSys, F1 Fitness Cente AirSys, F1 Leasing Offic AirSys, F1 Lobby AirSys, F1 Stairs E AirSys, F1 Stairs W AirSys, F2 Corridor AirSys, F2 Break Room AirSys, F2 Stairs E AirSys, F2 Stairs W AirSys, F3 Corridor AirSys, F3 Break Room AirSys, F3 Stairs E AirSys, F3 Stairs W AirSys, F4 Corridor AirSys, F4 Break Room AirSys, F4 Stairs E AirSys, F4 Stairs W AirSys, F5 Corridor AirSys, F5 Break Room AirSys, F5 Stairs E AirSys and F5 Stairs W AirSys.
Mechanical	NRCA-MCH-05-A - Air Economizer Controls
	BaseSys5 F1
Mechanical	NRCA-MCH-07-A Supply Fan Variable Flow Controls
	BaseSys5 F1

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 54 of 55)

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
<i>Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction. Lighting controls and mechanical NRCA's must be completed through an Acceptance Test Technician Certification Provider (ATTCP).</i>	
Building Component ¹	Form/Title & System Name(s)
Mechanical	NRCA-MCH-11-A Automatic Demand Shed Controls
	BaseSys5 F1
Mechanical	NRCA-MCH-12-A FDD for Packaged Direct Expansion Units
	BaseSys5 F1
Mechanical	NRCA-MCH-16-A Supply Air Temperature Reset Controls
	BaseSys5 F1
¹ Refer to other prescriptive NRCC forms applicable to the project for additional NRCA tests required that are not included in the NRCC-PRF-E form	

P. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION	
<i>Selections made by Documentation Author indicate which Certificates of Verification must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online</i>	
Building Component	Form/Title
Mechanical	NRCV-MCH-27 Indoor Air Quality & Mechanical Ventilation

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 55 of 55)

Documentation Author's Declaration Statement

1. I certify that this Certificate of Compliance documentation is accurate and complete.	
Documentation Author Name:	Documentation Author Signature:
Company:	Signature Date:
Address:	CEA/AEA/ECC Certification Identification (if applicable):
City/State/Zip: ,	Phone:

Responsible Person's Declaration statement

I certify the following under penalty of perjury, under the laws of the State of California:		
- The information provided on this Certificate of Compliance is true and correct. - I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer). - The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations. - The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application. - I understand that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building and shall be made available to the enforcement agency for all applicable inspections. I will take the necessary steps to fulfill this requirement. - I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy. I will take the necessary steps to fulfill this requirement.		
Responsible Designer Name:	Responsible Designer Signature:	
Company:		
Address:	Date Signed:	
City/State/Zip: ,	License #:	
Phone:	Title:	Scope: