

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD		NRCC-PRF-E
Nonresidential Performance Compliance Method		(Page 1 of 33)
Project Name:	Lab Classroom FPFC	Date Prepared: 2026-09-23

A. General Information				
1	Project Name	Lab Classroom FPFC		
2	Run Title			
3	Project Location	- specify -		
4	City	- specify -	5	Standards Version
		Compliance 2025		
6	Zip code	95837	7	Compliance Software (version)
		CBECC-CLI 2025.3.0 RC (1415)		
8	Climate Zone	9	9	Building Orientation (deg)
		0		
10	Building Type(s)	• Nonresidential	11	Weather File
		CA_Title24_2025_LOS-ANGELES-USC.epw		
12	Project Scope	• New envelope and mechanical	13	Number of Dwelling Units
		0		
14	Total Conditioned Floor Area in Scope (ft²)	27040.5	15	Total # of hotel/motel rooms
		0		
16	Total Unconditioned Floor Area (ft²)	1465.24	17	Fuel Type
		All electric		
18	Is Natural Gas Available per Section 100.1?	No	19	Nonresidential Conditioned Floor Area
		27040.5		
20	Total # of Stories (Habitable Above Grade)	2	21	Residential Conditioned Floor Area
		0		

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 2 of 33)

B1. PROJECT SUMMARY - Performance		
Table B1 shows which building components are included in the performance calculation. If indicated as not included, the project must show compliance prescriptively if within the permit application.		
Building Components Complying via Performance		
Envelope (See Table G)	Nonresidential	Included
	Multifamily	Not Included
Mechanical (See Table H)	Nonresidential	Included
	Multifamily	Not Included
Domestic Hot Water (See Table I)	Nonresidential	Not Included
	Multifamily	Not Included
Lighting (Indoor Conditioned, see Table K)	Nonresidential	Not Included
	Multifamily	Not Included
Solar Thermal Water Heating (See Table I3)		Not Included
Covered Process: Commercial Kitchens (see Table J)		Not Included
Covered Process: Laboratory Exhaust (see Table J)		Included
Photovoltaics (see Table F)		Included
Battery (see Table F)		Included

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 3 of 33)

B2. PROJECT SUMMARY - Prescriptive/Mandatory	
Building Components Not Supported via Performance Approach - Must Use the Following Certificate of Compliance Forms	
<i>The following building components are supported via the applicable Certificate of Compliance forms listed below when within the scope of the permit application.</i>	
Indoor Lighting - Unconditioned Spaces 140.6 & 141.0(b)2I & 170.2(e) & 180.2(b)4B	NRCC-LTI-01-E if any enclosed unconditioned spaces have new/alterd lighting
Indoor Lighting - Multifamily Dwelling Unit, Hotel/Motel Guest Room 160.5(a) & 130.0(b)	NRCC-LTI-01-E if dwelling units or guest rooms have new/alterd indoor lighting
Outdoor Lighting 140.7 & 141.0(b)2L & 170.2(e) & 180.2(b)4B	NRCC-LTO-01-E if any new/alterd outdoor lighting
Outdoor Lighting - Multifamily Dwelling Unit, Hotel/Motel Guest Room 160.5(a) & 130.0(b)	NRCC-LTO-01-E if dwelling units or guest rooms have new/alterd outdoor lighting
Illuminated Sign Lighting 140.8 & 141.0(b)2M & 170.2(e) & 180.2(b)4	NRCC-LTS-01-E if any new/alterd illuminated signs located indoors or outdoors
Electrical Power Distribution 130.5 & 141.0(b)2P & 170.2(e) & 180.2(b)4	NRCC-ELC-01-E if any new/alterd electrical power distribution components
Electrical Readiness for New Multifamily Buildings 160.9	NRCC-ELC-01-E if gas is used in dwelling unit heating, cooktop, clothes dryer or water heating systems
Design Review and Commissioning 120.8	NRCC-CXR-01-E if new building with conditioned nonresidential occupancy
Solar Readiness 110.10	NRCC-SAB-01-E if new conditioned building and no photovoltaic (PV) system is installed per the Energy Code
Covered Processes 120.6 & 140.9 & 141.1 & 160.7	NRCC-PRC-01-E if new/alterd Refrigerated Warehouse, Commercial Refrigeration, Enclosed Parking Garage, Process Boiler, Compressed Air, Elevator, Escalator, Moving Walkway, Controlled Environment Horticulture, Steam Trap, Computer/Data Room, Commercial Kitchen, Laboratory or Factory Exhaust

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 4 of 33)

C1. COMPLIANCE SUMMARY			
COMPLIES*			
	Long-term System Cost (LSC) ¹		Source Energy Use
	Efficiency ² (\$/ft ² -yr)	Total ³ (\$/ft ² -yr)	Total ³ (kBtu/ft ² -yr)
Standard Design	66.93	50.42	26.08
Proposed Design	43.48	26.97	9.54
Compliance Margins	23.45	23.45	16.54
	Pass	Pass	Pass
¹ Long-term System Cost (LSC) is a 30-year present value cost to California's energy system. LSC is not a predicted utility bill. ² Efficiency measures include energy efficiency improvements such as better building envelope and more efficient mechanical equipment ³ Compliance Totals include efficiency, photovoltaics and batteries * New Construction: Building complies when Proposed Design is equal to or less than Standard Design in all compliance categories and unmet load hour limits are not exceeded. Complete Addition Scope and Existing, Addition and Alteration Scope: Building complies when efficiency compliance margin is greater than or equal to zero and unmet load hour limits are not exceeded.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 5 of 33)

C2. LSC ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual LSC Energy Use, \$/ft²-yr)			
COMPLIES			
Energy Component	Standard Design (LSC)	Proposed Design (LSC)	Compliance Margin (LSC)¹
Space Heating	12.87	7.4	5.47
Space Cooling	18.97	15.18	3.79
Indoor Fans	27.72	12.96	14.76
Heat Rejection	0	0	0
Pumps & Misc.	0.01	0.58	-0.57
Domestic Hot Water	0	0	0
Indoor Lighting	7.36	7.36	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	66.93	43.48	23.45 (35%)
Photovoltaics	-16.5	-16.5	---
Batteries	-0.01	-0.01	---
TOTAL COMPLIANCE	50.42	26.97	23.45 (46.5%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 6 of 33)

C3. LSC ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (LSC)	Proposed Design (LSC)	Compliance Margin (LSC)²
Receptacle	60.2	60.2	---
Process	3.75	3.75	---
Other Ltg	0.26	0.26	---
Process Motors	0.12	0.12	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	114.75	91.3	23.45 (20.4%)
¹ Notes: This table is not used for Energy Code Compliance.			
² Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 7 of 33)

C4. SOURCE ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual SOURCE Energy Use, kBtu/ft² /yr)			
COMPLIES			
Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE)¹
Space Heating	15.06	2.92	12.14
Space Cooling	3.69	2.95	0.74
Indoor Fans	7.55	3.77	3.78
Heat Rejection	0	0	0
Pumps & Misc.	0	0.13	-0.13
Domestic Hot Water	0	0	0
Indoor Lighting	1.86	1.86	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	28.16	11.63	16.53 (58.7%)
Photovoltaics	-2.06	-2.06	---
Batteries	-0.02	-0.03	0.01
TOTAL COMPLIANCE	26.08	9.54	16.54 (63.4%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 8 of 33)

C5. SOURCE ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE)²
Receptacle	12.05	12.05	---
Process	1.13	1.13	---
Other Ltg	0.07	0.07	---
Process Motors	0.03	0.03	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	39.36	22.82	16.54 (42%)
¹ Notes: This table is not used for Energy Code Compliance.			
² Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

C6. 'ABOVE CODE' QUALIFICATIONS	
☐ This project is pursuing CalGreen Tier 1	☐ This project is pursuing CalGreen Tier 2

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 9 of 33)

C7. ENERGY USE SUMMARY						
Energy Component	Standard Design Site (MWh)	Proposed Design Site (MWh)	Margin (MWh)	Standard Design Site (MBtu)	Proposed Design Site (MBtu)	Margin (MBtu)
Space Heating	1.8	31.2	-29.4	401.6	---	---
Space Cooling	101.9	80.7	21.2	---	---	---
Indoor Fans	141.6	63.6	78	---	---	---
Heat Rejection	---	---	---	---	---	---
Pumps & Misc.	0	3	-3	---	---	---
Domestic Hot Water	---	---	---	---	---	---
Indoor Lighting	39.3	39.3	0	---	---	---
Flexibility	---	---	---	---	---	---
EFFICIENCY TOTAL	284.6	217.8	66.8	401.6	0	401.6
Photovoltaics	-105.7	-105.7	0	---	---	---
Batteries	0	0	0	---	---	---
ENERGY USE SUBTOTAL	178.9	112.1	66.8	401.6	0	401.6
Receptacle	355.1	355.1	0	---	---	---
Process	18	18	0	---	---	---
Other Ltg	1.4	1.4	0	---	---	---
Process Motors	0.6	0.6	0	---	---	---
ENERGY USE TOTAL	554	487.2	66.8	401.6	0	401.6

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 10 of 33)

C8. ENERGY USE INTENSITY (EUI)				
	Standard Design (kBtu/ft² / yr)	Proposed Design (kBtu/ft² / yr)	Margin (kBtu/ft² / yr)	Margin Percentage
GROSS EUI¹	93.05	70.97	22.08	23.73
NET EUI¹	80.4	58.32	22.08	27.46
¹ Notes: Gross EUI is Energy Use Total (not including PV)/Total Building Area. Net EUI is Energy Use Total (including PV)/Total Building Area.				

D1. EXCEPTIONAL CONDITIONS
• The aged solar reflectance and aged thermal emittance must be listed in the Cool Roof Rating Council database of certified products. For projects where initial reflectance is used, the initial reflectance must be listed, and the aged reflectance is calculated by the software program and used in the compliance model. • The project includes windows which have been classified as clerestory windows. Please verify that clerestories are present, and that daylighting controls are present for these areas. Clerestory windows do not trigger mandatory daylighting control requirements, and may allow users to claim PAF credit for daylighting controls in areas illuminated by clerestories. . • The building does not include service water heating. Verify that service water heating is not required and is not included in the design. • PV/Battery Building Type has been modified from software defaults for one or more spaces. Review project's PV/Battery Building Type(s) with documentation author. Refer to Energy Code section 140.10 for Nonresidential or 170.2(g) for more information. • Verify project meets the requirements for Vestibules as per Section 120.7(e).

F1. REQUIRED PV SYSTEMS											
01	02	03	04	05	06	07	08	09	10	11	12
DC System Size (kWdc)	Exception¹	Module Type	Array Type	Power Electronics	CFI	Azimuth (deg)	Tilt Input	Array Angle (deg)	Tilt: (x in 12)	Inverter Eff. (%)	Annual Solar Access (%)
64.83		Standard (14-17%)	Fixed	none	true	150-270	n/a	n/a	<=7:12	96	98
¹ See Table D1 for any PV exceptions used.											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 11 of 33)

F1B. PV BATTERY BUILDING TYPE(S)		
01	02	03
Building Occupancy Type* (From Table 140.10-A/B and 170.2-U/V)	Conditioned Floor Area (ft²)	Unconditioned Floor Area (ft²)
Events and Exhibits	0	0
Library	0	0
Hotel/Motel	0	0
Office, Financial Institutions, Unleased Tenant Space, Medical Office Building/Clinic	13833.8	654.061
Restaurants	0	0
Retail, Grocery	0	0
School	13206.7	811.181
Warehouse	0	0
Religious Worship	0	0
Sports and Recreation	0	0
Multifamily greater than 3 stories	0	0
None	0	0
<i>*Building Occupancy Types are defined in Section 100.1 of the Energy Code</i>		

F2. BATTERY SYSTEMS¹						
01	02	03	04	05	06	07
Control	Capacity (kWh)	Charging Efficiency	Charging Rate (kW)	Discharging Efficiency	Discharging Rate (kW)	Round Trip Efficiency
TOU	119	N/A	29.75	N/A	29.75	0.9
¹ See Table D1 for any Battery exceptions used.						

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 12 of 33)

G1. ENVELOPE GENERAL INFORMATION (conditioned spaces only)			
01	02	03	04
Opaque Surfaces & Orientation	Total Gross Surface Area (ft²)	Total Fenestration Area (ft²)	Window to Wall Ratio (%)
North-Facing ¹	4092.56	1075.16	26.27
East-Facing ²	2902.63	0	0
South-Facing ³	4555.71	2230.32	48.96
West-Facing ⁴	2852.35	722.46	25.33
Total	14403.3	4027.94	27.97
Roof	14006.4	134.44	0.96
Notes ¹ North-Facing is oriented to within 45 degrees of true north, including 4500'00" east of north (NE), but excluding 4500'00" west of north (NW), ² East-Facing is oriented to within 45 degrees of true east, including 4500'00" south of east (SE), but excluding 4500'00" north of east (NE), ³ South-Facing is oriented to within 45 degrees of true south, including 4500'00" west of south (SW), but excluding 4500'00" east of south (SE), ⁴ West-Facing is oriented to within 45 degrees of true west, including 4500'00" north of west (NW), but excluding 4500'00" south of west (SW),			

G2A. ROOFING PRODUCT SUMMARY (NONRESIDENTIAL)					
01	02	03	04	05	06
Assembly Name	Roof Pitch	Roof Rise (x in 12)	Aged Solar Reflectance	Thermal Emittance	SRI
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU028	LowSlope	N/A	0.63	0.75	N/A

G4. NONRESIDENTIAL AIR BARRIER	
01	02
Building Story Name	Air Barrier
Ground Floor	Air barrier - not verified
2nd Floor	Air barrier - not verified

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 13 of 33)

G5. OPAQUE SURFACE ASSEMBLY SUMMARY										
01	02	03	04	05	06		07	08	09	10
Surface Name	Construction Type	Area (ft²)	Framing Type	Cavity R-Value	Continuous R-Value		Units	Value	Description of Assembly Layers	Status¹
					Interior	Exterior				
Base_CZ12-SlabOnOrBelow GradeF073	Underground Floor	14,785.8	N/A	0	N/A	N/A	F-factor	0.73	Slab Type =Unheated slab on grade Insulation Orientation =None Insulation R-Value =none	N
Base_CZ12-NonresMetalFrameWallU055	Exterior Wall	14,916.7	Metal	0	N/A	16.05	U-factor	0.055	Stucco - 7/8 in. Compliance Insulation R14.60 Compliance Insulation R1.41 Compliance Insulation R0.02 Compliance Insulation R0.02 Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 1/2 in.	N
NACM_Interior Wall	Interior Wall	27,659.9	Metal	0	N/A	4.5	U-factor	0.1414	Gypsum Board - 5/8 in. Air - Metal Wall Framing - 16 or 24 in. OC Compliance Insulation R4.50	N
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU028	Roof	14,817.6	N/A	0	N/A	34.93	U-factor	0.028	Metal Standing Seam - 1/16 in. Compliance Insulation R34.93	N
Base_CZ12-NonresOtherFloorU071	Exterior Floor	31.83	N/A	0	N/A	14.6	U-factor	0.0553	Metal Deck - 1/16 in. Compliance Insulation R14.60 Carpet - 3/4 in.	N
NACM_Drop Ceiling	Interior Floor	13,688.1	N/A	0	N/A	N/A	U-factor	0.2924	Acoustic Tile - 3/4 in.	N
¹ Status: N - New, A - Altered, E - Existing										

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 14 of 33)

G7A. FENESTRATION ASSEMBLY SUMMARY (NONRESIDENTIAL)								
01	02	03	04	05	06	07	08	09
Fenestration Assembly Name	Fenestration Type/ Product Type / Frame Type	Certification Method ¹	Assembly Method	Area (ft ²)	Overall U-factor	Overall SHGC	Overall VT	Status ²
Base_AllCZ_FixedWindowU34	Vertical fenestration Fixed window N/A	NFRC	Manufactured	4,141.46	0.34	0.22	0.42	N
Skylight	Skylight Fixed window N/A	NFRC	Manufactured	141.17	0.3	0.25	0.5	N
¹ Notes: Newly installed fenestration shall have a certified NFRC Label Certificate or use the CEC default tables found in Table 110.6-A and Table 110.6-B. Center of Glass (COG) values are for the glass-only, determined by the manufacturer, and are shown for ease of verification. Site-built fenestration values are calculated per Nonresidential Appendix NA6 and are used in the analysis. ² Status: N - New, A - Altered, E - Existing								

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
DOAS-AHU	DOAS VAV Air System	1	310	0	N/A	NA - See Boiler	310	N/A	NA - See Chiller	No Economizer	N
AirSys 8 L1 IT	Single Zone Air Conditioner (SZAC) Air System	1	0	0	N/A	NA	70.03	NSenCOP	2.7	No Economizer	N
AirSys 8 L2 IT	Single Zone Air Conditioner (SZAC) Air System	1	0	0	N/A	NA	70.03	NSenCOP	2.7	No Economizer	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 15 of 33)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
FC-L2_ZN02_Core Classroom	Four Pipe Fan Coil	1	41.22	0	N/A	NA - See Boiler	56.49	N/A	NA - See Chiller	N/A	N
FC-L2_ZN07_Huddle Area	Four Pipe Fan Coil	1	34.18	0	N/A	NA - See Boiler	38.59	N/A	NA - See Chiller	N/A	N
FC-L2_ZN04_Huddle Offices	Four Pipe Fan Coil	1	10.77	0	N/A	NA - See Boiler	10.56	N/A	NA - See Chiller	N/A	N
FC-L2_ZN07 North Conf	Four Pipe Fan Coil	1	24.27	0	N/A	NA - See Boiler	39.08	N/A	NA - See Chiller	N/A	N
FC-L2_ZN01_Core Conf Room	Four Pipe Fan Coil	1	34.34	0	N/A	NA - See Boiler	47.06	N/A	NA - See Chiller	N/A	N
FC-L2_ZN06 Corner Conf	Four Pipe Fan Coil	1	12	0	N/A	NA - See Boiler	20.9	N/A	NA - See Chiller	N/A	N
FC-L1_ZN09 N Conf Room	Four Pipe Fan Coil	1	31.41	0	N/A	NA - See Boiler	51.43	N/A	NA - See Chiller	N/A	N
FC-L2_ZN13 Core Conf Room	Four Pipe Fan Coil	1	34.34	0	N/A	NA - See Boiler	47.06	N/A	NA - See Chiller	N/A	N
FC-L1_ZN08 NE Corridor	Four Pipe Fan Coil	1	74.82	0	N/A	NA - See Boiler	102.55	N/A	NA - See Chiller	N/A	N
FC-L1_ZN12 SE Corridor Corner	Four Pipe Fan Coil	1	16.12	0	N/A	NA - See Boiler	22.09	N/A	NA - See Chiller	N/A	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 16 of 33)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
FC-L1_ZN04_South Corridor	Four Pipe Fan Coil	1	23.23	0	N/A	NA - See Boiler	31.83	N/A	NA - See Chiller	N/A	N
FC-L1_ZN05_Core Corridor	Four Pipe Fan Coil	1	62.86	0	N/A	NA - See Boiler	86.16	N/A	NA - See Chiller	N/A	N
FC-L2_ZN09 NE Corridor	Four Pipe Fan Coil	1	27.74	0	N/A	NA - See Boiler	45.71	N/A	NA - See Chiller	N/A	N
FC-L2_ZN08_Recep Corridor	Four Pipe Fan Coil	1	78.4	0	N/A	NA - See Boiler	107.46	N/A	NA - See Chiller	N/A	N
FC-L1_ZN13 Elec Room	Four Pipe Fan Coil	1	2.34	0	N/A	NA - See Boiler	2.31	N/A	NA - See Chiller	N/A	N
FC-L2_ZN11_Breakroom	Four Pipe Fan Coil	1	14.42	0	N/A	NA - See Boiler	16.48	N/A	NA - See Chiller	N/A	N
FC-L1_ZN13 Lobby NW	Four Pipe Fan Coil	1	11.85	0	N/A	NA - See Boiler	15.07	N/A	NA - See Chiller	N/A	N
FC-L1_ZN03_South Open Office	Four Pipe Fan Coil	1	28.41	0	N/A	NA - See Boiler	32.9	N/A	NA - See Chiller	N/A	N
FC-L1_ZN02 Core_Open Office	Four Pipe Fan Coil	1	60.13	0	N/A	NA - See Boiler	59.19	N/A	NA - See Chiller	N/A	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 17 of 33)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
FC-L2_ZN03_South Open Office	Four Pipe Fan Coil	1	52.61	0	N/A	NA - See Boiler	68.19	N/A	NA - See Chiller	N/A	N
FC-L2_ZN05_Core Open Office Cor	Four Pipe Fan Coil	1	62.9	0	N/A	NA - See Boiler	79.56	N/A	NA - See Chiller	N/A	N
FC-L1_ZN14_Core Open Office	Four Pipe Fan Coil	1	39.88	0	N/A	NA - See Boiler	37.1	N/A	NA - See Chiller	N/A	N
FC-L2_ZN12 Storage	Four Pipe Fan Coil	1	19.71	0	N/A	NA - See Boiler	27.01	N/A	NA - See Chiller	N/A	N
FC-L1_ZN05_Fitness Center	Four Pipe Fan Coil	1	3.51	0	N/A	NA - See Boiler	27.12	N/A	NA - See Chiller	N/A	N
FC-L1_ZN01_SE_Open Office	Four Pipe Fan Coil	1	7.53	0	N/A	NA - See Boiler	19.48	N/A	NA - See Chiller	N/A	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 18 of 33)

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
DOAS-AHU	1	15878.5	17,578.5	0.5	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
AirSys 8 L1 IT	1	15.76	157.55	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
AirSys 8 L2 IT	1	15.76	157.55	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Exhaust_RR1	1	0	350	0.56	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Exhaust_RR2	1	0	400	0.49	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN02_Core Classroom	1	0	1,883	0.35	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN07_Huddle Area	1	0	1,776.5	0.35	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN04_Huddle Offices	1	0	532.27	1.17	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN07 North Conf	1	0	1,185.76	0.7	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN01_Core Conf Room	1	0	1,568.8	0.4	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN06 Corner Conf	1	0	541.72	2.29	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN09 N Conf Room	1	0	2,275.49	0.36	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN13 Core Conf Room	1	0	1,568.8	0.4	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN08 NE Corridor	1	0	3,418.18	0.35	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN12 SE Corridor Corner	1	0	736.42	0.84	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN04_South Corridor	1	0	1,061.12	0.59	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 19 of 33)

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
FC-L1_ZN05_Core Corridor	1	0	2,871.98	0.35	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN09_NE Corridor	1	0	1,350.42	0.92	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN08_Recep Corridor	1	0	3,581.92	0.35	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN13 Elec Room	1	0	98.13	8.44	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN11_Breakroom	1	0	715.84	1.16	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN13 Lobby NW	1	0	553.07	1.5	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN03_South Open Office	1	0	1,178.67	0.7	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN02_Core_Open Office	1	0	3,042.83	0.35	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN03_South Open Office	1	0	2,096.57	0.4	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN05_Core Open Office Cor	1	0	3,072.44	0.35	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN14_Core Open Office	1	0	1,929.27	0.35	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L2_ZN12 Storage	1	0	900.36	0.69	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN05_Fitness Center	1	0	1,412.22	0.44	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
FC-L1_ZN01_SE_Open Office	1	0	893.81	0.7	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 20 of 33)

01	14	15	16	17	18	19
Name or Item Tag	Supply Fan			Return / Relief Fan		
	Modeling Method	Fan Efficiency	Motor Efficiency	Modeling Method	Fan Efficiency	Motor Efficiency
DOAS-AHU	Power Per Unit Flow	0.65	0.92	N/A	N/A	N/A
AirSys 8 L1 IT	Power Per Unit Flow	0.65	0.86	N/A	N/A	N/A
AirSys 8 L2 IT	Power Per Unit Flow	0.65	0.86	N/A	N/A	N/A
Exhaust_RR1	Power Per Unit Flow	0.65	0.9	N/A	N/A	N/A
Exhaust_RR2	Power Per Unit Flow	0.65	0.9	N/A	N/A	N/A
FC-L2_ZN02_Core Classroom	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN07_Huddle Area	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN04_Huddle Offices	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN07 North Conf	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN01_Core Conf Room	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN06 Corner Conf	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN09 N Conf Room	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN13 Core Conf Room	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN08 NE Corridor	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A

¹ Status: N - New, A - Altered, E - Existing

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 21 of 33)

01	14	15	16	17	18	19
Name or Item Tag	Supply Fan			Return / Relief Fan		
	Modeling Method	Fan Efficiency	Motor Efficiency	Modeling Method	Fan Efficiency	Motor Efficiency
FC-L1_ZN12 SE Corridor Corner	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN04_South Corridor	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN05_Core Corridor	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN09 NE Corridor	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN08_Recep Corridor	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN13 Elec Room	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN11_Breakroom	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN13 Lobby NW	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN03_South Open Office	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN02 Core_Open Office	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN03_South Open Office	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN05_Core Open Office Cor	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN14_Core Open Office	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L2_ZN12 Storage	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A

¹ Status: N - New, A - Altered, E - Existing

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD						NRCC-PRF-E
Nonresidential Performance Compliance Method						(Page 22 of 33)

01	14	15	16	17	18	19
Name or Item Tag	Supply Fan			Return / Relief Fan		
	Modeling Method	Fan Efficiency	Motor Efficiency	Modeling Method	Fan Efficiency	Motor Efficiency
FC-L1_ZN05_Fitness Center	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
FC-L1_ZN01_SE_Open Office	Power Per Unit Flow	0.5	0.86	N/A	N/A	N/A
¹ Status: N - New, A - Altered, E - Existing						

H5. GENERAL EXHAUST FAN SUMMARY							
01	02	03	04	05	06	07	08
System ID	Zone Name	Qty	CFM	Power	Power Units	Continuous Operation?	Status ¹
Exhaust_RR1	L1_ZN07_Restroom	1	350	0.56	WattsPerCFM	Yes	N
Exhaust_RR2	L2_ZN14 Restroom	1	400	0.49	WattsPerCFM	Yes	N
Exhaust Lab 1	L1_ZN03_South Open Office L1_ZN02_Core_Open Office L2_ZN03_South Open Office L2_ZN05_Core Open Office Cor L1_ZN14_Core Open Office L1_ZN01_SE_Open Office	1	10585.1	0.65	WattsPerCFM	Yes	N
¹ Status: N - New, A - Altered, E - Existing							

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 23 of 33)

H6. WET SYSTEM EQUIPMENT (boilers, chillers, cooling towers, etc.)									
01	02	03	04	05	06	07	08	09	10
Name or Item Tag	Equipment Type	Parent Fluid System Name	Qty	Vol (gal)	Rated Capacity	Capacity Unit	Rating	Rating Unit	Status¹
Air Cooled Chiller	Screw	CHW Plant 1	1	N/A	648	kBtu/Hr	15	EER	N
Air to Water HP Heat Only	Air-to-Water Heat Pump	HHW Plant 1	1	N/A	432	kBtu/Hr	2.5	COP	N
¹ Status: N - New, A - Altered, E - Existing									

H7. PUMPS							
01	02	03	04	05	06	07	08
Name or Item Tag	Parent Equipment	Qty	Power	Power Units	GPM	VSD	Status¹
CHW Primary Pump	CHW Plant 1	1	4	BHP	107.96	☒	N
HHW Primary Pump	HHW Plant 1	1	4	BHP	86.37	☒	N
¹ Status: N - New, A - Altered, E - Existing							

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 24 of 33)

H8. SYSTEM SPECIAL FEATURES			
01	02	03	04
System Name	Equipment Type	Interlocks per 140.4(n)¹	Other Special Features and Controls
DOAS-AHU	DOAS VAV Air System	N/A	DDC Controls Single Maximum Reheat Controls Zone(s) With CO2 Sensor Vent. Control Supply Air Temp. Reset on Outside Air Temp. Heat Recovery Optimum Start
AirSys 8 L1 IT	Single Zone Air Conditioner (SZAC) Air System	N/A	DDC Controls
AirSys 8 L2 IT	Single Zone Air Conditioner (SZAC) Air System	N/A	DDC Controls
CHW Plant 1	Chilled Water System	N/A	DDC Controls Fixed Temperature Control
HHW Plant 1	Hot Water System	N/A	DDC Controls Fixed Temperature Control
<i>Notes: This table includes controls related to the performance path only. For projects using the prescriptive path, mandatory and prescriptive controls requirements are documented on the NRCC-MCH-E.</i>			
¹ Yes = interlocks are provided, No = interlocks are not provided, NA means no operable openings.			

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
L2_ZN02_Core Classroom	Education - Classrooms (ages 9-18) Misc - All others	43.41	656	197.56	1255.33	DCV
L2_ZN07_Huddle Area	Education - Classrooms (ages 9-18)	44.41	600	180.7	1184.33	DCV

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 25 of 33)

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
L2_ZN04_Huddle Offices	Education - Classrooms (ages 9-18)	13.31	250	75.29	354.85	N/A
L2_ZN07 North Conf	Education - Classrooms (ages 9-18)	29.64	400	120.47	790.5	DCV
L2_ZN01_Core Conf Room	Education - Classrooms (ages 9-18) Misc - All others	33.78	429.69	129.41	1045.87	DCV
L2_ZN06 Corner Conf	Education - Classrooms (ages 9-18)	13.54	250	75.29	361.15	DCV
L1_ZN09 N Conf Room	Office - Office space	7.58	300	602.33	1516.99	DCV
L2_ZN13 Core Conf Room	Office - Office space Misc - All others	5.23	179.69	54.12	1045.87	DCV
L1_ZN08 NE Corridor	General - Corridors	11.39	341.82	102.94	2278.79	N/A
L1_ZN12 SE Corridor Corner	General - Corridors	2.45	73.64	22.18	490.94	N/A
L1_ZN04_South Corridor	General - Corridors Misc - All others	3.54	106.11	31.96	707.41	N/A
L1_ZN05_Core Corridor	General - Corridors	9.57	287.2	86.49	1914.65	N/A
L2_ZN09 NE Corridor	General - Corridors	4.5	135.04	40.67	900.28	N/A
L2_ZN08_Recep Corridor	Office - Main entry lobbies General - Corridors	15.73	404.89	121.94	2387.95	N/A
L1_ZN13 Elec Room	Misc - Telephone closets	0.33	9.81	2.96	65.42	N/A
L1_ZN06_IT Room	Misc - Computer (not printing)	0.53	15.76	0	105.03	N/A
L2_ZN10_IT Room	Misc - Computer (not printing)	0.53	15.76	0	105.03	N/A
L2_ZN11_Breakroom	General - Break rooms	15.75	236.23	71.14	477.23	DCV

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 26 of 33)

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
L1_ZN13 Lobby NW	Office - Main entry lobbies	12.17	182.51	54.97	368.71	DCV
L1_ZN03_South Open Office	Education - University/college laboratories	19.64	1021.51	685.37	785.78	N/A
L1_ZN02 Core_Open Office	Education - University/college laboratories	50.71	2637.12	1769.35	2028.56	N/A
L2_ZN03_South Open Office	Education - University/college laboratories	34.94	1817.03	1141.47	1397.71	N/A
L2_ZN05_Core Open Office Cor	Education - University/college laboratories	102.41	2662.78	1672.78	2048.3	N/A
L1_ZN14_Core Open Office	Education - University/college laboratories	32.15	1672.03	1121.84	1286.18	N/A
L2_ZN12 Storage	General - Corridors Misc - All others	4.7	90.04	27.12	600.24	N/A
L1_ZN05_Fitness Center	Office - Office space Education - Classrooms (ages 9-18) General - Corridors	25.15	360.73	108.64	941.48	N/A
L1_ZN01_SE_Open Office	Education - University/college laboratories	14.9	774.63	519.73	595.87	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 27 of 33)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
AT-L2_ZN02_Core Classroom	Variable Air Volume No Reheat Box	1	N/A	N/A	656	188.3	0.29	N/A	N/A	N/A	☐
AT-L2_ZN07_Huddle Area	Variable Air Volume No Reheat Box	1	N/A	N/A	600	177.65	0.3	N/A	N/A	N/A	☐
AT-L2_ZN04_Huddle Offices	Variable Air Volume No Reheat Box	1	N/A	N/A	250	250	1	N/A	N/A	N/A	☐
AT-L2_ZN07 North Conf	Variable Air Volume No Reheat Box	1	N/A	N/A	400	118.58	0.3	N/A	N/A	N/A	☐
AT-L2_ZN01_Core Conf Room	Variable Air Volume No Reheat Box	1	N/A	N/A	429.69	156.88	0.37	N/A	N/A	N/A	☐
AT-L2_ZN06 Corner Conf	Variable Air Volume No Reheat Box	1	N/A	N/A	250	54.17	0.22	N/A	N/A	N/A	☐
AT-L1_ZN09 N Conf Room	Variable Air Volume No Reheat Box	1	N/A	N/A	2,000	227.55	0.11	N/A	N/A	N/A	☐
AT-L2_ZN13 Core Conf Room	Variable Air Volume No Reheat Box	1	N/A	N/A	179.69	156.88	0.87	N/A	N/A	N/A	☐
AT-L1_ZN08 NE Corridor	Variable Air Volume No Reheat Box	1	N/A	N/A	341.82	341.82	1	N/A	N/A	N/A	☐
AT-L1_ZN12 SE Corridor Corner	Variable Air Volume No Reheat Box	1	N/A	N/A	73.64	73.64	1	N/A	N/A	N/A	☐
AT-L1_ZN04_South Corridor	Variable Air Volume No Reheat Box	1	N/A	N/A	106.11	106.11	1	N/A	N/A	N/A	☐
AT-L1_ZN05_Core Corridor	Variable Air Volume No Reheat Box	1	N/A	N/A	287.2	287.2	1	N/A	N/A	N/A	☐
AT-L2_ZN09 NE Corridor	Variable Air Volume No Reheat Box	1	N/A	N/A	135.04	135.04	1	N/A	N/A	N/A	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 28 of 33)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
AT-L2_ZN08_Recep Corridor	Variable Air Volume No Reheat Box	1	N/A	N/A	404.89	404.89	1	N/A	N/A	N/A	☐
AT-L1_ZN13 Elec Room	Variable Air Volume No Reheat Box	1	N/A	N/A	9.81	9.81	1	N/A	N/A	N/A	☐
AT-L2_ZN11_Breakroom	Variable Air Volume No Reheat Box	1	N/A	N/A	236.23	71.58	0.3	N/A	N/A	N/A	☐
AT-L1_ZN13 Lobby NW	Variable Air Volume No Reheat Box	1	N/A	N/A	182.51	55.31	0.3	N/A	N/A	N/A	☐
AT-L1_ZN03_South Open Office	Variable Air Volume No Reheat Box	1	N/A	N/A	1,021.51	685.37	0.67	N/A	N/A	N/A	☐
AT-L1_ZN02 Core_Open Office	Variable Air Volume No Reheat Box	1	N/A	N/A	2,637.12	1,769.35	0.67	N/A	N/A	N/A	☐
AT-L2_ZN03_South Open Office	Variable Air Volume No Reheat Box	1	N/A	N/A	1,817.03	1,141.47	0.63	N/A	N/A	N/A	☐
AT-L2_ZN05_Core Open Office Cor	Variable Air Volume No Reheat Box	1	N/A	N/A	2,662.78	1,672.78	0.63	N/A	N/A	N/A	☐
AT-L1_ZN14_Core Open Office	Variable Air Volume No Reheat Box	1	N/A	N/A	1,672.03	1,121.84	0.67	N/A	N/A	N/A	☐
AT-L2_ZN12 Storage	Variable Air Volume No Reheat Box	1	N/A	N/A	90.04	90.04	1	N/A	N/A	N/A	☐
AT-L1_ZN05_Fitness Center	Variable Air Volume No Reheat Box	1	N/A	N/A	360.73	360.73	1	N/A	N/A	N/A	☐
AT-L1_ZN01_SE_Open Office	Variable Air Volume No Reheat Box	1	N/A	N/A	774.63	519.73	0.67	N/A	N/A	N/A	☐
CoreZn TU 8 (uncontrolled)	Uncontrolled	1	N/A	N/A	157.55	N/A	0	N/A	N/A	N/A	☐
CoreZn TU 8 (uncontrolled)-2	Uncontrolled	1	N/A	N/A	157.55	N/A	0	N/A	N/A	N/A	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 29 of 33)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
FC-L2_ZN02_Core Classroom	Four Pipe Fan Coil	1	41.22	56.49	1,883	564.9	0.3	0.35	W/cfm	Cycling	☒
FC-L2_ZN07_Huddle Area	Four Pipe Fan Coil	1	34.18	38.59	1,776.5	532.95	0.3	0.35	W/cfm	Cycling	☒
FC-L2_ZN04_Huddle Offices	Four Pipe Fan Coil	1	10.77	10.56	532.27	159.68	0.3	1.17	W/cfm	Cycling	☒
FC-L2_ZN07 North Conf	Four Pipe Fan Coil	1	24.27	39.08	1,185.76	355.73	0.3	0.7	W/cfm	Cycling	☒
FC-L2_ZN01_Core Conf Room	Four Pipe Fan Coil	1	34.34	47.06	1,568.8	470.64	0.3	0.4	W/cfm	Cycling	☒
FC-L2_ZN06 Corner Conf	Four Pipe Fan Coil	1	12	20.9	541.72	162.52	0.3	2.29	W/cfm	Cycling	☒
FC-L1_ZN09 N Conf Room	Four Pipe Fan Coil	1	31.41	51.43	2,275.49	682.65	0.3	0.36	W/cfm	Cycling	☒
FC-L2_ZN13 Core Conf Room	Four Pipe Fan Coil	1	34.34	47.06	1,568.8	470.64	0.3	0.4	W/cfm	Cycling	☒
FC-L1_ZN08 NE Corridor	Four Pipe Fan Coil	1	74.82	102.55	3,418.18	1,025.45	0.3	0.35	W/cfm	Cycling	☒
FC-L1_ZN12 SE Corridor Corner	Four Pipe Fan Coil	1	16.12	22.09	736.42	220.92	0.3	0.84	W/cfm	Cycling	☒
FC-L1_ZN04_South Corridor	Four Pipe Fan Coil	1	23.23	31.83	1,061.12	318.34	0.3	0.59	W/cfm	Cycling	☒
FC-L1_ZN05_Core Corridor	Four Pipe Fan Coil	1	62.86	86.16	2,871.98	861.59	0.3	0.35	W/cfm	Cycling	☒
FC-L2_ZN09 NE Corridor	Four Pipe Fan Coil	1	27.74	45.71	1,350.42	405.13	0.3	0.92	W/cfm	Cycling	☒
FC-L2_ZN08_Recep Corridor	Four Pipe Fan Coil	1	78.4	107.46	3,581.92	1,074.58	0.3	0.35	W/cfm	Cycling	☒
FC-L1_ZN13 Elec Room	Four Pipe Fan Coil	1	2.34	2.31	98.13	29.44	0.3	8.44	W/cfm	Cycling	☒
FC-L2_ZN11_Breakroom	Four Pipe Fan Coil	1	14.42	16.48	715.84	214.75	0.3	1.16	W/cfm	Cycling	☒
FC-L1_ZN13 Lobby NW	Four Pipe Fan Coil	1	11.85	15.07	553.07	165.92	0.3	1.5	W/cfm	Cycling	☒
FC-L1_ZN03_South Open Office	Four Pipe Fan Coil	1	28.41	32.9	1,178.67	353.6	0.3	0.7	W/cfm	Cycling	☒
FC-L1_ZN02 Core_Open Office	Four Pipe Fan Coil	1	60.13	59.19	3,042.83	912.85	0.3	0.35	W/cfm	Cycling	☒

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 30 of 33)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
FC-L2_ZN03_South Open Office	Four Pipe Fan Coil	1	52.61	68.19	2,096.57	628.97	0.3	0.4	W/cfm	Cycling	☒
FC-L2_ZN05_Core Open Office Cor	Four Pipe Fan Coil	1	62.9	79.56	3,072.44	921.73	0.3	0.35	W/cfm	Cycling	☒
FC-L1_ZN14_Core Open Office	Four Pipe Fan Coil	1	39.88	37.1	1,929.27	578.78	0.3	0.35	W/cfm	Cycling	☒
FC-L2_ZN12 Storage	Four Pipe Fan Coil	1	19.71	27.01	900.36	270.11	0.3	0.69	W/cfm	Cycling	☒
FC-L1_ZN05_Fitness Center	Four Pipe Fan Coil	1	3.51	27.12	1,412.22	423.67	0.3	0.44	W/cfm	Cycling	☒
FC-L1_ZN01_SE_Open Office	Four Pipe Fan Coil	1	7.53	19.48	893.81	268.14	0.3	0.7	W/cfm	Cycling	☒

H13. ENERGY RECOVERY SUMMARY									
01	02	03	04	05	06	07	08	09	10
Equipment Name	Equipment Type	Certification Type	Heating			Cooling			Status ¹
			Sensible	Latent	Total	Sensible	Latent	Total	
DOAS-AHU	DOAS VAV Air System	AHRI	0.6	0	0	0.6	0	0	N
¹ Status: N - New, A - Altered, E - Existing									

J3. LABORATORY/PROCESS EXHAUST					
1	2	3	4	5	6
Space Name	Design Exhaust Flow Rate (cfm)	Minimum Exhaust Flow Rate (cfm)	Total Fume Hood Length (ft)	Exhaust Flow for Fume Hoods with Vertical Sashes (cfm)	Fraction of Fume Hoods with Vertical Sash with automatic control (%)
RCA_Open Office 1 Space	1021.51	685.37	4	1,000	0
RCA_Open Office 2 Space	774.63	519.73	3	750	0

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 31 of 33)

J3. LABORATORY/PROCESS EXHAUST					
1	2	3	4	5	6
Space Name	Design Exhaust Flow Rate (cfm)	Minimum Exhaust Flow Rate (cfm)	Total Fume Hood Length (ft)	Exhaust Flow for Fume Hoods with Vertical Sashes (cfm)	Fraction of Fume Hoods with Vertical Sash with automatic control (%)
RCA_Open Office 3 Space	2637.12	1769.35	10	2,500	0
RCA_Open Office 7 Space	1672.03	1121.84	6	1,500	0
RCA_Open Office 4 Space	1205.13	757.07	4	1,000	0
RCA_Open Office 5 Space	611.9	384.4	2	500	0
RCA_Open Office 6 Space	2662.78	1672.78	10	2,500	0

N. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION	
<i>Selections made by Documentation Author indicate which Certificates of Installation must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online</i>	
Building Component	Form/Title
Envelope	NRCI-ENV-E - Envelope (for all buildings)
Mechanical	NRCI-MCH-E - For all buildings with Mechanical Systems
Solar and Battery	NRCI-SAB-E - Solar Water Heating, PV and Battery Storage Systems

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
<i>Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction. Lighting controls and mechanical NRCAs must be completed through an Acceptance Test Technician Certification Provider (ATTCP).</i>	
Building Component ¹	Form/Title & System Name(s)
Envelope	NRCA-ENV-02-F - NRFC label verification for fenestration
Envelope	NRCA-ENV-03-F - Daylighting Design PAFs
Covered Process	NRCA-PRC-14-F Lab Exhaust Ventilation System
Mechanical	NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap
	DOAS-AHU, AirSys 8 L1 IT and AirSys 8 L2 IT.

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 32 of 33)

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
<i>Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction. Lighting controls and mechanical NRCA's must be completed through an Acceptance Test Technician Certification Provider (ATTCP).</i>	
Building Component ¹	Form/Title & System Name(s)
Mechanical	NRCA-MCH-03-A - Constant Volume Single Zone HVAC
	AirSys 8 L1 IT and AirSys 8 L2 IT.
Mechanical	NRCA-MCH-06-A Demand Control Ventilation Systems must be submitted for all systems required to employ demand controlled ventilation (refer to) can vary outside ventilation flow rates based on maintaining interior carbon dioxide (CO2) concentration setpoints.
	DOAS-AHU
Mechanical	NRCA-MCH-07-A Supply Fan Variable Flow Controls
	DOAS-AHU
Mechanical	NRCA-MCH-08-A Valve Leakage Test
	CHW Plant 1 and HHW Plant 1.
Mechanical	NRCA-MCH-10-A Hydronic System Variable Flow Controls
	CHW Plant 1 and HHW Plant 1.
Mechanical	NRCA-MCH-11-A Automatic Demand Shed Controls
	DOAS-AHU, AirSys 8 L1 IT, AirSys 8 L2 IT and Exhaust Lab 1., CHW Plant 1 and HHW Plant 1.
Mechanical	NRCA-MCH-16-A Supply Air Temperature Reset Controls
	DOAS-AHU
Mechanical	NRCA-MCH-19-A Occupancy Sensor Controls
	DOAS-AHU
¹ Refer to other prescriptive NRCC forms applicable to the project for additional NRCA tests required that are not included in the NRCC-PRF-E form	

P. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION	
<i>Selections made by Documentation Author indicate which Certificates of Verification must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online</i>	
Building Component	Form/Title
Mechanical	NRCV-MCH-27 Indoor Air Quality & Mechanical Ventilation
Mechanical	NRCV-MCH-32 Local Mechanical Exhaust

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 33 of 33)

Documentation Author's Declaration Statement

1. I certify that this Certificate of Compliance documentation is accurate and complete.	
Documentation Author Name:	Documentation Author Signature:
Company:	Signature Date:
Address:	CEA/AEA/ECC Certification Identification (if applicable):
City/State/Zip: ,	Phone:

Responsible Person's Declaration statement

I certify the following under penalty of perjury, under the laws of the State of California:		
- The information provided on this Certificate of Compliance is true and correct. - I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer). - The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations. - The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application. - I understand that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building and shall be made available to the enforcement agency for all applicable inspections. I will take the necessary steps to fulfill this requirement. - I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy. I will take the necessary steps to fulfill this requirement.		
Responsible Designer Name:	Responsible Designer Signature:	
Company:		
Address:	Date Signed:	
City/State/Zip: ,	License #:	
Phone:	Title:	Scope: