

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD		NRCC-PRF-E
Nonresidential Performance Compliance Method		(Page 1 of 23)
Project Name:	Med Office PVAV PFPB	Date Prepared: 2026-09-23

A. General Information				
1	Project Name	Med Office PVAV PFPB		
2	Run Title			
3	Project Location	- specify -		
4	City	- specify -	5	Standards Version
		Compliance 2025		
6	Zip code	90045	7	Compliance Software (version)
		CBECC-CLI 2025.3.0 RC (1415)		
8	Climate Zone	9	9	Building Orientation (deg)
		0		
10	Building Type(s)	• Nonresidential	11	Weather File
		CA_Title24_2025_LOS-ANGELES-USC.epw		
12	Project Scope	• New complete scope	13	Number of Dwelling Units
		0		
14	Total Conditioned Floor Area in Scope (ft²)	53627.8	15	Total # of hotel/motel rooms
		0		
16	Total Unconditioned Floor Area (ft²)	0	17	Fuel Type
		Natural gas		
18	Is Natural Gas Available per Section 100.1?	Yes	19	Nonresidential Conditioned Floor Area
		53627.8		
20	Total # of Stories (Habitable Above Grade)	3	21	Residential Conditioned Floor Area
		0		

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 2 of 23)

B1. PROJECT SUMMARY - Performance		
Table B1 shows which building components are included in the performance calculation. If indicated as not included, the project must show compliance prescriptively if within the permit application.		
Building Components Complying via Performance		
Envelope (See Table G)	Nonresidential	Included
	Multifamily	Not Included
Mechanical (See Table H)	Nonresidential	Included
	Multifamily	Not Included
Domestic Hot Water (See Table I)	Nonresidential	Included
	Multifamily	Not Included
Lighting (Indoor Conditioned, see Table K)	Nonresidential	Included
	Multifamily	Not Included
Solar Thermal Water Heating (See Table I3)		Not Included
Covered Process: Commercial Kitchens (see Table J)		Not Included
Covered Process: Laboratory Exhaust (see Table J)		Not Included
Photovoltaics (see Table F)		Included
Battery (see Table F)		Included

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 3 of 23)

B2. PROJECT SUMMARY - Prescriptive/Mandatory	
Building Components Not Supported via Performance Approach - Must Use the Following Certificate of Compliance Forms	
<i>The following building components are supported via the applicable Certificate of Compliance forms listed below when within the scope of the permit application.</i>	
Indoor Lighting - Unconditioned Spaces 140.6 & 141.0(b)2I & 170.2(e) & 180.2(b)4B	NRCC-LTI-01-E if any enclosed unconditioned spaces have new/alterd lighting
Indoor Lighting - Multifamily Dwelling Unit, Hotel/Motel Guest Room 160.5(a) & 130.0(b)	NRCC-LTI-01-E if dwelling units or guest rooms have new/alterd indoor lighting
Outdoor Lighting 140.7 & 141.0(b)2L & 170.2(e) & 180.2(b)4B	NRCC-LTO-01-E if any new/alterd outdoor lighting
Outdoor Lighting - Multifamily Dwelling Unit, Hotel/Motel Guest Room 160.5(a) & 130.0(b)	NRCC-LTO-01-E if dwelling units or guest rooms have new/alterd outdoor lighting
Illuminated Sign Lighting 140.8 & 141.0(b)2M & 170.2(e) & 180.2(b)4	NRCC-LTS-01-E if any new/alterd illuminated signs located indoors or outdoors
Electrical Power Distribution 130.5 & 141.0(b)2P & 170.2(e) & 180.2(b)4	NRCC-ELC-01-E if any new/alterd electrical power distribution components
Electrical Readiness for New Multifamily Buildings 160.9	NRCC-ELC-01-E if gas is used in dwelling unit heating, cooktop, clothes dryer or water heating systems
Design Review and Commissioning 120.8	NRCC-CXR-01-E if new building with conditioned nonresidential occupancy
Solar Readiness 110.10	NRCC-SAB-01-E if new conditioned building and no photovoltaic (PV) system is installed per the Energy Code
Covered Processes 120.6 & 140.9 & 141.1 & 160.7	NRCC-PRC-01-E if new/alterd Refrigerated Warehouse, Commercial Refrigeration, Enclosed Parking Garage, Process Boiler, Compressed Air, Elevator, Escalator, Moving Walkway, Controlled Environment Horticulture, Steam Trap, Computer/Data Room, Commercial Kitchen, Laboratory or Factory Exhaust

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 4 of 23)

C1. COMPLIANCE SUMMARY			
COMPLIES*			
	Long-term System Cost (LSC) ¹		Source Energy Use
	Efficiency ² (\$/ft ² -yr)	Total ³ (\$/ft ² -yr)	Total ³ (kBtu/ft ² -yr)
Standard Design	18	-1.64	0.46
Proposed Design	17.86	-1.81	0.39
Compliance Margins	0.14	0.17	0.07
	Pass	Pass	Pass
¹ Long-term System Cost (LSC) is a 30-year present value cost to California's energy system. LSC is not a predicted utility bill. ² Efficiency measures include energy efficiency improvements such as better building envelope and more efficient mechanical equipment ³ Compliance Totals include efficiency, photovoltaics and batteries * New Construction: Building complies when Proposed Design is equal to or less than Standard Design in all compliance categories and unmet load hour limits are not exceeded. Complete Addition Scope and Existing, Addition and Alteration Scope: Building complies when efficiency compliance margin is greater than or equal to zero and unmet load hour limits are not exceeded.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 5 of 23)

C2. LSC ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual LSC Energy Use, \$/ft²-yr)			
COMPLIES			
Energy Component	Standard Design (LSC)	Proposed Design (LSC)	Compliance Margin (LSC)¹
Space Heating	0.97	0.66	0.31
Space Cooling	7.74	7.81	-0.07
Indoor Fans	2.8	2.89	-0.09
Heat Rejection	0	0	0
Pumps & Misc.	0	0.02	-0.02
Domestic Hot Water	1.23	1.22	0.01
Indoor Lighting	5.26	5.26	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	18	17.86	0.14 (0.8%)
Photovoltaics	-19.2	-19.29	0.09
Batteries	-0.44	-0.38	-0.06
TOTAL COMPLIANCE	-1.64	-1.81	0.17 (0%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 6 of 23)

C3. LSC ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (LSC)	Proposed Design (LSC)	Compliance Margin (LSC)²
Receptacle	20.14	20.14	---
Process	3.36	3.36	---
Other Ltg	---	---	---
Process Motors	---	---	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	21.86	21.69	0.17 (0.8%)
¹ Notes: This table is not used for Energy Code Compliance.			
² Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

Not useable for compliance

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 7 of 23)

C4. SOURCE ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual SOURCE Energy Use, kBtu/ft ² /yr)			
COMPLIES			
Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE) ¹
Space Heating	0.48	0.33	0.15
Space Cooling	1.03	1.04	-0.01
Indoor Fans	0.52	0.54	-0.02
Heat Rejection	0	0	0
Pumps & Misc.	0	0.01	-0.01
Domestic Hot Water	0.28	0.28	0
Indoor Lighting	1.26	1.26	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	3.57	3.46	0.11 (3.1%)
Photovoltaics	-2.69	-2.69	---
Batteries	-0.42	-0.38	-0.04
TOTAL COMPLIANCE	0.46	0.39	0.07 (15.2%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 8 of 23)

C5. SOURCE ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE)²
Receptacle	4.21	4.21	---
Process	0.81	0.81	---
Other Ltg	---	---	---
Process Motors	---	---	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	5.48	5.41	0.07 (1.3%)
¹ Notes: This table is not used for Energy Code Compliance.			
² Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

C6. 'ABOVE CODE' QUALIFICATIONS	
☐ This project is pursuing CalGreen Tier 1	☐ This project is pursuing CalGreen Tier 2

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 9 of 23)

C7. ENERGY USE SUMMARY						
Energy Component	Standard Design Site (MWh)	Proposed Design Site (MWh)	Margin (MWh)	Standard Design Site (MBtu)	Proposed Design Site (MBtu)	Margin (MBtu)
Space Heating	7.5	5	2.5	---	0.7	---
Space Cooling	91.5	92.5	-1	---	---	---
Indoor Fans	32.4	33.3	-0.9	---	---	---
Heat Rejection	---	---	---	---	---	---
Pumps & Misc.	0	0.1	-0.1	---	---	---
Domestic Hot Water	13.5	13.5	0	---	---	---
Indoor Lighting	57.1	57.1	0	---	---	---
Flexibility	---	---	---	---	---	---
EFFICIENCY TOTAL	202	201.5	0.5	0	0.7	-0.7
Photovoltaics	-273.6	-273.6	0	---	---	---
Batteries	2	2	0	---	---	---
ENERGY USE SUBTOTAL	-69.6	-70.1	0.5	0	0.7	-0.7
Receptacle	229.7	229.7	0	---	---	---
Process	36.3	36.3	0	---	---	---
Other Ltg	---	---	---	---	---	---
Process Motors	---	---	---	---	---	---
ENERGY USE TOTAL	196.4	195.9	0.5	0	0.7	-0.7

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 10 of 23)

C8. ENERGY USE INTENSITY (EUI)				
	Standard Design (kBtu/ft² / yr)	Proposed Design (kBtu/ft² / yr)	Margin (kBtu/ft² / yr)	Margin Percentage
GROSS EUI¹	29.9	29.88	0.02	0.07
NET EUI¹	12.5	12.48	0.02	0.16
¹ Notes: Gross EUI is Energy Use Total (not including PV)/Total Building Area. Net EUI is Energy Use Total (including PV)/Total Building Area.				

D1. EXCEPTIONAL CONDITIONS
• The aged solar reflectance and aged thermal emittance must be listed in the Cool Roof Rating Council database of certified products. For projects where initial reflectance is used, the initial reflectance must be listed, and the aged reflectance is calculated by the software program and used in the compliance model. • Verify project meets the requirements for Vestibules as per Section 120.7(e). • Verify that the project uses the JA18 Guideline 36 Library Version requirements as per Section 140.4(r). If applicable, a separate NRCC-MCH-E form must be completed. Refer to [https://www.energy.ca.gov/media/11605] to verify approved libraries by CEC.

F1. REQUIRED PV SYSTEMS											
01	02	03	04	05	06	07	08	09	10	11	12
DC System Size (kWdc)	Exception¹	Module Type	Array Type	Power Electronics	CFI	Azimuth (deg)	Tilt Input	Array Angle (deg)	Tilt: (x in 12)	Inverter Eff. (%)	Annual Solar Access (%)
167.86		Standard (14-17%)	Fixed	none	true	150-270	n/a	n/a	<=7:12	96	98
¹ See Table D1 for any PV exceptions used.											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 11 of 23)

F1B. PV BATTERY BUILDING TYPE(S)		
01	02	03
Building Occupancy Type* (From Table 140.10-A/B and 170.2-U/V)	Conditioned Floor Area (ft²)	Unconditioned Floor Area (ft²)
Events and Exhibits	0	0
Library	0	0
Hotel/Motel	0	0
Office, Financial Institutions, Unleased Tenant Space, Medical Office Building/Clinic	53627.8	0
Restaurants	0	0
Retail, Grocery	0	0
School	0	0
Warehouse	0	0
Religious Worship	0	0
Sports and Recreation	0	0
Multifamily greater than 3 stories	0	0
None	0	0
<i>*Building Occupancy Types are defined in Section 100.1 of the Energy Code</i>		

F2. BATTERY SYSTEMS¹						
01	02	03	04	05	06	07
Control	Capacity (kWh)	Charging Efficiency	Charging Rate (kW)	Discharging Efficiency	Discharging Rate (kW)	Round Trip Efficiency
Basic	296.84	N/A	70.5	N/A	70.5	0.9
¹ See Table D1 for any Battery exceptions used.						

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 12 of 23)

G1. ENVELOPE GENERAL INFORMATION (conditioned spaces only)			
01	02	03	04
Opaque Surfaces & Orientation	Total Gross Surface Area (ft²)	Total Fenestration Area (ft²)	Window to Wall Ratio (%)
North-Facing ¹	6386.25	2108.1	33.01
East-Facing ²	4257.47	1405.16	33
South-Facing ³	6386.25	2108.1	33.01
West-Facing ⁴	4257.47	1405.16	33
Total	21287.5	7026.53	33.01
Roof	0	0	0
Notes ¹ North-Facing is oriented to within 45 degrees of true north, including 4500'00" east of north (NE), but excluding 4500'00" west of north (NW), ² East-Facing is oriented to within 45 degrees of true east, including 4500'00" south of east (SE), but excluding 4500'00" north of east (NE), ³ South-Facing is oriented to within 45 degrees of true south, including 4500'00" west of south (SW), but excluding 4500'00" east of south (SE), ⁴ West-Facing is oriented to within 45 degrees of true west, including 4500'00" north of west (NW), but excluding 4500'00" south of west (SW),			

G2A. ROOFING PRODUCT SUMMARY (NONRESIDENTIAL)					
01	02	03	04	05	06
Assembly Name	Roof Pitch	Roof Rise (x in 12)	Aged Solar Reflectance	Thermal Emittance	SRI
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU034	LowSlope	N/A	0.63	0.75	N/A

G4. NONRESIDENTIAL AIR BARRIER	
01	02
Building Story Name	Air Barrier
BottomFlr	Air barrier - not verified
MidFlr	Air barrier - not verified
TopFloor	Air barrier - not verified

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 13 of 23)

G5. OPAQUE SURFACE ASSEMBLY SUMMARY										
01	02	03	04	05	06		07	08	09	10
Surface Name	Construction Type	Area (ft²)	Framing Type	Cavity R-Value	Continuous R-Value		Units	Value	Description of Assembly Layers	Status ¹
					Interior	Exterior				
Base_CZ12-SlabOnOrBelow GradeF073	Underground Floor	17,875.9	N/A	0	N/A	N/A	F-factor	0.73	Slab Type =Unheated slab on grade Insulation Orientation =None Insulation R-Value =none	N
Base_CZ12-NonresMetalFrameWallU055	Exterior Wall	21,287.5	Metal	0	N/A	16.05	U-factor	0.055	Stucco - 7/8 in. Compliance Insulation R14.60 Compliance Insulation R1.41 Compliance Insulation R0.02 Compliance Insulation R0.02 Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 1/2 in.	N
NACM_Interior Wall	Interior Wall	13,788.2	Metal	0	N/A	N/A	U-factor	0.3195	Gypsum Board - 5/8 in. Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 5/8 in.	N
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU034	Roof	17,875.9	N/A	0	N/A	28.63	U-factor	0.034	Metal Standing Seam - 1/16 in. Compliance Insulation R28.63	N
NACM_Drop Ceiling	Interior Floor	53,627.8	N/A	0	N/A	N/A	U-factor	0.2924	Acoustic Tile - 3/4 in.	N
NACM_Interior Floor	Interior Floor	35,751.9	N/A	0	N/A	N/A	U-factor	0.2375	Metal Deck - 1/16 in. Concrete - 140 lb/ft3 - 4 in. Carpet - 3/4 in.	N
¹ Status: N - New, A - Altered, E - Existing										

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 14 of 23)

G7A. FENESTRATION ASSEMBLY SUMMARY (NONRESIDENTIAL)								
01	02	03	04	05	06	07	08	09
Fenestration Assembly Name	Fenestration Type/ Product Type / Frame Type	Certification Method ¹	Assembly Method	Area (ft ²)	Overall U-factor	Overall SHGC	Overall VT	Status ²
Base_AllCZ_FixedWindowU34	Vertical fenestration Fixed window N/A	NFRC	Manufactured	7,026.53	0.34	0.22	0.42	N
¹ Notes: Newly installed fenestration shall have a certified NFRC Label Certificate or use the CEC default tables found in Table 110.6-A and Table 110.6-B. Center of Glass (COG) values are for the glass-only, determined by the manufacturer, and are shown for ease of verification. Site-built fenestration values are calculated per Nonresidential Appendix NA6 and are used in the analysis. ² Status: N - New, A - Altered, E - Existing								

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
BottomVAV	Package VAV Air System	1	279.82	0	N/A	NA - See Boiler	447.11	EER	9.8	Fixed DB	N
Mid VAV	Package VAV Air System	1	290.49	0	N/A	NA - See Boiler	469.24	EER	9.8	Fixed DB	N
Top VAV	Package VAV Air System	1	300.83	0	N/A	NA - See Boiler	487.7	EER	9.8	Fixed DB	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 15 of 23)

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
BottomVAV	1	2681.39	11,478.1	4.84	InH2O	VSD	N/A	N/A	N/A	N/A	N/A	N
Mid VAV	1	2681.39	12,116.1	4.84	InH2O	VSD	N/A	N/A	N/A	N/A	N/A	N
Top VAV	1	2681.39	12,788.4	4.87	InH2O	VSD	N/A	N/A	N/A	N/A	N/A	N

01	14	15	16	17	18	19
Name or Item Tag	Supply Fan			Return / Relief Fan		
	Modeling Method	Fan Efficiency	Motor Efficiency	Modeling Method	Fan Efficiency	Motor Efficiency
BottomVAV	Static Pressure	0.65	0.92	N/A	N/A	N/A
Mid VAV	Static Pressure	0.65	0.92	N/A	N/A	N/A
Top VAV	Static Pressure	0.65	0.93	N/A	N/A	N/A

¹ Status: N - New, A - Altered, E - Existing

H6. WET SYSTEM EQUIPMENT (boilers, chillers, cooling towers, etc.)									
01	02	03	04	05	06	07	08	09	10
Name or Item Tag	Equipment Type	Parent Fluid System Name	Qty	Vol (gal)	Rated Capacity	Capacity Unit	Rating	Rating Unit	Status ¹
backup boiler	Hot Water	HotWater Loop	1	N/A	536	kBtu/Hr	0.84	TE	N
AWHP Central	Air-to-Water Heat Pump	HotWater Loop	1	N/A	536	kBtu/Hr	2.92	COP	N

¹ Status: N - New, A - Altered, E - Existing

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 16 of 23)

H7. PUMPS							
01	02	03	04	05	06	07	08
Name or Item Tag	Parent Equipment	Qty	Power	Power Units	GPM	VSD	Status ¹
AWHP Pump	AWHP Central	1	7.5	BHP	226	☒	N
¹ Status: N - New, A - Altered, E - Existing							

H8. SYSTEM SPECIAL FEATURES			
01	02	03	04
System Name	Equipment Type	Interlocks per 140.4(n) ¹	Other Special Features and Controls
BottomVAV	Package VAV Air System	N/A	Dual Maximum Reheat Controls Warmest Zone Supply Air Temp. Reset Optimum Start DDC Controls (ASHRAE Guideline 36) Fixed DB
Mid VAV	Package VAV Air System	N/A	Dual Maximum Reheat Controls Warmest Zone Supply Air Temp. Reset Optimum Start DDC Controls (ASHRAE Guideline 36) Fixed DB
Top VAV	Package VAV Air System	N/A	Dual Maximum Reheat Controls Warmest Zone Supply Air Temp. Reset Optimum Start DDC Controls (ASHRAE Guideline 36) Fixed DB
SHWFluidSysElec	Service Hot Water	N/A	Fixed Temperature Control
HotWater Loop	Hot Water System	N/A	DDC Controls Fixed Temperature Control
Notes: This table includes controls related to the performance path only. For projects using the prescriptive path, mandatory and prescriptive controls requirements are documented on the NRCC-MCH-E.			
¹ Yes = interlocks are provided, No = interlocks are not provided, NA means no operable openings.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 17 of 23)

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
Core_bottom Thermal Zone	Office - Office space	52.93	1588.01	0	10586.7	N/A
Perimeter_bot_ZN_1 Thermal Zone	Office - Office space	11.16	334.76	0	2231.76	N/A
Perimeter_bot_ZN_2 Thermal Zone	Office - Office space	7.06	211.94	0	1412.9	N/A
Perimeter_bot_ZN_3 Thermal Zone	Office - Office space	11.16	334.76	0	2231.76	N/A
Perimeter_bot_ZN_4 Thermal Zone	Office - Office space	7.06	211.92	0	1412.8	N/A
Core_mid Thermal Zone	Office - Office space	52.93	1588.01	0	10586.7	N/A
Perimeter_mid_ZN_1 Thermal Zone	Office - Office space	11.16	334.76	0	2231.76	N/A
Perimeter_mid_ZN_2 Thermal Zone	Office - Office space	7.06	211.94	0	1412.9	N/A
Perimeter_mid_ZN_3 Thermal Zone	Office - Office space	11.16	334.76	0	2231.76	N/A
Perimeter_mid_ZN_4 Thermal Zone	Office - Office space	7.06	211.92	0	1412.8	N/A
Core_top Thermal Zone	Office - Office space	52.93	1588.01	0	10586.7	N/A
Perimeter_top_ZN_1 Thermal Zone	Office - Office space	11.16	334.76	0	2231.76	N/A
Perimeter_top_ZN_2 Thermal Zone	Office - Office space	7.06	211.94	0	1412.9	N/A
Perimeter_top_ZN_3 Thermal Zone	Office - Office space	11.16	334.76	0	2231.76	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 18 of 23)

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
Perimeter_top_ZN_4 Thermal Zone	Office - Office space	7.06	211.92	0	1412.8	N/A

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
CoreBottomZn TU	Variable Air Volume Reheat Box	1	128.43	N/A	7,510.68	1,588.01	0.21	N/A	N/A	N/A	☐
PerimeterBottomZn1 TU	Variable Air Volume Reheat Box	1	34.63	N/A	2,025.42	334.76	0.17	N/A	N/A	N/A	☐
PerimeterBottomZn2 TU	Variable Air Volume Reheat Box	1	20.87	N/A	1,220.57	211.94	0.17	N/A	N/A	N/A	☐
PerimeterBottomZn3 TU	Parallel Fan Box	1	11.45	N/A	1,391.17	334.76	0.24	0.3	W/cfm	N/A	☐
PerimeterBottomZn4 TU	Variable Air Volume Reheat Box	1	21.63	N/A	1,264.81	211.92	0.17	N/A	N/A	N/A	☐
CoreMidZn TU	Variable Air Volume Reheat Box	1	134.91	N/A	7,889.54	1,588.01	0.2	N/A	N/A	N/A	☐
PerimeterMidZn1 TU	Parallel Fan Box	1	11.45	N/A	2,440.55	334.76	0.14	0.3	W/cfm	N/A	☐
PerimeterMidZn2 TU	Variable Air Volume Reheat Box	1	25.02	N/A	1,463.21	211.94	0.14	N/A	N/A	N/A	☐
PerimeterMidZn3 TU	Variable Air Volume Reheat Box	1	26.21	N/A	1,532.72	334.76	0.22	N/A	N/A	N/A	☐
PerimeterMidZn4 TU	Variable Air Volume Reheat Box	1	26.6	N/A	1,555.38	211.92	0.14	N/A	N/A	N/A	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 19 of 23)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
Core Top Zn TU	Variable Air Volume Reheat Box	1	139.29	N/A	8,145.46	1,588.01	0.19	N/A	N/A	N/A	☐
PerimeterTopZn1 TU	Parallel Fan Box	1	11.45	N/A	2,499.79	334.76	0.13	0.3	W/cfm	N/A	☐
PerimeterTopZn2 TU	Variable Air Volume Reheat Box	1	24.91	N/A	1,456.83	211.94	0.15	N/A	N/A	N/A	☐
PerimeterTopZn3 TU	Variable Air Volume Reheat Box	1	27.19	N/A	1,590.3	334.76	0.21	N/A	N/A	N/A	☐
PerimeterTopZn4 TU	Variable Air Volume Reheat Box	1	28.01	N/A	1,637.78	211.92	0.13	N/A	N/A	N/A	☐

I1. WATER HEATER EQUIPMENT SUMMARY													
01	02	03	04	05	06	07	08	09	10	11	12	13	14
Name	Heater Element Type	Tank Type	Qty	Tank Vol (gal)	Rated Input	Rated Input Unit	Efficiency	Efficiency Unit	Tank Insulation R-value Int/Ext	Standby Loss Fraction	1st Hr. Rating or Flow Rate (gal)	Heat Pump Type	Tank Location or Ambient Condition
WaterHeaterElec	Electricity	Storage	1	30	8.74	kW	0.94	UEF	N/A	N/A	60	N/A	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 20 of 23)

K1. INDOOR CONDITIONED LIGHTING GENERAL INFO					
01	02	03	04	05	06
Occupancy Type¹	Conditioned Floor Area² (ft²)	Installed Lighting Power (Watts)	Lighting Control Credits (Watts)	Additional (Custom) Allowance	
				Area Category Footnotes (Watts)	Area Category Footnotes (Watts)
Office (250 square feet)	53627.8	32176.7	0	0	0
Building Totals:	53627.8	32176.7	0	0	0
¹ See Table 140.6-C ² See NRCC-LTI--E for unconditioned spaces ³ Lighting information for existing spaces modeled is not included in this table					

K4. INDOOR CONDITIONED LIGHTING MANDATORY LIGHTING CONTROL
See NRCC-LTI-E for mandatory controls

N. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION	
<i>Selections made by Documentation Author indicate which Certificates of Installation must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online</i>	
Building Component	Form/Title
Envelope	NRCI-ENV-E - Envelope (for all buildings)
Mechanical	NRCI-MCH-E - For all buildings with Mechanical Systems
Plumbing	NRCI-PLB-E - For all buildings with Plumbing Systems
Solar and Battery	NRCI-SAB-E - Solar Water Heating, PV and Battery Storage Systems
Indoor Lighting	NRCI-LTI-E - Indoor Lighting (for all buildings)

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 21 of 23)

O. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
<i>Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction. Lighting controls and mechanical NRCAs must be completed through an Acceptance Test Technician Certification Provider (ATTCP).</i>	
Building Component ¹	Form/Title & System Name(s)
Envelope	NRCA-ENV-02-F - NRFC label verification for fenestration
Indoor Lighting	NRCA-LTI-02-A - Occupancy Sensors and Automatic Time Switch Controls.
Indoor Lighting	NRCA-LTI-03-A - Automatic Daylight Controls.
Indoor Lighting	NRCA-LTI-04-A - Demand Responsive Lighting Controls.
Covered Process	NRCA-PRC-12-F Elevator Lighting & Ventilation Controls
Covered Process	NRCA-PRC-13-F Escalators & Moving Walkways Speed Controls
Mechanical	NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap BottomVAV, Mid VAV and Top VAV.
Mechanical	NRCA-MCH-05-A - Air Economizer Controls BottomVAV, Mid VAV and Top VAV.
Mechanical	NRCA-MCH-07-A Supply Fan Variable Flow Controls BottomVAV, Mid VAV and Top VAV.
Mechanical	NRCA-MCH-08-A Valve Leakage Test HotWater Loop
Mechanical	NRCA-MCH-10-A Hydronic System Variable Flow Controls HotWater Loop
Mechanical	NRCA-MCH-11-A Automatic Demand Shed Controls BottomVAV, Mid VAV and Top VAV., HotWater Loop
Mechanical	NRCA-MCH-12-A FDD for Packaged Direct Expansion Units BottomVAV, Mid VAV and Top VAV.
Mechanical	NRCA-MCH-16-A Supply Air Temperature Reset Controls BottomVAV, Mid VAV and Top VAV.
¹ Refer to other prescriptive NRCC forms applicable to the project for additional NRCA tests required that are not included in the NRCC-PRF-E form	

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 22 of 23)

P. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION	
<i>Selections made by Documentation Author indicate which Certificates of Verification must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online</i>	
Building Component	Form/Title
Mechanical	NRCV-MCH-27 Indoor Air Quality & Mechanical Ventilation

Not useable for compliance

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 23 of 23)

Documentation Author's Declaration Statement

1. I certify that this Certificate of Compliance documentation is accurate and complete.	
Documentation Author Name:	Documentation Author Signature:
Company:	Signature Date:
Address:	CEA/AEA/ECC Certification Identification (if applicable):
City/State/Zip: ,	Phone:

Responsible Person's Declaration statement

I certify the following under penalty of perjury, under the laws of the State of California:		
- The information provided on this Certificate of Compliance is true and correct. - I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer). - The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations. - The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application. - I understand that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building and shall be made available to the enforcement agency for all applicable inspections. I will take the necessary steps to fulfill this requirement. - I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy. I will take the necessary steps to fulfill this requirement.		
Responsible Designer Name:	Responsible Designer Signature:	
Company:		
Address:	Date Signed:	
City/State/Zip: ,	License #:	
Phone:	Title:	Scope: