MNSW2524, 4024 or 4048-CL250-REVF-1/9/17 Schneider **System Control** Panel (SCP) MNEAC50-2P MNEAC30-2P Bypass Breaker **AC input & output Breakers** Schneider Conext Load Positive SW2524, 4024 or 4048 MNEDC250 Battery breaker 8 Terminator **DC** Negative Plug BTS #10 #10 Classic250 #6 Neutral L2 Output Neutral L1 Output Miching L2 Input Neutral L1 Input #10= BTS Jack Aux2+ В В PV PV #6 Ground Ground SPD 300DC SPD 300AC SPD 300AC All AC wiring #8 unless otherwise Marked **(6)** +(a) (6) BTS Page 1 of 1