
You can see that the maximal short circuit current at the fault position is smaller than in the uncoupled case !!!!
HINT: For asymmetric cases always use the coupled lines,impedance models

Comparison of coupled and uncoupled line impedance

Uncoupled





```
.options vntol=1m abstol=1u
.options plotwinsize=0 numdgt=10; Für FFT

.param last=20e-6
.param last=20e6


.param tdv=1 tdt=1 fn1=50
.param omega_n={2*pi*fn1}
.param ce=5012n ce1=10n p=1.09

.tran 0 1.5 0 0.1m
```

Coupled



Inductivity of impedance computed in Petersen_fault_coupled_uncoupled.wxmx