



Warehouse OSHA Compliance Scorecard

Self-Assessment Tool | 29 CFR 1910 General Industry Standards
ACES Compliance Systems | acescompliancesystems@gmail.com

How to Use This Scorecard

Walk your facility with this checklist. For each item, check YES (in place), NO (not in place), or N/S (not sure).

Every NO is a potential OSHA citation. The right-hand column shows OSHA's 2026 maximum penalty for a single serious or other-than-serious violation. Every N/S deserves a closer look.

On the last page, total your answers to get your score and estimate your exposure.

		YES	NO	N/S	UP TO	
STORAGE & MATERIAL HANDLING (1910.176)						
1.	[1910.176(b)]	Materials stored in tiers are stacked, blocked, interlocked, and limited in height so they are stable and secure against collapse	☐	☐	☐	\$16,550
2.	[1910.176(a)]	Aisles and passageways kept clear and in good repair, with safe clearance for forklifts	☐	☐	☐	\$16,550
3.	[1910.176(a)]	Permanent aisles and passageways appropriately marked	☐	☐	☐	\$16,550
4.	[1910.176(c)]	Storage areas free of accumulated material that creates tripping, fire, explosion, or pest hazards	☐	☐	☐	\$16,550
WALKING-WORKING SURFACES & HOUSEKEEPING (1910.22)						
5.	[1910.22(a)(1)]	Work areas, passageways, and storerooms kept clean, orderly, and sanitary	☐	☐	☐	\$16,550
6.	[1910.22(a)(3)]	Walking surfaces free of hazards such as spills, leaks, loose boards, and protruding objects	☐	☐	☐	\$16,550
7.	[1910.22(d)]	Hazardous surface conditions (holes, damaged flooring) repaired, or guarded until repaired, before anyone uses the surface	☐	☐	☐	\$16,550
FIRE PROTECTION (1910.157)						
8.	[1910.157(c)(1)]	Fire extinguishers mounted, located, and identified so they are readily accessible	☐	☐	☐	\$16,550
9.	[1910.157(e)(2)]	Every portable extinguisher visually inspected at least monthly	☐	☐	☐	\$16,550
10.	[1910.157(c)]	Extinguishers fully charged, operable, and kept in their designated places	☐	☐	☐	\$16,550

		YES	NO	N/S	UP TO
ELECTRICAL SAFETY (1910.303-305)					
11. [1910.303(g)(1)(ii)]	Working space in front of electrical panels kept clear and never used for storage	☐	☐	☐	\$16,550
12. [1910.305(g)]	Extension cords not used as a substitute for permanent (fixed) wiring	☐	☐	☐	\$16,550
13. [1910.305(b)(2)(i)]	Every junction box, pull box, and fitting has its cover in place	☐	☐	☐	\$16,550
EXIT ROUTES (1910.36-37)					
14. [1910.37(a)(3)]	Exit routes free and unobstructed, with no materials or equipment in them, even temporarily	☐	☐	☐	\$16,550
15. [1910.37(b)(6)]	Exit signs illuminated by a reliable light source, or self-luminous	☐	☐	☐	\$16,550
16. [1910.36(d)(1)]	Exit doors open from the inside at all times without keys, tools, or special knowledge	☐	☐	☐	\$16,550
POWERED INDUSTRIAL TRUCKS (1910.178)					
17. [1910.178(l)]	Every forklift operator trained, evaluated, and certified, with a performance evaluation at least every 3 years	☐	☐	☐	\$16,550
18. [1910.178(q)(7)]	Each truck examined before use at least daily (after each shift if trucks run around the clock)	☐	☐	☐	\$16,550
19. [1910.178(n)]	Drivers slow down and sound the horn at cross aisles and wherever vision is obstructed	☐	☐	☐	\$16,550
PPE & HAZARD COMMUNICATION (1910.132, 1910.1200)					
20. [1910.132(d)]	PPE hazard assessment completed and certified in writing	☐	☐	☐	\$16,550
21. [1910.132(a)]	Employees use the PPE their hazard assessment requires, kept in reliable condition	☐	☐	☐	\$16,550
22. [1910.1200(g)(8)]	Safety data sheets readily accessible to employees during every work shift	☐	☐	☐	\$16,550

		YES	NO	N/S	UP TO
EMERGENCY & GENERAL SAFETY					
23. [1910.38(b)]	Emergency action plan in writing, kept on site, and available to employees (where OSHA requires one)	☐	☐	☐	\$16,550
24. [1910.151(b)]	Adequate first aid supplies readily available	☐	☐	☐	\$16,550
25. [1910.147(c)(4)]	Written lockout/tagout procedures for servicing machines and conveyors	☐	☐	☐	\$16,550

Your Compliance Score

Total YES answers: _____ / 25

Total NO answers: _____

Total N/S answers: _____

Score: $\text{YES} \div 25 =$ _____ %

■ 90-100%	Strong compliance posture
■ 70-89%	Gaps that need attention
■ Below 70%	Significant OSHA exposure
■ Below 50%	Urgent: high citation risk

What Is Your Exposure?

Each NO is a potential citation. \$16,550 is OSHA's 2026 maximum for one serious or other-than-serious violation; willful or repeated violations can reach \$165,514 each. Actual penalties depend on severity and probability, and OSHA can reduce them for company size, good faith, and history.

NO answers _____ × \$16,550 = \$ _____ estimated maximum exposure

Want the Full Picture?

This scorecard covers 25 common warehouse citation areas. A full ACES audit reviews photos of your facility against 146 OSHA standards and returns specific CFR citations, penalty exposure, and recommended corrective actions.

Request your free 30-minute consultation: acescompliancesystems.com

This scorecard is an educational self-assessment tool. It is not legal advice or a formal safety audit, and a YES on every item does not mean a facility is fully compliant. Some requirements apply only in certain conditions (for example, a written emergency action plan where an OSHA standard requires one). Penalty figures are OSHA's 2026 maximum amounts, published at [osha.gov/penalties](https://www.osha-slc.gov/penalties).