GRID CONTROLLER OF INDIA (GRID-INDIA)
NORTHERN REGIONAL LOAD DESPATCH CENTRE
DAILY OPERATION REPORT OF NORTHERN REGION

Power Supply Position in Northern Region For 10-Jun-2026

Date of Reporting:11-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy(Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage
86,724	0	86,724	50.028	74,927	0	74,927	50.057	1,943	0.96

2(A)State's Load Deails (At State Periphery) in MU:

State	State's Control Area Generation (Net MU)							Drawal Sch	Act Drawal	UI	Requirement	Shortage	Consumption
	Thermal	Hydro	Gas/Naptha/ Diesel	Solar	Wind	OthersBiomass/Co-gen etc.)	Total	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(Net MU)
PUNJAB	95.31	16.57	0	5	0	2.47	119.35	215.93	211.72	-4.21	331.07	0	331.07
HARYANA	59.1	0.5	0.2	1.39	0	1.26	62.45	203.82	199.15	-4.67	261.6	0	261.6
RAJASTHAN	154.61	0.03	1.66	54.82	64.38	6.15	281.67	86.35	82.59	-3.76	364.26	0	364.26
DELHI	0	0	15.97	0	0	1.54	17.51	147.85	146.06	-1.79	163.57	0	163.57
UTTAR PRADESH	334.3	15.6	0	18.7	0	1.2	369.8	287.12	282.63	-4.49	652.43	0	652.43
UTTARAKHAND	0	15.64	2.11	0.65	0	0	18.4	41.38	41.46	0.08	59.86	0	59.86
HIMACHAL PRADESH	0	35.17	0	0.15	0	0	35.32	4.95	4.65	-0.3	39.97	0	39.97
J&K(UT) & Ladakh(UT)	0	25.38	0	0	0	0	25.38	29.76	29.84	0.08	56.18	0.96	55.22
CHANDIGARH	0	0	0	0	0	0	0	8.33	8.26	-0.07	8.26	0	8.26
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	4.1	4.78	0.68	4.78	0	4.78
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	1.83	1.8	-0.03	1.8	0	1.8
Region	**643.32**	**108.89**	**19.94**	**80.71**	**64.38**	**12.62**	**929.88**	**1,031.42**	**1,012.94**	**-18.48**	**1,943.78**	**0.96**	**1,942.82**

2(B)State Demand Met (Peak and off-peak Hrs)

State	Evening Peak (20:00) MW				AVG DEMAND	Off-Peak (03:00) MW			
	Demand Met	Shortage	UI	STOA/PX/RTM Transaction	MW	Demand Met	Shortage	UI	STOA/PX/RTM Transaction
PUNJAB	13,541	0	-194	2,832	13,767	11,560	0	314	2,894
HARYANA	11,977	0	-220	146	10,984	9,981	0	-117	396
RAJASTHAN	16,087	0	-304	493	14,682	13,968	0	-23	-58
DELHI	6,859	0	-306	1,590	6,813	6,186	0	170	1,611
UTTAR PRADESH	30,660	0	-321	3,467	27,059	26,990	0	-345	2,525
UTTARAKHAND	2,755	0	-188	689	2,499	2,413	0	-22	304
HIMACHAL PRADESH	1,786	0	120	-747	1,705	1,413	0	-29	-673
J&K(UT) & Ladakh(UT)	2,468	0	-51	208	2,301	1,895	0	-6	119
CHANDIGARH	375	0	9	-15	344	298	0	-8	-48
RAILWAYS_NR ISTS	216	0	38	94	199	222	0	40	103
BULK CONSUMER_NR ISTS	0	0	0	0	75	0	0	0	0
Region	86,724	0	-1,417	8,757	80,428	74,926	0	-26	7,173

2(C)State's Demand Met in MWs (Maximum Demand Met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day						ACE			
	Maximum Demand Met of the day	Time	Shortage during at maximum demand	Requirement at the max demand met of the day	Maximum Requirement of the day	Time	Shortage during at maximum Requirement	Demand Met at maximum requiremnet	Min Demand Met	Time	ACE_MAX	Time	ACE_MIN	Time
PUNJAB	15,743	15:00	0	15,743	15,743	15:00	0	15,743	11,560	3:00	919.97	23:50:00	-747.31	20:01:00
HARYANA	12,872	22:00	0	12,872	12,872	22:00	0	12,872	9,113	7:00	1,984.34	09:35:00	-485.11	02:20:00
RAJASTHAN	17,190	22:00	0	17,190	17,190	22:00	0	17,190	13,047	11:00	4,064.01	09:35:00	-595.03	22:31:00
DELHI	8,366	23:00	0	8,366	8,366	23:00	0	8,366	5,062	8:00	1,638.65	09:35:00	-268.61	10:14:00
UP	31,141	21:00	0	31,141	31,141	21:00	0	31,141	21,397	7:00	1,495.7	07:22:00	-1,082.35	13:18:00
UTTARAKHA ..	2,859	21:00	0	2,859	2,859	21:00	0	2,859	2,098	10:00	692.72	09:39:00	-284.05	12:11:00
HP	1,902	7:00	0	1,902	1,902	7:00	0	1,902	1,413	3:00	131.57	15:31:00	-166.49	20:01:00
J&K(UT)&Lad ..	2,594	16:00	0	2,594	2,594	16:00	0	2,594	1,895	3:00	301.45	15:01:00	-1,091.01	13:31:00
CHANDIGARH	418	15:00	0	418	418	15:00	0	418	247	6:00	86.81	09:38:00	-26.91	20:59:00
RAILWAYS_NR ISTS	226	2:00	0	226	226	2:00	0	226	149	12:00	0	-	0	-
BULK CONSUMER_NR ISTS	105	13:00	0	105	105	13:00	0	105	46	19:00	-	-	-	-
NR	89,501	22:00	293	89,794	89,794	22:00	293	89,501	69,893	7:00	0	-	0	-

3(A) State Entities Generation:

CHANDIGARH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
NIL										
Total	0	0	0					0	0	0
Total	0	0	0					0	0	0

DELHI

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAWANA GPS(2 * 253 + 4 * 216)	1,370	272	467	467.55	00:00	0		9.05	8.73	364
DELHI GAS TURBINES(3 * 34 + 6 * 30)	282	30	33	33.45	05:00	0		0.77	0.72	30
PRAGATI GAS TURBINES(1 * 121.2 + 2 * 104.6)	331	267	267	288.49	18:00	0		6.68	6.52	272
RITHALA GPS(3 * 36)	108	0	0	0		0				
Total GAS/NAPTHA/DIESEL	2,091	569	767					16.5	15.97	666
WIND	0	0	0	0		0				
BIOMASS(52)	52	56	60	0		0		1.56	1.54	64
SOLAR(2)	2	0	0	0		0				
Total DELHI	2,145	625	827					18.06	17.51	730

HARYANA

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
DCRTPP (YAMUNA NAGAR)(2 * 300)	600	343	338	538	00:00	339	07:00	9.53	8.6	358
JHAJJAR(CLP)(2 * 660)	1,320	975	765	1,220	00:00	753	11:00	22.55	21.05	877
MAGNUM DIESEL (IPP)(4 * 6.3)	25	0	0	0		0				
PANIPAT TPS(1 * 210 + 2 * 250)	710	533	543	623	23:00	535	18:00	13.96	12.59	525
RGTPP(KHEDAR)(2 * 600)	1,200	707	717	803	22:00	694	16:00	17.45	16.87	703
Total THERMAL	3,855	2,558	2,363					63.49	59.11	2,463
FARIDABAD GPS(1 * 156.07 + 2 * 137.75)	432	0	0	110	23:00	0	18:00	0.2	0.2	8
Total GAS/NAPTHA/DIESEL	432	0	0					0.2	0.2	8
TOTAL HYDRO HARYANA(64.8)	65	9	33	33	03:00	9	18:00	0.51	0.5	21
Total HYDEL	65	9	33					0.51	0.5	21
WIND	0	0	0	0		0				
BIOMASS(106)	106	0	0	0		0		1.26	1.26	53
SOLAR(196)	196	0	0	0		0		1.39	1.39	58
Total HARYANA	4,654	2,567	2,396					66.85	62.46	2,603

HIMACHAL PRADESH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BAJOLI HOLI(3*60)	180	198	194	198	01:00	157	06:00	4.28	4.27	178
BASPA (IPP) HPS(3 * 100)	300	169	295	334	23:30	83	12:00	4.49	4.49	187
KUTEHAR(3 * 80)	240	240	214	246	23:30	143	12:00	5.23	5.23	218
MALANA (IPP) HPS(2 * 43)	86	44	43	57	23:30	25	11:00	0.94	0.94	39
MALANA2(2 * 50)	100	0	0	0		0				
NAITWAR MORI(2 * 30)	60	34	48	48	01:00	33	09:00	0.91	0.9	38
SAWARA KUDDU(3 * 37)	111	54	0	111	21:00	0	01:00	0.59	0.59	25
OTHER HYDRO HP(503.75)	504	311	377	0		0		9.57	9.53	397
Total HYDEL	1,581	1,050	1,171					26.01	25.95	1,082
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR	198	0	0	0		0		0.15	0.15	6
SMALL HYDRO(765.25)	765	419	440	0		0		9.24	9.23	385
Total SMALL HYDRO	765	419	440					9.24	9.23	385
Total HP	2,544	1,469	1,611					35.4	35.33	1,473

J&K(UT) & LADAKH(UT)

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAS/DIESEL/OTHERS J&K	0	0	0	0		0				
Total GAS/NAPTHA/DIESEL	0	0	0					0	0	0
BAGLIHAR (IPP) HPS(6 * 150)	900	896	895	896	20:00	0		21.49	21.49	895
OTHER HYDRO/IPP J&K(308)	308	171	163	177	22:00	0		3.9	3.9	163
Total HYDEL	1,208	1,067	1,058					25.39	25.39	1,058
WIND	0	0	0	0		0				
BIOMASS	0	0	0	0		0				
SOLAR	0	0	0	0		0				
SMALL HYDRO(98)	98	0	0	0		0				
Total SMALL HYDRO	98	0	0					0	0	0
Total J&K(UT)&Ladakh(UT)	1,306	1,067	1,058					25.39	25.39	1,058

PUNJAB										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GOINDWAL(GVK)(2 * 270)	540	215	270	491	06:00	215	20:00	8.05	6.98	291
GURU GOBIND SINGH TPS (ROPAR)(4 * 210)	840	288	412	439	09:00	288	18:00	9.39	8.34	348
GURU HARGOBIND SINGH TPS (LEHRA MOHABBAT)(2 * 210 + 2 * 250)	920	800	571	810	11:00	568	02:00	19.93	18.22	759
RAJPURA(NPL) TPS(2 * 700)	1,400	1,210	1,320	1,320	01:00	710	11:00	30.79	29.4	1,225
TALWANDI SABO TPS(3 * 660)	1,980	1,363	1,245	1,770	01:00	924	09:00	34.85	32.38	1,349
Total THERMAL	5,680	3,876	3,818					103.01	95.32	3,972
ANANADPUR SAHIB HYDRO PLANT(2 * 33.5 + 2 * 33.5)	134	109	112	114	05:00	109	18:00	2.75	2.75	115
MUKERIAN HYDRO PLANT(6 * 15 + 6 * 19.5 + 2 * 9)	225	170	180	198	23:00	147	14:00	4.14	4.13	172
RANJIT SAGAR POWER PLANT (4 * 150)	600	300	600	600	01:00	0	05:00	6.12	6.1	254
SHANAN(4 * 15 + 1 * 50)	110	100	110	110	01:00	74	16:00	2.33	2.32	97
UBDC(3 * 15 + 3 * 15.5)	92	39	40	40	01:00	39	15:00	0.94	0.94	39
OTHER HYDRO PUNJAB	0	0	0	0		0		0.32	0.32	13
Total HYDEL	1,161	718	1,042					16.6	16.56	690
WIND	0	0	0	0		0				
BIOMASS(303)	303	0	0	0		0		2.47	2.47	103
SOLAR(942)	942	44	43	511	12:00	43	01:00	5	5	208
Total PUNJAB	8,086	4,638	4,903					127.08	119.35	4,973

RAJASTHAN										
Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
BARSINGSAR (IPP) LTPS(2 * 125)	250	112	111	112	22:00	110	11:00	2.99	2.6	108
CHHABRA TPS(2 * 660 + 4 * 250)	2,320	1,972	1,755	1,980	21:00	1,222	11:00	43.51	40.32	1,680
GIRAL (IPP) LTPS(2 * 125)	250	0	0	0		0				
KALISINDH TPS(2 * 600)	1,200	768	895	916	01:00	626	11:00	19.38	17.93	747
KAWAI TPS(2 * 660)	1,320	613	606	632	00:00	373	16:00	13.33	12.32	513
KOTA TPS(2 * 110 + 2 * 195 + 3 * 210)	1,240	969	772	970	21:00	739	11:00	22.6	19.93	830
RAJWEST (IPP) LTPS(8 * 135)	1,080	660	639	692	00:00	505	11:00	16.35	14.35	598
SURATGARH TPS (6 * 250 + 2 * 660(SSCTPS))	2,820	2,371	2,075	2,392	22:00	1,507	13:00	48.47	44.4	1,850
VSLPP (IPP)(1 * 135)	135	118	117	119	01:00	115.51	12:00	3.15	2.77	115
Total THERMAL	10,615	7,583	6,970					169.78	154.62	6,441
DHOLPUR GPS(3 * 110)	330	0	0	0		0				
RAMGARH GPS(1 * 110 + 1 * 35.5 + 1 * 50 + 2 * 37.5)	271	66	69	69	07:00	66	17:00	1.73	1.66	69
Total GAS/NAPTHA/DIESEL	601	66	69					1.73	1.66	69
RAPS-A(1 * 100 + 1 * 200)	300	146	145	149	12:00	144	07:00	3.85	3.56	148
Total NUCLEAR	300	146	145					3.85	3.56	148
TOTAL HYDRO RAJASTHAN(550)	550	0	0	23	01:00	0	06:00	0.03	0.03	1
Total HYDEL	550	0	0					0.03	0.03	1
WIND(1 * 4328)	4,328	1,578	2,486	2,596	07:00	1,101	17:00	64.38	64.38	2,683
BIOMASS(180)	180	108	108	108	01:00	108	06:00	2.59	2.59	108
SOLAR(8269)	8,269	67	0	6,809	12:00	2	06:00	54.82	54.82	2,284
Total RAJASTHAN	24,843	9,548	9,778					297.18	281.66	11,734

UTTAR PRADESH

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
ANPARA TPS(2 * 500 + 3 * 210)	1,630	1,341	1,332	1,422	14:00	730	10:00	30.9	28.6	1,192
ANPARA-C TPS(2 * 600)	1,200	1,121	1,121	1,121	02:00	710	08:00	27.2	25.4	1,058
ANPARA-D TPS(2 * 500)	1,000	942	853	942	20:00	539	08:00	21.9	20.6	858
BAJAJ ENERGY PVT LTD (IPP) TPS(10 * 45)	450	342	286	405	15:00	225	02:00	7.6	6.9	288
BARA PPGCL TPS(3 * 660)	1,980	1,596	1,607	1,721	05:00	1,078	08:00	40.2	37.1	1,546
GHATAMPUR TPS (2*660)	1,320	1,190	1,164	1,193	10:00	653	14:00	28	26.6	1,108
HARDUAGANJ TPS(1 * 110 + 2 * 250 + 1*660)	1,270	939	345	1,046	22:00	271	10:00	14.3	13.1	546
INFIRM POWER	660	0	0	0		0				
JAWAHARPUR TPS(2*660)	1,320	1,060	676	1,074	22:00	657	04:00	21.8	20.6	858
JP CHURK(3 * 60)	180	0	0	0		0				
KHURJA TPS(2 * 660)	1,320	602	598	660	08:00	428	11:00	14.6	13.8	575
LALITPUR TPS(3 * 660)	1,980	1,725	1,479	1,834	12:00	1,006	08:00	40.4	37.9	1,579
MEJA TPS(2 * 660)	1,320	1,033	1,122	1,163	07:00	730	08:00	26	24.2	1,008
OBRA TPS (5 * 200+2*660)	2,320	1,523	1,652	1,758	05:00	1,153	10:00	38.4	35.5	1,479
PANKI_I TPS(1 * 660)	660	600	402	619	15:00	358	01:00	12.1	11.4	475
PARICHA TPS(2 * 210 + 2 * 250)	920	672	501	672	20:00	473	10:00	14.2	13	542
ROSA TPS(4 * 300)	1,200	1,007	714	1,084	15:00	587	11:00	21.5	19.6	817
Total THERMAL	20,730	15,693	13,852					359.1	334.3	13,929
ALAKHANANDA HEP(4 * 82.5)	330	168	165	168	20:00	83	05:00	3.6	3.6	150
RIHAND HPS(6 * 50)	300	150	0	290	15:00	0	01:00	1.9	1.9	79
VISHNUPARYAG HPS(4 * 110)	440	436	396	436	19:00	280	13:00	8.7	8.7	363
OTHER HYDRO UP(227)	227	94	55	124	22:00	3	14:00	1.4	1.4	58
Total HYDEL	1,297	848	616					15.6	15.6	650
WIND	0	0	0	0		0				
BIOMASS(26)	26	0	0	0		0				
SOLAR(2729)	2,729	0	0	2,369	13:00	0	01:00	18.7	18.7	779
CO-GENERATION(1360)	1,360	50	50	50	01:00	0		1.2	1.2	50
Total OTHERs	1,360	50	50					1.2	1.2	50
Total UP	26,142	16,591	14,518					394.6	369.8	15,408

UTTARAKHAND

Station/Constituents	Inst. Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy		AVG. MW
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross Gen(MU)	Net Gen(MU)	
GAMMA	225	88	88	99	02:00	87	09:00	2.16	2.11	88
SARAVANTI	450	0	0	0		0				
Total GAS/NAPTHA/DIESEL	675	88	88					2.16	2.11	88
OTHER HYDRO UK(1250)	1,250	850	706	850	20:00	456	15:00	15.7	15.64	652
Total HYDEL	1,250	850	706					15.7	15.64	652
WIND	0	0	0	0		0				
BIOMASS(127)	127	0	0	0		0				
SOLAR(278)	278	0	0	83	12:00	9	18:00	0.65	0.65	27
SMALL HYDRO(180)	180	0	0	0		0				
Total SMALL HYDRO	180	0	0					0	0	0
Total UTTARAKHAND	2,510	938	794					18.51	18.4	767

3(B) Regional Entities Generation

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy				AVG. MW	UI(Actual-Schedule-(+- AGC))
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen ACT (MU)	Net Gen ACT MU)	AGC(MU)		
Aravali Power Company Private Ltd														
ISTPP (JHAJJAR)(3 * 500)	1,500	1,406	895	906	1,458	23:15	821	18:15	20.49553	22.5	20.7	0.22	863	-0.01553
Sub-Total	1,500	1,406	895	906	-	-	-	-	20.49553	22.5	20.7	0.22	863	-0.01553
BBMB														
BHAKRA HPS(5 * 126 + 5 * 157)	1,415	1,325	1,303	895	1,303	20:00	525	17:00	19.3195	19.7	19.39	0	808	0.0705
DEHAR HPS(6 * 165)	990	480	495	495	495	20:00	280	17:00	11.36	11.54	11.23	0	468	-0.13
PONG HPS(6 * 66)	396	350	358	188	358	20:00	123	14:00	4.729	4.88	4.77	0	199	0.041
Sub-Total	2,801	2,155	2,156	1,578	-	-	-	-	35.4085	36.12	35.39	0	1,475	-0.0185
NHPC														
BAIRASIUL HPS(3 * 60)	180	186	181	60	185	20:45	0	12:30	2.03286	2.13	2.1	-0.01	88	0.07714
CHAMERA I HPS(3 * 180)	540	545	550	380	550	20:00	0	06:00	7.50733	7.52	7.43	-0.01	310	-0.06733
CHAMERA II HPS(3 * 100)	300	208	0	0	0	-	0	-	4.7736	4.82	4.77	0	199	-0.0036
CHAMERA III HPS(3 * 77)	231	240	217	220	221	23:00	214.3	19:00	5.235	5.25	5.19	0	216	-0.045
DHAULIGANGA HPS(4 * 70)	280	285	267	138	278	23:00	68.5	18:00	3.3964	3.39	3.37	-0.05	140	0.0236
DULHASTI HPS(3 * 130)	390	385	382	380	382	19:00	361.65	08:00	8.92596	9.12	9.01	0	375	0.08404
KISHANGANGA(3 * 110)	330	336	337	332	337	20:00	331.1	06:00	7.938	7.94	7.92	0	330	-0.018
PARBATI III HEP(4 * 130)	520	390	390	354	518	22:00	29.57	12:00	6.1145	6.26	6.22	0	259	0.1055
PARBATI-II(4 * 200)	800	700	626	595	738	21:00	125.6	11:00	10.6025	11.13	10.74	0	448	0.1375
SALAL HPS(6 * 115)	690	705	0	0	0	-	0	-	16.4825	16.76	16.61	0	692	0.1275
SEWA-II HPS(3 * 40)	120	130	128	0	128	-	0	-	0.7173	0.75	0.73	0	30	0.0127
TANAKPUR HPS(1 * 31.42 + 2 * 31.4)	94	45	95	36	96	13:59	27.6	12:00	1.01293	1.14	1.12	0	47	0.10707
URI HPS(4 * 120)	480	494	481	484	493	08:30	451	09:30	11.6545	11.82	11.74	0	489	0.0855
URI-II HPS(4 * 60)	240	250	244	245	245	01:15	244.15	04:15	5.72952	5.91	5.88	0	245	0.15048
Sub-Total	5,195	4,899	3,898	3,224	-	-	-	-	92.1229	93.94	92.83	-0.07	3,868	0.7771
NPCL														
NAPS(2 * 220)	440	390	424	432	436	07:00	416	16:00	9.36	10.16	9.16	0	382	-0.2
RAPP-D	700	618	0	0	683	-	0	-	14.832	16.12	14.8	0	617	-0.032
RAPS-B(2 * 220)	440	320	340	370	374	07:00	335	18:00	7.674	8.62	7.52	0	313	-0.154
RAPS-C(2 * 220)	440	411	447	453	458	08:00	447	16:00	9.864	10.88	9.81	0	409	-0.054
Sub-Total	2,020	1,739	1,211	1,255	-	-	-	-	41.73	45.78	41.29	0	1,721	-0.44
NTPC														
ANTA GPS(1 * 153.2 + 3 * 88.71)	419	380	0	0	145	23:05	0	-	0.54977	0.34	0.26	0	11	-0.28977
AURAIYA GPS(2 * 109.3 + 4 * 111.19)	663	626	0	0	0	-	0	-	0.37194	0.06	-0.05	0	-2	-0.42194
DADRI GPS(2 * 154.51 + 4 * 130.19)	830	780	518	0	726	22:00	0	-	4.15891	2.85	2.58	0	108	-1.57891
DADRI-I TPS(4 * 210)	840	769	432	439	432	20:00	0	-	11.09817	12.6	11.43	0	476	0.33183
DADRI-II TPS(2 * 490)	1,000	938	712	512	712	20:00	0	-	14.55768	15.84	14.72	0	613	0.16232
KOLDAM HPS(4 * 200)	800	871	871	0	872	21:00	0	-	6.46515	6.51	6.47	0	270	0.00485
RIHAND-I STPS(2 * 500)	1,000	920	961	982	1,011	16:00	544	11:00	18.70055	20.45	18.51	-0.03	771	-0.16055
RIHAND-II STPS(2 * 500)	1,000	943	968	954	993	21:00	544	11:00	19.81448	20.74	19.3	-0.04	804	-0.47448
RIHAND-III STPS(2 * 500)	1,000	943	962	964	998	07:00	543	11:00	19.97975	21.06	19.84	-0.07	827	-0.06975
SINGRAULI HYDRO(1 * 8)	8	6	6	6	6	20:00	0	-	0.1379	0.15	0.14	0	6	0.0021
SINGRAULI STPS(2 * 500 + 5 * 200)	2,000	1,853	1,978	1,256	1,978	20:00	0	-	38.70275	42.01	38.72	0	1,613	0.01725
TANDA TPS(4 * 110)	440	-	0	0	0	-	0	-	-	-	-	-	-	-
TANDA TPS STAGE-II(2 * 660)	1,320	1,238	1,216	1,219	1,242	02:30	0	-	23.92614	25.41	23.63	0	985	-0.29614
UNCHAHAR II TPS(2 * 210)	420	375	375	246	413	19:30	236	18:00	6.0884	6.93	6.14	0.04	256	0.0116
UNCHAHAR III TPS(1 * 210)	210	189	191	123	202	19:30	116	18:00	3.03658	3.41	3.07	0.02	128	0.01342
UNCHAHAR IV TPS(1 * 500)	500	466	492	295	500	23:00	269	15:00	7.84431	8.48	7.85	0.04	327	-0.03431
UNCHAHAR TPS(2 * 210)	420	378	371	254	405	21:00	236	08:00	6.209	7.01	6.09	0	254	-0.119
Sub-Total	12,870	11,675	10,053	7,250	-	-	-	-	181.64148	193.85	178.7	-0.04	7,447	-2.90148
SJVNL														
NATHPA-JHAKRI HPS(6 * 250)	1,500	1,630	1,628	944	1,628	20:00	0	13:00	24.2	24.51	24.32	0	1,013	0.12
RAMPUR HEP(6 * 68.67)	412	449	443	268	443	20:00	0	13:00	6.66568	6.92	6.87	0	286	0.20432
Sub-Total	1,912	2,079	2,071	1,212	-	-	-	-	30.86568	31.43	31.19	0	1,299	0.32432
THDC														
KOTESHWAR HPS(4 * 100)	400	90	93	64	94	21:00	63	14:00	1.505	1.59	1.58	0	66	0.075
TEHRI HPS(4 * 250)	1,000	472	468	234	468	20:00	0	07:00	3.363	3.3	3.3	-0.01	138	-0.053
Sub-Total	1,400	562	561	298	-	-	-	-	4.868	4.89	4.88	-0.01	204	0.022
Total	27,698	24,515	20,845	15,723					407.13209	428.51	404.98	0.1	16,877	-2.25209

IPP/JV

Station/Constituents	Inst. Capacity	Declared Capacity	20:00	03:00	Day Peak		Min Generation (06:00-18:00)		Day Energy			AVG. MW	UI
	(MW)	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	SCHD (MU)	Gross Gen(MU)	Net Gen(MU)		
IPP													
ADHPL(IPP) HPS(2 * 96)	192	150	99	163	192	23:59	0	-	2.66528	2.7	2.68	112	0.01472
BUDHIL HPS (IPP)(2 * 35)	70	69	71	71	72	19:00	35.32	12:00	1.29742	1.34	1.33	55	0.03258
KARCHAM WANGTOO HPS(4 * 261.25)	1,045	988	1,000	450	1,000	20:00	0	12:00	13.15321	13.6	13.5	563	0.34679
SHREE CEMENT (IPP) TPS(2 * 150 + 2 * 19 + 1 * 6)	344	185	0	0	0	-	0	-	3.33375	3.33	3.23	135	-0.10375
SAINJ HEP(2 * 50)	100	49	50	80	105	21:00	0	-	1.4089	1.45	1.43	60	0.0211
SINGOLI BHATWARI HEP(3 * 33)	99	98	72	71	91	21:00	0	-	1.11748	1.22	1.2	50	0.08252
SORANG HYDROELECTRIC PROJECT(2 * 50)	100	98	70	46	70	20:00	0	-	1.109	1.19	1.18	49	0.071
Sub-Total	1,950	1,637	1,362	881	-	-	-	-	24.08504	24.83	24.55	1,024	0.46496
SOLAR IPP													
ADANI GREEN ENERGY TWENTY FIVE LIMITED	500	0	0	0	0	-	0	-	4.4747	3.98	3.98	166	-0.4947
ABC RENEWABLE ENERGY(1 * 300)	300	0	0	0	0	-	0	-	2.28914	2.29	2.29	95	0.00086
ABC RENEWABLE ENERGY_2	550	0	0	0	0	-	0	-	0.87961	0.88	0.88	37	0.00039
ACME CHITTORGARH SOLAR ENERGY PVT LTD(1 * 250)	250	0	0	0	210	12:19	0	-	1.62836	1.56	1.56	65	-0.06836
ACME DEOGHAR SOLAR POWER PRIVATE LIMITED(ADSPPL)	300	0	0	0	0	-	0	-	2.39811	2.4	2.4	100	0.00189
ACME HEERGARH POWERTECH PRIVATE LIMITED(1*300)	300	0	0	0	0	-	0	-	2.36244	2.36	2.36	98	-0.00244
ACME PHALODI SOLAR ENERGY PRIVATE LIMITED(APSEPL)	300	0	0	0	0	-	0	-	2.39847	2.4	2.4	100	0.00153
ACME RAISAR SOLAR ENERGY PRIVATE LIMITED(ARSEPL)	300	0	0	0	0	-	0	-	2.4414	2.44	2.44	102	-0.0014
ACME SIKAR SOLAR PRIVATE LIMITED	300	0	0	0	0	-	0	-	2.36643	2.17	2.17	90	-0.19643
ACMEDHAULPUR POWERTECH PRIVATE LIMITED(ADPPL)	300	0	0	0	0	-	0	-	2.39412	2.4	2.4	100	0.00588
AMP ENERGY GREEN SIX PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.41235	0.41	0.41	17	-0.00235
AMP GREEN ENERGY FIVE PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.9166	0.92	0.92	38	0.0034
ADANI GREEN ENERGY TWENTY FIVE B	138	0	0	0	0	-	0	-	0.36563	0.37	0.37	15	0.00437
ADANI GREEN ENERGY TWENTY FOUR LIMITED	500	0	0	0	481	13:04	0	-	3.95708	3.19	3.19	133	-0.76708
ADANI RENEWABLE ENERGY RJ LIMITED (ARERJL)(1 * 200)	200	0	0	0	172	11:48	0	-	1.33147	1.24	1.24	52	-0.09147
ADANI SOLAR ENERGY BARMER ONE LIMITED_FTG3	251	0	0	0	246	12:36	0	-	1.91098	1.81	1.8	75	-0.11098
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED(1*150)	150	0	0	0	137	13:15	0	-	1.0654	1.06	1.06	44	-0.0054
ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED (PROJECT-2)(1*150)	150	0	0	0	127	13:30	0	-	1.00391	1.05	1.04	43	0.03609
ADANI SOLAR ENERGY JODHPUR SIX PRIVATE LIMITED	50	0	0	0	0	-	0	-	0.1844	0.18	0.18	8	-0.0044
ADANI SOLAR ENERGY RJ TWO PVT LTD_BHADLA(1*150)	150	0	0	0	150	10:49	0	-	1.08367	1.21	1.21	50	0.12633
ADANI SOLAR ENERGY RJ TWO PVT LTD_FATEGARH 2(1*180)	180	0	0	0	180	13:22	0	-	1.76922	1.63	1.62	68	-0.14922
ADEPT RENEWABLE TECHNOLOGIES PVT LTD(1*110)	110	0	0	0	116	11:34	0	-	1.00988	0.98	0.98	41	-0.02988
ALTRA XERGI POWER PRIVATE LIMITED	380	0	0	0	0	-	0	-	2.84396	2.34	2.34	98	-0.50396
AMBUJA CEMENTS LIMITED	150	0	0	0	0	-	0	-	2.22	2.21	2.21	92	-0.01
AMP ENERGY GREEN FOUR PRIVATE LIMITED	100	0	0	0	0	-	0	-	0.33258	0.33	0.33	14	-0.00258
AMPLUS AGES PRIVATE LIMITED(1*100)	100	0	0	0	84	09:32	0	-	0.70518	0.68	0.68	28	-0.02518
AURAIYA SOLAR(1 * 40)	40	0	0	0	0	-	0	-	0.22878	0.26	0.25	10	0.02122
AVAADA RJHN PRIVATE LIMITED(1*240)	240	0	0	0	219	13:17	0	-	1.63018	1.64	1.64	68	0.00982
AVAADA SUNCE ENERGY PRIVATE LIMITED, BIKANER(1 * 350)	350	0	0	0	317	13:16	0	-	2.37761	2.21	2.21	92	-0.16761
AVAADA SUNRAYS ENERGY PRIVATE LTD(1*320)	320	0	0	0	322	13:16	0	-	2.44054	2.47	2.46	103	0.01946
AVAADA SUSTAINABLE RJPROJECT PVT LTD(1*300)	300	0	0	0	276	13:15	0	-	2.10516	1.88	1.88	78	-0.22516
AYANA RENEWABLE POWER ONE PRIVATE LIMITED, BIKANER(300)	300	0	0	0	275	13:17	0	-	2.04353	2.11	2.11	88	0.06647
AZURE POWER FORTY THREE PRIVATE LIMITED(1 * 150 + 1 * 150 + 1 * 300)	600	0	0	0	532	13:15	0	-	4.03374	3.57	3.57	149	-0.46374
AZURE POWER INDIA PVT LTD.(4 * 50)	200	0	0	0	156	13:25	0	-	1.17437	1.13	1.13	47	-0.04437
AZURE POWER MAPLE PVT LTD(1*300)	300	0	0	0	268	12:38	0	-	2.0766	1.81	1.81	75	-0.2666
AZURE POWER THIRTY FOUR PRIVATE LTD(1 * 130)	130	0	0	0	123	11:24	0	-	0.89106	0.89	0.89	37	-0.00106
BBMB SOLAR BHIWANI	9	0	0	0	0	-	0	-	0.04092	0.04	0.05	2	0.00908

BBMB SOLAR HISSAR	2	0	0	0	0	-	0	-	0.00901	0.01	0.01	0	0.00099
BANDERWALA SOLAR PLANT LTD(1*300)	300	0	0	0	0	-	0	-	0.74446	0.75	0.75	31	0.00554
CLEAN SOLAR POWER (BHADLA) PVT LTD(1 * 300)	300	0	0	0	280	12:02	0	-	2.2106	2.01	2.01	84	-0.2006
CLEAN SOLAR POWER(JODHPUR) PRIVATE LIMITED(1*250)	250	0	0	0	241	12:26	0	-	1.84391	1.65	1.65	69	-0.19391
DADRI SOLAR(5)	5	0	0	0	3	-	0	-	0.01881	0.02	0.02	1	0.00119
DEVIKOT SOLAR POWER NTPC	240	0	0	0	0	-	0	-	1.59272	1.59	1.59	66	-0.00272
EDEN RENEWABLE ALMA PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.74563	0.74	0.74	31	-0.00563
EDEN RENEWABLE CITE PRIVATE LIMITED(1 * 300)	300	0	0	0	294	13:03	0	-	2.24561	2.21	2.21	92	-0.03561
ENERGIZENT POWER PRIVATE LIMITED	69	0	0	0	0	-	0	-	0.15392	0.15	0.15	6	-0.00392
GORBEA SOLAR PRIVATE LIMITED	300	0	0	0	224	09:22	0	-	0.76602	0.86	0.86	36	0.09398
GRIAN ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	81	09:33	0	-	0.70179	0.68	0.68	28	-0.02179
HRP GREEN POWER PRIVATE LIMITED_BHD3	244	0	0	0	0	-	0	-	0.75836	0.76	0.76	32	0.00164
IB VOGT SOLAR SEVEN PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.34836	0.43	0.43	18	0.08164
JUNIPER GREEN COSMIC PRIVATE LIMITED	100	0	0	0	95	12:34	0	-	0.77806	0.74	0.74	31	-0.03806
JUNA RENEWABLE ENERGY PRIVATE LIMITED	335	0	0	0	0	-	0	-	2.87852	2.58	2.58	108	-0.29852
JUNIPER NIRJARA ENERGY PRIVATE LIMITED	50	0	0	0	35	10:46	0	-	0.222	0.22	0.22	9	-0.002
KARNISAR SOLAR PLANT NHPC LIMITED	300	0	0	0	0	-	0	-	2.2157	2.21	2.21	92	-0.0057
KHABA RENEWABLE ENERGY PRIVATE LIMITED_FTG3	250	0	0	0	0	-	0	-	0.387	0.39	0.39	16	0.003
KHIDRAT RENEWABLE ENERGY PRIVATE LIMITED	300	0	0	0	0	-	0	-	0.82222	0.82	0.82	34	-0.00222
KOLAYAT SOLAR POWER PLANT NTPC LIMITED(1*550)	550	0	0	0	0	-	0	-	4.03283	4.03	4.03	168	-0.00283
M/S ADANI SOLAR ENERGY FOUR PRIVATE LIMITED(1 * 50)	50	0	0	0	48	12:13	0	-	0.364	0.37	0.37	15	0.006
M/S ADANI SOLAR ENERGY JODHPUR TWO LIMITED(1 * 50)	50	0	0	0	49	11:52	0	-	0.3732	0.38	0.38	16	0.0068
M/S AZURE POWER FORTY ONE PRIVATE LIMITED(1 * 300)	300	0	0	0	285	12:45	0	-	2.14351	1.93	1.93	80	-0.21351
M/S. ONEVOLT ENERGY PRIVATE LIMITED(1*100)	100	0	0	0	82	09:43	0	-	0.69007	0.67	0.66	28	-0.03007
MEGA SOILS RENEWABLE PRIVATE LIMITED(1 * 250)	250	0	0	0	0	-	0	-	1.76026	1.76	1.76	73	-0.00026
MEGA SURYAURJA PVT LTD(1*250)	250	0	0	0	0	-	0	-	1.94972	1.95	1.95	81	0.00028
NTPC ANTA SOLAR PV STATION	90	0	0	0	0	-	0	-	0.69781	0.7	0.7	29	0.00219
NTPC NOKH SOLAR PROJECT	735	0	0	0	0	-	0	-	6.09698	5.6	5.6	233	-0.49698
NTPC NIDAN SOLAR(1*296)	296	0	0	0	0	-	0	-	2.20673	2.21	2.21	92	0.00327
NEEMBA RENEW SURYA VIHAAN PRIVATE LIMITED	200	0	0	0	0	-	0	-	0.53504	0.54	0.54	23	0.00496
NOKHRA SOLAR POWER NTPC	300	0	0	0	0	-	0	-	2.26325	2.26	2.26	94	-0.00325
PROJECT ELEVEN RENEWABLE POWER PL_BHDL2	150	0	0	0	0	-	0	-	0.292	0.29	0.29	12	-0.002
PROJECT SIXTEEN RENEWABLE POWER_BHDL2	150	0	0	0	0	-	0	-	0.628	0.63	0.63	26	0.002
RENEW DINKAR URJA PRIVATE LIMITED_BKN2	300	0	0	0	0	-	0	-	1.19575	1.2	1.2	50	0.00425
RENEW SAMIR SHAKTI PRIVATE LIMITED_FTG3	300	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SOLAR SHAKTI THREE PRIVATE LIMITED_FTG3	300	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SUN BRIGHT PRIVATE LIMITED (RSBPL)(1 * 300)	300	0	0	0	264	13:31	0	-	2.12421	2.06	2.06	86	-0.06421
RENEW SURYA RAVI PVT LTD(1*300)	300	0	0	0	230	12:06	0	-	1.94134	1.88	1.88	78	-0.06134
RENEW SOLAR (SHAKTI FIVE) PRIVATE LIMITED_FTG3	211	0	0	0	0	-	0	-	0	-	-	-	-
RENEW SOLAR ENERGY (JHARKHAND THREE) PVT LTD(300)	300	0	0	0	251	13:17	0	-	2.07646	2.25	2.25	94	0.17354
RENEW SOLAR POWER PVT LTD(50)	50	0	0	0	217	13:12	0	-	0.3742	1.69	1.69	70	1.3158
RENEW SOLAR POWER PVT LTD. BIKANER(1 * 250)	250	0	0	0	0	-	0	-	1.7176	1.72	1.72	72	0.0024
RENEW SOLAR URJA PVT LIMITED(300)	300	0	0	0	258	13:12	0	-	2.0362	1.99	1.99	83	-0.0462
RENEW SURYA AAYAN PRIVATE LIMITED	300	0	0	0	282	11:53	0	-	2.18824	2.13	2.12	88	-0.06824
RENEW SURYA JYOTI PRIVATE LIMITED	210	0	0	0	136	09:16	0	-	0.55537	0.51	0.51	21	-0.04537
RENEW SURYA PRATAP PRIVATE LIMITED(1*200)	200	0	0	0	194	12:35	0	-	1.50886	1.39	1.38	58	-0.12886
RENEW SURYA ROSHNI PVT LTD_SOLAR(1*400)	400	0	0	0	0	-	0	-	3.09271	2.59	2.59	108	-0.50271
RENEW SURYA VIHAAN PRIVATE LIMITED	100	0	0	0	92	12:35	0	-	0.7088	0.66	0.66	28	-0.0488
RISING SUN ENERGY (K) PVT LTD(1*164)	190	0	0	0	0	-	0	-	1.38278	1.38	1.38	58	-0.00278
SB ENERGY FOUR PVT LTD(2 * 100)	200	0	0	0	0	-	0	-	1.21536	1.22	1.22	51	0.00464
SB ENERGY SIX PRIVATE LIMITED(1 * 300)	300	0	0	0	294	13:31	0	-	2.02432	2.12	2.12	88	0.09568

SJVN GREEN ENERGY LIMITED	888	0	0	0	597	13:22	0	-	4.62193	4.47	4.47	186	-0.15193
SERENTICA RENEWABLES INDIA 4 PRIVATE LIMITED_BKN2	168	0	0	0	0	-	0	-	1.65088	1.65	1.65	69	-0.00088
SERENTICA RENEWABLES INDIA 5 PRIVATE LIMITED	220	0	0	0	222	09:16	0	-	1.01946	0.91	0.91	38	-0.10946
SINGRAULI SOLAR(15)	15	0	0	0	0	-	0	-	0.06979	0.07	0.07	3	0.00021
SOLZEN URJA PRIVATE LIMITED(1 * 300)	300	0	0	0	289	13:00	0	-	2.19024	2.14	2.14	89	-0.05024
TRANSITION CLEANTECH SERVICES PRIVATE LIMITED	24	0	0	0	65	09:31	0	-	0.21706	0.51	0.51	21	0.29294
TATA POWER GREEN ENERGY LIMITED	225	0	0	0	183	12:55	0	-	1.46182	1.43	1.43	60	-0.03182
TATA POWER RENEWABLE ENERGY LTD(1 * 300)	300	0	0	0	275	13:33	0	-	2.14785	2.06	2.02	84	-0.12785
TATA POWER SAURYA LIMITED	110	0	0	0	91	09:57	0	-	0.75357	0.72	0.72	30	-0.03357
THAR SURYA 1PRIVATE LIMITED(1*300)	300	0	0	0	222	14:30	0	-	1.62293	1.66	1.66	69	0.03707
TRANSITION ENERGY SERVICES PRIVATE LIMITED	60	0	0	0	0	-	0	-	0.35033	0.35	0.35	15	-0.00033
TRANSITION GREEN ENERGY PRIVATE LIMITED	100	0	0	0	73	16:19	0	-	0.36625	0.3	0.3	13	-0.06625
TRANSITION SUSTAINABLE ENERGY SERVICES PVT. LTD.	50	0	0	0	51	13:13	0	-	0.43206	0.4	0.4	17	-0.03206
TRANSITION SUSTAINABLE ENERGY SERVICES ONE PVT LTD	56	0	0	0	0	-	0	-	0.31362	0.31	0.31	13	-0.00362
UNCHAHAR SOLAR(10)	10	0	0	0	6	10:00	0.52	17:30	0.04144	0.04	0.04	2	-0.00144
XL XERGI POWER PRIVATE LIMITED	400	0	0	0	0	-	0	-	0.88072	0.88	0.88	37	-0.00072
Sub-Total	24,251	0	0	0	-	-	-	-	149.54583	145.33	145.22	6,051	-4.32583
HYBRID IPP													
AMPIN ENERGY GREEN EIGHT PRIVATE LIMITED_SOLAR	113	0	0	0	0	-	0	-	0.4505	0.46	0.46	19	0.0095
AMPIN ENERGY GREEN EIGHT PRIVATE LIMITED_WIND	44	0	0	0	0	-	0	-	0.49852	0.5	0.5	21	0.00148
AMPIN ENERGY GREEN TEN PRIVATE LIMITED_SOLAR	110	0	0	0	0	-	0	-	0.397	0.4	0.4	17	0.003
AMPIN ENERGY GREEN TEN PRIVATE LIMITED_WIND	41	0	0	0	0	-	0	-	0.45045	0.45	0.45	19	-0.00045
AMPIN ENERGY GREEN THREE PRIVATE LIMITED_SOLAR	50	0	0	0	0	-	0	-	0.17175	0.17	0.17	7	-0.00175
AMPIN ENERGY GREEN THREE PRIVATE LIMITED_WIND	19	0	0	0	0	-	0	-	0.2085	0.21	0.21	9	0.0015
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED SOLAR(1*600)	600	0	0	0	0	-	0	-	5.9195	5.92	5.92	247	0.0005
ADANI HYBRID ENERGY JAISALMER FOUR LIMITED WIND(1*510)	510	0	368	450	460	-	0	-	6.69024	7.5	7.5	313	0.80976
ADANI HYBRID ENERGY JAISALMER ONE LIMITED SOLAR(1 * 235.1 + 1 * 124.8)	360	0	0	0	345	12:56	0	-	2.90562	2.67	2.67	111	-0.23562
ADANI HYBRID ENERGY JAISALMER ONE LIMITED WIND(1 * 101)	101	0	63	62	79	08:45	0	-	1.28373	0.14	0.14	6	-1.14373
ADANI HYBRID ENERGY JAISALMER THREE LIMITED SOLAR(1*300)	300	0	0	0	296	-	0	-	2.86749	2.64	2.64	110	-0.22749
ADANI HYBRID ENERGY JAISALMER THREE LIMITED WIND(1*75)	75	0	54	66	68	01:30	0	-	0.84561	0.15	0.15	6	-0.69561
ADANI HYBRID ENERGY JAISALMER TWO LIMITED SOLAR(1*299)	300	0	0	0	297	09:30	0	-	2.96912	2.76	2.76	115	-0.20912
ADANI HYBRID ENERGY JAISALMER TWO LIMITED WIND(1*75)	75	0	53	72	74	02:30	0	-	0.83046	0.11	0.11	5	-0.72046
ADANI JAISALMER ONE SEPL SOLAR(1*420)	420	0	0	0	394	12:18	0	-	3.27792	2.54	2.54	106	-0.73792
ADANI JAISALMER ONE SEPL WIND(1*105)	105	0	0	0	0	-	0	-	1.36821	1.37	1.37	57	0.00179
AYANA RENEWABLE THREE PVT LTD (1*300)	300	0	0	0	293	13:27	0	-	2.15433	2.19	2.19	91	0.03567
JUNIPER GREEN STELLAR PRIVATE LIMITED_S_FTG3	185	0	0	0	0	-	0	-	0.62717	0.63	0.63	26	0.00283
Sub-Total	3,708	0	538	650	-	-	-	-	33.91612	30.81	30.81	1,285	-3.10612
Total	29,909	1,637	1,900	1,531					207.54699	200.97	200.58	8,360	-6.96699

STORAGE

Station/Constituents	Inst. Capacity (MW)	Declared Capacity (MW)	20:00 Peak MW	03:00 Off Peak MW	Day Peak (MW)	Day Peak Hrs	Min Generation (06:00-18:00) (MW)	Min Generation (06:00-18:00) Hrs	Day Energy SCHD (MU)	Day Energy Gross Gen(MU)	Day Energy Net Gen(MU)	AVG. MW	UI
PUMP STORAGE													
TEHRI PSP(4 * 250)	1,000	360	387	356	387	20:00	0	-	-1.02972	2.86	-0.89	-37	0.13972
Sub-Total	1,000	360	387	356	-	-	-	-	-1.02972	2.86	-0.89	-37	0.13972
BESS													
ACME SUN POWER PRIVATE LIMITED_BESS	167	0	0	0	0	-	0	-	0.1121	0.11	0.11	5	-0.0021
ACME SURYA POWER PRIVATE LIMITED_BESS	107	0	0	0	0	-	0	-	0.01828	0.02	0.02	1	0.00172
ACME SURYODAYA PRIVATE LIMITED_BESS	247	0	0	0	0	-	0	-	0.02515	0.02	0.02	1	-0.00515
JUNIPER GREEN STELLAR PRIVATE LIMITED_BESS_FTG4	180	0	0	0	0	-	0	-	0.16625	0.17	0.17	7	0.00375
JUNIPER GREEN COSMIC PRIVATE LIMITED_BESS	41	0	0	0	0	-	0	-	0.10026	0.1	0.1	4	-0.00026
RENEW SURYA ROSHNI PVT LTD_BESS	23	0	0	0	0	-	0	-	0.092	0.09	0.09	4	-0.002
Sub-Total	765	0	0	0	-	-	-	-	0.51404	0.51	0.51	22	-0.00404
Total	1,765	360	387	356					-0.51568	3.37	-0.38	-15	0.13568

Summary Section

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy Gross Gen	Day Energy Net Gen	Day AVG.
Total State Control Area Generation	72,230	37,443	35,885	983.07	929.9	38,746
J. Net Inter Regional Exchange [Import (+ve)/Export (-ve)]		5,332	6,357	433.23	433.23	17,668
Inter National Exchange with Nepal[Import (+ve)/Export (-ve)]		45	31	-1.8	-1.8	-42
Total Regional Availability(Gross)	131,602	65,952	59,883	2,047.35	1,966.51	81,594

Total Hydro Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy Gross Gen	Day Energy Net Gen	Day AVG.
Regional Entities Hydro	14,722	11,312	7,555	197.4	191.33	7,974
State Control Area Hydro	8,155	4,961	5,066	109.08	108.9	4,539
Total Regional Hydro	22,877	16,273	12,621	306.48	300.23	12,513

Total Renewable Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy Gross Gen	Day Energy Net Gen	Day AVG.
Regional Entities Renewable	27,959	538	650	176.14	176.03	7,336
State Control Area Renewable	17,736	1,853	2,697	152.97	152.95	6,373
Total Regional Renewable	45,695	2,391	3,347	329.11	328.98	13,709

Total Solar Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy Gross Gen	Day Energy Net Gen	Day AVG.
Regional Entities Solar	26,989	0	0	165.71	165.6	6,900
State Control Area Solar	12,614	111	43	80.71	80.71	3,362
Total Solar	39,603	111	43	246.42	246.31	10,262

Total Wind Generation

	Inst. Capacity	PEAK	OFF-PEAK	Day Energy Gross Gen	Day Energy Net Gen	Day AVG.
Regional Entities Wind	970	538	650	10.43	10.43	436
State Control Area Wind	4,328	1,578	2,486	64.38	64.38	2,683
Total Wind	5,298	2,116	3,136	74.81	74.81	3,119

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00 (MW)	03:00 MW	Maximum Interchange (MW) Import (MW)	Maximum Interchange (MW) Export (MW)	Import in MU	Export in MU	NET
Import/Export between EAST REGION and NORTH REGION								
1	132KV-Chandauli (UP)-Karmnasa(PG)	-	-	-	-	-	-	-
2	132KV-Myorepur (UP)-Nagar Untari	-	-	-	-	0	0.13	-0.13
3	132KV-Rihand (UP)-Garhwa(CG)	35	33	-	31	0	0.71	-0.71
4	132KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	-	-	-
5	220KV-Sahupuri (UP)-Karamnasa(PG)	-	-	-	-	2.12	0	2.12
6	400KV-Allahabad (PG)-Sasaram(PG)	-	-	-	-	0.36	0	0.36
7	400KV-Balia (PG)-Biharsharif(PG)	-	-	-	-	0	2.33	-2.33
8	400KV-Balia (PG)-Naubatpur(Bihar)	-	-	-	-	1.12	0	1.12
9	400KV-Balia (PG)-Patna(PG)	-	-	-	-	13.52	0	13.52
10	400KV-Gorakhpur (UP)-Motihari(DMT)	438	496	536	0	7.82	0	7.82
11	400KV-Gorakhpur (UP)-Muzaffarpur(PG)	503	616	694	162	6.74	0	6.74
12	400KV-Sahupuri (UP)-Biharsharif(PG)	-	-	-	-	1.7	0	1.7
13	400KV-Varanasi (PG)-Sasaram(PG)	-52	-67	121	0	1.89	0	1.89
14	765KV-Balia (PG)-Gaya(PG)	-	-	-	-	14.13	0	14.13

Import/Export between EAST REGION and NORTH REGION								
15	765KV-Sasaram (PG)-Fatehpur(PG)	-	-	-	-	1.72	0	1.72
16	765KV-Varanasi (PG)-Gaya(PG)	-655	-728	861	1,125	2.84	0	2.84
17	HVDC800KV-Agra (PG)-Alipurduar(PG)	-	-	-	-	-	-	-
Sub-Total EAST REGION		269	350	2,212	1,318	53.96	3.17	50.79
Import/Export between NORTH_EAST REGION and NORTH REGION								
1	HVDC800KV-Agra (PG)-Biswanath Charialli(PG)	-	-	-	-	13.98	0	13.98
Sub-Total NORTH_EAST REGION		0	0	0	0	13.98	0	13.98
Import/Export between WEST REGION and NORTH REGION								
1	132KV-Lalitpur (UP)-Rajghat(MP)	-	-	-	-	-	-	-
2	132KV-Sawai Madhopur (RJ)-Gwalior(MP)	-	-	-	-	-	-	-
3	220KV-Auraiya (NT)-Malanpur(PG)	-21	-21	-	42	0	0.01	-0.01
4	220KV-Auraiya (NT)-Mehgaon(PG)	-	-	-	-	-	-	-
5	220KV-Modak (RJ)-Bhanpura(MP)	45	53	54	25	1.01	0	1.01
6	220KV-Ranpur (RS)-Bhanpura(MP)	93	100	113	68	2.13	0	2.13
7	400KV-Bhinmal (PG)-Zerda(PG)	-	-	-	-	-	-	-
8	400KV-Chittorgarh 765 (PG)-Neemuch (WR)	-415	-435	652	289	6.2	0	6.2
9	400KV-Kankroli (RJ)-Zerda(PG)	-	-	-	-	5.35	0	5.35
10	400KV-RAPS C (NP)-Sujalpur	222	290	321	630	0.37	1	-0.63
11	400KV-Rihand (NT)-Vindhyachal(PG)	-	-	-	-	-	-	-
12	765KV-0rai-Gwalior (PG)	-442	-277	0	-625	0	6.89	-6.89
13	765KV-0rai-Jabalpur	2,700	2,228	2,907	0	41.22	0	41.22
14	765KV-0rai-Satna	1,194	1,027	1,211	0	20.84	0	20.84
15	765KV-Agra (PG)-Gwalior(PG)	-	-	-	-	36.57	0	36.57
16	765KV-Chittorgarh-Banaskata D/C	-1,408	-846	2,233	508	29.69	0	29.69
17	765KV-Dausa (PG)-Gwalior(PG)	-	-	-	-	19.94	0	19.94
18	765KV-Varanasi (PG)-Vindhyachal(PG)	-3,206	-2,310	3,517	0	66.29	0	66.29
19	HVDC500KV-Mohindergarh (JH)-Mundra(JH)	1,701	1,498	1,703	0	38.7	0	38.7
20	HVDC500KV-Vindhyachal (PG)-Vindhaychal B/B	100	200	500	0	2.99	0	2.99
21	HVDC800KV-Kurukshetra (PG)(PG)-Champa(PG)	4,500	4,500	4,500	0	105.06	0	105.06
Sub-Total WEST REGION		5,063	6,007	17,711	937	376.36	7.9	368.46
TOTAL IR EXCHANGE		5,332	6,357	19,923	2,255	444.3	11.07	433.23

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

	ISGS+GNA+URS schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total IR Schedule	Total IR Actual	NET IR UI
NR-ER	114.78	11.47	0	2.41	0	108.17	50.79	-57.38
NR-NORTH_EAST REGION	0	0	0	0	0	0	13.98	13.98
NR-WR	205.7	95.24	0	10.13	0	335.9	368.46	32.56
Total	320.48	106.71	0	12.54	0	444.07	433.23	-10.84

5.Inter National Exchange with Nepal [Import (+ve)/Export(-ve)] [Linkwise]

Element	Peak	Off-Peak	Maximum Interchange(MW)		Energy (MU)		Net Energy	Schedule Energy
	MW	MW	Import	Export	Import	Export	(MU)	(MU)
132KV-Tanakpur(NH)-Mahendranagar(PG)	45	31	25.104	67	0.03	0.89	-0.87	0
132KV-Nautanwa (UP)-Mainhiya (Nepal)						0.93	-0.93	0

5.Frequency Profile

RANGE(Hz)	< 49.2	< 49.7	< 49.8	< 49.9	< 50.0	>= 49.9 - <= 50.05	> 50.05 - <= 50.1	> 50.1 - <= 50.2	> 50.2	> 50.05
%	0	0	.08	7.51	43.98	69.22	17.58	5.31	.37	23.26

<----------Frequency (Hz)---------->

Maximum		Minimum		Average	Freq Variation	Standard	Freq. in 15 mnt blk		Freq Dev Index
Frequency	Time	Frequency	Time	Frequency	Index	Deviation	Max.	Min.	(% of Time)
50.257	18:03:40	49.79	12:44:50	50.003	0.048	0.069	50.137	49.833	30.78

6.Voltage Profile: 400kV

	Maximum		Minimum		Voltage (in %)				Voltage Deviation Index
					< 380	< 390	> 420	> 430	(% of time)
Abdullapur(PG) - 400KV	412	02:50	397	12:40	0	0	0	0	0
Amritsar(PG) - 400KV	406	03:55	381	14:45	0	31.6	0	0	0
Ballabgarh(PG) - 400KV	412	07:00	381	12:10	0	14.93	0	0	0
Bareilly II(PG) - 400KV	413	23:50	392	12:10	0	0	0	0	0
Bareilly(UP) - 400KV	414	23:50	393	12:10	0	0	0	0	0

Baspa(HP) - 400KV	407	02:30	390	14:45	0	0	0	0	0
Bassi(PG) - 400KV	417	07:55	389	23:20	0	2.78	0	0	0
Bawana(DTL) - 400KV	411	07:25	389	12:10	0	1.39	0	0	0
Dadri HVDC(PG). - 400KV	409	07:25	383	12:10	0	12.15	0	0	0
Gorakhpur(PG) - 400KV	417	07:50	392	19:35	0	0	0	0	0
Hisar(PG) - 400KV	418	04:00	386	12:40	0	5.56	0	0	0
Kanpur(PG) - 400KV	416	08:00	395	22:10	0	0	0	0	0
Kashipur(UT) - 400KV	416	23:50	405	12:10	0	0	0	0	0
Kishenpur(PG) - 400KV	413	23:55	396	12:40	0	0	0	0	0
Moga(PG) - 400KV	410	03:50	385	12:40	0	13.19	0	0	0
Nallagarh(PG) - 400KV	407	02:30	390	14:45	0	0	0	0	0
Rihand HVDC(PG) - 400KV	398	14:05	390	21:35	0	0	0	0	0
Rihand(NT) - 400KV	401	09:40	394	23:20	0	0	0	0	0

6.1 Voltage Profile: 765kV

	Maximum		Minimum		Voltage (in %)				Voltage Deviation Index
					< 728	< 742	> 800	> 820	
Anta RS(RJ) - 765KV	792	15:40	764	22:25	0	0	0	0	0
Balia(PG) - 765KV	789	07:55	749	19:50	0	0	0	0	0
Bareilly II(PG) - 765KV	784	07:55	748	12:10	0	0	0	0	0
Bhiwani(PG) - 765KV	792	19:00	747	12:15	0	0	0	0	0
Fatehpur(PG) - 765KV	797	08:00	758	23:05	0	0	0	0	0
Jhatikara(PG) - 765KV	785	07:00	736	12:10	0	5.56	0	0	0
Lucknow II(PG) - 765KV	786	08:00	745	19:50	0	0	0	0	0
Meerut(PG) - 765KV	790	07:15	737	12:10	0	2.43	0	0	0
Moga(PG) - 765KV	794	19:00	733	12:45	0	5.56	0	0	0
Phagi(RJ) - 765KV	796	08:00	761	22:30	0	0	0	0	0
Unnao(UP) - 765KV	787	08:00	752	22:15	0	0	0	0	0

7(A). Short-Term Open Access Details:

State	Off- Peak Hours (03:00)										Peak Hours (20:00)									
	T-GNA Bilateral(MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX RTM (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXI RTM (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX RTM (MW)	Bilateral (MW)	IEX GDAM (MW)	IEX DAM (MW)	IEX RMT (MW)	PXIL GDAM (MW)	PXIL DAM (MW)	PXIL RMT (MW)	HPX GDAM (MW)	HPX DAM (MW)	HPX RTM (MW)
PUNJAB	2,894.18	0	0	0	0	0	0	0	0	0	2,820.49	0.74	2.67	7.72	0	0	0	0	0	0
HARYANA	458.91	3.32	333.19	-399.9	0	0	0	0	0	0	1,175.69	1.43	5.15	-1,036.2	0	0	0	0	0	0
RAJASTHAN	216.28	-35.64	-33.44	-205.31	0	0	0	0	0	0	552.32	-50.59	-46.15	37.88	0	0	0	0	0	0
DELHI	1,866.8	0	-284	27.76	0	0	0	0	0	0	2,373.95	0.14	-453.53	-330.07	0	0	0	0	0	0
UTTAR PRADESH	1,444.26	95.5	166.53	818.54	0	0	0	0	0	0	1,010.11	5.68	368.67	2,082.69	0	0	0	0	0	0
UTTARAKHAND	314.95	-21.4	41.48	-30.9	0	0	0	0	0	0	605.61	-17.7	84.59	16.95	0	0	0	0	0	0
HIMACHAL PRADESH	-430.47	-7.9	-37.55	-196.76	0	0	0	0	0	0	-479.37	-8.1	-189.51	-70.48	0	0	0	0	0	0
J&K(UT) & LADAKH(UT)	-16	-55.3	-15	205.29	0	0	0	0	0	0	-216	-55.3	-15	494.22	0	0	0	0	0	0
CHANDIGARH	0	0	-40	-8	0	0	0	0	0	0	79.75	0	-95	0	0	0	0	0	0	0
RAILWAYS_NR ISTS	0	57.78	44.76	0	0	0	0	0	0	0	0	6.42	23.11	64.63	0	0	0	0	0	0
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL	6,748.91	36.36	175.97	210.72	0	0	0	0	0	0	7,922.55	-117.28	-315	1,267.34	0	0	0	0	0	0

State	Day Energy (MU)					
	GNA schedule	T-GNA Bilateral (MW)	GDAM Schedule	DAM Schedule	RTM Schedule	Total (MU)
PUNJAB	114.34	69.53	0.06	0.07	31.93	215.93
HARYANA	182.17	16.87	0.99	5.37	-1.38	203.82
RAJASTHAN	106.13	7.14	-0.64	-18.75	-7.54	86.35
DELHI	103.1	49.02	0.19	-4.02	-0.44	147.85
UTTAR PRADESH	247.11	13.35	1.37	8.11	16.8	287.12
UTTARAKHAND	30.14	8.2	-0.36	3.09	0.31	41.38
HIMACHAL PRADESH	14.59	-6.23	0.52	-2.49	-1.44	4.95
J&K(UT) & LADAKH(UT)	30.3	-1.28	-0.9	0.79	0.85	29.76
CHANDIGARH	7.44	0.42	0.05	0.26	0.17	8.33
RAILWAYS_NR ISTS	2.55	0	0.48	0.63	0.44	4.1
BULK CONSUMER_NR ISTS	1.75	0.08	0	0	0	1.83
TOTAL	839.62	157.1	1.76	-6.94	39.7	1,031.42

7(B). Short-Term Open Access Details

State	GNA schedule		T-GNA Bilateral (MW)		IEX GDAM (MW)		PXI GDAM (MW)		HPX GDAM(MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	5,270.58	4,159.96	2,987.04	2,815.37	29.84	0	0	0	0	0
HARYANA	8,402.71	6,387	1,289.1	436	105.5	0	0	0	0	0
RAJASTHAN	5,826.2	2,529.14	592.06	117.98	29.26	-72.79	0	0	0	0
DELHI	4,906.62	3,628.85	2,777.03	1,468.61	227.09	0	0	0	0	0
UTTAR PRADESH	11,508.67	8,973.43	1,657.26	-37.67	221.28	-29.05	0	0	0	0
UTTARAKHAND	1,373.65	1,037.66	605.7	42.62	-3	-22.7	0	0	0	0
HIMACHAL PRADESH	955.17	417.74	-63.97	-479.37	73.35	-8.1	0	0	0	0
J&K(UT) & Ladakh(UT)	1,612.24	702.75	-8	-216	-9	-55.3	0	0	0	0
CHANDIGARH	375.12	190.77	79.75	0	53.28	0	0	0	0	0
RAILWAYS_NR ISTS	120.63	97.68	0	0	84.7	0	0	0	0	0
BULK CONSUMER_NR ISTS	-	-	-	-	-	-	-	-	-	-

State	IEX DAM (MW)		PXI DAM(MW)		HPX DAM (MW)		IEX RTM (MW)		PXI RTM (MW)		HPX RTM (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
PUNJAB	152.18	0	0	0	0	0	3,005.04	-900	0	0	0	0
HARYANA	1,215.52	-48.81	0	0	0	0	771.76	-1,295.85	169.3	169.3	169.3	0
RAJASTHAN	42.57	-2,982.98	0	0	0	0	859.48	-2,248.8	255.37	255.37	255.37	0
DELHI	337.64	-761	0	0	0	0	919.22	-877	0	0	0	0
UTTAR PRADESH	907.43	-182.87	0	0	0	0	2,116.55	-171.42	17	17	17	0
UTTARAKHAND	528.75	0.01	0	0	0	0	235.3	-218.92	0	0	0	0
HIMACHAL PRADESH	11.76	-352.65	0	0	0	0	285.3	-325.04	0	0	0	0
J&K(UT) & LADAKH(UT)	226.18	-15	0	0	0	0	544.48	-1,360	0	0	0	0
CHANDIGARH	159.18	-95	0	0	0	0	52.09	-35	0	0	0	0
RAILWAYS_NR ISTS	86.53	0	0	0	0	0	113.83	0	0	0	0	0
BULK CONSUMER_NR ISTS	-	-	-	-	-	-	-	-	-	-	-	-

8.Major Reservoir Particulars

RESERVOIR	Parameters			Present Parameters		LAST YEAR		LAST DAY	
	MDDL (Mts)	FRL (Mts)	Energy Content at FRL	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)	Inflow (m3/s)	Usage (m3/s)
Bhakra	445.62	513.59	1,728.8	480.52	475	474.1	335	445.25	651.97
Chamera-I	748.75	760	753.95	756.52	7	-	-	206.15	203.77
Gandhisagar	381	399.9	725	-	-	-	-	-	0
Jawahar Sagar	295.96	298.7	2.01	-	-	-	-	-	0
Koteshwar	598.5	612.5	610.73	609.9	5	611.55	5	121.12	103.92
Pong	384.05	426.72	1,084	404.62	328	393.71	107	56.72	330.32
RPS	343.81	352.81	175.66	-	-	-	-	-	0
RSD	487.91	527.91	390.3	510.39	221	506.95	185	24.5	372.7
Rihand	252.98	268.22	860.5	-	-	-	-	-	0
Tehri	740.04	830	1,164.11	741.54	9	741.83	10	175.6	121
TOTAL	-	-	-	-	1,045	-	642	1,029.34	1,783.68

9. System Reliability Indices(Violation of TTC and ATC):

(i)%age of times N-1 Criteria was violated in the inter and intra regional corridors	
WR	0
ER	0
Simultaneous	0
Delhi	0
Rajasthan	0
UP	0
Punjab	0
Haryana	0

ii)%age of times ATC violated on the inter and intra regional corridors

WR	3.47
ER	0
Simultaneous	2.08
Delhi	0
Rajasthan	2.78
UP	0
Punjab	3.13
Haryana	0

iii)%age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand-Dadri	0

10. Zero Crossing Violations

State	No. of violations(Maximum 15 in a day)	Maximum number of continuous blocks without sign change
CHANDIGARH	0	1
DELHI	6	24
HARYANA	3	16
HIMACHAL PRADESH	3	12
J&K(UT) & Ladakh(UT)	8	16
PUNJAB	7	15
RAJASTHAN	9	22
UTTAR PRADESH	5	13
UTTARAKHAND	7	24

11. NCR's and Ladakh Power Supply Position(based on SCADA data)

	Inst Capacity	20:00	03:00	Day Peak			
Station/Constituents	(MW)	Peak MW	Off Peak MW	MW	HRS	Net MU	AVG MW
NCR_GENERATION	9225	5,142	4,245	6616	22:15:00	110.78	4,616
NCR_DRAWAL	-	15,389	12,821	15975	22:45:00	313.99	13,083
NCR_DEMAND	-	20,532	17,067	22451	21:45:00	424.78	17,699
LADAKH_DEMAND	-	20	-5	21	20:15:00	0.05	2

12. RE/Load Curtailment details

	Load Curtailment (Shortage)			RE Curtailment				
State	Energy	Maximum	At the time of maximum demand	Wind		Solar		Reason
	MU	MW	MW	Max MW	Energy(MU)	Max MW	Energy(MU)	
PUNJAB	0	0	0	0	0	0	0	
HARYANA	0	0	0	0	0	0	0	
RAJASTHAN	0	0	0	0	0	0	0	
DELHI	0	0	0	0	0	0	0	
UTTAR PRADESH	0	0	0	0	0	0	0	
UTTARAKHAND	0	0	0	0	0	0	0	
HIMACHAL PRADESH	0	0	0	0	0	0	0	
J&K(UT) & Ladakh(UT)	0.959	362	0	0	0	0	0	
CHANDIGARH	0	0	0	0	0	0	0	
RAILWAYS_NR ISTS	0	0	0	0	0	0	0	
BULK CONSUMER_NR ISTS	0	0	0	0	0	0	0	

13.Grid Disturbance / Any Other Significant Event:

14.Weather Conditions :

15.Synchronisation of new generating units :

16.Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / /substation :

227(ALF CKT2) MAIN BAY - 220 KV BIKANER_2 (PBTSL) - BUS 1 (PBTSL) AT 220 KV BIKANER_2 (PBTSL)-Charged at 22:26 Hrs

17.Instances of persistent/significant non-complaint with the grid code

18.Constraints and instances of congestion in the transmission system

19.Remarks :

No Records Found

Note: Data(regarding drawal,generation, shortage , inter-regional flows and reservoir levels)of the constituents filled in the report are as per last furnished data by the respective state/constituent to NRLDC.
***Unscheduled Load Shedding carried out by Uttar Pradesh.**

Shift In Charge