

Power Supply Position Report For

10-Jun-2026

1. Regional Availability/Demand:

Evening Peak (20:00) MW				Off-Peak (03:00) MW				Day Energy (Net MU)	
Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage	Requirement	Freq (Hz)	Demand Met	Shortage #
54506	0	54506	50.05	47070	0	47070	50.08	1277.12	0

2(A) State's Load Deals (At State Periphery) in MUs:

State	State's Control Area Generation (Net MU)						Net SCH	Drawal	UI	Availability	Demand Met	Shortage #
	THERMAL	HYDRO	GAS/DIESEL /NAPTHA	WIND	SOLAR	OTHERS	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)	(Net Mu)
Andhra Pradesh	118.55	4.68	0	48.13	16.86	2.18	70	67.11	-2.89	260.4	257.51	0
Karnataka	90.63	10.46	0	54.37	30.19	6.08	65.24	60.46	-4.78	256.97	252.19	0
Kerala	0	16.31	0	0.56	0.85	0.3	66.37	67.63	1.26	84.39	85.65	0
Puducherry	0	0	0.36	0	0.06	0	10.79	10.42	-0.37	11.21	10.84	0
Tamil Nadu	79.68	9.29	3.35	68.22	46	9.05	221.53	218.9	-2.63	437.12	434.49	0
Telangana	98.07	1.73	0	1.51	24.2	5.38	106.65	105.55	-1.1	237.54	236.44	0
Total	386.93	42.47	3.71	172.79	118.16	22.99	540.58	530.07	-10.51	1287.63	1277.12	0

2(B) State's Demand Met in MWs and day energy forecast and deviation particulars

State	Evening Peak (20:00) MW			Off-Peak (03:00) MW			Average Demand	Day Energy (Net MU)	
	Demand Met	Shortage	Requirement	Demand Met	Shortage	Requirement	(MW)	Forecast (LGBR)	Deviation [Forecast - Consumption]
Andhra Pradesh	10210	0	10210	10457	0	10457	10727	261	-3.49
Karnataka	10516	0	10516	8276	0	8276	10511	257.38	-5.19
Kerala	4449	0	4449	2940	0	2940	3712	86.32	-0.67
Puducherry	509	0	509	420	0	420	443	12	-1.16
Tamil Nadu	19445	0	19445	16683	0	16683	18671	441	-6.51
Telangana	9377	0	9377	8294	0	8294	10075	225	11.44
Total	54506	0	54506	47070	0	47070	54139	1282.7	-5.58

2(C) State's Demand Met in MWs (maximum demand met and Maximum requirement of the day details)

State	Maximum Demand, corresponding shortage and requirement details for the day				Maximum requirement, corresponding shortage and demand details for the day				ACE			
	Maximum Demand Met	Time	Shortage at maximum demand	Requirement at the max demand met	Demand Met at maximum requiremnet	Time	Shortage at maximum Requirement	Maximum Requirement	Maximum ACE(MW)	Time	Minimum ACE(MW)	Time
Andhra Pradesh	12972	14:40	0	12972	12972	14:40	0	12972	875.19	20:05	-843.91	01:04
Karnataka	12609	10:00	0	12609	12609	10:00	0	12609	1188.6	11:00	-744.76	06:45
Kerala	4654	19:16	0	4654	4654	19:16	0	4654	323.62	20:45	-281.22	13:41
Puducherry	552	21:45	0	552	552	21:45	0	552	142.83	01:19	-34.16	23:59
Tamil Nadu	20529	22:00	0	20529	20529	22:00	0	20529	2526.47	10:41	-1011.51	06:46
Telangana	12029	15:32	0	12029	12029	15:32	0	12029	601.3	18:46	-426.62	15:02
Region	59163	16:01	0	59163	59163	16:01	0	59163	2870.42	18:01	-2496.79	07:29

3(A) State Entities Generation:

ANDHRA PRADESH

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
HINDUJA POWER CORPORATION LTD (2*520)	1040	1014	1015	1034	19:09	546	08:27	21.57	20.37	849
KRISHNAPATTANAM (3*800)	2400	1704	1715	1970	02:22	1270	17:04	37.14	34.8	1450
RAYALASEEMA TPP (5*210 + 600)	1650	1354	987	1383	20:04	910	11:26	26.36	23.8	992
SEIL P2 Unit-2 (1*660)	660	0	0	0	00:00	0	06:00	0	0	0
VIJAYAWADA TPS (6*210 + 500 + 800)	2560	2063	1934	2129	23:39	1353	10:44	43.23	39.59	1650

Total Thermal	8310	6135	5651	-	-	-	-	128.3	118.56	4941
DONKARAYI (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
HAMPI & T.B.DAM (8 * 9)	57	0	0	0	00:00	0	06:00	0	0	0
LOWER SILERU (4*115)	460	13	248	313	22:41	13	06:04	3.2	3.18	133
MACHKUND (3 * 17 + 3 * 23)	84	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNASAGAR TAILPOND (2*25)	50	0	0	0	00:00	0	06:00	0	0	0
NSR RT.CANAL.P.H (3*30)	90	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM RBPB (7*110)	770	0	0	0	00:00	0	06:00	0	0	0
UPPER SILERU (4*60)	240	0	50	147	12:08	0	06:00	1.5	1.5	63
OTHER HYDEL	124	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	1900	13	298	-	-	-	-	4.7	4.68	196
GAUTAMI CCPP (2*145 + 174)	464	0	0	0	00:00	0	06:00	0	0	0
GMR (BARG) (1 * 237)	237	0	0	0	00:00	0	06:00	0	0	0
JEGURUPADU (GAS) (2*45.8 + 49.9 + 75.5)	217	0	0	0	00:00	0	06:00	0	0	0
Jegrupadu Ext. (1 * 220)	220	0	0	0	00:00	0	06:00	0	0	0
KONASEEMA CCPP (145 + 140 + 165)	450	0	0	0	00:00	0	06:00	0	0	0
LANCO (GAS) (2*115 + 121)	351	0	0	0	00:00	0	06:00	0	0	0
RELIANCE ENERGY LTD. (GAS) (140 + 80)	220	0	0	0	00:00	0	06:00	0	0	0
SPECTRUM (GAS) (46.8 + 2*46.1 + 68.8)	208	0	0	0	00:00	0	06:00	0	0	0
VEMAGIRI POWER GENERATION LTD.(GAS) (233 + 137)	370	0	0	0	00:00	0	06:00	0	0	0
VIJESWARAM GTS (2*33 + 34 + 112.5 + 59.5)	272	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	27	0	0	0	00:00	0	06:00	0	0	0
Total Gas	3036	0	0	-	-	-	-	0	0	0
WIND	4102	2266	2049	2864	21:31	1663	07:28	48.13	48.13	2005
SOLAR	3965	2	0	2395	11:52	19	06:00	16.86	16.86	703
OTHERS	619	118	118	160	13:35	112	14:37	2.18	2.18	91
Total ANDHRA PRADESH	21932	8534	8116	-	-	-	-	200.17	190.41	7936

TELANGANA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
BHADRADRI TPS (4*270)	1080	845	865	901	07:23	515	10:49	19.38	17.45	727
KAKATIYA ST1&ST2 (500 + 600)	1100	999	1021	1070	06:41	539	11:52	22.26	20.95	873
KOTHAGUDEM TPS (2*250 + 500 + 800)	1800	1193	1073	1391	06:26	912	12:04	27.89	25.85	1077
RAMAGUNDAM-B (1*62.5)	63	0	0	0	00:00	0	06:00	0	0	0
SINGARENI TPS (2*600)	1200	1118	1128	1159	02:45	0	11:45	24.56	23.03	960
YADADRI (4*800)	3200	530	489	537	17:51	377	13:23	11.75	10.79	450
Total Thermal	8443	4685	4576	-	-	-	-	105.84	98.07	4087
L JURALA (6*40)	240	0	0	0	00:00	0	06:00	0	0	0
NAGARJUNA SAGAR (110 + 7*100.8)	816	0	0	621	00:02	0	06:00	1.74	1.72	72
NAGARJUNA SAGAR (Pump) (110 + 7*100.8)	816	0	0	326	10:30	0	11:45	3.18	3.18	133
NIZAMSAGAR (2*5)	10	0	0	0	00:00	0	06:00	0	0	0
NSR LT.CANAL.P.H (2*30)	60	0	0	0	00:00	0	06:00	0	0	0
POCHAMPAD (4*9)	36	0	0	0	00:00	0	06:00	0	0	0
PULICHINTALA (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
SINGUR (2*7.5)	15	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPB (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
SRISAILAM LBPB(Pump) (6*150)	900	0	0	0	00:00	0	06:00	0	0	0
U JURALA (6*39)	234	0	0	220	05:41	0	06:00	0.01	0.01	0
OTHER HYDEL	51	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	2482	0	0	-	-	-	-	1.75	1.73	72
WIND	128	45	93	102	00:23	14	14:20	1.51	1.51	63
SOLAR	3848	0	0	2799	12:04	28	06:00	24.2	24.2	1008
OTHERS	252	224	224	224	00:00	224	06:00	5.38	5.38	224
Total TELANGANA	15153	4954	4893	-	-	-	-	138.68	130.89	5454

KARNATAKA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Bellary TPS (2*500 + 700)	1700	1492	888	1508	05:25	879	07:30	28.28	26.42	1101
JINDAL (2*130 + 4*300)	1460	895	969	1112	18:16	592	09:24	20.8	19.03	793
Jindal (Excl. Captive Consumption) (2 * 130 + 4 * 300)	1460	335	256	477	18:48	0	06:45	5.8	5.8	242
Raichur TPS (7*210 + 250)	1720	914	724	980	22:46	705	14:48	21.19	19.01	792
UPCL (2*600)	1200	658	606	1120	21:33	582	12:38	17.57	16.4	683
YERAMARAS TPS (2*800)	1600	1107	859	1284	05:47	808	15:44	24.64	23	958
Total Thermal	7680	4506	3333	-	-	-	-	97.48	90.63	3776
Almatty (15 + 5*55)	290	0	0	0	00:00	0	06:00	0	0	0
Bhadra (2*12.1 + 7 + 2 + 6)	39	0	0	0	00:00	0	06:00	0	0	0
Ghataprabha (2*16)	32	0	0	0	00:00	0	06:00	0	0	0
JOG (MGHES) (4*21.6 + 4*13.2)	139	55	56	60	11:09	55	09:16	1.34	1.33	55
LINGANAMAKKI.P.H. (2*27.5)	55	8	8	8	10:24	0	14:56	0.17	0.15	6
Kadra (3*50)	150	0	0	100	07:25	0	06:00	0.16	0.15	6
Kodasalli (3*40)	120	30	0	36	08:39	0	06:00	0.26	0.25	10
MANI DAM.P.H. (2*4.5)	9	1	1	1	00:18	0	06:16	0.03	0.03	1
Munirabad (3*9 + 10)	37	0	0	0	00:00	0	06:00	0	0	0
NAGJHERI (135 + 5*150)	885	0	0	130	18:58	0	06:04	0.06	0.06	3
SHARAVATHI (10*103.5)	1035	332	228	568	19:33	212	12:17	6.49	6.43	268
Sharavati Tail Race (4*60)	240	108	0	208	07:15	0	06:00	0.49	0.48	20
SIVANSAMUDRAM (6*3 + 4*6)	42	0	0	0	00:00	0	06:00	0	0	0
Supa (2*50)	100	0	0	0	00:00	0	06:00	0	0	0
U JURALA (6*39)	234	0	0	0	00:00	0	06:00	0	0	0
Varahi UGPH (4*115)	460	57	51	252	19:37	45	07:59	1.62	1.59	66
OTHER HYDEL	143	0	0	0	00:00	0	06:00	0	0	0
Total Hydro	4010	591	344	-	-	-	-	10.62	10.47	435
OTHER GAS/NAPTHA/DIESEL	126	0	0	0	00:00	0	06:00	0	0	0
Total Gas	126	0	0	-	-	-	-	0	0	0
WIND	5676	2840	2214	2864	18:31	1765	07:45	54.37	54.37	2265
SOLAR	7171	0	0	4081	13:10	0	06:00	30.19	30.19	1258
OTHERS	1832	84	90	132	18:07	76	10:41	6.08	6.08	253
Total KARNATAKA	26495	8021	5981	-	-	-	-	198.74	191.74	7987

KERALA

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Idamalayar (2*37.5)	75	49	0	50	19:55	0	06:00	0.2	0.19	8
Iddukki (6*130)	780	751	223	760	20:46	25	11:03	5.68	5.65	235
Kakkad (2*25)	50	24	17	39	21:52	0	06:00	0.47	0.47	20
KALLADA (2*7.5)	15	8	7	8	20:04	2	11:38	0.11	0.11	5
Kuttiyadi (3*25)	75	99	0	103	19:33	0	09:20	0.53	0.52	22
Lower Periyar (3*60)	180	163	0	165	19:00	0	06:00	1.35	1.34	56
Neriamangalam (3*17.5 + 25)	78	70	17	71	16:21	0	06:00	0.9	0.9	38
PALLIVASAL (3*5 + 3*7.5)	38	0	0	0	00:00	0	06:00	0	0	0
PALLIVASAL EXTENSION SCHEME (2*30)	60	49	39	59	15:29	18	08:41	1.05	1.05	44
Panniar (2*16.2)	32	0	0	0	00:00	0	06:00	0.18	0.18	8
PORINGALKUTHU (4*9)	36	51	16	52	17:45	10	15:33	0.65	0.64	27
Sengulam (4*12.8)	51	50	20	51	16:20	14	07:26	0.64	0.64	27
Sholayar (3*18)	54	53	0	53	19:51	0	06:00	0.34	0.34	14
Sabarigiri (4*55 + 2*60)	340	228	24	229	23:04	0	07:44	1.43	1.43	60
THOTTIYAR HEP (2*20)	40	38	38	40	06:58	18	07:37	0.73	0.73	30
OTHER HYDEL	230	151	0	211	21:52	0	06:00	2.12	2.12	88
Total Hydro	2134	1784	401	-	-	-	-	16.38	16.31	682
BRAHMAPURAM DGPP (DIESEL) (3*21.32)	64	0	0	0	00:00	0	06:00	0	0	0

BSES (NAPTHA) (3*40.5 + 35.5)	157	0	0	0	00:00	0	06:00	0	0	0
KOZHICODE DPP (DIESEL) (6*16)	96	0	0	0	00:00	0	06:00	0	0	0
MPS STEEL CASTINGS (1 * 10)	10	0	0	0	00:00	0	06:00	0	0	0
RGCCPP KAYAMKULAM (KSEB) - NTPC (2*116.6 + 126.38)	360	0	0	0	00:00	0	06:00	0	0	0
OTHER GAS/NAPTHA/DIESEL	22	0	0	0	00:00	0	06:00	0	0	0
Total Gas	709	0	0	-	-	-	-	0	0	0
WIND	70	10	8	16	11:54	1	13:35	0.56	0.56	23
SOLAR	1988	1	0	149	12:38	0	06:11	0.85	0.85	35
OTHERS	20	10	9	155	12:44	3	06:11	0.3	0.3	13
Total KERALA	4921	1805	418	-	-	-	-	18.09	18.02	753

TAMIL NADU

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
Mettur TPS (4*210 + 600)	1440	952	1210	1253	23:41	779	17:19	28.97	26.65	1110
NORTH CHENNAI TPS STG-III (1*800)	800	0	0	0	00:00	0	06:00	0	0	0
NORTH CHENNAI TPS STG-II (2*600)	1200	606	667	734	14:51	595	10:20	17.7	15.87	661
North Chennai TPS (3*210)	630	416	356	494	23:04	350	14:15	10.09	10.09	420
UDANGUDI(Infirm - 660MW)	0	306	306	306	00:00	306	06:00	8.12	7.34	306
OPG PGPL (2*77 + 80 + 180)	414	308	334	338	06:20	234	13:18	7.17	6.54	273
SEPC (1*525)	525	0	0	0	00:00	0	06:00	0	0	0
ST - CMS (1*250)	250	214	207	299	14:45	46	17:08	5.44	5	208
Tuticorin (5*210)	1050	373	383	389	13:41	268	16:04	9.14	8.2	342
Total Thermal	6309	3175	3463	-	-	-	-	86.63	79.69	3320
Kadamparai (4*100)	400	0	98	100	13:51	0	09:52	1.1	1.09	45
Kadamparai (Pump) (4*100)	400	0	0	0	00:00	0	06:00	0	0	0
Kodayar I (1*60)	60	0	0	0	00:00	0	06:00	0	0	0
Kodayar II (1*40)	40	40	40	40	00:00	40	06:00	0.94	0.93	39
Kundah I (3*20)	60	8	34	53	19:08	2	09:42	0.59	0.59	25
Kundah II (5*35)	175	18	108	177	14:59	12	14:23	1.54	1.52	63
Kundah III (3*60)	180	12	12	12	00:00	12	06:00	1.01	1	42
Kundah IV (2*50)	100	48	47	49	00:02	0	07:57	0.47	0.47	20
Kundah V (2*20)	40	20	20	20	00:00	8	15:37	0.23	0.23	10
Kundah VI (1*30)	30	0	0	31	11:20	0	06:00	0.02	0.01	0
Mettur Dam (4*12.5)	50	0	0	0	13:07	0	06:00	0.21	0.21	9
Mettur Tunnel (4*50)	200	0	0	0	00:00	0	06:00	0	0	0
Moyar (3*12)	36	28	28	28	15:26	2	16:43	0.48	0.48	20
PAPANASAM (4*8)	32	8	8	30	14:45	8	06:00	0.19	0.19	8
Periyar (4*35)	140	33	33	33	02:21	33	16:50	0.79	0.78	33
Pykara (3*6.65 + 11 + 2*14)	59	10	9	18	19:33	6	10:36	0.24	0.24	10
PYKARA ULTIMATE (3*50)	150	0	151	152	02:23	0	06:00	0.97	0.96	40
Sarkarpathy (1*30)	30	0	12	13	06:38	0	13:07	0.16	0.16	7
Servalar (1*20)	20	18	0	18	06:18	0	06:00	0.06	0.06	3
Sholayar I (2*42)	84	0	0	0	00:00	0	06:00	0	0	0
Sholayar II (1*25)	25	0	0	0	00:00	0	06:00	0	0	0
Suruliyar (1*35)	35	0	0	0	00:00	0	06:00	0	0	0
OTHER HYDEL	1826	31	12	489	06:43	1	12:45	0.38	0.38	16
Total Hydro	3772	274	612	-	-	-	-	9.38	9.3	390
BASIN BRIDGE (NAPTHA) (4*30)	120	0	0	0	00:00	0	06:00	0	0	0
KOVIL KALAPPAL (GAS) (70 + 37.88)	108	0	0	0	00:00	0	06:00	0	0	0
KUTTALAM (GAS) (64 + 37)	101	84	85	86	09:42	72	17:31	1.93	1.79	75
MADURAI POWER CL (DIESEL) (1 * 106)	106	0	0	0	00:00	0	06:00	0	0	0
P P NALLUR (NAPTHA) (1 * 330.5)	331	0	0	0	00:00	0	06:00	0	0	0
SAMALPATTY (DIESEL) (7 * 15.1)	106	0	0	0	00:00	0	06:00	0	0	0
VALATTUR(STG1&STG2) (2*60 + 35 + 32)	187	27	33	62	10:38	31	06:20	1.68	1.56	65
OTHER GAS/NAPTHA/DIESEL	362	0	0	0	00:00	0	06:00	0	0	0

Total Gas	1421	111	118	-	-	-	-	3.61	3.35	140
WIND	9495	3061	2129	4595	11:43	1561	07:23	68.22	68.22	2843
SOLAR	12065	0	0	6826	11:33	39	06:01	46	46	1917
OTHERS	2029	722	637	736	04:38	654	17:01	9.05	9.05	377
Total TAMIL NADU	35091	7343	6959	-	-	-	-	222.89	215.61	8987

PUDUCHERRY

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KARAIKAL POWER PLANT (GAS) (1 * 22.9 + 1 * 9.6)	33	15	15	15	00:00	15	06:00	0.38	0.36	15
Total Gas	33	15	15	-	-	-	-	0.38	0.36	15
SOLAR	20	0	0	10	12:44	0	06:00	0.06	0.06	3
Total PUDUCHERRY	53	15	15	-	-	-	-	0.44	0.42	18

3(B) Regional Entities Generation:

ISGS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KUDGI (3*800)	2400	1755	1280	2272	23:27	1243	15:15	37.04	34.47	1436
Neyveli TS I Expn (2*210)	420	123	311	318	03:13	138	17:39	5.86	5.26	219
Neyveli TS II (7*210)	1470	694	719	779	04:34	549	15:20	17.95	14.53	605
Neyveli TS II Expn (2*250)	500	0	0	0	00:00	0	06:00	0	0	0
NNTPS (2*500)	1000	650	653	696	05:33	529	14:29	15.58	13.65	569
NTPC-TELANGANA STPP (2*800)	1600	1507	1446	1556	06:55	776	11:10	31.31	29.28	1220
Ramagundam (3*200 + 4*500)	2600	2376	1477	2429	19:45	1322	11:11	43.83	40.8	1700
Simhadri Stage I (2*500)	1000	916	888	941	19:53	488	11:14	19.39	18.03	751
Simhadri Stage II (2*500)	1000	956	913	962	06:25	501	08:04	19.71	18.36	765
TALCHER ST2 (4*500)	2000	1389	1400	1584	00:25	778	09:34	32	29.84	1243
Total Thermal	13990	10366	9087	-	-	-	-	222.67	204.22	8508
KAIGA STG1 (2*220)	440	201	200	210	12:50	191	12:54	4.97	4.47	186
KAIGA STG2 (2*220)	440	444	446	451	00:00	439	10:48	11.3	10.34	431
KUDANKULAM (2*1000)	2000	1995	2004	2016	03:04	1972	16:46	49.09	46.17	1924
MAPS (2*220)	440	203	211	215	18:03	208	08:51	5.09	4.14	173
Total Nuclear	3320	2843	2861	-	-	-	-	70.45	65.12	2714
Total ISGS	17310	13209	11948	-	-	-	-	293.12	269.34	11222

JOINT VENTURE

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
NTPL (2*500)	1000	889	516	956	20:49	488	06:03	16.15	15.21	634
Vallur TPS (3*500)	1500	1318	1337	1370	02:22	729	11:07	29	26.96	1123
Total Thermal	2500	2207	1853	-	-	-	-	45.15	42.17	1757
Total JOINT VENTURE	2500	2207	1853	-	-	-	-	45.15	42.17	1757

IPP UNDER OPEN ACCESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
COASTAL ENERGEN (2*600)	1200	1164	1166	1176	02:58	642	10:47	23.34	21.73	905
IL&FS (2*600)	1200	996	992	1026	22:19	588	10:58	21.12	19.78	824
JINDAL POWER LIMITED (Simhapuri Unit) (4*150)	600	535	312	547	22:56	255	10:41	10.01	8.95	373
MEENAKSHI ENERGY LTD STAGE1 (2*150)	300	95	92	98	23:47	63	13:22	2.17	1.93	80
MEENAKSHI ENERGY LTD STAGE2 (2*350)	700	297	298	309	18:33	184	11:09	6.59	6.14	256
SEIL (2*660)	1320	1257	1129	1265	23:03	616	13:18	26.92	25.39	1058
SEIL-PROJECT2 (1*660)	660	621	629	632	01:58	293	11:04	13.5	12.57	524
Total Thermal	5980	4965	4618	-	-	-	-	103.65	96.49	4020

Greenko (6 * 240 + 2 * 120)	1680	1214	388	1228	19:54	0	07:29	10.62	10.55	440
GREENKO(Pump) (6 * 240 + 2 * 120)	1680	0	0	1566	11:03	0	06:00	12.15	12.18	508
Total Hydro	1680	1214	388	-	-	-	-	10.62	10.55	440
LKPPL ST2 (233 + 133)	366	0	0	0	00:00	0	06:00	0	0	0
LKPPL ST3 (2*233 + 2*133)	732	0	0	0	00:00	0	06:00	0	0	0
Total Gas	1098	0	0	-	-	-	-	0	0	0
Total IPP UNDER OPEN ACCESS	8758	6179	5006	-	-	-	-	114.27	107.04	4460

RENEWABLE WIND

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
GADAG_GreenInfra_W	55	0	0	0	00:00	0	06:00	0	0	0
GADAG_RSPL_W	202	227	201	246	18:45	89	11:26	4.4	4.4	183
GADAG_Serentica3_W	52	155	142	190	18:52	46	09:20	3.34	3.34	139
GADAG_VENA_W	133	0	0	0	00:00	0	06:00	0	0	0
GREEN INFRA	250	224	33	232	18:14	10	08:10	3.15	3.15	131
Hiriyur_Ostro	300	239	146	273	18:19	88	11:27	4.57	4.57	190
HIRIYUR_ZREPL_W	66	0	77	105	00:44	0	06:00	0.49	0.49	20
JSW RENEW ENERGY TWO LTD	300	207	171	284	17:22	63	06:03	4.51	4.51	188
KARUR_JSWRENEW_W	162	150	75	157	20:10	0	15:28	2.53	2.53	105
Karur_JSWRETwo_W	150	127	49	136	15:47	44	16:56	2.31	2.31	96
KARUR_TPVARDHAMAN_W	50	173	96	189	17:09	75	07:52	3.25	3.25	135
KOPPAL_AyanaSix_W	300	222	224	283	18:32	105	12:29	5.12	5.12	213
KOPPAL_Kleio_W	101	59	41	69	15:42	6	16:27	1.24	1.24	52
Koppal_RenewOjas_W	322	230	239	251	18:50	45	09:27	4.32	4.32	180
Koppal_RenewRoshni_W	286	229	168	271	18:46	69	08:58	3.96	3.96	165
KOPPAL_SRIIPL_W	79	157	166	174	21:31	83	10:15	3.43	3.43	143
Kurnool_AMGreen_W	304	227	208	284	22:54	104	07:13	4.93	4.93	205
MYTRA	250	166	114	221	13:29	25	07:54	3.29	3.29	137
ORANGE	200	177	26	188	18:33	1	07:28	2.43	2.43	101
PGLR_SAUPL_W	53	47	3	47	13:26	2	07:42	0.73	0.73	30
PGLR_SREPL	300	276	72	309	16:13	19	07:41	4.8	4.8	200
TuticorinJSWRenewW	540	326	432	490	17:35	282	08:14	9.16	9.16	382
VIVID SOLAIRE (BEETAM)	220	218	59	222	18:54	16	06:00	3.19	3.19	133
Total SR_Wind	4675	3836	2742	-	-	-	-	75.15	75.15	3128
Total RENEWABLE WIND	4675	3836	2742	-	-	-	-	75.15	75.15	3128

RENEWABLE SOLAR

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
ANP_AdaniAPSeven	250	0	0	218	13:20	2	06:00	1.25	1.25	52
ANP_ATHENA BIWADI	50	0	0	42	11:00	0	17:45	0.28	0.28	12
ANP_ATHENA HISAR	50	0	0	42	11:00	0	17:45	0.28	0.28	12
ANP_ATHENA KARNAL	50	0	0	42	11:00	0	17:45	0.28	0.28	12
ANP_AYANA	250	0	0	242	13:22	2	06:00	1.44	1.44	60
ANP_AZURE	50	0	0	35	11:00	1	06:00	0.27	0.27	11
ANP_IGS1	50	0	0	36	10:15	2	06:00	0.27	0.27	11
ANP_IGS2	50	0	0	43	12:00	2	06:00	0.31	0.31	13
ANP_NTPC	250	0	0	158	13:24	0	06:06	0.88	0.88	37
ANP_TATA	100	0	0	65	10:15	5	06:00	0.46	0.46	19
SPRING ANG ITRA	250	0	0	218	13:40	0	06:00	1.4	1.4	58
Total NP_KUNTA	1400	0	0	-	-	-	-	7.12	7.12	297
PVG_ADYAH	300	0	0	235	13:34	6	06:00	1.35	1.35	56
PVG_AMPLUS PAVAGADA	50	0	0	42	15:02	1	06:00	0.25	0.25	10
PVG_AMPLUS TUMKUR	50	0	0	40	13:39	1	06:00	0.25	0.25	10
PVG_AVAADA SOLAR	150	0	0	131	13:37	1	06:00	0.69	0.69	29

PVG_AVAADA SOLARISE	150	0	0	112	14:41	1	06:00	0.64	0.64	27
PVG_AZURE POWER EARTH	100	0	0	93	13:33	0	06:00	0.49	0.49	20
PVG_FORTUM FIN SURYA	100	0	0	90	13:37	1	06:00	0.41	0.41	17
PVG_IRCON_S	225	0	0	345	14:46	1	06:00	1.87	1.87	78
PVG_KREDL	50	0	0	39	13:32	1	06:00	0.23	0.23	10
PVG_PARAMPUJYA	150	0	0	114	13:41	1	06:00	0.61	0.61	25
PVG_RENEW TN2	50	0	0	47	13:34	1	06:00	0.24	0.24	10
PVG_SBG ENERGY	200	0	0	168	13:34	0	06:00	0.81	0.81	34
PVG_SPRING SOLAR INDIA	250	0	0	215	13:25	1	06:00	1.16	1.16	48
PVG_TATA RENEWABLES	400	0	0	308	13:31	1	06:00	1.62	1.62	68
PVG_YARROW	50	0	0	37	13:41	1	06:00	0.22	0.22	9
Total PAVAGADA	2275	0	0	-	-	-	-	10.84	10.84	451
GADAG_Serentica3_S	69	0	0	147	14:04	0	06:01	0.79	0.79	33
GADAG_VENA_S	31	0	0	0	00:00	0	06:00	0	0	0
GRT	150	0	0	148	13:30	0	06:00	0.73	0.73	30
HIRIYUR_ZREPL_S	94	0	0	93	13:15	0	06:00	0.51	0.51	21
KOPPAL_Kleio_S	105	0	0	71	13:36	0	06:06	0.36	0.36	15
KOPPAL_RenewOjas_S	81	0	0	81	13:25	0	06:00	0.28	0.28	12
KOPPAL_SRIIPL_S	188	0	0	156	09:30	0	06:04	0.8	0.8	33
KOPPAL_TPSAURYA_S	131	0	0	239	13:51	0	06:05	1.2	1.2	50
Kurnool3_SAE1_S	300	0	0	307	12:45	4	06:00	2.04	2.04	85
Kurnool3_SAE12_S	300	0	0	298	11:42	4	06:00	1.79	1.79	75
Kurnool_AMGreen_S	599	0	0	543	13:24	4	06:00	3.26	3.26	136
Kurnool_Greenko_S	300	0	0	467	12:02	6	06:00	2.78	2.78	116
NTPC ETTAYAPURAM SOLAR PLANT	230	0	0	234	13:43	0	06:15	1.1	1.1	46
RAMANGUNDAM (SOLAR)	100	0	0	96	12:29	0	06:00	0.72	0.72	30
SIMHADRI (SOLAR)	25	0	0	21	10:39	0	14:50	0.13	0.13	5
Total OTHER	2703	0	0	-	-	-	-	16.49	16.49	687
Total RENEWABLE SOLAR	6378	0	0	-	-	-	-	34.45	34.45	1435

RENEWABLE BESS

Station/Constituents	Inst. Capacity	19:00	03:00	Day Peak		Min Generation (06:00 to 18:00)		Day Energy		Avg
	(MW)	Peak MW	Off Peak MW	(MW)	Hrs	(MW)	Hrs	Gross (MU)	Net (MU)	(MW)
KOPPAL_RenewOjas_BESS (Discharge)	75	0	0	0	00:00	0	06:00	0	0	0
KOPPAL_RenewOjas_BESS (Charge)	75	1	1	75	00:26	0	09:08	0.07	0.07	3
Total SR_BESS	75	0	0	-	-	-	-	0	0	0
Total RENEWABLE BESS	75	0	0	-	-	-	-	0	0	0

Total ISGS IPP Thermal	22470	17538	15558	-	-	-	-	371.47	342.88	14285
Total State Thermal	30742	18501	17023	-	-	-	-	418.25	386.95	16124
Total ISGS IPP Hydro	1680	1214	388	-	-	-	-	10.62	10.55	440
Total State Hydro	14298	2662	1655	-	-	-	-	42.83	42.49	1775
Total Gas/Naptha/Diesel	6423	126	133	-	-	-	-	3.99	3.71	155
Total Nuclear	3320	2843	2861	-	-	-	-	70.45	65.12	2714
Total Wind	24146	12058	9235	-	-	-	-	247.94	247.94	10327
Total Solar	35435	3	0	-	-	-	-	152.61	152.61	6359
Total Others	4752	1158	1078	-	-	-	-	22.99	22.99	958
Total BESS	75	0	0	-	-	-	-	0	0	0

4(A) INTER-REGIONAL EXCHANGES (Import=(+ve) /Export =(-ve))

SL.No.	Element	20:00	03:00	Maximum Interchange (MW)		Import in MU	Export in MU	NET
		MW	MW	Import	Export			
Import/Export between SOUTH REGION and EAST REGION								
1	220KV-UPPER_SILERU-BALIMELA	0	0	0.0	-	0	0	0
2	400KV-GAZUWAKA-JEYPORE	0	0	0.0	-	0	0	0
3	765KV-SRIKAKULAM-ANGUL	1587	1530	2614.0	-	36.85	0	36.85

4	HVDC500KV-TALCHER-KOLAR_DC	1497	1855	1856.0	-	35.78	0	35.78
Sub-Total EAST REGION		3084	3385	-	-	72.63	0	72.63
Import/Export between SOUTH REGION and WEST REGION								
1	220KV-AMBEWADI-PONDA	0	0	0.0	-	0	0	0
2	220KV-AMBEWADI-XELDEM	83	66	-	94.0	0	1.81	-1.81
3	220KV-CHIKKODI-MUDASANGI	0	0	0.0	-	0	0	0
4	220KV-CHIKKODI-TALANGADE	0	0	0.0	-	0	0	0
5	220KV-LOWER_SILERU-BARSUR	0	0	0.0	-	0	0	0
6	400KV-BHADRAVTAHI-RAMAGUNDAM	927	926	-	937.0	0	22.23	-22.23
7	400KV-KUDGI_PG-KHOLAPUR_PG	1771	1524	-	2302.0	0	40.01	-40.01
8	765KV-NIZAMABAD-WARDHA	546	567	2128.0	-	18.9	0	18.9
9	765KV-RAICHUR_PG-SHOLAPUR	797	539	-	1618.0	0	10.27	-10.27
10	765KV-WARANGAL(NEW)-WARORA	691	805	2424.0	-	23.35	0	23.35
11	HVDC800KV-RAIGARH HVDC-PUGALUR HVDC	563	567	1446.0	-	16.68	0	16.68
Sub-Total WEST REGION		5378	4994	-	-	58.93	74.32	-15.39
TOTAL IR EXCHANGE		8462	8379	-	-	131.56	74.32	57.24

4(B) Inter Regional Schedule & Actual Exchange (Import=(+ve) /Export =(-ve)) in MU

Link	ISGS+URS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total IR Schedule	Total IR Actual	Net UI
East-South	9.62	-6.95	0	0	0	0	-27.89	42.79	70.68
West-South	54.22	-11.33	1.18	22.57	0	2.98	56.24	-15.39	-71.63
Total	63.84	-18.28	1.18	22.57	0	2.98	28.35	27.4	-0.95

5. Frequency Profile

RANGE(Hz)	< 48.8	< 49	< 49.2	< 49.5	< 49.7	< 49.9	>= 49.9 - <= 50.05	> 50	> 50.05
%	0	0	0	0	0	7.512	69.225	56.019	23.264

Max Freq		Min Freq		Avg Freq	Freq Variation Index	Standard Deviation	Freq in 15 mnt blk	
Freq (HZ)	Time	Freq (HZ)	Time				Max (Hz)	Min (Hz)
50.257	18:03:40	49.79	12:44:50	50.003	0.047	0.069	50.14	49.83

6(A). Voltage Profile: 765 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 720	< 750	> 780	> 800
KURNOOL - 765KV	803	03:03	770	14:41	0	0	62.43	8.19
NIZAMABAD - 765KV	795	01:55	773	15:45	0	0	85.21	0
RAICHUR_PG - 765KV	794	03:01	760	14:40	0	0	46.46	0
SRIKAKULAM - 765KV	796	23:36	772	16:27	0	0	83.54	0

6(B). Voltage Profile: 400 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 380	< 390	> 420	> 430
GHANAPUR - 400KV	423	02:04	403	14:52	0	0	23.68	0
GOOTY - 400KV	424	03:03	400	12:28	0	0	13.89	0
HIRIYUR - 400KV	426	03:01	401	09:51	0	0	18.13	0
KAIGA - 400KV	426	03:00	401	12:42	0	0	21.53	0
KOLAR_AC - 400KV	421	03:02	393	09:40	0	0	3.54	0
KUDANKULAM - 400KV	418	03:58	401	12:34	0	0	0	0
SHANKARAPALLY - 400KV	422	02:00	408	15:56	0	0	13.96	0
SOMANAHALLI - 400KV	424	03:01	392	10:37	0	0	14.44	0
SRIPERUMBADUR - 400KV	420	03:47	399	14:40	0	0	0	0
TRICHY - 400KV	413	03:55	397	10:38	0	0	0	0
TRIVANDRUM - 400KV	421	03:55	397	10:37	0	0	1.88	0
VIJAYAWADA - 400KV	420	18:03	402	14:39	0	0	0	0

6(C). Voltage Profile: 220 kV

Station	Max		Min		Voltage (in %)			
	Voltage	Time	Voltage	Time	< 198	< 210	> 235	> 245
GHANAPUR - 220KV	232	02:32	218	15:45	0	0	0	0
GOOTY - 220KV	234	04:01	222	10:16	0	0	0	0
HIRIYUR - 220KV	229	03:01	215	09:58	0	0	0	0
KAIGA - 220KV	235	03:02	221	12:27	0	0	0.76	0
KOLAR_AC - 220KV	230	03:01	212	08:48	0	0	0	0
SOMANAHALLI - 220KV	238	03:01	217	10:40	0	0	18.61	0
SRIPERUMBADUR - 220KV	228	03:35	212	22:20	0	0	0	0
TRICHY - 220KV	227	23:43	215	12:34	0	0	0	0
TRIVANDRUM - 220KV	233	03:56	229	06:11	0	0	0	0
VIJAYAWADA - 220KV	241	21:45	215	14:52	0	0	8.82	0

7. Major Reservoir Particulars

RESERVOIR	DESIGNED			PRESENT		LAST YEAR		LAST DAY		MONTH	
	MDDL (m)	FRL (m)	Energy (MU)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (MU)	Usage (MU)	Prog Inflow (MU)	Prog Usage (MU)
IDUKKI	694.94	732.43	2148	706.92	491	713.79	855	11.96	2.95	58.32	40.72
JALAPUT	818.39	838.4	534	825.4	129	837.74	511	0.51	0	2.82	0
KAKKI	908.3	981.45	916	943.28	154	962.27	389	10.34	1.4	54.29	14.19
LINGANAMAKKI	522.73	554.5	4557	533.28	537	537.51	948	3.41	6.81	24.32	84.7
N.SAGAR	149.3	179.9	1398	157.92	78	156.03	18	2.19	2.49	26.33	20.91
NILAGIRIS	0	0	1504	0	482	0	705	8.45	4.51	28.72	42.03
SRISAILAM	243.84	270.7	1392	249.75	63	254.57	145	0	0	2.17	0
SUPA	495	564	3159	526.17	676	529.4	815	1.11	0.58	4.07	36.52
Total	-	-	15608	-	2610	-	4386	37.97	18.74	201.04	239.07

8(A). Short-Term Open Access Details

State	Off- Peak Hours (03:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-62.14	-8.3	-131	0	151.93	0	0	0	0	0	0	0	0
Karnataka	-1443.14	-50	61.33	0	-59.05	0	0	0	0	0	0	0	0
Kerala	0	0	-10.7	0	114.76	0	0	0	0	0	0	0	0
Puducherry	48.24	0	-76	0	-79	0	0	0	0	0	0	0	0
Tamil Nadu	2234.93	0	-11.8	0	187.6	0	0	0	0	0	0	0	0
Telangana	-161.05	0.19	385.98	0	267.41	0	0	0	0	0	0	0	0
Total	616.84	-58.11	217.81	0	583.65	0	0	0	0	0	0	0	0

State	Peak Hours (20:00)												
	TGNA	IEX GDAM	IEX DAM	IEX HPDAM	IEX RTM	PXIL GDAM	PXIL DAM	PXIL HPDAM	PXIL RTM	HPX GDAM	HPX DAM	HPX HPDAM	HPX RTM
Andhra Pradesh	-61.3	-10	-30.99	0	193.05	0	0	0	0	0	0	0	0
Karnataka	-1529.32	-53.31	6.84	0	-43.7	0	0	0	0	0	0	0	0
Kerala	0	0	-10.7	0	684.13	0	0	0	0	0	0	0	0
Puducherry	48.24	0	0	0	-61	0	0	0	0	0	0	0	0
Tamil Nadu	3100.21	3.05	1050.73	0	390.99	0	0	0	0	0	0	0	0
Telangana	-162.88	0.19	557.88	0	993.12	0	0	0	0	0	0	0	0
Total	1394.95	-60.07	1573.76	0	2156.59	0	0	0	0	0	0	0	0

State	Day Energy (MU)						
	ISGS+GNA	TGNA	GDAM	DAM	HPDAM	RTM	Total
Andhra Pradesh	56.56	-0.04	0.71	10.4	0	2.37	70
Karnataka	90.63	-20.34	-2.03	0.62	0	-3.63	65.25
Kerala	53.11	1.3	0.56	5.45	0	5.96	66.38
Puducherry	12.29	1.49	0	-1.5	0	-1.49	10.79
Tamil Nadu	193.21	45.13	1.87	-6.77	0	-11.91	221.53
Telangana	82.03	-1.18	0.56	11.28	0	13.96	106.65
Total	487.83	26.36	1.67	19.48	0	5.26	540.6

8(B). Short-Term Open Access Details

State	ISGS+GNA		TGNA		IEX GDAM		PXI GDAM		HPX GDAM		IEX DAM		PXI DAM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	2929.41	1807.28	80.96	-68.9	160.36	-12	0	0	0	0	1144.09	-442.3	0	0
Karnataka	4718.54	2410.12	-89.81	-1941.59	38.4	-541.21	0	0	0	0	92.66	-40.4	0	0
Kerala	2470.96	1620.25	369.54	0	71.29	0	0	0	0	0	610.86	-10.7	0	0
Puducherry	572.61	442.81	81.34	48.24	0	0	0	0	0	0	0	-152	0	0
Tamil Nadu	8931.21	6680.87	4481.94	263.49	222.56	0	0	0	0	0	1307.65	-2326.09	0	0
Telangana	5928.52	2239.67	54.25	-162.88	72.9	0.09	0	0	0	0	1620	-43.9	0	0

State	HPX DAM		IEX HPDAM		PXI HPDAM		HPX HPDAM		IEX RTM		PXI RTM		HPX RTM	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
Andhra Pradesh	0	0	0	0	0	0	0	0	1199.32	-1829.5	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0	1.37	-1267.46	0	0	0	0
Kerala	0	0	0	0	0	0	0	0	888.84	-1	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	-139	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0	1103.77	-2899.28	0	0	0	0
Telangana	0	0	0	0	0	0	0	0	2028.09	-257.84	0	0	0	0

9. Synchronisation of new generating units:

SL.NO	Station Name	Owner	Inst. Capacity (MW)	Date	Time
-------	--------------	-------	---------------------	------	------

10. Synchronisation of new 220 / 400 / 765 KV Transmission elements and energising of bus /substation:

11. Significant events (If any):

At 10:53Hrs/10.06.2026, Power supply failure occurred at 220 kV Koramangala, 220 kV NIMHANS, 220 kV HSR and 220 kV Nagnathpura . Load loss of ~500 MW reported. Power extended to 220 kV NIMHANS by normalizing 220 kV NIMHANS - EDC line at 11:13 Hrs .Power extended to 220 kV Nagnathpura by normalizing 220 kV Mylasandra - Nagnathpura line at 11:22 Hrs. Power extended to 220 kV HSR by normalizing 220 kV Mylasandra - HSR -1 line at 11:25 Hrs .Power extended to 220 kV Koramangala by normalizing 220 kV Koramangala - HSR line at 11:55 Hrs .

12. Constraints and instances of congestion in the transmission system

1) 400KV-KALPAKKA-KHAMMAM_PG-1 & 400KV-KALPAKKA-ASUPAKA-I Lines Under S/D for replacement of badly damaged rusted towers from Loc No.1 to 11 in 400KV Kalapaka – Khammam along with stringing of conductor at 400kv SS Kalapaka. S/D availed on 05-05-2026 ,Expected to be restored on 26-06-2026. 2) 400KV Kaiga-Guttur 1&2 tripped on 14.05.2026 at 17:39Hrs due to the tower collapse in multiple locations. 3) 400KV-GAZUWAKA-JEYPORE-1,2 under shutdown for NH-130CD Diversion works (Between 130-133/150-153/179-180) availed on 15-05-2026 at 09:36 Hrs. Expected to restore by 16.06.2026 18:00 Hrs. 4) 220KV-GADAG_PSS-Vena_GadagPS-1 and 220KV-GADAG_PSS-Green Infra_GadagPS-1 tripped on 17-05-2026 at 16:14 Hrs due to the tower collapse Loc. No.32-36. Generation affected 237MW(L.C) 5) At 18:13 hrs of 23-05-2026, 400KV-GADAG_PSS-KOPPAL D/C tripped on Y-B fault due to tower collapse. total 15 number of tower Collapsed (Tower location number 52-66). 6) 400KV-NAGAPATTNAM_PS-TRICHY-1&2 tripped on 31.05.2026 at 17:05Hrs due to the tower collapse at loc. 437(DA), 438(DA), 439(DB) towers are collapsed and 435(DA),436(DA),440(DA), 441(DA) towers are found cross arm/earth peak damaged. 7) 400/220kv SOMANAHALLI ICT-1 tripped at 20:07 hours of 31-05-2026 due to REF, Differential & body protections. 8) 400KV/220KV VIJAYAWADA-ICT-2 tripped on 25.05.2026 due to the failure of 220kV B-ph bushing. Expected charging on 15.06.2026

13. Weather Condition

Karnataka: Light rains reported in Bangalore, Hassan and Mysore areas. Andhra Pradesh: Light rains reported in East & West Godavari, Vishakapatnam, Krishna, Eluru and Guntur districts. Kerala: Scattered rains reported in the state.

14. RE/Load Curtailment details

State	Load Curtailment (Shortage)			RE Curtailment				
	Energy (MU)	Max (MW)	At the time of maximum demand	Wind Max (MW)	Wind Energy (MU)	Solar Max (MW)	Solar Energy (MU)	Reason
Andhra Pradesh	0	0	0	0	0	0	0	0
Karnataka	0	0	0	0	0	0	0	0
Kerala	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0
Tamil Nadu	0	0	0	0	0	0	0	0
Telangana	0	0	0	0	0	0	0	0

15.Instances of persistant/significant non-complaint with grid code

State	Frequency and Deviation				Voltage				ICT loading			
	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance	Alert	Emergency	Extreme Emergency	Non Compliance

Andhra Pradesh	0	2	0	0	5	0	0	0	7	0	0	0
Karnataka	0	1	0	1	0	0	0	0	0	0	0	0
Kerala	0	0	0	0	0	0	0	0	0	0	0	0
Puducherry	0	0	0	0	0	0	0	0	0	0	0	0
Tamil Nadu	0	1	0	1	0	4	0	0	3	9	1	0
Telangana	0	0	0	0	12	0	0	0	0	0	0	0