



Commonwealth of Virginia

VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY

www.deq.virginia.gov

David L. Bulova
Secretary of Natural and Historic Resources

Michael S. Rolband, PE, PWD, PWS Emeritus
Director

April 9, 2026

Mr. Lee Hayes
President and CEO
Chirisa Richmond LLC
1401 Meadowville Technology Pkwy,
Chester, Virginia 23836

Location: Chesterfield County
Registration No.: 52432

Dear Mr. Hayes:

Attached is a permit approval to construct and operate a project at a data processing center in accordance with the provisions of the Virginia Regulations for the Control and Abatement of Air Pollution. This combined permit document supersedes your permit document dated July 7, 2025.

In the course of evaluating the application and arriving at a final decision to approve the project, the Department of Environmental Quality (DEQ) deemed the application complete on February 19, 2026.

This permit contains legally enforceable conditions. Failure to comply may result in a Notice of Violation and/or civil charges. Please read all permit conditions carefully.

This permit approval to construct and operate shall not relieve Chirisa Richmond LLC of the responsibility to comply with all other local, state, and federal permit regulations.

The diesel engine-generator sets may be subject to 40 CFR 63, Maximum Achievable Control Technology (MACT), Subpart ZZZZ and 40 CFR 60, New Source Performance Standard (NSPS), Subpart IIII. Virginia has not accepted delegation of these rules for sources that are not major. In summary, the units are required to comply with certain federal emission standards and operating limitations. The Department of Environmental Quality (DEQ) advises you to review the referenced MACT and NSPS to ensure compliance with applicable emission and operational limitations. As the owner/operator you are also responsible for any monitoring, testing, notification, reporting and recordkeeping requirements of the MACT and NSPS. Notifications shall only be sent to EPA, Region III.

To review any federal rules referenced in the above paragraph or in the attached permit, the US Government Publishing Office maintains the text of these rules at www.ecfr.gov, Title 40, Part 60 and 63.

The Regulations as contained in Title 9 of the Virginia Administrative Code 5-170-200 provide that you may request a formal hearing from this case decision by filing a petition with the DEQ within 30 days after this case decision notice was mailed or delivered to you. Please consult the relevant regulations for additional requirements for such requests.

As provided by Rule 2A:2 of the Supreme Court of Virginia, you have 30 days from the date you actually received this permit or the date on which it was mailed to you, whichever occurred first, within which to initiate an appeal of this decision by filing a Notice of Appeal with:

Director
Department of Environmental Quality
P. O. Box 1105
Richmond, VA 23218

If this permit was delivered to you by mail, three days are added to the thirty-day period in which to file an appeal. Please refer to Part Two A of the Rules of the Supreme Court of Virginia for information on the required content of the Notice of Appeal and for additional requirements governing appeals from decisions of administrative agencies.

If you have any questions concerning this permit, please contact the regional office at (804) 527-5020.

Sincerely,



James E. Kyle, P.E., Air Permit Manager
Virginia Department of Environmental Quality
(804) 489-6241
james.kyle@deq.virginia.gov
Piedmont Regional Office
4949-A Cox Road, Glen Allen, VA 23060
(804) 527-5020

Attachments: Permit
Source Testing Report Format

cc: File
Inspector and Manager, Air Compliance



Commonwealth of Virginia

VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY

www.deq.virginia.gov

David L. Bulova
Secretary of Natural and Historic Resources

Michael S. Rolband, PE, PWD, PWS Emeritus
Director

STATIONARY SOURCE PERMIT TO CONSTRUCT AND OPERATE

This permit document supersedes your permit document dated July 7, 2025.

In compliance with the Federal Clean Air Act and the Commonwealth of Virginia Regulations for the Control and Abatement of Air Pollution,

Chirisa Richmond LLC
1401 Meadowville Technology Pkwy
Chester, Virginia 23836
Registration No.: 52432

is authorized to construct and operate

a data processing center

located at

1401 Meadowville Rd. Chester Virginia 23836 and adjacent
properties comprised of buildings CTP-01, CTP-02, CTP-03,
DDC-01 and DDC-02.

in accordance with the Conditions of this permit.

Approved on April 9, 2026.

A handwritten signature in blue ink, appearing to read "J. Kyle", written over a horizontal line.

James E. Kyle, P.E.
Air Permit Manager

Permit consists of 17 pages.
Permit Conditions 1 to 32.

INTRODUCTION

This permit document is based on and combines permit terms and conditions in accordance with 9VAC5-80-1255 from the following permit approvals and the respective permit applications:

- Minor NSR permit approval dated April 9, 2026 based on the permit application dated February 19, 2026.
- Minor NSR administrative amendment dated July 7, 2025 based on the permit application dated June 9, 2025.
- Minor NSR permit approval dated November 14, 2024 based on the permit application dated August 12, 2024.
- Minor NSR permit approval dated November 8, 2023 based on the permit application dated July 28, 2023.
- Minor NSR permit approval dated October 11, 2012, based on the permit application dated August 28, 2012;

Any changes in the permit application specifications or any existing facilities which alter the impact of the facility on air quality may require a permit. Failure to obtain such a permit prior to construction may result in enforcement action. In addition, this facility may be subject to additional applicable requirements not listed in this permit document.

Words or terms used in this permit shall have meanings as provided in 9 VAC 5-10-10 of the State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. The regulatory reference or authority for each condition is listed in parentheses () after each condition. The enabling permit program or permit programs is provided below each permit condition in the regulatory authority parenthetical as follows: 9VAC5-80-850 for Article 5, 9VAC5-80-1180 for Article 6, 9VAC5-80-1985 for Article 8, and 9VAC5-80-2050 for Article 9. The most recent effective date for a condition is listed in brackets [] after each regulatory reference. When identical conditions on approval for one or more emission units are combined, the listed effective date does not alter the prior effective date(s) for any such conditions as issued in a previous permit action. In accordance with 9VAC5-80-1120F, any condition not marked as state-only enforceable (SOE) is state and federally enforceable.

Annual requirements to fulfill legal obligations to maintain current stationary source emissions data will necessitate a prompt response by the permittee to requests by the DEQ for information to include, as appropriate: process and production data; changes in control equipment; and operating schedules. Such requests for information from the DEQ will either be in writing or by personal contact.

The availability of information submitted to the DEQ or the Board will be governed by applicable provisions of the Freedom of Information Act, §§ 2.2-3700 through 2.2-3714 of the Code of Virginia, § 10.1-1314 (addressing information provided to the DEQ) of the Code of

Virginia, and 9 VAC 5-170-60 of the State Air Pollution Control Board Regulations. Information provided to federal officials is subject to appropriate federal law and regulations governing confidentiality of such information.

Equipment List - Equipment at this facility covered by this permit consists of:

Equipment included in the project:

Ref. No.	Equipment Description	Rated Capacity	Referenced Federal Requirements	Original Permit Date
EG-3-H	One (1) Cummins Model 1500DQGAF emergency generator; Cummins Model QSK50-G5 engine	2,220 bhp 1,500 kW	N/A	April 9, 2026
EG-3-01 through EG-3-28 and EG-DD1C-01 through EG-DD1C-04	Thirty-two (32) Cummins Model C3000D6EB Low (NOX)-Optimized emergency generators; Cummins Model QSK78-G36 engine	4,441 bhp each 3,000 kW each	N/A	April 9, 2026
EG-DD1A-01 through EG-DD1A-24 and EG-DD2A-01 through EG-DD2A-24	Forty-Eight (48) Caterpillar Model C175-20 emergency engine generators	5,166 bhp each 3,500 kW each	N/A	April 9, 2026
EG-DD1B-01 through EG-DD1B-13	Thirteen (13) Cummins Model 2500DQKAN Low NOX-Optimized emergency generators; Cummins Model QSK60-G26 engine	3,640 bhp each 2,500 kW each	N/A	April 9, 2026
EG-DD2B-01 through EG-DD2B-13	Thirteen (13) Cummins Model 2500DQKAN Low NOX-Optimized emergency generators; Cummins Model QSK60-G26 engine or Thirteen (13) Caterpillar Model 3516C emergency engine generators	3,640 bhp each 2,500 kW each or 3,633 bhp each 2,500 kW each	N/A	April 9, 2026
EG-DD2C-01 through EG-DD2C-04	Four (4) Cummins Model C3000D6EB Low NOX-Optimized emergency generators; Cummins Model QSK78-G36 engine or Four (4) Caterpillar Model 3516E emergency engine generators	4,441 bhp each 3,000 kW each or 4,393 bhp each 3,000 kW each	N/A	April 9, 2026

Equipment permitted prior to the date of this permit:

Reference No.	Equipment Description	Rated Capacity	Delegated Federal Requirements	Original Permit Date
EG01 through EG05	Five (5) Caterpillar Model C175-16 backup engine-generator sets	4,423 bhp 3,000 kW, each	N/A	October 11, 2012
EG06	One (1) Caterpillar Model 3512C backup engine-generator sets	2,206 bhp 1,500 kW	N/A	October 11, 2012
EG07 through EG15	Nine (9) Caterpillar Model 3516C backup engine-generator sets	3,633 bhp 2,500 kW, each	N/A	November 8, 2023
EG-2-01 through EG-2-31	Thirty-one (31) Cummins Model C3000D6EB (QSK78-36) backup engine-generator sets	4,441 bhp 3,000 kW each	N/A	November 14, 2024

*The buildings in this permit are under the following ownership, commonly operated by Chirisa Richmond LLC: Chirisa Richmond LLC (CTP-01 property owner), CTP-02 PropCo LLC (CTP-02 property owner), CTP-03 PropCo LLC (CTP-03 property owner), DDC-01 PropCo LLC (DDC-01 property owner), and DDC-02 PropCo LLC (DDC-02 property owner).

Specifications included in the above tables are for informational purposes only and do not form enforceable terms or conditions of the permit.

PROCESS REQUIREMENTS

1. Emission Controls - Nitrogen oxides (NO_x) emissions from the engine-generator sets (Ref. Nos. EG07 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) shall be controlled by turbocharged engine and aftercooler/charge air cooler and/or low NO_x emission package. The permittee shall maintain documentation that demonstrates the engine design and/or control device has been installed on each engine-generator set.
(9 VAC 5-80-1180 and 9 VAC 5-50-260) [April 9, 2026]
2. Emission Controls - Visible emissions, particulate emissions, carbon monoxide (CO) emissions, nitrogen oxide (NO_x) emissions and volatile organic compounds (VOC) shall be controlled by the use of good operating practices and performing appropriate maintenance in accordance with the manufacturer recommendations. In addition, the permittee may only change those settings that are permitted by the manufacturer and do not increase air emissions.
(9 VAC 5-80-1180 and 9 VAC 5-50-260) [April 9, 2026]
3. Monitoring Devices - Each engine-generator set (Ref. Nos. EG01 through EG05, EG06, EG07 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) shall be equipped with a non-

resettable hour metering device to monitor the operating hours. The non-resettable hour meter used to continuously measure the hours of operation for each engine-generator set shall be observed by the owner or operator with a frequency of not less than once each day the engine-generator set is operated. The owner or operator shall keep a log of these observations.

(9 VAC 5-80-1180 D) [April 9, 2026]

4. Monitoring Devices - Each engine generator set Ref. Nos. EG01 through EG05, EG06, EG07 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04 shall be equipped with a fuel flow meter to continuously measure the fuel throughput for each engine generator set. The fuel flow meter shall be observed by the owner or operator with a frequency of not less than once each day the engine generator set is operated. The owner or operator shall keep a log of these observations. Each monitoring device shall be installed, maintained, calibrated (as appropriate) and operated in accordance with approved procedures which shall include, as a minimum, the manufacturer's written requirements or recommendations. Each monitoring device shall be provided with adequate access for inspection and shall be in operation when the engine-generator set is operating.

(9 VAC 5-80-1180 D) [April 9, 2026]

OPERATING/EMISSION LIMITATIONS

5. Operation of the Engine-Generator Set - The permittee shall operate and maintain each engine-generator set (Ref. Nos. EG01 through EG05, EG06, EG07 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) and control device according to the manufacturer's written instructions or procedures developed by the permittee that are approved by the engine manufacturer.

(9 VAC 5-80-1180) [April 9, 2026]

6. Emergency Power Generation - The engine-generator sets (Ref. Nos. EG01 through EG05, EG06, and EG07 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) shall only be operated in the following modes:
 - a. In situations that arise from sudden and reasonably unforeseeable events where the primary energy or power source is disrupted or disconnected due to conditions beyond the control of an owner or operator of a facility including:

- i. A failure of the electrical grid;

- ii. On-site disaster or equipment failure; or
 - iii. Public service emergencies such as flood, fire, natural disaster, or severe weather conditions.
- b. For participation in an ISO-declared emergency, where an ISO emergency is:
- i. An abnormal system condition requiring manual or automatic action to maintain system frequency, to prevent loss of firm load, equipment damage, or tripping of system elements that could adversely affect the reliability of an electric system or the safety of persons or property;
 - ii. Capacity deficiency or capacity excess conditions;
 - iii. A fuel shortage requiring departure from normal operating procedures in order to minimize the use of such scarce fuel;
 - iv. Abnormal natural events or man-made threats that would require conservative operations to posture the system in a more reliable state; or
 - v. An abnormal event external to the ISO service territory that may require ISO action.
- c. For periodic maintenance, testing, and operational training.

When changing from Emergency Power Generation to Non-Emergency (Alternate) Power Generation, the permittee shall submit appropriate documentation to the Department of Environmental Quality (DEQ) and receive DEQ approval for the change in the method of operation of the engine-generator set to ensure that the facility remains in compliance with the appropriate permitting requirements. Total emissions for any 12-month period, calculated as the sum of all emissions from operations under the scenarios above, shall not exceed the limits stated in Conditions 15 and 16.

(9 VAC 5-80-1180) [April 9, 2026]

7. Operating Hours – Each emergency diesel engine-generator set (Ref. Nos. EG01 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) shall not operate more than 500 hours per year, calculated monthly as the sum of each consecutive 12-month period. Compliance for the consecutive 12-month period shall be demonstrated monthly by adding the total for the most recently completed calendar month to the individual monthly totals for the preceding 11 months.

(9 VAC 5-80-1180) [April 9, 2026]

8. Fuel Throughput - The engine-generator sets (Ref. Nos. EG01 through EG15) combined shall consume no more than 105,000 gallons of diesel fuel per year, calculated daily as the sum of each consecutive 365-day period. Compliance for the consecutive 365-day period shall be demonstrated daily by adding the total for the most recently completed calendar day to the individual daily totals for the preceding 364 days.
(9 VAC 5-80-1180) [April 9, 2026]
9. Fuel Throughput - The engine-generator sets (Ref. Nos. EG-2-01 through EG-2-31) combined shall consume no more than 125,000 gallons of diesel fuel per year, calculated daily as the sum of each consecutive 365-day period. Compliance for the consecutive 365-day period shall be demonstrated daily by adding the total for the most recently completed calendar day to the individual daily totals for the preceding 364 days.
(9 VAC 5-80-1180) [April 9, 2026]
10. Fuel Throughput - The engine generator sets (Ref. Nos. EG-3-H and EG-3-01 through EG-3-28) combined shall consume no more than 125,000 gallons of diesel fuel per year, calculated daily as the sum of each consecutive 365-day period. Compliance for the consecutive 365-day period shall be demonstrated daily by adding the total for the most recently completed calendar day to the individual daily totals for the preceding 364 days.
(9 VAC 5-80-1180) [April 9, 2026]
11. Fuel Throughput - The engine-generator sets (Ref. Nos. EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, and EG-DD1C-01 through EG-DD1C-04) shall consume no more than the combined quantity of diesel fuel each consecutive 365-day period, as demonstrated by using the following equation:

$$\frac{\text{Group 1 Fuel Consumption}}{162,000 \text{ Gallons}} + \frac{\text{Group 2 Fuel Consumption}}{172,700 \text{ Gallons}} + \frac{\text{Group 3 Fuel Consumption}}{174,750 \text{ Gallons}} \leq 1$$

Engine Group	Ref. Nos.	Engine Model
Group 1A	EG-DD1A-01 through EG-DD1A-24	Caterpillar C175-20
Group 2A	EG-DD1B-01 through EG-DD1B-13	Cummins 2500DQKAN
Group 3A	EG-DD1C-01 through EG-DD1C-04	Cummins C3000D6EB

Compliance for the consecutive 365-day period shall be demonstrated daily by adding the total for the most recently completed calendar day to the individual daily totals for the preceding 364 days.

(9VAC 5-80-1180) [April 9, 2026]

12. Fuel Throughput - The engine-generator sets (Ref. Nos. EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) shall consume no more than the combined quantity of diesel fuel each consecutive 365-day period, as demonstrated by using the following equation:

$$\frac{\text{Group 1 Fuel Consumption}}{162,000 \text{ Gallons}} + \frac{\text{Group 2-Cummins Fuel Consumption}}{172,700 \text{ Gallons}} + \frac{\text{Group 2-Caterpillar Fuel Consumption}}{163,300 \text{ Gallons}} + \frac{\text{Group 3-Cummins Fuel Consumption}}{174,750} + \frac{\text{Group 3-Caterpillar Fuel Consumption}}{164,850} \leq 1$$

Engine Group	Ref. Nos.	Engine Model
Group 1B	EG-DD2A-01 through EG-DD2A-24	Caterpillar C175-20
Group 2B – Cummins	EG-DD2B-01 through EG-DD2B-13	Cummins 2500DQKAN
Group 2B – Caterpillar	EG-DD2B-01 through EG-DD2B-13	Caterpillar Model 3516C
Group 3B – Cummins	EG-DD3C-01 through EG-DD2C-04	Cummins C3000D6EB
Group 3B – Caterpillar	EG-DD3C-01 through EG-DD2C-04	Caterpillar Model 3516E

Compliance for the consecutive 365-day period shall be demonstrated daily by adding the total for the most recently completed calendar day to the individual daily totals for the preceding 364 days.

(9VAC 5-80-1180) [April 9, 2026]

13. Fuel - The approved fuel for the engine-generator sets (Ref. Nos. EG01 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) is diesel fuel. The diesel fuel shall meet the ASTM D975 specification for S15 diesel fuel oil with a maximum sulfur content per shipment of 0.0015%. A change in the fuel shall be considered a change in the method of operation of the data processing center and may require a new or amended permit. However, if a change in the fuel is not subject to new source review permitting requirements, this condition should not be construed to prohibit such a change.
 (9 VAC 5-80-1180 and 9 VAC 5-50-260) [April 9, 2026]

14. Fuel Certification - The permittee shall obtain a certification from the fuel supplier with each shipment of diesel fuel. Each fuel supplier certification shall include the following:
 - a. The name of the fuel supplier;
 - b. The date on which the diesel fuel was received;
 - c. The quantity of diesel fuel delivered in the shipment;
 - d. A statement that the diesel fuel complies with the American Society for Testing and Materials specifications (ASTM D975) for S15 diesel fuel oil; and
 - e. The sulfur content of the diesel fuel.

Fuel sampling and analysis, independent of that used for certification, as may be periodically required or conducted by DEQ may be used to determine compliance with the fuel specifications stipulated in Condition 13. Exceedance of these specifications may be considered credible evidence of the exceedance of emission limits.
(9 VAC 5-80-1180) [April 9, 2026]

EMISSION LIMITS

15. Emission Limits (Hourly - Emergency) - Emissions from the operation of each emergency diesel fuel generator shall not exceed the limits specified below:

Pollutant	Caterpillar Model C175-16 lb/hr	Caterpillar Model 3512C lb/hr	Caterpillar Model 3516C lb/hr
Nitrogen Oxides (NO _x as NO ₂)	71	29.7	48.1
Particulate Matter (PM)	1	0.5	0.6
Particulate Matter (PM ₁₀)	1	0.5	0.6
Particulate Matter (PM _{2.5})	1	0.5	0.6
Carbon Monoxide (CO)	14.4	4.1	6.1
Volatile Organic Compounds (VOC)	2.4	0.9	1.3

Pollutant	Cummins Model C3000D6EB lb/hr	Cummins Model 1500DQGAF lb/hr	Caterpillar Model C175-20 lb/hr
Nitrogen Oxides (NO _x as NO ₂)	57.2	29.4	68.4
Particulate Matter (PM)	0.7	0.5	0.8
Particulate Matter (PM ₁₀)	0.7	0.5	0.8
Particulate Matter (PM _{2.5})	0.7	0.5	0.8
Carbon Monoxide (CO)	2.5	7.9	23.6
Volatile Organic Compounds (VOC)	1.1	1.1	1.5

Pollutant	Cummins Model 2500DQKAN lb/hr	Caterpillar Model 3516E lb/hr
Nitrogen Oxides (NO _x as NO ₂)	47.2	58.2
Particulate Matter (PM)	0.9	1
Particulate Matter (PM ₁₀)	0.9	1
Particulate Matter (PM _{2.5})	0.9	1
Carbon Monoxide (CO)	6.5	9.9
Volatile Organic Compounds (VOC)	0.6	0.6

Compliance with these pollutant limits shall be based on the proper operation and maintenance of the diesel engines or by testing, if required.
(9VAC5-80-1180 and 9VAC5-50-260) [April 9, 2026]

16. Emission Limits (Annual) – Emissions from the operation of the emergency diesel fuel generator sets, shall not exceed the limits specified below for all operations:

Pollutants	A. Max TPY from Condition 8	B. Max TPY from Condition 9	C. Max TPY from Condition 10	D. Max TPY from Condition 11	E. Max TPY from Condition 12
Nitrogen Oxides (NO _x as NO ₂)	17.4	16.4	16.7	23	23
Particulate Matter (PM)	0.7	0.5	0.5	0.7	0.7
Particulate Matter (PM ₁₀)	0.7	0.5	0.5	0.7	0.7
Particulate Matter (PM _{2.5})	0.7	0.5	0.5	0.7	0.7
Carbon Monoxide (CO)	7.9	2.6	4.3	12.9	12.9
Volatile Organic Compounds (VOC)	1.5	1	1.3	1.3	1.3

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Condition(s) 1, 2, 5, 8, 9, 10, 11, and 12.

(9 VAC 5-80-1180 and 9 VAC 5-50-260) [April 9, 2026]

17. Process Emission Standard – The combined emissions of nitrogen oxides and hydrocarbons from each generator (EG01 through EG06) shall not exceed 6.4 grams per kilowatt hour as determined by the procedures described in 40 CFR part 1039 Subpart B.
(9 VAC 5-80-1180 and 9 VAC 5-50-260) [October 11, 2012].

18. Visible Emission Limit - Visible emissions from each stack of the generators (Ref. Nos. EG01 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) shall each not exceed 10 percent opacity except during one six-minute period in any one hour in which visible emissions shall not exceed 20 percent opacity as determined by the EPA Method 9 (reference 40 CFR 60, Appendix A). This condition applies at all times except during startup, shutdown, and malfunction.

(9 VAC 5-80-1180 and 9 VAC 5-50-260) [April 9, 2026]

INITIAL COMPLIANCE DETERMINATION

19. Stack Test – Initial performance tests shall be conducted dependent upon the model of emergency diesel fuel generators installed. The permittee shall conduct an initial performance test for nitrogen oxides (as NO₂) and carbon monoxide (CO) on at least 10% of each model's corresponding engine generator set installed after the issuance of this permit, dated April 9, 2026, to determine compliance with the emission limits contained in Condition 15. The models specified below are subject to initial performance testing:

- a. Cummins Model 1500DQGAF.
- b. Caterpillar Model C175-20.
- c. Caterpillar Model 3516C.

d. Caterpillar Model 3516E

The tests shall be performed and demonstrate compliance within 60 days after achieving the maximum production rate at which the facility will be operated but in no event later than 180 days after start-up of the permitted facility. Tests shall be conducted and reported and data reduced as set forth in 9 VAC 5-50-30. The details of the tests are to be arranged with the Piedmont Regional Office. The permittee shall submit a test protocol at least 30 days prior to testing. One copy of the test results shall be submitted to the Piedmont Regional Office within 45 days after test completion and shall conform to the test report format enclosed with this permit.

- e. Emissions testing of each pollutant for each selected engine-generator set shall consist of three one-hour test runs under load. The average of the three runs shall be reported as the short-term emission rate for that engine-generator.
- f. Testing shall be conducted with the engine(s) operating at greater than 90% electrical capacity, unless multiple load band testing is approved by DEQ.
- g. Recorded information shall include, but not be limited to:
 - i. Generator load/kilowatt output.
 - ii. Fuel consumption and fuel sulfur content of the diesel fuel oil.
 - iii. Records that indicate which engine generator set was tested.

(9 VAC 5-50-30 and 9 VAC 5-80-1200) [April 9, 2026]

- 20. Visible Emissions Evaluation – Concurrent with the initial performance test required in Condition 19, Visible Emission Evaluations (VEE) in accordance with 40 CFR Part 60, Appendix A, Method 9, shall be conducted by the permittee on the selected emergency diesel engine generator sets selected for initial performance testing. The evaluation shall be performed, reported, and demonstrate compliance within 60 days after achieving the maximum production rate at which the facility will be operated but in no event later than 180 days after start-up of the permitted facility. Should conditions prevent concurrent opacity observations, the Piedmont Regional Office shall be notified in writing, within seven days, and visible emissions testing shall be rescheduled within 30 days. Rescheduled testing shall be conducted under the same conditions (as possible) as the initial performance tests. The details of the tests are to be arranged with the Piedmont Regional Office. The permittee shall submit a test protocol at least 30 days prior to testing. One copy of the test result shall be submitted to the Piedmont Regional Office within 45 days after test completion and shall conform to the test report format enclosed with this permit.
 - a. Each test shall consist of 30 sets of 24 consecutive observations (at 15 second intervals) to yield a six-minute average.

- b. Testing shall be conducted with the engine(s) operating at greater than 90% electrical capacity, unless multiple load band testing is approved by DEQ.

(9 VAC 5-50-30 and 9 VAC 5-80-1200) [April 9, 2026]

- 21. Emissions Testing - The facility shall be constructed so as to allow for emissions testing upon reasonable notice at any time, using appropriate methods. This includes constructing the facility/equipment such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and providing a stack or duct that is free from cyclonic flow. Sampling ports shall be provided when requested at the appropriate locations and safe sampling platforms and access shall be provided.

(9 VAC 5-50-30 F and 9 VAC 5-80-1180) [April 9, 2026]

RECORDS

- 22. On Site Records - The permittee shall maintain records of emission data and operating parameters as necessary to demonstrate compliance with this permit. The content and format of such records shall be arranged with the Piedmont Regional Office. These records shall include, but are not limited to:

- a. Annual hours of operation of each engine-generator set (Ref. Nos. EG01 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04), calculated monthly as the sum of each consecutive 12 month period. Compliance for the consecutive 12 month period shall be demonstrated monthly by adding the total for the most recently completed calendar month to the individual monthly totals for the preceding 11 months.
- b. Daily and annual fuel consumption of each diesel engine generator set (Ref. Nos. EG01 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) calculated daily as the sum of each consecutive 365-day period, as specified in Conditions 8, 9, 10, 11, and 12.
- c. Daily and annual fuel consumption for each diesel engine generator set (Ref. Nos. EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, and EG-DD1C-01 through EG-DD1C-04) by fuel group (Group 1A through Group 3A), calculated daily as the sum of each consecutive 365-day period for the purposes of the compliance demonstration with the diesel fuel throughput limit equation in Condition 11.
- d. Daily and annual fuel consumption for each diesel engine generator set (Ref. Nos. EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-

DD2C-01 through EG-DD2C-04) by fuel group (Group 1B through Group 3B - Caterpillar), calculated daily as the sum of each consecutive 365-day period for the purposes of the compliance demonstration with the diesel fuel throughput limit equation in Condition 12.

- e. Daily and annual results of the computed fuel throughput equation used by the diesel engine generator sets' (Ref. Nos. Ref. Nos. EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, and EG-DD1C-01 through EG-DD1C-04) fuel groups (Group 1A through Group 3A), calculated daily as the sum of each consecutive 365 day period for the purposes of the compliance demonstration with the diesel fuel throughput limit equation in Condition 11.
- f. Daily and annual results of the computed fuel throughput equation used by the diesel engine generator sets' (Ref. Nos. Ref. Nos. EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) fuel groups (Group 1B through Group 3B - Caterpillar), calculated daily as the sum of each consecutive 365 day period for the purposes of the compliance demonstration with the diesel fuel throughput limit equation in Condition 12.
- g. Daily and annual emissions calculations for NO_x (as NO₂), CO, VOC, PM, PM₁₀, and PM_{2.5}, from the diesel engine generator sets (Ref. Nos EG01 through EG15), with annual emissions calculated daily, as the sum of each consecutive 365-day period, to verify compliance with the annual emission limits in Condition 16A
- h. Daily and annual emissions calculations for NO_x (as NO₂), CO, VOC, PM, PM₁₀, and PM_{2.5} from the diesel engine generator sets (Ref. Nos. EG-2-01 through EG-2-31), with annual emissions calculated daily, as the sum of each consecutive 365-day period, to verify compliance with the annual emission limits in Condition 16B
- i. Daily and annual emissions calculations for NO_x (as NO₂), CO, VOC, PM, PM₁₀, and PM_{2.5} from the diesel engine generator sets (Ref. Nos. EG-3-H and EG-3-01 through EG-3-28), with annual emissions calculated daily, as the sum of each consecutive 365-day period, to verify compliance with the annual emission limits in Condition 16C
- j. Daily and annual emissions calculations for NO_x (as NO₂), CO, VOC, PM, PM₁₀, and PM_{2.5} from the diesel engine generator sets (Ref. Nos. EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, and EG-DD1C-01 through EG-DD1C-04), with annual emissions calculated daily, as the sum of each consecutive 365-day period, to verify compliance with the annual emission limits in Condition 16D
- k. Daily and annual emissions calculations for NO_x (as NO₂), CO, VOC, PM, PM₁₀, and PM_{2.5} from the diesel engine generator sets (Ref. Nos. EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04), with annual emissions calculated daily, as the sum of each consecutive 365-day period, to verify compliance with the annual emission limits in Condition 16E

- l. All fuel supplier certifications.
- m. Engine information including make, model, serial number, model year, maximum engine power (bhp), and engine displacement for each engine-generator set.
- n. The manufacturer's written operating instructions or procedures developed by the owner/operator that are approved by the engine manufacturer for each engine-generator set.
- o. Records of the reasons for operation for each engine-generator set including, but not limited to, the date, cause of operation, cause of the emergency, and the hours of operation.
- p. Operation and control device monitoring records for each engine-generator set (Ref. Nos. Ref. Nos. EG01 through EG05, EG06, EG07 through EG15, EG-2-01 through EG-2-31, EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) as required in Condition 3.
- q. Results of all stack tests and visible emission evaluations.
- r. Records that each generator (Ref. Nos. EG01 through EG6) is certified to achieve the emission standard required by Condition 17.
- s. Scheduled and unscheduled maintenance and operator training.

These records shall be available for inspection by DEQ and shall be current for the most recent five years.

(9 VAC 5-80-1180 and 9 VAC 5-50-50) [April 9, 2026]

NOTIFICATIONS

23. Initial Notifications - The permittee shall furnish written notification to the Piedmont Regional Office of:
 - a. The actual date on which construction of the engine-generator sets (Ref. Nos. EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) commenced within 30 days after such date.
 - b. The anticipated start-up date of the engine-generator set (Ref. Nos. EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-

24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) postmarked not more than 60 days nor less than 30 days prior to such date.

- c. The actual start-up date of the engine-generator set (Ref. Nos. EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) within 15 days after such date. The actual start-up date shall be the date on which each engine completes manufacturer's trials but shall be no later than thirty days after the initial startup for manufacturer's trials.
- d. The anticipated date of the performance tests and visible emissions evaluation of the applicable engine-generator set (Ref. Nos. EG-3-H, EG-3-01 through EG-3-28, EG-DD1A-01 through EG-DD1A-24, EG-DD1B-01 through EG-DD1B-13, EG-DD1C-01 through EG-DD1C-04, EG-DD2A-01 through EG-DD2A-24, EG-DD2B-01 through EG-DD2B-13, and EG-DD2C-01 through EG-DD2C-04) postmarked at least 30 days prior to such date.

(9 VAC 5-80-1180 and 9 VAC 5-50-50) [April 9, 2026]

GENERAL CONDITIONS

24. Permit Invalidation - This permit approval dated April 9, 2026 to construct the project shall become invalid, unless an extension is granted by the DEQ, if:

- a. A program of continuous construction is not commenced within 18 months from the date of this permit.
- b. A program of construction is discontinued for a period of 18 months or more, or is not completed within a reasonable time, except for a DEQ approved period between phases of the phased construction of a new stationary source or project.

(9 VAC 5-80-1210)

25. Permit Suspension/Revocation - This permit may be suspended or revoked if the permittee:

- a. Knowingly makes material misstatements in the permit application or any amendments to it;
- b. Fails to comply with the conditions of this permit;
- c. Fails to comply with any emission standards applicable to a permitted emissions unit;
- d. Causes emissions from the stationary source which result in violations of, or interfere with the attainment and maintenance of, any ambient air quality standard; or

- e. Fails to operate in conformance with any applicable control strategy, including any emission standards or emissions limitations, in the State Implementation Plan in effect at the time an application for this permit is submitted.

(9 VAC 5-80-1210 G)

26. Right of Entry - The permittee shall allow authorized local, state, and federal representatives, upon the presentation of credentials:
- a. To enter upon the permittee's premises on which the facility is located or in which any records are required to be kept under the terms and conditions of this permit;
 - b. To have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit or the State Air Pollution Control Board Regulations;
 - c. To inspect at reasonable times any facility, equipment, or process subject to the terms and conditions of this permit or the State Air Pollution Control Board Regulations; and
 - d. To sample or test at reasonable times.

For purposes of this condition, the time for inspection shall be deemed reasonable during regular business hours or whenever the facility is in operation. Nothing contained herein shall make an inspection time unreasonable during an emergency.

(9 VAC 5-170-130 and 9 VAC 5-80-1180)

27. Maintenance/Operating Procedures - At all times, including periods of start-up, shutdown, and malfunction, the permittee shall, to the extent practicable, maintain and operate the affected source, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

The permittee shall take the following measures in order to minimize the duration and frequency of excess emissions:

- a. Develop a maintenance schedule and maintain records of all scheduled and non-scheduled maintenance.
- b. Maintain an inventory of spare parts.
- c. Have available written operating procedures for equipment. These procedures shall be based on the manufacturer's recommendations, at a minimum.
- d. Train operators in the proper operation of all such equipment and familiarize the operators with the written operating procedures, prior to their first operation of such

equipment. The permittee shall maintain records of the training provided including the names of trainees, the date of training and the nature of the training.

Records of maintenance and training shall be maintained on site for a period of five years and shall be made available to DEQ personnel upon request.

(9 VAC 5-50-20 E and 9 VAC 5-80-1180 D)

28. Record of Malfunctions - The permittee shall maintain records of the occurrence and duration of any bypass, malfunction, shutdown or failure of the facility or its associated air pollution control equipment that results in excess emissions for more than one hour. Records shall include the date, time, duration, description (emission unit, pollutant affected, cause), corrective action, preventive measures taken and name of person generating the record.
(9 VAC 5-20-180 J and 9 VAC 5-80-1180 D)
29. Notification for Facility or Control Equipment Malfunction - The permittee shall furnish notification to the Piedmont Regional Office of malfunctions of the affected facility or related air pollution control equipment that may cause excess emissions for more than one hour. Such notification shall be made no later than four daytime business hours after the malfunction is discovered. The permittee shall provide a written statement giving all pertinent facts, including the estimated duration of the breakdown, within 14 days of discovery of the malfunction. When the condition causing the failure or malfunction has been corrected and the equipment is again in operation, the permittee shall notify the Piedmont Regional Office.
(9 VAC 5-20-180 C and 9 VAC 5-80-1180)
30. Violation of Ambient Air Quality Standard - The permittee shall, upon request of the DEQ, reduce the level of operation or shut down a facility, as necessary to avoid violating any primary ambient air quality standard and shall not return to normal operation until such time as the ambient air quality standard will not be violated.
(9 VAC 5-20-180 I and 9 VAC 5-80-1180)
31. Change of Ownership - In the case of a transfer of ownership of a stationary source, the new owner shall abide by any current permit issued to the previous owner. The new owner shall notify the Piedmont Regional Office of the change of ownership within 30 days of the transfer.
(9 VAC 5-80-1240)
32. Permit Copy - The permittee shall keep a copy of this permit on the premises of the facility to which it applies.
(9 VAC 5-80-1180)

SOURCE TESTING REPORT FORMAT

Report Cover

1. Plant name and location
2. Units tested at source (indicate Ref. No. used by source in permit or registration)
3. Test Dates.
4. Tester; name, address and report date

Certification

1. Signed by team leader/certified observer (include certification date)
2. Signed by responsible company official
3. *Signed by reviewer

Copy of approved test protocol

Summary

1. Reason for testing
2. Test dates
3. Identification of unit tested & the maximum rated capacity
4. *For each emission unit, a table showing:
 - a. Operating rate
 - b. Test Methods
 - c. Pollutants tested
 - d. Test results for each run and the run average
 - e. Pollutant standard or limit
5. Summarized process and control equipment data for each run and the average, as required by the test protocol
6. A statement that test was conducted in accordance with the test protocol or identification & discussion of deviations, including the likely impact on results
7. Any other important information

Source Operation

1. Description of process and control devices
2. Process and control equipment flow diagram
3. Sampling port location and dimensioned cross section. Attached protocol includes: sketch of stack (elevation view) showing sampling port locations, upstream and downstream flow disturbances and their distances from ports; and a sketch of stack (plan view) showing sampling ports, ducts entering the stack and stack diameter or dimensions

Test Results

1. Detailed test results for each run
2. *Sample calculations
3. *Description of collected samples, to include audits when applicable

Appendix

1. *Raw production data
2. *Raw field data
3. *Laboratory reports
4. *Chain of custody records for lab samples
5. *Calibration procedures and results
6. Project participants and titles
7. Observers' names (industry and agency)
8. Related correspondence
9. Standard procedures

* Not applicable to visible emission evaluations