

Procedure for Telemecanique V4 PLC transfer to V5 version

1. Copy V5 new station from exist.
2. Ren bin \plc_3\appli\F12.bin to PL7_3.bin
3. Run PL7_3 icon
4. Run icon "V5 conf and confirm:V5 processor (Yes)
5. Choose 1-reconfiguration
6. If message showing "16136 reconfigurationOK", re configuration is successful.
7. Choose "Store " twice.
8. Choose Yes if message showing "FILE ALREADY EXIST: Replace?"
9. When Message "Save completed"
10. Select transfer in station tools.
11. Select transfer menu with " transfer from disk to PLC station" & " complete transfer : from Disk to PLC station"
12. If screen shows "Upload complete", then you done.