

F-13 MODULE LIST

MAST

MAIN - CALL SUBROUTINES
SR0 - CONFIGURATION SCM 2222
SR1 - READ/WRITE DATA TO PC;PLC
SR2 - CONFIGURATION AEM 413
SR3 - CONFIGURATION AEM 811
SR4 - CONFIGURATION ASR 403
SR5 - ALL EQUIPMENTS - CONTACT ANSWER
SR6 - MDO
SR7 - CHILL ROLL
SR8 - START ALL EQUIPMENTS - INTERNAL BIT
SR9 - TDO (EXCEPT BLOWERS & BURNERS)
SR10 - TDO BLOWERS
SR11 - TDO BURNERS
SR12 - PRS & AUX WINDER #3
SR13 - COLD & WARM START INITIALIZATION
SR14 - DC MOTOR INTERLOCK
SR15 - MDO WARM DC MOTOR INTERLOCK
SR16 - TEMPERATURE MEASURE
SR17 - TEMPERATUER CONTROL OUTPUT 4-20MA
SR18 - TEMPERATURE CONTROL - TRANSFER SET VALUE FROM PC -> PLC
SR19 - TEMPERATURE CONTROL - TRANSFER ALARM FROM PLC -> PC
SR20 - KLAXON OF F13
SR21 - ROTATING LIGHT OF F13
SR22 - RELEASE ALL DEFECT
SR23 - INCREASE ALL SET POINT TDO
SR24 - SCREEN TOP FAULT VIEWS

AUX0

MAIN - CALL P.I.D CONTROL LOOPS
SR0 - P.I.D CONTROL OUTPUT CALCULATION

F13 I/O LIST

F13\INPUTBIT.DOC

I/O WORD	DESCRIPTION	SYMBOL	PAGE # (DRAW')
I80,0	FAN FOR EXHAUST HOOD F23	M1263-01	64
I80,1	AIR KNIFE BLOWER F23	M1310-01	64
I80,2	FILM WATER REMOVAL BLOWER #1 F23	M1310-02	64
I80,3	FILM WATER REMOVAL BLOWER #2 F23	M1310-03	64
I80,4	C. R. DRYING BLOWER F23	M1330-01	64
I80,5	C. R. BRAKE ELECTRON MAGNETIC BRAKE F23	Y1302-01	64
I80,6	(FREE)		64
I80,7	AUX. WINDER #1 F23	M1360-01 & 02	64
I80,8	(FREE)		65
I80,9	(FREE)		65
I80,A	(FREE)		65
I80,B	(FREE)		65
I80,C	AUX. WINDER #2 (W506,A) F23	M1450-01 & 02	65
I80,D	MDO PUMP, ROLL #1&2 (Z1) F23	M1430-01	65
I80,E	MDO PUMP, ROLL #3&4 (Z2) F23	M1430-02	65
I80,F	MDO PUMP, ROLL #5&6 (Z3) F23	M1430-03	65
I81,0	TDO CENT. EXHAUST AIR FAN F24	M1525-01	68
I81,1	TDO CLIPS COOLING FAN (INLET) F24	M1528-01	68
I81,2	TDO CLIPS COOLING FAN (MIDDLE) F24	M1528-02	68
I81,3	TDO CLIPS COOLING FAN (INTERVAL) F24	M1528-03	68
I81,4	TDO EXHAUST AIR FAN (OUTLET) F24	M1530-01	68
I81,5	(FREE)		68
I81,6	(FREE)		68
I81,7	TDO FAN ZONE 1 (H.S) - E185 F24	M1520-01	68
I81,8	TDO FAN ZONE 1 (L.S) - E185 F24	M1520-01	69
I81,9	TDO FAN ZONE 2 (H.S) - E187 F24	M1520-02	69
I81,A	TDO FAN ZONE 2 (L.S) - E187 F24	M1520-02	69
I81,B	TDO FAN ZONE 3 (H.S) - E188 F24	M1520-03	69
I81,C	TDO FAN ZONE 3 (L.S) - E188 F24	M1520-03	69
I81,D	TDO FAN ZONE 4 (H.S) - E189 F24	M1520-04	69
I81,E	TDO FAN ZONE 4 (L.S) - E189 F24	M1520-04	69
I81,F	TDO FAN ZONE 5 (H.S) - E190 F24	M1520-05	69
I82,0	TDO FAN 2 ZONE 11 (L.S) - E198 F24	M1520-13	72
I82,1	TDO FAN 1 ZONE 12 (H.S) - E199 F24	M1520-14	72
I82,2	TDO FAN 1 ZONE 12 (L.S) - E199 F24	M1520-14	72
I82,3	TDO FAN 2 ZONE 12 (H.S) - E200 F24	M1520-15	72
I82,4	TDO FAN 2 ZONE 12 (L.S) - E200 F24	M1520-15	72
I82,5	TDO FAN 1 ZONE 13 (H.S) - E201 F24	M1520-16	72
I82,6	TDO FAN 1 ZONE 13 (L.S) - E201 F24	M1520-16	72
I82,7	TDO FAN 2 ZONE 13 (H.S) - E202 F24	M1520-17	72
I82,8	TDO FAN 2 ZONE 13 (L.S) - E202 F24	M1520-17	73
I82,9	TDO FAN 1 ZONE 14 (H.S) - E203 F24	M1520-18	73
I82,A	TDO FAN 1 ZONE 14 (L.S) - E203 F24	M1520-18	73
I82,B	TDO FAN 2 ZONE 14 (H.S) - E204 F24	M1520-19	73
I82,C	TDO FAN 2 ZONE 14 (L.S) - E204 F24	M1520-19	73

I82,D	TDO FAN 1 ZONE 15 (H.S) - E205	F24	M1520-20	73
I82,E	TDO FAN 1 ZONE 15 (L.S) - E205	F24	M1520-20	73
I82,F	TDO FAN 2 ZONE 15 (H.S) - E206	F24	M1520-21	73
I83,0	TDO FAN 2 ZONE 19 (L.S) - E214	F24	M1520-29	76
I83,1	TDO FAN 1 ZONE 20 (H.S) - E215	F24	M1520-30	76
I83,2	TDO FAN 1 ZONE 20 (L.S) - E215	F24	M1520-30	76
I83,3	TDO FAN 2 ZONE 20 (H.S) - E216	F24	M1520-31	76
I83,4	TDO FAN 2 ZONE 20 (L.S) - E216	F24	M1520-31	76
I83,5	TDO FAN 1 COOLING ZONE (H.S) - E217	F24	M1520-32	76
I83,6	TDO FAN 1 COOLING ZONE (L.S) - E217	F24	M1520-32	76
I83,7	TDO FAN 2 COOLING ZONE (H.S) - E218	F24	M1520-33	76
I83,8	TDO FAN 2 COOLING ZONE (L.S) - E218	F24	M1520-33	77
I83,9	TDO FAN 3 COOLING ZONE (H.S) - E219	F24	M1520-34	77
I83,A	TDO FAN 3 COOLING ZONE (L.S) - E219	F24	M1520-34	77
I83,B	TDO FAN 4 COOLING ZONE (H.S) - E220	F24	M1520-35	77
I83,C	TDO FAN 4 COOLING ZONE (L.S) - E220	F24	M1520-35	77
I83,D	(FREE)			77
I83,E	(FREE)			77
I83,F	FAN FOR VACUUM ROLL	F24	M1812-01	77
I84,0	C. R. HAND CRANK	C. R	ZS1301-03	80
I84,1	C. R. HOME POS.	C. R	ZS1301-04	80
I84,2	C. R. HIGH/LOW SPEED	C. R	ZS1301-05	80
I84,3	C. R. WORKING POS.	C. R	ZS1301-06	80
I84,4	AIR KNIFE IN WORK POS. (DRIVING SIDE)	C. R	ZSH1310-05	80
I84,5	AIR KNIFE IN WORK POS. (OPERATING SIDE)	C. R	ZSH1310-06	80
I84,6	AIR KNIFE IN HOME POS. (DRIVING SIDE)	C. R	ZSH1310-07	80
I84,7	AIR KNIFE IN HOME POS. (OPERATING SIDE)	C. R	ZSH1310-08	80
I84,8	ROLL #1 LOW POS.	MDO	ZSL1402-04	81
I84,9	ROLL #1 MIDDLE POS.	MDO	ZSM1402-05	81
I84,A	ROLL #1 INTER POS.	MDO	ZSI1402-06	81
I84,B	ROLL #1 HIGH POS.	MDO	ZSH1402-07	81
I84,C	ROLL #2 LOW POS.	MDO	ZSL1402-08	81
I84,D	ROLL #2 MIDDLE POS.	MDO	ZSM1402-09	81
I84,E	ROLL #2 INTER POS.	MDO	ZSI1402-10	81
I84,F	ROLL #2 HIGH POS.	MDO	ZSH1402-11	81
I85,0	COR. ELECTRODE 1 IN POS., R SIDE	PRS	ZSH1820-08	84
I85,1	COR. ELECTRODE 1 PRESSURE (INSTALLED, BUT DOESN'T WORK)	PRS	PSL1820-09	84
I85,2	COR. ELECTRODE 1 IN POS., L SIDE	PRS	ZSH1820-10	84
I85,3	COR. ELECTRODE 3 IN POS., R SIDE	PRS	ZSH1820-12	84
I85,4	COR. ELECTRODE 3 PRESSURE (INSTALLED, BUT DOESN'T WORK)	PRS	PSL1820-14	84
I85,5	COR. ELECTRODE 3 IN POS., L SIDE PRS WEB DETECTOR	PRS	ZSH1820-13	84
I85,6	COR. ELECTRODE 2 IN POS., R SIDE PRS WEB DETECTOR	PRS	ZSL1820-17	84
I85,7	COR. ELECTRODE 2 IN POS., L SIDE	PRS	ZSL1820-18	84
I85,8	COR. ELECTRODE 2 PRESSURE PRS (INSTALLED, BUT DOESN'T WORK)		PSL1820-19	85

I85,9	EXTRAC. FLOW #1	PRS	FSL1831-06	85
I85,A	EXTRAC. FLOW #3	PRS	FSL1831-07	85
I85,B	AUX. WINDER 3, AIR PRESSURE LOW	PRS	PSL1860-	85
I85,C	(FREE)			85
I85,D	WEB BREAK DETECTOR	PRS	ZT1840-10	85
I85,E	ANTENNA SENSOR O.S. - XE01	PRS		85
I85,F	ANTENNA SENSOR D.S. - XE01	PRS		85
I86,0	EXHAUST HOOD - START	F32		88
I86,1	EXHAUST HOOD - STOP	F32		88
I86,2	EDGE PINNING - START	F32		88
I86,3	EDGE PINNING - STOP	F32		88
I86,4	C. R. FORWARD	F32		88
I86,5	C. R. BACKWARD	F32		88
I86,6	C. R. STOP	F32		88
I86,7	AIR KNIFE - ENGAGE	F32		88
I86,8	AIR KNIFE - RETRACT	F32		89
I86,9	AIR KNIFE BLOWER - START	F32		89
I86,A	AIR KNIFE BLOWER - STOP	F32		89
I86,B	FILM REMOVAL POS. ENGAGE	F32		89
I86,C	FILM REMOVAL POS. RETRACT	F32		89
I86,D	RUBBER ROLL - ENGAGE	F32		89
I86,E	RUBBER ROLL - RETRACT	F32		89
I86,F	CHROMED ROLL - ENGAGE	F32		89
I87,0	MDO STOP	F40		92
I87,1	THREADING SYSTEM - START	F40		92
I87,2	THREADING SYSTEM - STOP	F40		92
I87,3	(FREE)			92
I87,4	TREADING SYSTEM - STOP	F41		92
I87,5	MDO STOP	F41		92
I87,6	PRESS ROLL INLET - ENGAGE	F42		92
I87,7	PRESS ROLL INLET - RETRACT	F42		92
I87,8	PRESS ROLL OUTLET - ENGAGE	F42		93
I87,9	PRESS ROLL OUTLET - RETRACT	F42		93
I87,A	NIP ROLL 1 - ENGAGE	F42		93
I87,B	NIP ROLL 1 - RETRACT	F42		93
I87,C	NIP ROLL 2 - ENGAGE	F42		93
I87,D	NIP ROLL 2 - RETRACT	F42		93
I87,E	NIP ROLL 3 - ENGAGE	F42		93
I87,F	NIP ROLL 3 - RETRACT	F42		93
I90,0	PUMP ROLL #7&8	F23	M1430-04	66
I90,1	PUMP ROLL #9&10	F23	M1430-05	66
I90,2	PUMP ROLL #11&12	F23	M1430-06	66
I90,3	PUMP ROLL #13&14	F23	M1430-07	66
I90,4	PUMP ROLL #15&16	F23	M1430-08	66
I90,5	PUMP ROLL #17&18	F23	M1430-09	66
I90,6	PUMP ROLL #19&20	F23	M1430-10	66
I90,7	PUMP ROLL #21&22	F23	M1430-11	66
I90,8	PUMP ROLL #23&24	F23	M1430-12	67
I90,9	(FREE)			67

I90,A	(FREE)			67
I90,B	(FREE)			67
I90,C	(FREE)			67
I90,D	(FREE)			67
I90,E	(FREE)			67
I90,F	(FREE)			67
I91,0	AIR FAN ZONE 5 (L.S)	F24	M1520-05	70
I91,1	AIR FAN ZONE 6 (H.S)	F24	M1520-06	70
I91,2	AIR FAN ZONE 6 (L.S)	F24	M1520-06	70
I91,3	AIR FAN ZONE 7 (H.S)	F24	M1520-07	70
I91,4	AIR FAN ZONE 7 (L.S)	F24	M1520-07	70
I91,5	AIR FAN ZONE 8 (H.S)	F24	M1520-08	70
I91,6	AIR FAN ZONE 8 (L.S)	F24	M1520-08	70
I91,7	AIR FAN ZONE 9 (H.S)	F24	M1520-09	70
I91,8	AIR FAN ZONE 9 (L.S)	F24	M1520-09	71
I91,9	AIR FAN 1 ZONE 10 (H.S)	F24	M1520-10	71
I91,A	AIR FAN 1 ZONE 10 (L.S)	F24	M1520-10	71
I91,B	AIR FAN 2 ZONE 10 (H.S)	F24	M1520-11	71
I91,C	AIR FAN 2 ZONE 10 (L.S)	F24	M1520-11	71
I91,D	AIR FAN 1 ZONE 11 (H.S)	F24	M1520-12	71
I91,E	AIR FAN 1 ZONE 11 (L.S)	F24	M1520-12	71
I91,F	AIR FAN 2 ZONE 11 (H.S)	F24	M1520-13	71
I92,0	AIR FAN 2 ZONE 15 (L.S)	F24	M1520-21	74
I92,1	AIR FAN 1 ZONE 16 (H.S)	F24	M1520-22	74
I92,2	AIR FAN 1 ZONE 16 (L.S)	F24	M1520-22	74
I92,3	AIR FAN 2 ZONE 16 (H.S)	F24	M1520-23	74
I92,4	AIR FAN 2 ZONE 16 (L.S)	F24	M1520-23	74
I92,5	AIR FAN 1 ZONE 17 (H.S)	F24	M1520-24	74
I92,6	AIR FAN 1 ZONE 17 (L.S)	F24	M1520-24	74
I92,7	AIR FAN 2 ZONE 17 (H.S)	F24	M1520-25	74
I92,8	AIR FAN 2 ZONE 17 (L.S)	F24	M1520-25	75
I92,9	AIR FAN 1 ZONE 18 (H.S)	F24	M1520-26	75
I92,A	AIR FAN 1 ZONE 18 (L.S)	F24	M1520-26	75
I92,B	AIR FAN 2 ZONE 18 (H.S)	F24	M1520-27	75
I92,C	AIR FAN 2 ZONE 18 (L.S)	F24	M1520-27	75
I92,D	AIR FAN 1 ZONE 19 (H.S)	F24	M1520-28	75
I92,E	AIR FAN 1 ZONE 19 (L.S)	F24	M1520-28	75
I92,F	AIR FAN 2 ZONE 19 (H.S)	F24	M1520-29	75
I93,0	FAN FOR VACUUM ROLL	F24	M1825-01	78
I93,1	OZONE EXHAUST 1	F24	M1831-01	78
I93,2	OZONE EXHAUST 2	F24	M1831-02	78
I93,3	OZONE EXHAUST 3	F24	M1831-03	78
I93,4	OZONE TREATER FAN 1	F24		78
I93,5	OZONE TREATER FAN 2	F24		78
I93,6	OZONE TREATER FAN 3	F24		78
I93,7	OZONE TREATER FAN 4	F24		78
I93,8	(FREE)			79
I93,9	(FREE)			79
I93,A	(FREE)			79

I93,B	CHAIN TENSION - HYDRAULIC PUMP	F24	M1515-01	79
I93,C	(FREE)			79
I93,D	(FREE)			79
I93,E	(FREE)			79
I93,F	(FREE)			79
I94,0	STRETCHING ROLL #3 LOW POS.	MDO	ZSL1402-12	82
I94,1	STRETCHING ROLL #3 MIDDLE POS.	MDO	ZSM1402-13	82
I94,2	STRETCHING ROLL #3 INTER. POS.	MDO	ZSI1402-14	82
I94,3	STRETCHING ROLL #3 HIGH POS.	MDO	ZSH1402-15	82
I94,4	MDO WEB BREAK OCT.	MDO	ZT1420-01	82
I94,5	MDO WEB BREAK OCT.	MDO	ZT1420-02	82
I94,6	TDO FAULT ALARM	TDO		82
I94,7	TDO FAST STOP , CRITICAL ALARM	TDO		82
I94,8	CHAIN TENSION OIL PUMP LOW LEVEL	TDO	LSL1515-02	83
I94,9	CHAIN TENSION PUMP PRESSURE LOW	TDO	PSL1515-03	83
I94,A	WEB BREAK FILM (F149) TDO EXIT	TDO	ZT1531-01	83
I94,B	WEB BREAK FILM (F148) COOLING ZONE	TDO	ZT1531-02	83
I94,C	DRIVE SIDE TENSION		ZS1515-06	83
I94,D	OPERATOR SIDE TENSION		ZS1515-07	83
I94,E	DRIVE SIDE COUNTER (TDO OUTLET SPROCKET)	TDO	ZS1550-01	83
I94,F	OPERATOR SIDE COUNTER MDO WEB DET. (TDO OUTLET SPROCKET)	MDO	ZS1550-02	83
I95,0	AUX. WINDER 1 THERMOSTAT		TSH1360-03	86
I95,1	AUX. WINDER 2 THERMOSTAT		TSH1450-03	86
I95,2	C. R. WATER BATH LEVEL SWITCH	C. R	LSL1350-03	86
I95,3	NIP ROLL 1 IN POS.	MDO	ZSH1404-06	86
I95,4	NIP ROLL 1 IN POS.	MDO	ZSH1404-07	86
I95,5	NIP ROLL 2 IN POS.	MDO	ZSH1404-08	86
I95,6	NIP ROLL 2 IN POS.	MDO	ZSH1404-09	86
I95,7	NIP ROLL 3 IN POS.	MDO	ZSH1404-10	86
I95,8	NIP ROLL 3 IN POS.	MDO	ZSH1404-11	87
I95,9	PRESS ROLL INLET IN POS.	MDO	ZSH1404-12	87
I95,A	PRESS ROLL INLET IN POS.	MDO	ZSH1404-13	87
I95,B	PRESS ROLL OUTLET IN POS.	MDO	ZSH1404-14	87
I95,C	PRESS ROLL OUTLET IN POS.	MDO	ZSH1404-15	87
I95,D	PRS WEB BREAK	PRS		87
I95,E	PRS WEB BREAK	PRS		87
I95,F	PRS WEB BREAK	PRS		87
I96,0	CHROMED ROLL - RETRACT	F32		90
I96,1	C. R. WATER REMOVAL - START	F32		90
I96,2	C. R. WATER REMOVAL - STOP	F32		90
I96,3	FILM WATER REMOVAL - START, 1	F32		90
I96,4	FILM WATER REMOVAL - STOP, 1	F32		90
I96,5	FILM WATER REMOVAL - START, 2	F32		90
I96,6	FILM WATER REMOVAL - STOP, 2	F32		90
I96,7	WATER BATH LEVEL - ON	F32	90S32	90
I96,8	WATER BATH LEVEL - AUTO	F32	90S32	91
I96,9	C. R. STOP	F32		91

I96,A	INST. AIR START (NO USE)	F32		91
I96,B	INST. AIR STOP (NO USE)	F32		91
I96,C	TEST LAMPS	F32		91
I96,D	(FREE)			91
I96,E	(FREE)			91
I96,F	(FREE)			91
I97,0	STRETCHING ROLL 1 - UP			94
I97,1	STRETCHING ROLL 1 - DOWN			94
I97,2	STRETCHING ROLL 2 - UP	F42		94
I97,3	STRETCHING ROLL 2 - DOWN	F42		94
I97,4	STRETCHING ROLL 3 - UP	F42		94
I97,5	STRETCHING ROLL 3 - DOWN	F42		94
I97,6	GENERAL STRETCHING ROLL - UP	F42		94
I97,7	GENERAL STRETCHING ROLL - DOWN	F42		94
I97,8	FILM <> 60 MICRO-M	F42		95
I97,9	WEB BREAK DETECTOR MDO	F42		95
I97,A	MDO STOP	F42		95
I97,B	(FREE)			95
I97,C	LAMPS TEST	F42		95
I97,D	(FREE)			95
I97,E	(FREE)			95
I97,F	(FREE)			95
IA0,0	AUX. WINDER 2 MOTOR - START	F46		97
IA0,1	AUX. WINDER 2 MOTOR - STOP	F46		97
IA0,2	AUX. WINDER 2 SPINDLE - ENGAGE	F46		97
IA0,3	AUX. WINDER 2 SPINDLE - RETRACT	F46		97
IA0,4	AUX. WINDER 2 FOOT SWITCH	F46		97
IA0,5	AUX. WINDER 1 MOTOR - START	F36		97
IA0,6	AUX. WINDER 1 MOTOR - STOP	F36		97
IA0,7	AUX. WINDER 1 SPINDLE - ENGAGE	F36		97
IA0,8	AUX. WINDER 1 SPINDLE - RETRACT	F36		98
IA0,9	AUX. WINDER 1 FOOT SWITCH	F36		98
IA0,A	AUX. WINDER 3 WEB BREAK BYPASS	F70		98
IA0,B	TDO DEFECT TO F13 SHUT OFF BLOWER	F50		98
IA0,C	CLIPS OPENING/CLOSING	F50		98
IA0,D	CHAIN TENSION START	F50		98
IA0,E	CHAIN TENSION STOP	F50		98
IA0,F	TDO STOP	F50		98
IA1,0	VACUUM ROLL 1 - START	F55		101
IA1,1	VACUUM ROLL 1 - STOP	F55		101
IA1,2	WEB BREAK PRS BYPASS / ON	F55		101
IA1,3	OZONE EXHAUST FAN 1 - START	F55		101
IA1,4	OZONE EXHAUST FAN 1 - STOP	F55		101
IA1,5	OZONE EXHAUST FAN 2 - START	F55		101
IA1,6	OZONE EXHAUST FAN 2 - STOP	F55		101
IA1,7	OZONE EXHAUST FAN 3 - START	F55		101
IA1,8	OZONE EXHAUST FAN 3 - STOP	F55		102
IA1,9	VACUUM ROLL 2 - START	F55		102
IA1,A	VACUUM ROLL 2 - STOP	F55		102

IA1,B	NIP ROLL FOR CORONA #1 - ENGAGE	F55		102
IA1,C	NIP ROLL FOR CORONA #1 - RETRACT	F55		102
IA1,D	COR. ELECTRODE 1 ENGAGE	F55		102
IA1,E	COR. ELECTRODE 1 RETRACT	F55		102
IA1,F	NIP ROLL FOR CORONA #3 - ENGAGE	F55		102
IA2,0	NIP ROLL FOR CORONA #1 - ENGAGE	F56		105
IA2,1	NIP ROLL FOR CORONA #1 - RETRACT	F56		105
IA2,2	NIP ROLL FOR CORONA #3 - ENGAGE	F56		105
IA2,3	NIP ROLL FOR CORONA #3 - RETRACT	F56		105
IA2,4	SPREADER ROLL 2 ENGAGE	F56		105
IA2,5	SPREADER ROLL 2 RETRACT	F56		105
IA2,6	SPREADER ROLL 3 ENGAGE	F56		105
IA2,7	SPREADER ROLL 3 RETRACT	F56		105
IA2,8	OP. SPREADER ROLL 2 ENGAGE	F66		106
IA2,9	OP. SPREADER ROLL 2 RETRACT	F66		106
IA2,A	DRIVE SPREADER ROLL 2 ENGAGE	F66		106
IA2,B	DRIVE SPREADER ROLL 2 RETRACT	F66		106
IA2,C	OP. SPREADER ROLL 3 ENGAGE	F68		106
IA2,D	OP. SPREADER ROLL 3 RETRACT	F68		106
IA2,E	DRIVE SPREADER ROLL 3 ENGAGE	F68		106
IA2,F	DRIVE SPREADER ROLL 3 RETRACT	F68		106
IA3,0	BURNER 1 ON	F151		109
IA3,1	BURNER 1 DEFECT	F151		109
IA3,2	BURNER 2 ON	F152		109
IA3,3	BURNER 2 DEFECT	F152		109
IA3,4	BURNER 3 ON	F153		109
IA3,5	BURNER 3 DEFECT	F153		109
IA3,6	BURNER 4 ON	F154		109
IA3,7	BURNER 4 DEFECT	F154		109
IA3,8	BURNER 5 ON	F155		110
IA3,9	BURNER 5 DEFECT	F155		110
IA3,A	BURNER 6 ON	F156		110
IA3,B	BURNER 6 DEFECT	F156		110
IA3,C	BURNER 7 ON	F157		110
IA3,D	BURNER 7 DEFECT	F157		110
IA3,E	BURNER 8 ON	F158		110
IA3,F	BURNER 8 DEFECT	F158		110
IA4,0	BURNER 17 ON	F167		113
IA4,1	BURNER 17 DEFECT	F167		113
IA4,2	BURNER 18 ON	F168		113
IA4,3	BURNER 18 DEFECT	F168		113
IA4,4	BURNER 19 ON	F169		113
IA4,5	BURNER 19 DEFECT	F169		113
IA4,6	BURNER 20 ON	F170		113
IA4,7	BURNER 20 DEFECT	F170		113
IA4,8	RELEASE DEFECT	F12		114
IA4,9	RELEASE KLAXON (ALARM)	F12		114
IA4,A	UP TO SPEED FOR TREATERS FROM F16 (075,A) - XE02			114
IA4,B	CORONA A DEFECT			114

IA4,C	(FREE) INTRO STRETCH SIGNAL FOR PRS BARRIER		114
IA4,D	(FREE) LOW STRETCH SIGNAL FOR PRS BARRIER		114
IA4,E	CORONA B DEFECT		114
IA4,F	(FREE)		114
IA5,0	UP TO SPEED FOR TREATERS FROM F16 (075,A) - XE01		117
IA5,1	(FREE)		117
IA5,2	(FREE)		117
IA5,3	(FREE)		117
IA5,4	(FREE)		117
IA5,5	(FREE)		117
IA5,6	(FREE)		117
IA5,7	(FREE)		117
IA5,8	(FREE)		118
IA5,9	(FREE)		118
IA5,A	(FREE)		118
IA5,B	(FREE)		118
IA5,C	(FREE)		118
IA5,D	(FREE)		118
IA5,E	(FREE)		118
IA5,F	(FREE)		118
IA7,0	C. R. RUNNING	F16	125
IA7,1	MDO 1 RUNNING	F16	125
IA7,2	MDO 2 RUNNING	F16	125
IA7,3	MDO 3 RUNNING	F16	125
IA7,4	TDO RUNNING	F16	125
IA7,5	PRS 1 RUNNING	F16	125
IA7,6	PRS 2 RUNNING	F16	125
IA7,7	AUX. 1 RUNNING	F16	125
IA7,8	AUX. 2 RUNNING	F16	126
IA7,9	AUX. WINDER RUNNING	F16	126
IA7,A	PRODUCTION STRETCHING	F16	126
IA7,B	C. R. ROTATION	F16	126
IA7,C	MDO 1 ROTATION	F16	126
IA7,D	MDO 2 ROTATION	F16	126
IA7,E	MDO 3 ROTATION	F16	126
IA7,F	TDO ROTATION	F16	126
IB0,0	AIR ON CLIPS - ON		99
IB0,1	AIR ON CLIPS - AUTO		99
IB0,2	TDO STOP	F52	99
IB0,3	TDO STOP	F53	99
IB0,4	OP. TRIM NIP ROLL ENGAGE	F62	99
IB0,5	OP. NIP ROLL RETRACT	F62	99
IB0,6	DRIVE NIP ROLL ENGAGE	F62	99
IB0,7	DRIVE NIP ROLL RETRACT	F62	99
IB0,8	OP. KNIFE - ENGAGE	F62	100
IB0,9	OP. KNIFE - RETRACT	F62	100
IB0,A	DRIVE KNIFE - ENGAGE	F62	100
IB0,B	DRIVE KNIFE - RETRACT	F62	100
IB0,C	OP. SPREADER ROLL 1 ENGAGE	F62	100

IB0,D	OP. SPREADER ROLL 1 RETRACT	F62		100
IB0,E	DRIVE SPREADER ROLL 1 ENGAGE	F62		100
IB0,F	DRIVE SPREADER ROLL 1 RETRACT	F62		100
IB1,0	NIP ROLL FOR CORONA #3 - RETRACT	F55		103
IB1,1	COR. ELECTRODE 3 ENGAGE	F55		103
IB1,2	COR. ELECTRODE 3 RETRACT	F55		103
IB1,3	COR. ELECTRODE 2 ENGAGE	F55		103
IB1,4	COR. ELECTRODE 2 RETRACT	F55		103
IB1,5	PRS STOP	F55		103
IB1,6	(FREE)			103
IB1,7	LAMPS TEST	F55		103
IB1,8	WEB BREAK TDO BYPASS / ON	F55		104
IB1,9	INDEPENDENT MODE PRS - CORONA TREATERS			104
IB1,A	(FREE)			104
IB1,B	(FREE)			104
IB1,C	(FREE)			104
IB1,D	(FREE)			104
IB1,E	AUX. WINDER 1 WEB BREAK BYPASS	F36		104
IB1,F	AUX. WINDER 2 WEB BREAK BYPASS	F46		104
IB2,0	NIP ROLL ENGAGE	F63		107
IB2,1	NIP ROLL RETRACT	F63		107
IB2,2	KNIFE ENGAGE	F63		107
IB2,3	KNIFE RETRACT	F63		107
IB2,4	SPREADER ROLL 1 ENGAGE	F63		107
IB2,5	SPREADER ROLL 1 RETRACT	F63		107
IB2,6	PRS STOP E	F95		107
IB2,7	PRS STOP E	F63		107
IB2,8	(FREE)			108
IB2,9	AUX. WINDER 3 START	F70		108
IB2,A	AUX. WINDER 3 STOP	F70		108
IB2,B	AUX. WINDER 3 ENGAGE	F70		108
IB2,C	AUX. WINDER 3 RETRACT	F70		108
IB2,D	(FREE)			108
IB2,E	C. R. COOLING STOP			108
IB2,F	WATER BATH COOLING STOP			108
IB3,0	BURNER 9 ON	F159		111
IB3,1	BURNER 9 DEFECT	F159		111
IB3,2	BURNER 10 ON	F160		111
IB3,3	BURNER 10 DEFECT	F160		111
IB3,4	BURNER 11 ON	F161		111
IB3,5	BURNER 11 DEFECT	F161		111
IB3,6	BURNER 12 ON	F162		111
IB3,7	BURNER 12 DEFECT	F162		111
IB3,8	BURNER 13 ON	F163		112
IB3,9	BURNER 13 DEFECT	F163		112
IB3,A	BURNER 14 ON	F164		112
IB3,B	BURNER 14 DEFECT	F164		112
IB3,C	BURNER 15 ON	F165		112
IB3,D	BURNER 15 DEFECT	F165		112

IB3,E	BURNER 16 ON	F166		112
IB3,F	BURNER 16 DEFECT	F166		112
IB4,0	(FREE)			115
IB4,1	(FREE)			115
IB4,2	(FREE)			115
IB4,3	(FREE)			115
IB4,4	(FREE)			115
IB4,5	(FREE)			115
IB4,6	(FREE)			115
IB4,7	(FREE)			115
IB4,8	CORE A DEFECT	CANCELLED		116
IB4,9	CORE A RUNNING	CANCELLED		116
IB4,A	CORE B DEFECT	CANCELLED		116
IB4,B	CORE B RUNNING	CANCELLED		116
IB4,C	WEB BREAK -> B1211	F201		116
IB4,D	ROLL 2 DEFECT	CANCELLED		116
IB4,E	ROLL 2 RUNNING	CANCELLED		116
IB4,F	LIGHT BARRIER	PRS		116
IB5,0	(FREE)			119
IB5,1	(FREE)			119
IB5,2	(FREE)			119
IB5,3	(FREE)			119
IB5,4	(FREE)			119
IB5,5	(FREE)			119
IB5,6	(FREE)			119
IB5,7	(FREE)			119
IB5,8	(FREE)			119
IB5,9	(FREE)			119
IB5,A	(FREE)			119
IB5,B	(FREE)			119
IB5,C	(FREE)			119
IB5,D	(FREE)			119
IB5,E	(FREE)			119
IB5,F	(FREE)			119
IB7,0	C. R. COOLING ON	C1340	C1340	127
IB7,1	C. R. COOLING DEFECT	C1340	C1340	127
IB7,2	WATER BATH ON	C1350	C1350	127
IB7,3	WATER BATH DEFECT	C1350	C1350	127
IB7,4	MDO OIL SKID ON	C1430	C1430	127
IB7,5	MDO OIL SKID DEFECT	C1430	C1430	127
IB7,6	(FREE)			127
IB7,7	CORONA 1 ON	F75	G1820-01	127
IB7,8	CORONA 1 DEFECT	F75	G1820-01	128
IB7,9	CORONA 2 ON	F76	G1820-02	128
IB7,A	CORONA 2 DEFECT	F76	G1820-02	128
IB7,B	CORONA 3 ON	F77	G1820-03	128
IB7,C	CORONA 3 DEFECT	F77	G1820-03	128
IB7,D	CORONA 4 ON	F78	G1820-04	128
IB7,E	CORONA 4 DEFECT	F78	G1820-04	128

IB7, F	EMERGENCY STOP		128

F13 TO LIST

F13\OUTPUTBIT.DOC

I/O WORD	DESCRIPTION	SYMBOL	PAGE # (DRAW')
OC4,0	FAN FOR DIE EXHAUST HOOD F23	M1260-01	146
OC4,1	AIR KNIFE BLOWER F23	M1310-01	146
OC4,2	FILM WATER REMOVAL BLOWER #1 F23	M1310-02	146
OC4,3	FILM WATER REMOVAL BLOWER #2 F23	M1330-01	146
OC4,4	C. R. DRYING BLOWER F23	M1330-01	146
OC4,5	C. R. BRAKE F23	Y1302-01	146
OC4,6	AUX. WINDER 1 BRAKE (NOT USED) F23		146
OC4,7	AUX. WINDER #1 F23	M1360-01 & 02	146
OC4,8	WYE DELTA FILM DRYING BLOWER		147
OC4,9	(FREE)		147
OC4,A	THREAD UP MOTOR - FAST ROLLS MUST BE UP POSITION		147
OC4,B	AUX. WINDER 2 BRAKE (NOT USED) F23		147
OC4,C	AUX. WINDER #2 F23	M1450-01 & 02	147
OC4,D	MDO PUMP PREHEATING ROLL #1 & 2 F23	M1430-01	147
OC4,E	MDO PUMP STRETCHING ROLL #3 & 4 F23	M1430-02	147
OC4,F	MDO PUMP STRETCHING ROLL #5 & 6 F23	M1430-03	147
OC5,0	CENT. EXHAUST AIR FAN F24	M1525-01	150
OC5,1	CLIPS COOLING FAN - INLET F24	M1520-01	150
OC5,2	CLIPS COOLING FAN - MIDDLE F24	M1520-02	150
OC5,3	CLIPS COOLING FAN - INTERVAL F24	M1520-03	150
OC5,4	TDO EXHAUST FAN - OUTLET F24	M1530-01	150
OC5,5	(FREE)		150
OC5,6	(FREE)		150
OC5,7	TDO FAN ZONE 1 (H.S) - E185 F24	M1520-01	150
OC5,8	TDO FAN ZONE 1 (L.S) - E185 F24	M1520-01	151
OC5,9	TDO FAN ZONE 2 (H.S) - E187 F24	M1520-02	151
OC5,A	TDO FAN ZONE 2 (L.S) - E187 F24	M1520-02	151
OC5,B	TDO FAN ZONE 3 (H.S) - E188 F24	M1520-03	151
OC5,C	TDO FAN ZONE 3 (L.S) - E188 F24	M1520-03	151
OC5,D	TDO FAN ZONE 4 (H.S) - E189 F24	M1520-04	151
OC5,E	TDO FAN ZONE 4 (L.S) - E189 F24	M1520-04	151
OC5,F	TDO FAN ZONE 5 (H.S) - E190 F24	M1520-05	151
OC6,0	TDO FAN W. ZONE 11 (L.S) - E198 F24	M1520-13	154
OC6,1	TDO FAN E. ZONE 12 (H.S) - E199 F24	M1520-14	154
OC6,2	TDO FAN E. ZONE 12 (L.S) - E199 F24	M1520-14	154
OC6,3	TDO FAN W. ZONE 12 (H.S) - E200 F24	M1520-15	154
OC6,4	TDO FAN W. ZONE 12 (L.S) - E200 F24	M1520-15	154
OC6,5	TDO FAN E. ZONE 13 (H.S) - E201 F24	M1520-16	154
OC6,6	TDO FAN E. ZONE 13 (L.S) - E201 F24	M1520-16	154
OC6,7	TDO FAN W. ZONE 13 (H.S) - E202 F24	M1520-17	154
OC6,8	TDO FAN W. ZONE 13 (L.S) - E202 F24	M1520-17	155
OC6,9	TDO FAN E. ZONE 14 (H.S) - E203 F24	M1520-18	155
OC6,A	TDO FAN E. ZONE 14 (L.S) - E203 F24	M1520-18	155
OC6,B	TDO FAN W. ZONE 14 (H.S) - E204 F24	M1520-19	155
OC6,C	TDO FAN W. ZONE 14 (L.S) - E204 F24	M1520-19	155

OC6,D	TDO FAN E. ZONE 15 (H.S) - E205	F24	M1520-20	155
OC6,E	TDO FAN E. ZONE 15 (L.S) - E205	F24	M1520-20	155
OC6,F	TDO FAN W. ZONE 15 (H.S) - E206	F24	M1520-21	155
OC7,0	TDO FAN 2. ZONE 19 (L.S) - E214	F24	M1520-29	158
OC7,1	TDO FAN E. ZONE 20 (H.S) - E215	F24	M1520-30	158
OC7,2	TDO FAN E. ZONE 20 (L.S) - E215	F24	M1520-30	158
OC7,3	TDO FAN W. ZONE 20 (H.S) - E216	F24	M1520-31	158
OC7,4	TDO FAN W. ZONE 20 (L.S) - E216	F24	M1520-31	158
OC7,5	TDO FAN E. COOLING ZONE (H.S) - E217	F24	M1520-32	158
OC7,6	TDO FAN E. COOLING ZONE (L.S) - E217	F24	M1520-32	158
OC7,7	TDO FAN W. COOLING ZONE (H.S) - E218	F24	M1520-33	158
OC7,8	TDO FAN W. COOLING ZONE (L.S) - E218	F24	M1520-33	159
OC7,9	TDO FAN 3 COOLING ZONE (H.S) - E219	F24	M1520-34	159
OC7,A	TDO FAN 3 COOLING ZONE (L.S) - E219	F24	M1520-34	159
OC7,B	TDO FAN 4 COOLING ZONE (H.S) - E220	F24	M1520-35	159
OC7,C	TDO FAN 4 COOLING ZONE (L.S) - E220	F24	M1520-35	159
OC7,D	(FREE)			159
OC7,E	(FREE)			159
OC7,F	FAN FOR PRS1 VACUUM ROLL	F23	M1812-01	159
OD4,0	MDO PUMP ROLL #7 & 8	F23	M1430-04	148
OD4,1	MDO PUMP ROLL #9 & 10	F23	M1430-05	148
OD4,2	MDO PUMP ROLL #11 & 12	F23	M1430-06	148
OD4,3	MDO PUMP ROLL #13 & 14	F23	M1430-07	148
OD4,4	MDO PUMP ROLL #15 & 16	F23	M1430-08	148
OD4,5	MDO PUMP ROLL #17 & 18	F23	M1430-09	148
OD4,6	MDO PUMP ROLL #19 & 20	F23	M1430-10	148
OD4,7	MDO PUMP ROLL #21 & 22	F23	M1430-11	148
OD4,8	MDO PUMP ROLL #23 & 24	F23	M1430-12	149
OD4,9	LI1 (AUX. WINDER 1)	F23	M1360-01	149
OD4,A	LI2 (AUX. WINDER 1)	F23	M1360-01	149
OD4,B	FW (AUX. WINDER 1)	F23	M1360-01	149
OD4,C	LI1 (AUX. WINDER 2)	F23	M1450-01	149
OD4,D	LI2 (AUX. WINDER 2)	F23	M1450-01	149
OD4,E	FW (AUX. WINDER 2)	F23	M1450-01	149
OD4,F	(FREE)			149
OD5,0	TDO FAN ZONE 5 (L.S) - E190	F24	M1520-05	152
OD5,1	TDO FAN ZONE 6 (H.S) - E191	F24	M1520-06	152
OD5,2	TDO FAN ZONE 6 (L.S) - E191	F24	M1520-06	152
OD5,3	TDO FAN ZONE 7 (H.S) - E192	F24	M1520-07	152
OD5,4	TDO FAN ZONE 7 (L.S) - E192	F24	M1520-07	152
OD5,5	TDO FAN ZONE 8 (H.S) - E193	F24	M1520-08	152
OD5,6	TDO FAN ZONE 8 (L.S) - E193	F24	M1520-08	152
OD5,7	TDO FAN ZONE 9 (H.S) - E194	F24	M1520-09	152
OD5,8	TDO FAN ZONE 9 (L.S) - E194	F24	M1520-09	153
OD5,9	TDO FAN ZONE 10 (H.S) - E195	F24	M1520-10	153
OD5,A	TDO FAN ZONE 10 (L.S) - E195	F24	M1520-10	153
OD5,B	TDO FAN W. ZONE 10 (H.S) - E196	F24	M1520-11	153
OD5,C	TDO FAN W. ZONE 10 (L.S) - E196	F24	M1520-11	153
OD5,D	TDO FAN E. ZONE 11 (H.S) - E197	F24	M1520-12	153

OD5,E	TDO FAN E. ZONE 11 (L.S) - E197	F24	M1520-12	153
OD5,F	TDO FAN W. ZONE 11 (H.S) - E198	F24	M1520-13	153
OD6,0	TDO FAN W. ZONE 15 (L.S) - E206	F24	M1520-21	156
OD6,1	TDO FAN E. ZONE 16 (H.S) - E207	F24	M1520-22	156
OD6,2	TDO FAN E. ZONE 16 (L.S) - E207	F24	M1520-22	156
OD6,3	TDO FAN W. ZONE 16 (H.S) - E208	F24	M1520-23	156
OD6,4	TDO FAN W. ZONE 16 (L.S) - E208	F24	M1520-23	156
OD6,5	TDO FAN E. ZONE 17 (H.S) - E209	F24	M1520-24	156
OD6,6	TDO FAN E. ZONE 17 (L.S) - E209	F24	M1520-24	156
OD6,7	TDO FAN W. ZONE 17 (H.S) - E210	F24	M1520-25	156
OD6,8	TDO FAN W. ZONE 17 (L.S) - E210	F24	M1520-25	157
OD6,9	TDO FAN E. ZONE 18 (H.S) - E211	F24	M1520-26	157
OD6,A	TDO FAN E. ZONE 18 (L.S) - E211	F24	M1520-26	157
OD6,B	TDO FAN W. ZONE 18 (H.S) - E212	F24	M1520-27	157
OD6,C	TDO FAN W. ZONE 18 (L.S) - E212	F24	M1520-27	157
OD6,D	TDO FAN E. ZONE 19 (H.S) - E213	F24	M1520-28	157
OD6,E	TDO FAN E. ZONE 19 (L.S) - E213	F24	M1520-28	157
OD6,F	TDO FAN W. ZONE 19 (H.S) - E214	F24	M1520-29	157
OD7,0	FAN FOR PRS2 VACUUM ROLL	F24	M1825-01	160
OD7,1	OZONE EXHAUST 1 (NOT USED)		M1831-01	160
OD7,2	OZONE EXHAUST 2 (NOT USED)		M1831-02	160
OD7,3	OZONE EXHAUST 3 (NOT USED)		M1831-03	160
OD7,4	OZONE TREATER 1	F24		160
OD7,5	OZONE TREATER 2	F24		160
OD7,6	OZONE TREATER 3	F24		160
OD7,7	OZONE TREATER 4	F24		160
OD7,8	RELEASE DEFECT			161
OD7,9	TDO ROTATION			161
OD7,A	TDO CLIPS CLEANING AIR OFF CONDITIONS			161
OD7,B	CHAIN TENSION PUMP		M1515-01	161
OD7,C	CLIP CLEANING AIR OUTPUT			161
OD7,D	(FREE)			161
OD7,E	(FREE)			161
OD7,F	(FREE)			161
OE0,0	C. R. BRAKE	F23	Y1301-02	163
OE0,1	C. R. HOR. MOV. (BACKWARD)	F23	M1301-01	163
OE0,2	C. R. HOR. MOV. (FORWARD)	F23	M1301-01	163
OE0,3	C. R. HOR. MOV. (H.S)	F23	M1301-01	163
OE0,4	C. R. HOR. MOV. (L.S)	F23	M1301-01	163
OE0,5	STRETCHING ROLL #1 UP	F23	M1402-01	163
OE0,6	STRETCHING ROLL #1 DOWN	F23	M1402-01	163
OE0,7	STRETCHING ROLL #2 UP	F23	M1402-02	163
OE0,8	STRETCHING ROLL #2 DOWN	F23	M1402-02	164
OE0,9	STRETCHING ROLL #3 UP	F23	M1402-03	164
OE0,A	STRETCHING ROLL #3 DOWN	F23	M1402-03	164
OE0,B	MDO THREADING CLUTCH	F23	Y1410-01	164
OE0,C	CHILL ROLL IN WORKING POSITION			164
OE0,D	CHILL ROLL IN HOME POSITION			164
OE0,E	(FREE)			164

OE0,F	(FREE)			164
OE1,0	AIR KNIFE POS. TO POSITION	F23	SV1310-09	167
OE1,1	ROLL POS. FOR WATER REMOVAL CARRIAGE	F23	SV1310-11	167
OE1,2	CHROMEO ROLL TO POSITION	F23	SV1310-12	167
OE1,3	RUBBER ROLL TO POSITION	F23	SV1310-13	167
OE1,4	COOLING WATER VALVE FOR WATER BATH	F23	SV1350-03	167
OE1,5	AUX. WINDER #1 ENGAGE	F23	SV1360-04	167
OE1,6	AUX. WINDER #1 RETRACT	F23	SV1360-05	167
OE1,7	EDGE PINNING TO POSITION	F23	SV1310-10	167
OE1,8	INST. AIR OPEN (NOT USED)		SV1310-14	168
OE1,9	MDO NIP ROLL 1 SOLENOID	F23	SV1404-01	168
OE1,A	MDO NIP ROLL 2 SOLENOID	F23	SV1404-02	168
OE1,B	MDO NIP ROLL 3 SOLENOID	F23	SV1404-03	168
OE1,C	MDO PRESS ROLL INLET	F23	SV1404-04	168
OE1,D	MDO PRESS ROLL OUTLET	F23	SV1404-05	168
OE1,E	AUX. WINDER 2 RETRACT	F23	SV1450-04	168
OE1,F	AUX. WINDER 2 ENGAGE	F23	SV1450-05	168
OE2,0	NIP ROLL FOR CORONA #3	F23	SV1820-15	171
OE2,1	SR12 L230+9			171
OE2,2	OP. SPREADER ROLL 1	F23	SV1840-01	171
OE2,3	DRIVE SPREADER ROLL 1	F23	SV1840-02	171
OE2,4	OP. SPREADER ROLL 2	F23	SV1840-03	171
OE2,5	DRIVE SPREADER ROLL 2	F23	SV1840-04	171
OE2,6	OP. SPREADER ROLL 3	F23	SV1840-05	171
OE2,7	DRIVE SPREADER ROLL 3	F23	SV1840-06	171
OE2,8	OP. NIP ROLL FOR EDGE TRIM	F23	SV1850-01	172
OE2,9	DRIVE NIP ROLL FOR EDGE TRIM	F23	SV1850-02	172
OE2,A	OP. KNIFE FOR EDGE TRIM	F23	SV1850-03	172
OE2,B	DRIVE KNIFE FOR EDGE TRIM	F23	SV1850-04	172
OE2,C	AUX. WINDER 3 ENGAGE	F23	SV1860-01	172
OE2,D	AUX. WINDER 3 RETRACT	F23	SV1860-02	172
OE2,E	AUX. WINDER 3 LOCKING	F23	SV1860-03	172
OE2,F	TDO GAS SUPPLY OPEN/CLOSE	F23	SV1500-00	172
OE3,0	WEB BREAK MDO LAMP	F42		175
OE3,1	WEB BREAK MDO LAMP	F42		175
OE3,2	FILM BREAK BYPASS ON	F42		175
OE3,3	CHAIN TENSION LAMP	F50		175
OE3,4	(FREE)			175
OE3,5	WEB BREAK TDO LAMP	F55		175
OE3,6	WEB BREAK PRS LAMP	F55		175
OE3,7	NIP ROLL FOR CORONA #1	F55		175
OE3,8	COR. ELECTRODE 1 ENGAGED - LAMP	F55		176
OE3,9	COR. ELECTRODE 2 ENGAGED - LAMP	F55		176
OE3,A	NIP ROLL FOR CORONA #3	F55		176
OE3,B	COR. ELECTRODE 3 ENGAGED - LAMP	F55		176
OE3,C	VACUUM ROLL 1 ON - LAMP	F55		176
OE3,D	VACUUM ROLL 2 ON - LAMP	F55		176
OE3,E	OZONE EXHAUST FAN 1	F55		176
OE3,F	OZONE EXHAUST FAN 2	F55		176

OE4,0	TDO BURNER 1 INTER.	F151	179
OE4,1	TDO BURNER 1 START/STOP	F151	179
OE4,2	TDO BURNER 2 INTER.	F152	179
OE4,3	TDO BURNER 2 START/STOP	F152	179
OE4,4	TDO BURNER 3 INTER.	F153	179
OE4,5	TDO BURNER 3 START/STOP	F153	179
OE4,6	TDO BURNER 4 INTER.	F154	179
OE4,7	TDO BURNER 4 START/STOP	F154	179
OE4,8	TDO BURNER 5 INTER.	F155	180
OE4,9	TDO BURNER 5 START/STOP	F155	180
OE4,A	TDO BURNER 6 INTER.	F156	180
OE4,B	TDO BURNER 6 START/STOP	F156	180
OE4,C	TDO BURNER 7 INTER.	F157	180
OE4,D	TDO BURNER 7 START/STOP	F157	180
OE4,E	TDO BURNER 8 INTER.	F158	180
OE4,F	TDO BURNER 8 START/STOP	F158	180
OE5,0	TDO BURNER 17 INTER.	F167	183
OE5,1	TDO BURNER 17 START/STOP	F167	183
OE5,2	TDO BURNER 18 INTER.	F168	183
OE5,3	TDO BURNER 18 START/STOP	F168	183
OE5,4	TDO BURNER 19 INTER.	F169	183
OE5,5	TDO BURNER 19 START/STOP	F169	183
OE5,6	TDO BURNER 20 INTER.	F170	183
OE5,7	TDO BURNER 20 START/STOP	F170	183
OE5,8	CLOSE TOP KNIFE GATE TO WEIGH HOPPER		184
OE5,9	OPEN TOP KNIFE GATE TO WEIGH HOPPER		184
OE5,A	(FREE)		184
OE5,B	(FREE)		184
OE5,C	(FREE)		184
OE5,D	(FREE)		184
OE5,E	(FREE)		184
OE5,F	(FREE)		184
OE6,0	C. R. INTERLOCK	F16	187
OE6,1	MDO 1 INTERLOCK	F16	187
OE6,2	MDO 2 INTERLOCK	F16	187
OE6,3	MDO 3 INTERLOCK	F16	187
OE6,4	TDO INTERLOCK	F16	187
OE6,5	PRS 1 INTERLOCK	F16	187
OE6,6	PRS 2 INTERLOCK	F16	187
OE6,7	AUX. 1 INTERLOCK	F16	187
OE6,8	AUX. 2 INTERLOCK	F16	188
OE6,9	AUX. WINDER INTERLOCK	F16	188
OE6,A	WEB BREAK MDO	F16	188
OE6,B	WEB BREAK TDO	F16	188
OE6,C	WEB BREAK PRS	F16	188
OE6,D	MDO WARM ROLLS	F16	188
OE6,E	TDO WARM	F16	188
OE6,F	AUX. WINDER START/STOP	F16	188

OF0,0	RAISE CLIP CLOSER WHILE INDEPENDENT MODE		165
OF0,1	WEST CLIP CLOSER RAISE WHILE SEQUENCE MODE		165
OF0,2	MDO ZONE 9, HEATING	MDO	SV1435-13
OF0,3	MDO ZONE 10, HEATING	MDO	SV1435-14
OF0,4	MDO ZONE 1	MDO	SV1435-01
OF0,5	MDO ZONE 2	MDO	SV1435-02
OF0,6	MDO ZONE 3	MDO	SV1435-03
OF0,7	MDO ZONE 4	MDO	SV1435-04
OF0,8	MDO ZONE 5	MDO	SV1435-05
OF0,9	MDO ZONE 6	MDO	SV1435-06
OF0,A	MDO ZONE 7	MDO	SV1435-07
OF0,B	MDO ZONE 8	MDO	SV1435-08
OF0,C	MDO ZONE 9, COOLING	MDO	SV1435-09
OF0,D	MDO ZONE 10, COOLING	MDO	SV1435-10
OF0,E	MDO ZONE 11, COOLING	MDO	SV1435-11
OF0,F	MDO ZONE 12, COOLING	MDO	SV1435-12
OF1,0	LUMP CAMERA		169
OF1,1	TABLE RAISE CYLINDER	F140	SV1511-02
OF1,2	CHAIN TENSION CYLINDER	TDO	SV1515-08
OF1,3	CHAIN TRACK LUBRIF. EAST SIDE	F143	SV1518-01
OF1,4	CLIPS LUBRIF. EAST SIDE - PUMP ENGAGE	F143	SV1518-03
OF1,5	CLIPS LUBRIF. EAST SIDE - PUMP RETRACT	F143	SV1518-04
OF1,6	CHAIN TRACK LUBRIF. WEST SIDE	F142	SV1518-02
OF1,7	CLIPS LUBRIF. WEST SIDE - PUMP ENGAGE	F142	SV1518-05
OF1,8	CLIPS LUBRIF. WEST SIDE - PUMP RETRACT	F142	SV1518-06
OF1,9	AIR ON CLIPS VALVE	F142	SV1511-03
OF1,A	MDO ZONE 11, HEATING	MDO	SV1435-15
OF1,B	MDO ZONE 12, HEATING	MDO	SV1435-16
OF1,C	COR. ELECTRODE 1 CYLINDER	PRS	SV1820-07
OF1,D	NIP ROLL FOR CORONA #1	PRS	SV1820-19
OF1,E	COR. ELECTRODE 2 CYLINDER	PRS	SV1820-16
OF1,F	COR. ELECTRODE 3 CYLINDER	PRS	SV1820-11
OF2,0	DIE EXHAUST HOOD ON - LAMP	F32	173
OF2,1	EDGE PINNING ON - LAMP	F32	173
OF2,2	AIR KNIFE POS. - LAMP	F32	173
OF2,3	AIR KNIFE BLOWER ON - LAMP	F32	173
OF2,4	C. R. WATER REMOVAL FAN ON - LAMP	F32	173
OF2,5	FILM WATER REMOVAL 1 ON - LAMP	F32	173
OF2,6	FILM WATER REMOVAL 2 ON - LAMP	F32	173
OF2,7	INSTRUMENT AIR (NOT USED)		173
OF2,8	(FREE)		174
OF2,9	KLAXON FOR F13	F32	174H14
OF2,A	MDO NIP ROLL 1 ON - LAMP	F32	174
OF2,B	MDO NIP ROLL 2 ON - LAMP	F32	174
OF2,C	MDO NIP ROLL 3 ON - LAMP	F32	174
OF2,D	PRESS ROLL INLET ON - LAMP	F32	174
OF2,E	PRESS ROLL OUTLET ON - LAMP	F32	174
OF2,F	> 60M MICRO m - LAMP	F32	174
OF3,0	OZONE EXHAUST FAN 3	F55	177

OF3,1	WEB BREAKER DETECTOR TDO - LAMP	F55		177
OF3,2	WEB BREAKER DETECTOR 1 - LAMP	F55		177
OF3,3	WEB BREAKER DETECTOR 2 - LAMP	F55		177
OF3,4	OP. NIP ROLL FOR EDGE TRIM ON - LAMP	F62		177
OF3,5	OP. KNIFE FOR EDGE TRIM ON - LAMP	F62		177
OF3,6	DRIVE NIP ROLL FOR EDGE TRIM ON - LAMP	F62		177
OF3,7	DRIVE KNIFE FOR EDGE TRIM ON - LAMP	F62		177
OF3,8	DRIVE NIP ROLL FOR EDGE TRIM ON - LAMP	F63		178
OF3,9	DRIVE KNIFE FOR EDGE TRIM ON - LAMP	F63		178
OF3,A	NIP ROLL FOR CORONA #1, FOR EDGE TRIM ON - LAMP	F56		178
OF3,B	NIP ROLL FOR CORONA #3, FOR EDGE TRIM ON - LAMP	F56		178
OF3,C	(FREE)			178
OF3,D	AUX. WINDER 3 WEB BREAK BYPASS ON - LAMP	F70		178
OF3,E	AUX. WINDER 1 WEB BREAK BYPASS ON - LAMP	F36		178
OF3,F	AUX. WINDER 2 WEB BREAK BYPASS ON - LAMP	F46		178
OF4,0	TDO BURNER 9 INTER.	F159		181
OF4,1	TDO BURNER 9 START/STOP	F159		181
OF4,2	TDO BURNER 10 INTER.	F160		181
OF4,3	TDO BURNER 10 START/STOP	F160		181
OF4,4	TDO BURNER 11 INTER.	F161		181
OF4,5	TDO BURNER 11 START/STOP	F161		181
OF4,6	TDO BURNER 12 INTER.	F162		181
OF4,7	TDO BURNER 12 START/STOP	F162		181
OF4,8	TDO BURNER 13 INTER.	F163		181
OF4,9	TDO BURNER 13 START/STOP	F163		181
OF4,A	TDO BURNER 14 INTER.	F164		181
OF4,B	TDO BURNER 14 START/STOP	F164		181
OF4,C	TDO BURNER 15 INTER.	F165		181
OF4,D	TDO BURNER 15 START/STOP	F165		181
OF4,E	TDO BURNER 16 INTER.	F166		181
OF4,F	TDO BURNER 16 START/STOP	F166		181
OF5,0	TDO AND PRS WEB BREAK -> WINDER SR12 L250 + 15			185
OF5,1	FLAME TREATER WEB BREAK / PROCESS STOP ACTION & PRS VACUUM ROLL #2 ON			185
OF5,2	FLAME TREATER WEB BREAK / PROCESS STOP ACTION & PRS VACUUM ROLL #2 ON			185
OF5,3	FLAME TREATER WEB BREAK / PROCESS STOP ACTION & PRS VACUUM ROLL #2 ON			185
OF5,4	CHILL ROLL SPEED CONTROLLED BY THE GAUGE			185
OF5,5	KLAXON FM F12 I96,E TO INPUT OF F12 FOR KLAXON ALARM			185
OF5,6	(FREE) SOFTAL TREATER C.D ENGAGE ELECTRODES			185
OF5,7	(FREE) SOFTAL TREATER C.D RETRACT ELECTRODES			185
OF5,8	(FREE) UP TO SPEED FOR SOFTAL TREATER C			186
OF5,9	(FREE) UP TO SPEED FOR SOFTAL TREATER D			186
OF5,A	(FREE) SOFTAL TREATER A,B ENGAGED ELECTRODES			186
OF5,B	(FREE) SOFTAL TREATER A,B RETRACT ELECTRODES			186
OF5,C	SOFTAL TREATER KLAXON ALARM TO I84,8 (F12)			186
OF5,D	(FREE)			186
OF5,E	(FREE)			186

OF5,F	(FREE)			186
OF6,0	C. R. COOLING SKID INTER.	C.R		189
OF6,1	C. R. COOLING SKID START/STOP	C.R		189
OF6,2	WATER BATH SKID INTER.	C.R		189
OF6,3	WATER BATH SKID START/STOP	C.R		189
OF6,4	MDO BOILER SKID START/STOP	MDO		189
OF6,5	MDO SR5 L834+10			189
OF6,6	WATER BATH LEVEL	C.R		189
OF6,7	FILM BREAK TO MEASUREX	MEASUREX		189
OF6,8	MDO BOILER SKID INTERLOCK		C1430	190
OF6,9	KLAXON FOR F13	F13	17H3	190
OF6,A	ROTATING LIGHT FOR F13	F13	17H7	190
OF6,B	COR. 1 INTERLOCK UP TO SPEED SOFTAL A	F75	G1820-01	190
OF6,C	COR. 2 INTERLOCK UP TO SPEED SOFTAL B	F76	G1820-02	190
OF6,D	COR. 3 INTERLOCK	F77	G1820-03	190
OF6,E	COR. 4 INTERLOCK	F78	G1820-04	190
OF6,F	ISO DAC GAUGE CONTROL ON/OFF TO MEASUREX	MEASUREX		190

F13 I/O LIST

F13\INPUTWD.DOC

I/O WORD	DESCRIPTION	SYMBOL	PAGE # (DRAW')
IW01,3	C. R. TEMPERATURE MEASUREMENT	TE1340-02	32
IW01,4	WATER BATH TEMPERATUER MEASUREMENT	TE1350-02	32
IW01,5	(FREE)		32
IW01,6	(FREE)		32
IW02,3	MDO ZONE 1, TEMP. MEASUREMENT	TE1435-01	33
IW02,4	MDO ZONE 2, TEMP. MEASUREMENT	TE1435-02	33
IW02,5	MDO ZONE 3, TEMP. MEASUREMENT	TE1435-03	33
IW02,6	MDO ZONE 4, TEMP. MEASUREMENT	TE1435-04	33
IW03,3	MDO ZONE 5, TEMP. MEASUREMENT	TE1435-05	34
IW03,4	MDO ZONE 6, TEMP. MEASUREMENT	TE1435-06	34
IW03,5	MDO ZONE 7, TEMP. MEASUREMENT	TE1435-07	34
IW03,6	MDO ZONE 8, TEMP. MEASUREMENT	TE1435-08	34
IW04,3	MDO ZONE 9, TEMP. MEASUREMENT	TE1435-09	35
IW04,4	MDO ZONE 10, TEMP. MEASUREMENT	TE1435-10	35
IW04,5	MDO ZONE 11, TEMP. MEASUREMENT	TE1435-11	35
IW04,6	MDO ZONE 12, TEMP. MEASUREMENT	TE1435-12	35
IW05,3	TDO ZONE 1, TEMP. MEASUREMENT	TE1545-01	36
IW05,4	TDO ZONE 2, TEMP. MEASUREMENT	TE1545-02	36
IW05,5	TDO ZONE 3, TEMP. MEASUREMENT	TE1545-03	36
IW05,6	TDO ZONE 4, TEMP. MEASUREMENT	TE1545-04	36
IW06,3	TDO ZONE 5, TEMP. MEASUREMENT	TE1545-05	37
IW06,4	TDO ZONE 6, TEMP. MEASUREMENT	TE1545-06	37
IW06,5	TDO ZONE 7, TEMP. MEASUREMENT	TE1545-07	37
IW06,6	TDO ZONE 8, TEMP. MEASUREMENT	TE1545-08	37
IW07,3	TDO ZONE 9, TEMP. MEASUREMENT	TE1545-09	38
IW07,4	TDO ZONE 10, TEMP. MEASUREMENT	TE1545-10	38
IW07,5	TDO ZONE 11, TEMP. MEASUREMENT	TE1545-11	38
IW07,6	TDO ZONE 12, TEMP. MEASUREMENT	TE1545-12	38
IW40,3	TDO ZONE 13, TEMP. MEASUREMENT	TE1545-13	40
IW40,4	TDO ZONE 14, TEMP. MEASUREMENT	TE1545-14	40
IW40,5	TDO ZONE 15, TEMP. MEASUREMENT	TE1545-15	40
IW40,6	TDO ZONE 16, TEMP. MEASUREMENT	TE1545-16	40
IW41,3	TDO ZONE 17, TEMP. MEASUREMENT	TE1545-17	41
IW41,4	TDO ZONE 18, TEMP. MEASUREMENT	TE1545-18	41
IW41,5	TDO ZONE 19, TEMP. MEASUREMENT	TE1545-19	41
IW41,6	TDO ZONE 20, TEMP. MEASUREMENT	TE1545-20	41
IW42,3	(FREE)		42
IW42,4	(FREE)		42
IW42,5	(FREE)		42
IW42,6	(FREE)		42
IW43,3	AUX. WINDER 1 CURRENT		43
IW43,3	(FREE)		44
IW43,4	AUX. WINDER 2 CURRENT		43

IW43,4	(FREE)		44
IW43,5	F. P. C. FLOWMETER	FT1310-15	43
IW43,5	(FREE)		44
IW43,6	LINE SPEED		43
IW43,6	(FREE)		44

F13 I/O LIST

F13\OUTPUTWD.DOC

I/O WORD	DESCRIPTION	SYMBOL	PAGE # (DRAW')
OW44,3	(FREE)		47
OW44,4	(FREE)		47
OW44,5	C. R. BRAKE	Y1302-01	47
OW44,6	(FREE)		47
OW45,3	MDO ZONE 1, CONTROL VALVE	TV1435-01	48
OW45,4	MDO ZONE 2, CONTROL VALVE	TV1435-02	48
OW45,5	MDO ZONE 3, CONTROL VALVE	TV1435-03	48
OW45,6	MDO ZONE 4, CONTROL VALVE	TV1435-04	48
OW46,3	MDO ZONE 5, CONTROL VALVE	TV1435-05	49
OW46,4	MDO ZONE 6, CONTROL VALVE	TV1435-06	49
OW46,5	MDO ZONE 7, CONTROL VALVE	TV1435-07	49
OW46,6	MDO ZONE 8, CONTROL VALVE	TV1435-08	49
OW47,3	MDO ZONE 9, CONTROL VALVE	TV1435-09	50
OW47,4	MDO ZONE 10, CONTROL VALVE	TV1435-10	50
OW47,5	MDO ZONE 11, CONTROL VALVE	TV1435-11	50
OW47,6	MDO ZONE 12, CONTROL VALVE	TV1435-12	50
OW60,3	TDO ZONE 1	BURNER 1	52
OW60,4	TDO ZONE 2	BURNER 2	52
OW60,5	TDO ZONE 3	BURNER 3	52
OW60,6	TDO ZONE 4	BURNER 4	52
OW61,3	TDO ZONE 5	BURNER 5	53
OW61,4	TDO ZONE 6	BURNER 6	53
OW61,5	TDO ZONE 7	BURNER 7	53
OW61,6	TDO ZONE 8	BURNER 8	53
OW62,3	TDO ZONE 9	BURNER 9	54
OW62,4	TDO ZONE 10	BURNER 10	54
OW62,5	TDO ZONE 11	BURNER 11	54
OW62,6	TDO ZONE 12	BURNER 12	54
OW63,3	TDO ZONE 13	BURNER 13	55
OW63,4	TDO ZONE 14	BURNER 14	55
OW63,5	TDO ZONE 15	BURNER 15	55
OW63,6	TDO ZONE 16	BURNER 16	55
OW64,3	TDO ZONE 17	BURNER 17	56
OW64,4	TDO ZONE 18	BURNER 18	56
OW64,5	TDO ZONE 19	BURNER 19	56
OW64,6	TDO ZONE 20	BURNER 20	56
OW65,3	SMOOT #1		57
OW65,4	(FREE)		57
OW65,5	(FREE)		57
OW65,6	(FREE)		57
OW66,3	MDO ZONE 9, CTRL. VAL., HEATING	TV1435-13	58
OW66,4	MDO ZONE 10, CTRL. VAL., HEATING	TV1435-14	58
OW66,5	MDO ZONE 11, CTRL. VAL., HEATING	TV1435-15	58

OW66,6	MDO ZONE 12, CTRL. VAL., HEATING	TV1435-16	58
--------	----------------------------------	-----------	----

B 0	
B 1	1 SEC PULSE
B 2	1 SEC SYSTEM BIT
B 3	100 MS PULSE
B 4	100 MS SYSTEM BIT
B 5	
B 6	
B 7	
B 8	
B 9	
B 10	CONFIGURATION CARD AEM 413 RACK 0-1 TXT0
B 11	CONFIGURATION CARD AEM 413 RACK 0-2 TXT1
B 12	CONFIGURATION CARD AEM 413 RACK 0-3 TXT2
B 13	CONFIGURATION CARD AEM 413 RACK 0-4 TXT3
B 14	CONFIGURATION CARD AEM 413 RACK 0-5 TXT4
B 15	CONFIGURATION CARD AEM 413 RACK 0-6 TXT5
B 16	CONFIGURATION CARD AEM 413 RACK 0-7 TXT6
B 17	
B 18	
B 19	
B 20	CONFIGURATION CARD AEM 413 RACK 4-0 TXT7
B 21	CONFIGURATION CARD AEM 413 RACK 4-1 TXT8
B 22	CONFIGURATION CARD AEM 413 RACK 4-2 TXT9
B 23	
B 24	
B 25	
B 26	
B 27	
B 28	
B 29	
B 30	
B 31	
B 32	CONFIGURATION CARD AEM 811 RACK 4-3 TXT17
B 33	CONFIGURATION CARD AEM 811 RACK 4-2 TXT17
B 34	
B 35	
B 36	
B 37	
B 38	
B 39	
B 40	
B 41	
B 42	MODULE SCM 2222 CONFIGURED; CHANNEL OK
B 43	COLD RESTART OR WARM RESTART
B 44	CHANNEL CONFIGURED
B 45	MODULE IN "EXCHANGE VALUES" MODE
B 46	
B 47	BLOCK TEXT EXCHANGE OVER WITHOUT DEFECT
B 48	SCM2222 IN FAULT OR NOT PRESENT
B 49	RECEIVING IN PROGRESS
B 50	IN USE
B 51	IN USE
B 52	IN USE
B 53	IN USE
B 54	IN USE
B 55	IN USE
B 56	IN USE

B 57	IN USE
B 58	IN USE
B 59	IN USE
B 60	IN USE
B 61	IN USE
B 62	IN USE
B 63	IN USE
B 64	DRIVING SIDE COUNTER - TDO OUTLET SPROCKET
B 65	OPERATING SIDE COUNTER - TDO OUTLET SPROCKET
B 66	
B 67	
B 68	
B 69	
B 70	
B 71	
B 72	
B 73	
B 74	
B 75	
B 76	
B 77	
B 78	
B 79	
B 80	BIT RELEASE DEFECT
B 81	
B 82	
B 83	
B 84	
B 85	
B 86	
B 87	
B 88	
B 89	
B 90	
B 91	
B 92	
B 93	
B 94	
B 95	
B 96	
B 97	
B 98	
B 99	
B 100	STEP 0 E170 MDO START PUMP
B 101	STEP 1 E170 MDO START PUMP
B 102	STEP 2 E170 MDO START PUMP
B 103	STEP 0 E171 MDO START PUMP
B 104	STEP 1 E171 MDO START PUMP
B 105	STEP 2 E171 MDO START PUMP
B 106	STEP 0 E172 MDO START PUMP
B 107	STEP 1 E172 MDO START PUMP
B 108	STEP 2 E172 MDO START PUMP
B 109	STEP 0 E173 MDO START PUMP
B 110	STEP 1 E173 MDO START PUMP
B 111	STEP 2 E173 MDO START PUMP
B 112	STEP 0 E174 MDO START PUMP
B 113	STEP 1 E174 MDO START PUMP
B 114	STEP 2 E174 MDO START PUMP

B 115	STEP 0 E175 MDO START PUMP
B 116	STEP 1 E175 MDO START PUMP
B 117	STEP 2 E175 MDO START PUMP
B 118	STEP 0 E176 MDO START PUMP
B 119	STEP 1 E176 MDO START PUMP
B 120	STEP 2 E176 MDO START PUMP
B 121	STEP 0 E177 MDO START PUMP
B 122	STEP 1 E177 MDO START PUMP
B 123	STEP 2 E177 MDO START PUMP
B 124	STEP 0 E178 MDO START PUMP
B 125	STEP 1 E178 MDO START PUMP
B 126	STEP 2 E178 MDO START PUMP
B 127	STEP 0 E179 MDO START PUMP
B 128	STEP 1 E179 MDO START PUMP
B 129	STEP 2 E179 MDO START PUMP
B 130	STEP 0 E180 MDO START PUMP
B 131	STEP 1 E180 MDO START PUMP
B 132	STEP 2 E180 MDO START PUMP
B 133	STEP 0 E181 MDO START PUMP
B 134	STEP 1 E181 MDO START PUMP
B 135	STEP 2 E181 MDO START PUMP
B 136	
B 137	
B 138	
B 139	
B 140	
B 141	
B 142	
B 143	
B 144	
B 145	
B 146	
B 147	
B 148	
B 149	
B 150	INTERLOCK OF CHILL ROLL SKID E160
B 151	INTERLOCK OF WATER BATH COOLING SKID E161
B 152	
B 153	
B 154	AUXILIARY WINDER #1 DEFECT
B 155	AUXILIARY WINDER #2 DEFECT
B 156	
B 157	
B 158	
B 159	
B 160	
B 161	
B 162	
B 163	
B 164	
B 165	
B 166	
B 167	
B 168	
B 169	
B 170	
B 171	
B 172	

B 173	
B 174	
B 175	
B 176	
B 177	
B 178	
B 179	
B 180	
B 181	
B 182	
B 183	
B 184	
B 185	
B 186	
B 187	
B 188	
B 189	
B 190	
B 191	
B 192	
B 193	
B 194	
B 195	
B 196	
B 197	
B 198	
B 199	
B 200	CHILL ROLL FORWARD MOVEMENT STEP 0
B 201	CHILL ROLL FORWARD MOVEMENT STEP 1
B 202	CHILL ROLL FORWARD MOVEMENT STEP 2
B 203	CHILL ROLL FORWARD MOVEMENT STEP 3
B 204	CHILL ROLL FORWARD MOVEMENT STEP 4
B 205	CHILL ROLL FORWARD MOVEMENT STEP 5
B 206	CHILL ROLL BACKWARD MOVEMENT STEP 0
B 207	CHILL ROLL BACKWARD MOVEMENT STEP 1
B 208	CHILL ROLL BACKWARD MOVEMENT STEP 2
B 209	CHILL ROLL BACKWARD MOVEMENT STEP 3
B 210	CHILL ROLL BACKWARD MOVEMENT STEP 4
B 211	
B 212	
B 213	EXHAUST HOOD BLOWER STEP 0, M1263.01
B 214	EXHAUST HOOD BLOWER STEP 1, M1263.01
B 215	AIR KNIFE BLOWER STEP 0, M1310.01
B 216	AIR KNIFE BLOWER STEP 1, M1310.01
B 217	FILM WATER REMOVAL BLOWER M1310,02 STEP 0
B 218	FILM WATER REMOVAL BLOWER M1310,02 STEP 1
B 219	FILM WATER REMOVAL BLOWER M1310,03 STEP 0
B 220	FILM WATER REMOVAL BLOWER M1310,03 STEP 1
B 221	CHILL ROLL WATER REMOVAL BLOWER M1330,01 STEP 0
B 222	CHILL ROLL WATER REMOVAL BLOWER M1330,01 STEP 1
B 223	RUBBER ROLL WATER REMOVAL POSITION SV1310.03, STEP 0
B 224	RUBBER ROLL WATER REMOVAL POSITION SV1310.03, STEP 1
B 225	CHROMED ROLL POSITION SV1310.12 STEP 0
B 226	CHROMED ROLL POSITION SV1310.12 STEP 1
B 227	ROLL FOR CARRIAGE FILM REMOVAL POSITION SV1310.11 STEP 0
B 228	ROLL FOR CARRIAGE FILM REMOVAL POSITION SV1310.11 STEP 1
B 229	EDGE PINNING STEP 0
B 230	EDGE PINNING STEP 1

B 231	AIR KNIFE POSITION SV1310.09 STEP 0
B 232	AIR KNIFE POSITION SV1310.09 STEP 1
B 233	AUXILIARY WINDER 1 TEMPERATURE HIGH, TAH1360.03 STEP 0
B 234	AUXILIARY WINDER 1 TEMPERATURE HIGH, TAH1360.03 STEP 1
B 235	AUXILIARY WINDER 1 TEMPERATURE HIGH, TAH1360.03 STEP 2
B 236	AUXILIARY WINDER 1 MOTOR M1360.01, STEP 0
B 237	AUXILIARY WINDER 1 MOTOR M1360.01, STEP 1
B 238	AUXILIARY WINDER 1 CHUCK SV1360.04/SV1360.05, RETRACT
B 239	AUXILIARY WINDER 1 CHUCK SV1360.04/SV1360.05, ENGAGE
B 240	WATER BATH WATER FILLING SV1350.03, STEP 0
B 241	WATER BATH WATER FILLING SV1350.03, STEP 1
B 242	WATER BATH WATER FILLING SV1350.03, STEP 2
B 243	WATER BATH WATER FILLING SV1350.03, STEP 3
B 244	CHILL ROLL ELECTROMAGNETIC BRAKE (E162) Y1301.02, STEP 0
B 245	CHILL ROLL ELECTROMAGNETIC BRAKE (E162) Y1301.02, STEP 1
B 246	CHILL ROLL INTERLOCK NOT OK
B 247	CHILL ROLL INTERLOCK OK
B 248	
B 249	
B 250	MDO THREADING CHAIN CLUTCH Y1410.01 => OFF
B 251	MDO THREADING CHAIN CLUTCH Y1410.01 => ON
B 252	MDO WEB BREAK BYPASS
B 253	MDO NO WEB BREAK AND NO BYPASS
B 254	MDO WEB BREAK AND NO BYPASS
B 255	MDP WEB BREAK AND BYPASS
B 256	MDO NIP ROLL 1 SV1404.01 RETRACTED
B 257	MDO NIP ROLL 1 SV1404.01 ENGAGED
B 258	MDO NIP ROLL 2 SV1404.02 RETRACTED
B 259	MDO NIP ROLL 2 SV1404.02 ENGAGED
B 260	MDO NIP ROLL 3 SV1404.03 RETRACTED
B 261	MDO NIP ROLL 3 SV1404.03 ENGAGED
B 262	STRETCHING ROLL 1 UP
B 263	STRETCHING ROLL 1 UP
B 264	STRETCHING ROLL 2 UP
B 265	STRETCHING ROLL 2 UP
B 266	STRETCHING ROLL 3 UP
B 267	STRETCHING ROLL 3 UP
B 268	STRETCHING ROLL 1 DOWN
B 269	STRETCHING ROLL 1 DOWN
B 270	STRETCHING ROLL 2 DOWN
B 271	STRETCHING ROLL 2 DOWN
B 272	STRETCHING ROLL 3 DOWN
B 273	STRETCHING ROLL 3 DOWN
B 274	MDO OUTLET PRESSURE ROLL SV1404.05 RETRACTED
B 275	MDO OUTLET PRESSURE ROLL SV1404.05 ENGAGED
B 276	
B 277	WEB BREAK MDO & BYPASS STEP 0
B 278	WEB BREAK MDO & BYPASS STEP 1
B 279	WEB BREAK MDO & BYPASS STEP 2
B 280	MDO PROCESS STOP
B 281	
B 282	
B 283	TAH 1450,03 AUXILIARY WINDER 2 HIGH TEMP. => RELEASE DEFECT
B 284	TAH 1450,03 MDO AUXILIARY WINDER 2 => HIGH TEMP.
B 285	TAH 1450,03 MDO AUXILIARY WINDER 2 HIGH TEMP. => END OF TIMER
B 286	AUXILIARY WINDER 2 M1450,02, STOP
B 287	AUXILIARY WINDER 2 M1450,02, START
B 288	AUXILIARY WINDER 2 CHUCK RETRACT

B 289	AUXILIARY WINDER 2 CHUCK ENGAGE
B 290	MDO1 MDO2 MDO3 => INTERLOCK NOT OK
B 291	MDO1 MDO2 MDO3 => INTERLOCK OK
B 292	
B 293	
B 294	
B 295	
B 296	
B 297	
B 298	
B 299	
B 300	TDO CHAIN TENSION SYSTEM => LOW LEVEL (LSL1515.02)
B 301	TDO CHAIN TENSION LOW LEVEL ALARM => RELEASE DEFECT
B 302	TDO CHAIN TENSION SYSTEM LOW LEVEL => END OF TIMER
B 303	PSL1515.03 CHAIN TENSION SYSTEM => PRESSURE LOW
B 304	PSL CHAIN TENSION SYSTEM => RELEASE DEFECT
B 305	PSL CHAIN TENSION SYSTEM => END OF TIMER
B 306	CHAIN TENSION SYSTEM MOTOR (M1515,01) => STOP
B 307	CHAIN TENSION SYSTEM MOTOR (M1515,01) => START
B 308	CHAIN TENSION SYSTEM MOTOR (M1515,01) => DEFECT
B 309	CHAIN TENSION SYSTEM MOTOR CYLINDER (SV1515.08) => RETRACTED
B 310	CHAIN TENSION SYSTEM MOTOR CYLINDER (SV1515.08) => ENGAGED
B 311	TDO WEB BREAK DETECTOR (ZT1531.01 ZT1531.02)
B 312	TDO WEB BREAK DETECTOR
B 313	TDO WEB BREAK DETECTOR
B 314	TDO INLET CLIPS OPENING/CLOSING => CLOSE
B 315	TDO SWITCH CLIPS OPENING/CLOSING => OPEN
B 316	TDO AIR ON CLIPS (SV1511.03) => OFF
B 317	TDO AIR ON CLIPS (SV1511.04) => ON
B 318	TDO TABLE RAISE (SV1511.08) => OFF
B 319	TDO TABLE RAISE (SV1511.08) => ON
B 320	TDO LUBRICATION CLIPS
B 321	TDO LUBRICATION CLIPS
B 322	TDO LUBRICATION CLIPS
B 323	TDO LUBRICATION TRACKS
B 324	TDO LUBRICATION TRACKS
B 325	TDO LUBRICATION TRACKS
B 326	IMPULSE ZS 1550.01
B 327	IMPULSE ZS 1550.01
B 328	IMPULSE ZS 1550.02
B 329	IMPULSE ZS 1550.02
B 330	
B 331	TDO INTERLOCK
B 332	TDO MAIN GAS VALVE (SV 1500,00) => STOP
B 333	TDO MAIN GAS VALVE (SV 1500,00) => START
B 334	
B 335	
B 336	MDO INLET PRESSURE ROLL SV1404.05 RETRACTED
B 337	MDO INLET PRESSURE ROLL SV1404.05 ENGAGED
B 338	
B 339	
B 340	TIMER FOR TDO WEB BREAK
B 341	TIMER FOR PRS WEB BREAK
B 342	
B 343	
B 344	
B 345	
B 346	INSTRUMENT AIR (NOT USED)

B 347	INSTRUMENT AIR (NOT USED)
B 348	
B 349	
B 350	SPREADER ROLL #1, RETRACT - DRIVING SIDE
B 351	SPREADER ROLL #1, ENGAGE - DRIVING SIDE
B 352	SPREADER ROLL #2, RETRACT - DRIVING SIDE
B 353	SPREADER ROLL #2, ENGAGE - DRIVING SIDE
B 354	SPREADER ROLL #3, RETRACT - DRIVING SIDE
B 355	SPREADER ROLL #3, ENGAGE - DRIVING SIDE
B 356	OPERATING SIDE NIP ROLL (SV1850.01) => RETRACT
B 357	OPERATING SIDE NIP ROLL (SV1850.01) => ENGAGE
B 358	DRIVING SIDE NIP ROLL (SV1850.02) => RETRACT
B 359	DRIVING SIDE NIP ROLL (SV1850.02) => ENGAGE
B 360	OPERATING SIDE KNIFE (SV1850.03) => RETRACT
B 361	OPERATING SIDE KNIFE (SV1850.03) => ENGAGE
B 362	DRIVING SIDE KNIFE (SV1850.04) => RETRACT
B 363	DRIVING SIDE KNIFE (SV1850.04) => ENGAGE
B 364	PRS OZONE BLOWER #1 - LOW FLOW ALARM (FSL1831.06) RELEASE DEFECT
B 365	PRS OZONE BLOWER #1 - LOW FLOW ALARM (FSL1831.06)
B 366	PRS OZONE BLOWER #1 - LOW FLOW ALARM (FSL1831.06) END OF TIMER
B 367	PRS OZONE BLOWER #2 - LOW FLOW ALARM (FSL1831.07) RELEASE DEFECT
B 368	PRS OZONE BLOWER #2 - LOW FLOW ALARM (FSL1831.07)
B 369	PRS OZONE BLOWER #2 - LOW FLOW ALARM (FSL1831.07) END OF TIMER
B 370	CORONA ELECTRODE #1, PAL1820.09
B 371	CORONA ELECTRODE #1, PAL1820.09
B 372	CORONA ELECTRODE #1, PAL1820.09
B 373	CORONA ELECTRODE #2, PAL1820.19
B 374	CORONA ELECTRODE #2, PAL1820.19
B 375	CORONA ELECTRODE #2, PAL1820.19
B 376	CORONA ELECTRODE #3, PAL1820.14
B 377	CORONA ELECTRODE #3, PAL1820.14
B 378	CORONA ELECTRODE #3, PAL1820.14
B 379	BLOWER PRS ROLL 2 (M1812.01) => STOP
B 380	BLOWER PRS ROLL 2 (M1812.01) => START
B 381	CORONA ELECTRODE #1 - OZONE EXHAUST BLOWER => STOP (CELLIER SUPPLY)
B 382	CORONA ELECTRODE #1 - OZONE EXHAUST BLOWER => START (CELLIER SUPPLY)
B 383	CORONA ELECTRODE #2 - OZONE EXHAUST BLOWER => STOP (CELLIER SUPPLY)
B 384	CORONA ELECTRODE #2 - OZONE EXHAUST BLOWER => START (CELLIER SUPPLY)
B 385	VACUUM ROLL 2 BLOWER - STOP
B 386	VACUUM ROLL 2 BLOWER - START
B 387	CORONA #1 NIP ROLL RETRACT (SV1820.19)
B 388	CORONA #1 NIP ROLL ENGAGE (SV1820.19)
B 389	CORONA #3 NIP ROLL RETRACT (SV1820.15)
B 390	CORONA #3 NIP ROLL ENGAGE (SV1820.15)
B 391	CORONA ELECTRODE #1 => RETRACT
B 392	CORONA ELECTRODE #1 => ENGAGE
B 393	CORONA ELECTRODE #2 => RETRACT
B 394	CORONA ELECTRODE #2 => ENGAGE
B 395	CORONA ELECTRODE #3 => RETRACT
B 396	CORONA ELECTRODE #3 => ENGAGE
B 397	WEB BREAK PRS (ZT1840.10) OR WINDER
B 398	WEB BREAK PRS (ZT1840.10) OR WINDER
B 399	WEB BREAK PRS (ZT1840.10) OR WINDER
B 400	INTERLOCK GENERATOR 1 & 2
B 401	INTERLOCK GENERATOR 1 & 2
B 402	INTERLOCK GENERATOR 3 & 4
B 403	INTERLOCK GENERATOR 3 & 4
B 404	CORONA ELECTRODE #2 - OZONE EXHAUST BLOWER => STOP (CELLIER SUPPLY)

B 405	CORONA ELECTRODE #2 - OZONE EXHAUST BLOWER => START (CELLIER SUPPLY)
B 406	
B 407	
B 408	PRS OZONE BLOWER #3 - LOW FLOW ALARM (FSL1831.07) RELEASE DEFECT
B 409	PRS OZONE BLOWER #3 - LOW FLOW ALARM (FSL1831.07)
B 410	PRS OZONE BLOWER #3 - LOW FLOW ALARM (FSL1831.07) END OF TIMER
B 411	PRS SPREADER ROLL #1 RETRACT - OPERATING SIDE
B 412	PRS SPREADER ROLL #1 ENGAGE - OPERATING SIDE
B 413	PRS SPREADER ROLL #2 RETRACT - OPERATING SIDE
B 414	PRS SPREADER ROLL #2 ENGAGE - OPERATING SIDE
B 415	PRS SPREADER ROLL #3 RETRACT - OPERATING SIDE
B 416	PRS SPREADER ROLL #3 ENGAGE - OPERATING SIDE
B 417	AUXILIARY WINDER #3 CHUCK - RETRACT, END OF TIMER
B 418	AUXILIARY WINDER #3 CHUCK - ENGAGE
B 419	AUXILIARY WINDER #3 CHUCK - ENGAGE, END OF TIMER
B 420	AUXILIARY WINDER #3 CHUCK - RETRACT
B 421	OZONE TREATER #1 BLOWER => STOP (FPC SUPPLY)
B 422	OZONE TREATER #1 BLOWER => START (FPC SUPPLY)
B 423	OZONE TREATER #2 BLOWER => STOP (FPC SUPPLY)
B 424	OZONE TREATER #2 BLOWER => START (FPC SUPPLY)
B 425	OZONE TREATER #3 BLOWER => STOP (FPC SUPPLY)
B 426	OZONE TREATER #3 BLOWER => START (FPC SUPPLY)
B 427	OZONE TREATER #4 BLOWER => STOP (FPC SUPPLY)
B 428	OZONE TREATER #4 BLOWER => START (FPC SUPPLY)
B 429	
B 430	PRS1 & PRS2 INTERLOCK NOT OK
B 431	PRS1 & PRS2 INTERLOCK OK
B 432	
B 433	
B 434	
B 435	
B 436	
B 437	
B 438	
B 439	
B 440	
B 441	
B 442	
B 443	
B 444	
B 445	
B 446	
B 447	
B 448	
B 449	
B 450	
B 451	
B 452	
B 453	
B 454	
B 455	
B 456	
B 457	
B 458	
B 459	
B 460	
B 461	
B 462	

B 463	
B 464	
B 465	
B 466	
B 467	
B 468	
B 469	
B 470	
B 471	
B 472	
B 473	
B 474	
B 475	
B 476	
B 477	
B 478	
B 479	
B 480	
B 481	
B 482	
B 483	
B 484	
B 485	
B 486	
B 487	
B 488	
B 489	
B 490	
B 491	
B 492	
B 493	
B 494	
B 495	
B 496	
B 497	
B 498	
B 499	
B 500	BIT MDO ZONE 1 TEMP > 60 CW 800
B 501	BIT MDO ZONE 2 TEMP > 60 CW 800
B 502	BIT MDO ZONE 3 TEMP > 60 CW 800
B 503	BIT MDO ZONE 4 TEMP > 60 CW 800
B 504	BIT MDO ZONE 5 TEMP > 60 CW 800
B 505	BIT MDO ZONE 6 TEMP > 60 CW 800
B 506	BIT MDO ZONE 7 TEMP > 60 CW 800
B 507	BIT MDO ZONE 8 TEMP > 60 CW 800
B 508	BIT MDO ZONE 9 TEMP > 60 CW 800
B 509	BIT MDO ZONE 10 TEMP > 60 CW 800
B 510	BIT MDO ZONE 11 TEMP > 60 CW 800
B 511	BIT MDO ZONE 12 TEMP > 60 CW 800
B 512	
B 513	
B 514	
B 515	
B 516	
B 517	
B 518	
B 519	
B 520	

B 521	
B 522	
B 523	
B 524	
B 525	
B 526	
B 527	
B 528	
B 529	
B 530	
B 531	
B 532	
B 533	
B 534	
B 535	
B 536	
B 537	
B 538	
B 539	
B 540	BIT TDO ZONE 1 TEMP > 60 CW 801
B 541	BIT TDO ZONE 2 TEMP > 60 CW 801
B 542	BIT TDO ZONE 3 TEMP > 60 CW 801
B 543	BIT TDO ZONE 4 TEMP > 60 CW 801
B 544	BIT TDO ZONE 5 TEMP > 60 CW 801
B 545	BIT TDO ZONE 6 TEMP > 60 CW 801
B 546	BIT TDO ZONE 7 TEMP > 60 CW 801
B 547	BIT TDO ZONE 8 TEMP > 60 CW 801
B 548	BIT TDO ZONE 9 TEMP > 60 CW 801
B 549	BIT TDO ZONE 10 TEMP > 60 CW 801
B 550	BIT TDO ZONE 11 TEMP > 60 CW 801
B 551	BIT TDO ZONE 11 TEMP > 60 CW 801
B 552	BIT TDO ZONE 11 TEMP > 60 CW 801
B 553	BIT TDO ZONE 11 TEMP > 60 CW 801
B 554	BIT TDO ZONE 11 TEMP > 60 CW 801
B 555	BIT TDO ZONE 11 TEMP > 60 CW 801
B 556	BIT TDO ZONE 11 TEMP > 60 CW 801
B 557	BIT TDO ZONE 11 TEMP > 60 CW 801
B 558	BIT TDO ZONE 11 TEMP > 60 CW 801
B 559	BIT TDO ZONE 11 TEMP > 60 CW 801
B 560	
B 561	
B 562	
B 563	
B 564	
B 565	
B 566	
B 567	
B 568	
B 569	
B 570	
B 571	
B 572	
B 573	
B 574	
B 575	
B 576	
B 577	
B 578	

B 579	
B 580	
B 581	
B 582	
B 583	
B 584	
B 585	
B 586	
B 587	
B 588	
B 589	
B 590	
B 591	
B 592	
B 593	
B 594	
B 595	
B 596	
B 597	
B 598	
B 599	
B 600	TDO BLOWER E186
B 601	TDO BLOWER E186
B 602	TDO BLOWER E221
B 603	TDO BLOWER E221
B 604	TDO BLOWER E185 OFF
B 605	TDO BLOWER E185 ON
B 606	TDO BLOWER E187
B 607	TDO BLOWER E187
B 608	TDO BLOWER E188
B 609	TDO BLOWER E188
B 610	TDO BLOWER E189
B 611	TDO BLOWER E189
B 612	TDO BLOWER E190
B 613	TDO BLOWER E190
B 614	TDO BLOWER E191
B 615	TDO BLOWER E191
B 616	TDO BLOWER E192
B 617	TDO BLOWER E192
B 618	TDO BLOWER E193
B 619	TDO BLOWER E193
B 620	TDO BLOWER E194
B 621	TDO BLOWER E194
B 622	TDO BLOWER E195
B 623	TDO BLOWER E195
B 624	TDO BLOWER E196
B 625	TDO BLOWER E196
B 626	TDO BLOWER E197
B 627	TDO BLOWER E197
B 628	TDO BLOWER E198
B 629	TDO BLOWER E198
B 630	TDO BLOWER E199
B 631	TDO BLOWER E199
B 632	TDO BLOWER E200
B 633	TDO BLOWER E200
B 634	TDO BLOWER E201
B 635	TDO BLOWER E201
B 636	TDO BLOWER E202

B 637	TDO BLOWER E202
B 638	TDO BLOWER E203
B 639	TDO BLOWER E203
B 640	TDO BLOWER E204
B 641	TDO BLOWER E204
B 642	TDO BLOWER E205
B 643	TDO BLOWER E205
B 644	TDO BLOWER E206
B 645	TDO BLOWER E206
B 646	TDO BLOWER E207
B 647	TDO BLOWER E207
B 648	TDO BLOWER E208
B 649	TDO BLOWER E208
B 650	TDO BLOWER E209
B 651	TDO BLOWER E209
B 652	TDO BLOWER E210
B 653	TDO BLOWER E210
B 654	TDO BLOWER E211
B 655	TDO BLOWER E211
B 656	TDO BLOWER E212
B 657	TDO BLOWER E212
B 658	TDO BLOWER E213
B 659	TDO BLOWER E213
B 660	TDO BLOWER E214
B 661	TDO BLOWER E214
B 662	TDO BLOWER E215
B 663	TDO BLOWER E215
B 664	TDO BLOWER E216
B 665	TDO BLOWER E216
B 666	TDO BLOWER E217
B 667	TDO BLOWER E217
B 668	TDO BLOWER E218
B 669	TDO BLOWER E218
B 670	TDO BLOWER E219
B 671	TDO BLOWER E219
B 672	TDO BLOWER E220
B 673	TDO BLOWER E220
B 674	TDO BLOWER E222
B 675	TDO BLOWER E222
B 676	TDO BLOWER E223
B 677	TDO BLOWER E223
B 678	TDO BLOWER E224
B 679	TDO BLOWER E224
B 680	
B 681	
B 682	
B 683	
B 684	
B 685	
B 686	
B 687	
B 688	
B 689	
B 690	CHILL ROLL MEMORIZATION ORDER
B 691	MDO MEMORIZATION ORDER
B 692	TDO MEMORIZATION ORDER
B 693	
B 694	

B 695	
B 696	
B 697	
B 698	
B 699	
B 700	
B 701	
B 702	
B 703	
B 704	
B 705	
B 706	
B 707	
B 708	
B 709	
B 710	
B 711	
B 712	
B 713	
B 714	
B 715	
B 716	
B 717	
B 718	
B 719	
B 720	
B 721	
B 722	
B 723	
B 724	
B 725	
B 726	
B 727	
B 728	
B 729	
B 730	
B 731	
B 732	
B 733	
B 734	
B 735	
B 736	
B 737	
B 738	
B 739	
B 740	
B 741	
B 742	
B 743	
B 744	
B 745	
B 746	
B 747	
B 748	
B 749	
B 750	
B 751	
B 752	

B 753	
B 754	
B 755	
B 756	
B 757	
B 758	
B 759	
B 760	
B 761	
B 762	
B 763	
B 764	
B 765	
B 766	
B 767	
B 768	
B 769	
B 770	
B 771	
B 772	
B 773	
B 774	
B 775	
B 776	
B 777	
B 778	
B 779	
B 780	
B 781	
B 782	
B 783	
B 784	
B 785	
B 786	
B 787	
B 788	
B 789	
B 790	
B 791	START TIMER T50 FOR STARTING MDO EQUIPMENT
B 792	END OF STARTING MDO EQUIPMENT
B 793	START TIMER T51 FOR STARTING CHILL ROLL EQUIPMENT
B 794	END OF STARTING CHILL ROLL EQUIPMENT
B 795	START TIMER T52 FOR STARTING TDO EQUIPMENT
B 796	END OF STARTING TDO EQUIPMENT
B 797	
B 798	
B 799	
B 800	BIT START E169
B 801	BIT START E170
B 802	BIT START E171
B 803	BIT START E172
B 804	BIT START E173
B 805	BIT START E174
B 806	BIT START E175
B 807	BIT START E176
B 808	BIT START E177
B 809	BIT START E178
B 810	BIT START E179

B 811	BIT START	E180
B 812	BIT START	E181
B 813		
B 814	BIT START	E160
B 815	BIT START	E161
B 816	BIT START	E162
B 817		
B 818	BIT START	E122
B 819	BIT START	E223
B 820	BIT START	E224
B 821	BIT START	E456
B 822	BIT START	E221
B 823		
B 824	BIT START	E186
B 825	BIT START	E187
B 826	BIT START	E188
B 827	BIT START	E189
B 828	BIT START	E190
B 829	BIT START	E191
B 830	BIT START	E192
B 831	BIT START	E193
B 832	BIT START	E194
B 833	BIT START	E195
B 834	BIT START	E196
B 835	BIT START	E197
B 836	BIT START	E198
B 837	BIT START	E199
B 838	BIT START	E200
B 839	BIT START	E201
B 840	BIT START	E202
B 841	BIT START	E203
B 842	BIT START	E204
B 843	BIT START	E205
B 844	BIT START	E206
B 845	BIT START	E207
B 846	BIT START	E208
B 847	BIT START	E209
B 848	BIT START	E210
B 849	BIT START	E211
B 850	BIT START	E212
B 851	BIT START	E213
B 852	BIT START	E214
B 853	BIT START	E215
B 854	BIT START	E216
B 855	BIT START	E217
B 856	BIT START	E218
B 857	BIT START	E219
B 858	BIT START	E220
B 859		
B 860		
B 861		
B 862		
B 863		
B 864		
B 865		
B 866		
B 867		
B 868		

B 869	
B 870	ALARM "STOEXT" IN TOP VIW
B 871	ALARM "STOSAT1" IN TOP VIW
B 872	ALARM "STOSAT2" IN TOP VIW
B 873	ALARM PCC MAIN LOADING
B 874	
B 875	
B 876	
B 877	
B 878	
B 879	
B 880	
B 881	
B 882	
B 883	
B 884	
B 885	
B 886	
B 887	
B 888	
B 889	
B 890	

B 2000	AUTO/MANUAL (MANUAL -> 1)
B 2001	CONTROL LOCKED
B 2002	ALARM H+/L-
B 2003	ALARM H
B 2004	ALARM L
B 2005	DEFECT MEASURE
B 2006	
B 2007	CONTROL LOOP FAULT
B 2008	
B 2009	SAMPLE TIME SELECT (60 OR 1)
B 2010	START CONTROL LOOP
B 2011	REVERSE CONTROL LOOP
B 2012	
B 2013	BIT OUTPUT 100; -100
B 2014	
B 2015	TEMPERATURE NO DEFECT (OK)

B 2300	FOR SMOOTH SYSTEM
--------	-------------------

W0	CONFIGURATION OF SCM2222
W1	CONFIGURATION OF SCM2222
W2	CONFIGURATION OF SCM2222
W3	CONFIGURATION OF SCM2222
W4	CONFIGURATION OF SCM2222
W5	CONFIGURATION OF SCM2222
W6	CONFIGURATION OF SCM2222
W7	CONFIGURATION OF SCM2222
W8	CONFIGURATION OF SCM2222
W9	CONFIGURATION OF SCM2222
W10	CONFIGURATION OF SCM2222
W11	CONFIGURATION OF SCM2222
W12	CONFIGURATION OF SCM2222
W13	CONFIGURATION OF SCM2222
W14	CONFIGURATION OF SCM2222
W15	CONFIGURATION OF SCM2222
W16	CONFIGURATION OF SCM2222
W17	CONFIGURATION OF SCM2222
W18	CONFIGURATION OF SCM2222
W19	CONFIGURATION OF SCM2222
W20	CONFIGURATION OF SCM2222
W21	CONFIGURATION OF SCM2222
W22	CONFIGURATION OF SCM2222
W23	CONFIGURATION OF SCM2222
W24	CONFIGURATION OF SCM2222
W25	CONFIGURATION OF SCM2222
W26	CONFIGURATION OF SCM2222
W27	CONFIGURATION OF SCM2222
W28	CONFIGURATION OF SCM2222
W29	
W30	
W31	
W32	
W33	
W34	
W35	
W36	
W37	
W38	
W39	
W40	
W41	
W42	
W43	
W44	
W45	
W46	
W47	
W48	
W49	
W50	
W51	

W52	
W53	
W54	
W55	
W56	
W57	
W58	
W59	
W60	
W61	
W62	
W63	
W64	
W65	
W66	
W67	
W68	
W69	
W70	
W71	
W72	
W73	
W74	
W75	
W76	
W77	
W78	
W79	
W80	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W81	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W82	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W83	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W84	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W85	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W86	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W87	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W88	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W89	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W90	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W91	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W92	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W93	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W94	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W95	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W96	
W97	
W98	
W99	
W100	TRANSFER RECEIVE CODE FOR READ CODE FROM SCM2222
W101	
W102	
W103	

W104	
W105	
W106	
W107	INDEX FOR MODBUS IN SR0
W108	
W109	
W110	WORD FOR RECEIVE READ CODE
W111	WORD FOR RECEIVE READ CODE
W112	WORD FOR RECEIVE READ CODE
W113	WORD FOR RECEIVE READ CODE
W114	WORD FOR RECEIVE READ CODE
W115	WORD FOR RECEIVE READ CODE
W116	WORD FOR RECEIVE READ CODE
W117	WORD FOR RECEIVE READ CODE
W118	WORD FOR RECEIVE READ CODE
W119	WORD FOR RECEIVE READ CODE
W120	WORD FOR RECEIVE READ CODE
W121	WORD FOR RECEIVE READ CODE
W122	WORD FOR RECEIVE READ CODE
W123	WORD FOR RECEIVE READ CODE
W124	WORD FOR RECEIVE READ CODE
W125	WORD FOR RECEIVE READ CODE
W126	WORD FOR RECEIVE READ CODE
W127	WORD FOR RECEIVE READ CODE
W128	WORD FOR RECEIVE READ CODE
W129	WORD FOR RECEIVE READ CODE
W130	WORD FOR RECEIVE READ CODE
W131	WORD FOR RECEIVE READ CODE
W132	WORD FOR RECEIVE READ CODE
W133	WORD FOR RECEIVE READ CODE
W134	WORD FOR RECEIVE READ CODE
W135	WORD FOR RECEIVE READ CODE
W136	WORD FOR RECEIVE READ CODE
W137	WORD FOR RECEIVE READ CODE
W138	WORD FOR RECEIVE READ CODE
W139	WORD FOR RECEIVE READ CODE
W140	WORD FOR RECEIVE READ CODE
W141	WORD FOR RECEIVE READ CODE
W142	WORD FOR RECEIVE READ CODE
W143	WORD FOR RECEIVE READ CODE
W144	WORD FOR RECEIVE READ CODE
W145	WORD FOR RECEIVE READ CODE
W146	WORD FOR RECEIVE READ CODE
W147	WORD FOR RECEIVE READ CODE
W148	WORD FOR RECEIVE READ CODE
W149	WORD FOR RECEIVE READ CODE
W150	WORD FOR RECEIVE READ CODE
W151	WORD FOR RECEIVE READ CODE
W152	WORD FOR RECEIVE READ CODE
W153	WORD FOR RECEIVE READ CODE
W154	WORD FOR RECEIVE READ CODE
W155	WORD FOR RECEIVE READ CODE

W156	WORD FOR RECEIVE READ CODE
W157	WORD FOR RECEIVE READ CODE
W158	WORD FOR RECEIVE READ CODE
W159	WORD FOR RECEIVE READ CODE
W160	WORD FOR RECEIVE READ CODE
W161	WORD FOR RECEIVE READ CODE
W162	WORD FOR RECEIVE READ CODE
W163	WORD FOR RECEIVE READ CODE
W164	WORD FOR RECEIVE READ CODE
W165	WORD FOR RECEIVE READ CODE
W166	WORD FOR RECEIVE READ CODE
W167	WORD FOR RECEIVE READ CODE
W168	WORD FOR RECEIVE READ CODE
W169	WORD FOR RECEIVE READ CODE
W170	WORD FOR RECEIVE READ CODE
W171	WORD FOR RECEIVE READ CODE
W172	WORD FOR RECEIVE READ CODE
W173	WORD FOR RECEIVE READ CODE
W174	WORD FOR RECEIVE READ CODE
W175	WORD FOR RECEIVE READ CODE
W176	WORD FOR RECEIVE READ CODE
W177	WORD FOR RECEIVE READ CODE
W178	WORD FOR RECEIVE READ CODE
W179	WORD FOR RECEIVE READ CODE
W180	WORD FOR RECEIVE READ CODE
W181	WORD FOR RECEIVE READ CODE
W182	WORD FOR RECEIVE READ CODE
W183	WORD FOR RECEIVE READ CODE
W184	WORD FOR RECEIVE READ CODE
W185	WORD FOR RECEIVE READ CODE
W186	WORD FOR RECEIVE READ CODE
W187	WORD FOR RECEIVE READ CODE
W188	WORD FOR RECEIVE READ CODE
W189	WORD FOR RECEIVE READ CODE
W190	WORD FOR RECEIVE READ CODE
W191	WORD FOR RECEIVE READ CODE
W192	WORD FOR RECEIVE READ CODE
W193	WORD FOR RECEIVE READ CODE
W194	WORD FOR RECEIVE READ CODE
W195	WORD FOR RECEIVE READ CODE
W196	WORD FOR RECEIVE READ CODE
W197	WORD FOR RECEIVE READ CODE
W198	WORD FOR RECEIVE READ CODE
W199	WORD FOR RECEIVE READ CODE
W200	WORD FOR RECEIVE READ CODE
W201	WORD FOR RECEIVE READ CODE
W202	WORD FOR RECEIVE READ CODE
W203	WORD FOR RECEIVE READ CODE
W204	WORD FOR RECEIVE READ CODE
W205	WORD FOR RECEIVE READ CODE
W206	WORD FOR RECEIVE READ CODE
W207	WORD FOR RECEIVE READ CODE

W208	WORD FOR RECEIVE READ CODE
W209	WORD FOR RECEIVE READ CODE
W210	WORD FOR RECEIVE READ CODE
W211	WORD FOR RECEIVE READ CODE
W212	WORD FOR RECEIVE READ CODE
W213	WORD FOR RECEIVE READ CODE
W214	WORD FOR RECEIVE READ CODE
W215	WORD FOR RECEIVE READ CODE
W216	WORD FOR RECEIVE READ CODE
W217	WORD FOR RECEIVE READ CODE
W218	WORD FOR RECEIVE READ CODE
W219	WORD FOR RECEIVE READ CODE
W220	WORD FOR RECEIVE READ CODE
W221	WORD FOR RECEIVE READ CODE
W222	WORD FOR RECEIVE READ CODE
W223	WORD FOR RECEIVE READ CODE
W224	WORD FOR RECEIVE READ CODE
W225	WORD FOR RECEIVE READ CODE
W226	WORD FOR RECEIVE READ CODE
W227	WORD FOR RECEIVE READ CODE
W228	WORD FOR RECEIVE READ CODE
W229	WORD FOR RECEIVE READ CODE
W230	WORD FOR RECEIVE READ CODE
W231	WORD FOR RECEIVE READ CODE
W232	WORD FOR RECEIVE READ CODE
W233	WORD FOR RECEIVE READ CODE
W234	WORD FOR RECEIVE READ CODE
W235	WORD FOR RECEIVE READ CODE
W236	WORD FOR RECEIVE READ CODE
W237	WORD FOR RECEIVE READ CODE
W238	WORD FOR RECEIVE READ CODE
W239	WORD FOR RECEIVE READ CODE
W240	WORD FOR RECEIVE READ CODE
W241	WORD FOR RECEIVE READ CODE
W242	WORD FOR RECEIVE READ CODE
W243	WORD FOR RECEIVE READ CODE
W244	WORD FOR RECEIVE READ CODE
W245	WORD FOR RECEIVE READ CODE
W246	WORD FOR RECEIVE READ CODE
W247	WORD FOR RECEIVE READ CODE
W248	WORD FOR RECEIVE READ CODE
W249	WORD FOR RECEIVE READ CODE
W250	WORD FOR RECEIVE READ CODE
W251	WORD FOR RECEIVE READ CODE
W252	WORD FOR RECEIVE READ CODE
W253	WORD FOR RECEIVE READ CODE
W254	WORD FOR RECEIVE READ CODE
W255	WORD FOR RECEIVE READ CODE
W256	WORD FOR RECEIVE READ CODE
W257	WORD FOR RECEIVE READ CODE
W258	WORD FOR RECEIVE READ CODE
W259	WORD FOR RECEIVE READ CODE

W260	WORD FOR RECEIVE READ CODE
W261	WORD FOR RECEIVE READ CODE
W262	WORD FOR RECEIVE READ CODE
W263	WORD FOR RECEIVE READ CODE
W264	WORD FOR RECEIVE READ CODE
W265	WORD FOR RECEIVE READ CODE
W266	WORD FOR RECEIVE READ CODE
W267	WORD FOR RECEIVE READ CODE
W268	WORD FOR RECEIVE READ CODE
W269	WORD FOR RECEIVE READ CODE
W270	WORD FOR RECEIVE READ CODE
W271	WORD FOR RECEIVE READ CODE
W272	WORD FOR RECEIVE READ CODE
W273	WORD FOR RECEIVE READ CODE
W274	WORD FOR RECEIVE READ CODE
W275	WORD FOR RECEIVE READ CODE
W276	WORD FOR RECEIVE READ CODE
W277	WORD FOR RECEIVE READ CODE
W278	WORD FOR RECEIVE READ CODE
W279	WORD FOR RECEIVE READ CODE
W280	WORD FOR RECEIVE READ CODE
W281	WORD FOR RECEIVE READ CODE
W282	WORD FOR RECEIVE READ CODE
W283	WORD FOR RECEIVE READ CODE
W284	WORD FOR RECEIVE READ CODE
W285	WORD FOR RECEIVE READ CODE
W286	WORD FOR RECEIVE READ CODE
W287	WORD FOR RECEIVE READ CODE
W288	WORD FOR RECEIVE READ CODE
W289	WORD FOR RECEIVE READ CODE
W290	WORD FOR RECEIVE READ CODE
W291	WORD FOR RECEIVE READ CODE
W292	WORD FOR RECEIVE READ CODE
W293	WORD FOR RECEIVE READ CODE
W294	WORD FOR RECEIVE READ CODE
W295	WORD FOR RECEIVE READ CODE
W296	WORD FOR RECEIVE READ CODE
W297	WORD FOR RECEIVE READ CODE
W298	WORD FOR RECEIVE READ CODE
W299	WORD FOR RECEIVE READ CODE
W300	WORD FOR RECEIVE READ CODE
W301	WORD FOR RECEIVE READ CODE
W302	WORD FOR RECEIVE READ CODE
W303	WORD FOR RECEIVE READ CODE
W304	WORD FOR RECEIVE READ CODE
W305	WORD FOR RECEIVE READ CODE
W306	WORD FOR RECEIVE READ CODE
W307	WORD FOR RECEIVE READ CODE
W308	WORD FOR RECEIVE READ CODE
W309	WORD FOR RECEIVE READ CODE
W310	WORD FOR RECEIVE READ CODE
W311	FREE

W312	FREE
W313	FREE
W314	FREE
W315	FREE
W316	FREE
W317	FREE
W318	FREE
W319	FREE
W320	FREE
W321	FREE
W322	FREE
W323	FREE
W324	FREE
W325	FREE
W326	FREE
W327	FREE
W328	FREE
W329	FREE
W330	FREE
W331	FREE
W332	FREE
W333	FREE
W334	FREE
W335	FREE
W336	FREE
W337	FREE
W338	FREE
W339	FREE
W340	FREE
W341	FREE
W342	FREE
W343	FREE
W344	FREE
W345	FREE
W346	FREE
W347	FREE
W348	FREE
W349	FREE
W350	FREE
W351	FREE
W352	FREE
W353	FREE
W354	FREE
W355	FREE
W356	FREE
W357	FREE
W358	FREE
W359	FREE
W360	FREE
W361	FREE
W362	FREE
W363	FREE

W364	FREE
W365	FREE
W366	FREE
W367	FREE
W368	FREE
W369	FREE
W370	FREE
W371	FREE
W372	FREE
W373	FREE
W374	FREE
W375	FREE
W376	FREE
W377	FREE
W378	FREE
W379	FREE
W380	FREE
W381	FREE
W382	FREE
W383	FREE
W384	FREE
W385	FREE
W386	FREE
W387	FREE
W388	FREE
W389	FREE
W390	FREE
W391	FREE
W392	FREE
W393	FREE
W394	FREE
W395	FREE
W396	FREE
W397	FREE
W398	FREE
W399	FREE
W400	WORD FOR COUNTER FOR ALL CONTROL LOOP INDEX AUX0, S0
W401	WORD FOR COUNTER FOR ALL CONTROL LOOP INDEX AUX1, S0
W402	COUNTER FOR MODBUS
W403	FREE
W404	FREE
W405	FREE
W406	FREE
W407	FREE
W408	FREE
W409	FREE
W410	FREE
W411	FREE
W412	FREE
W413	FREE
W414	FREE
W415	FREE

W416	FREE
W417	FREE
W418	FREE
W419	FREE
W420	FREE
W421	FREE
W422	FREE
W423	FREE
W424	FREE
W425	FREE
W426	FREE
W427	FREE
W428	FREE
W429	FREE
W430	FREE
W431	FREE
W432	FREE
W433	FREE
W434	FREE
W435	FREE
W436	FREE
W437	FREE
W438	FREE
W439	FREE
W440	FREE
W441	FREE
W442	FREE
W443	FREE
W444	FREE
W445	FREE
W446	FREE
W447	FREE
W448	FREE
W449	FREE
W450	0000 0000 1111 1111 MASK
W451	
W452	
W453	
W454	SEE " WORD BIT "
W455	SEE " WORD BIT "
W456	SEE " WORD BIT "
W457	
W458	
W459	
W460	CONTROL LOOPS [R365, R366]
W461	
W462	CONTROL LOOPS [R370, R371]
W463	
W464	CONTROL LOOPS [R372, R373]
W465	
W466	CONTROL LOOPS [R374, R375]
W467	

W468	CONTROL LOOPS [R376, R377]
W469	
W470	CONTROL LOOPS [R378, R379]
W471	
W472	CONTROL LOOPS [R380, R381]
W473	
W474	CONTROL LOOPS [R386, R387]
W475	
W476	CONTROL LOOPS [R388, R389]
W477	
W478	CONTROL LOOPS [R390, R391]
W479	
W480	CONTROL LOOPS [R392, R393]
W481	
W482	CONTROL LOOPS [R394, R395]
W483	
W484	CONTROL LOOP [R396, R397]
W485	
W486	CONTROL LOOP [R398, R399]
W487	
W488	CONTROL LOOP [R400, R401]
W489	
W490	CONTROL LOOP [R402, R403]
W491	
W492	
W493	
W494	
W495	
W496	
W497	
W498	
W499	
W500	SEE " WORD BIT "
W501	SEE " WORD BIT "
W502	SEE " WORD BIT "
W503	SEE " WORD BIT "
W504	SEE " WORD BIT "
W505	SEE " WORD BIT "
W506	SEE " WORD BIT "
W507	SEE " WORD BIT "
W508	SEE " WORD BIT "
W509	SEE " WORD BIT "
W510	SEE " WORD BIT "
W511	SEE " WORD BIT "
W512	SEE " WORD BIT "
W513	SEE " WORD BIT "
W514	SEE " WORD BIT "
W515	SEE " WORD BIT "
W516	SEE " WORD BIT "
W517	SEE " WORD BIT "
W518	SEE " WORD BIT "
W519	SEE " WORD BIT "

W520	SEE " WORD BIT "
W521	SEE " WORD BIT "
W522	SEE " WORD BIT "
W523	SEE " WORD BIT "
W524	SEE " WORD BIT "
W525	SEE " WORD BIT "
W526	SEE " WORD BIT "
W527	SEE " WORD BIT "
W528	SEE " WORD BIT "
W529	SEE " WORD BIT "
W530	SEE " WORD BIT "
W531	SEE " WORD BIT "
W532	SEE " WORD BIT "
W533	SEE " WORD BIT "
W534	SEE " WORD BIT "
W535	SEE " WORD BIT "
W536	SEE " WORD BIT "
W537	SEE " WORD BIT "
W538	SEE " WORD BIT "
W539	SEE " WORD BIT "
W540	
W541	
W542	
W543	
W544	
W545	
W546	
W547	
W548	
W549	
W550	COUNTER FOR ELECTROMAGNETIC BRAKE E162
W551	COUNTER FOR E170
W552	COUNTER FOR E171
W553	COUNTER FOR E172
W554	COUNTER FOR E173
W555	COUNTER FOR E174
W556	COUNTER FOR E175
W557	COUNTER FOR E176
W558	COUNTER FOR E177
W559	COUNTER FOR E178
W560	COUNTER FOR E179
W561	COUNTER FOR E180
W562	COUNTER FOR E181
W563	COUNTER FOR FLOWER E185
W564	COUNTER FOR FLOWER E186
W565	COUNTER FOR FLOWER E187
W566	COUNTER FOR FLOWER E188
W567	COUNTER FOR FLOWER E189
W568	COUNTER FOR FLOWER E190
W569	COUNTER FOR FLOWER E191
W570	COUNTER FOR FLOWER E192
W571	COUNTER FOR FLOWER E193

W572	COUNTER FOR FLOWER E194
W573	COUNTER FOR FLOWER E195
W574	COUNTER FOR FLOWER E196
W575	COUNTER FOR FLOWER E197
W576	COUNTER FOR FLOWER E198
W577	COUNTER FOR FLOWER E199
W578	COUNTER FOR FLOWER E200
W579	COUNTER FOR FLOWER E201
W580	COUNTER FOR FLOWER E202
W581	COUNTER FOR FLOWER E203
W582	COUNTER FOR FLOWER E204
W583	COUNTER FOR FLOWER E205
W584	COUNTER FOR FLOWER E206
W585	COUNTER FOR FLOWER E207
W586	COUNTER FOR FLOWER E208
W587	COUNTER FOR FLOWER E209
W588	COUNTER FOR FLOWER E210
W589	COUNTER FOR FLOWER E211
W590	COUNTER FOR FLOWER E212
W591	COUNTER FOR FLOWER E213
W592	COUNTER FOR FLOWER E214
W593	COUNTER FOR FLOWER E215
W594	COUNTER FOR FLOWER E216
W595	COUNTER FOR FLOWER E217
W596	COUNTER FOR FLOWER E218
W597	COUNTER FOR FLOWER E219
W598	COUNTER FOR FLOWER E220
W599	COUNTER FOR FLOWER E221
W600	COUNTER FOR FLOWER E222
W601	COUNTER FOR FLOWER E223
W602	COUNTER FOR FLOWER E224
W603	
W604	
W605	
W606	
W607	
W608	
W609	
W610	COUNTER CHILL ROLL EXHAUST HOOD
W611	COUNTER CHILL ROLL WATR REMOVAL
W612	COUNTER CHILL ROLL WATR REMOVAL
W613	COUNTER CHILL ROLL WATR REMOVAL
W614	COUNTER CHILL ROLL WATR REMOVAL
W615	COUNTER CHILL ROLL HORIZONTAL MOVEMENT
W616	COUNTER CHILL ROLL HORIZONTAL MOVEMENT
W617	COUNTER CHILL ROLL AUXILARY WINDER1
W618	COUNTER MDO AUXILARY WINDER2
W619	COUNTER TDO CHAIN TENSION SYSTEM
W620	COUNTER PRS FAN ROLL #2
W621	COUNTER PRS FAN ROLL #1
W622	COUNTER PRS OZONE EXHAUST BLOWER#1 BLOWER, MOTOR M1831.01
W623	COUNTER PRS OZONE EXHAUST BLOWER#2 BLOWER, MOTOR M1831.02

W624	COUNTER PRS OZONE EXHAUST BLOWER#3 BLOWER, MOTOR M1831.03
W625	
W626	
W627	COUNTER FOR OZONE TREATER#1 BLOWER, CORONA#1
W628	COUNTER FOR OZONE TREATER#2 BLOWER, CORONA#1
W629	COUNTER FOR OZONE TREATER#3 BLOWER, CORONA#2
W630	COUNTER FOR OZONE TREATER#4 BLOWER, CORONA#2
W631	
W632	SETPOINT WITHOUT LUBRICTION OF TRACK
W633	SETPOINT WITHOUT LUBRICTION OF TRACK
W634	SETPOINT WITHOUT LUBRICTION OF CHAIN
W635	SETPOINT WITHOUT LUBRICTION OF CHAIN
W636	
W637	
W638	COUNTER WITHOUT LUBRICATION OF TRACK
W639	COUNTER WITHOUT LUBRICATION OF TRACK
W640	COUNTER WITH LUBRICATION OF TRACK
W641	COUNTER WITH LUBRICATION OF TRACK
W642	COUNTER WITHOUT LUBRICATION OF CHAIN
W643	COUNTER WITHOUT LUBRICATION OF CHAIN
W644	COUNTER WITH LUBRICATION OF CHAIN
W645	COUNTER WITH LUBRICATION OF CHAIN
W646	
W647	
W648	
W649	
W650	

NO.	TAGNAME	DESCRIPTION
W4000		
W4001		
W4002	AOSPR365	SETPOINT R365
W4003	AOOUR365	OUTPUT
W4004	AOPR365	PROPORTIONAL VALUE
W4005	AOINR365	INTEGRAL
W4006	AODER365	DERIVATIVE
W4007	AOAH+0	HIGH ALARM
W4008	AOAH+1	H+/L- (CONTROL OUT OF RANGE)
W4009	AOAH+2	LOW ALARM
W4010		
W4011	AOSPR366	SETPOINT R365
W4012	AOOUR366	OUTPUT
W4013	AOPR366	PROPORTIONAL VALUE
W4014	AOINR366	INTEGRAL
W4015	AODER366	DERIVATIVE
W4016	AOAH+9	HIGH ALARM
W4017	AOAH+10	H+/L- (CONTROL OUT OF RANGE)
W4018	AOAH+12	LOW ALARM
W4019		
W4020		
W4021		
W4022		
W4023		
W4024		
W4025		
W4026		
W4027		
W4028		
W4029		
W4030		
W4031		
W4032		
W4033		
W4034		
W4035		
W4036		
W4037		
W4038		
W4039		
W4040		
W4041		
W4042		
W4043		
W4044		
W4045		
W4046		
W4047	AOSPR370	SETPOINT R370
W4048	AOOUR370	OUTPUT
W4049	AOPR370	PROPORTIONAL VALUE
W4050	AOINR370	INTEGRAL

W4051	AODER370	DERIVATIVE
W4052	AOAH+45	HIGH ALARM
W4053	AOAH+46	H+/L- (CONTROL OUT OF RANGE)
W4054	AOAH+47	LOW ALARM
W4055		
W4056	AOSPR371	SETPOINT R371
W4057	AOOUR371	OUTPUT
W4058	AOPR371	PROPORTIONAL VALUE
W4059	AOINR371	INTEGRAL
W4060	AODER371	DERIVATIVE
W4061	AOAH+54	HIGH ALARM
W4062	AOAH+55	H+/L- (CONTROL OUT OF RANGE)
W4063	AOAH+56	LOW ALARM
W4064		
W4065	AOSPR372	SETPOINT R372
W4066	AOOUR372	OUTPUT
W4067	AOPR372	PROPORTIONAL VALUE
W4068	AOINR372	INTEGRAL
W4069	AODER372	DERIVATIVE
W4070	AOAH+63	HIGH ALARM
W4071	AOAH+64	H+/L- (CONTROL OUT OF RANGE)
W4072	AOAH+65	LOW ALARM
W4073		
W4074	AOSPR373	SETPOINT R373
W4075	AOOUR373	OUTPUT
W4076	AOPR373	PROPORTIONAL VALUE
W4077	AOINR373	INTEGRAL
W4078	AODER373	DERIVATIVE
W4079	AOAH+72	HIGH ALARM
W4080	AOAH+73	H+/L- (CONTROL OUT OF RANGE)
W4081	AOAH+74	LOW ALARM
W4082		
W4083	AOSPR374	SETPOINT R374
W4084	AOOUR374	OUTPUT
W4085	AOPR374	PROPORTIONAL VALUE
W4086	AOINR374	INTEGRAL
W4087	AODER374	DERIVATIVE
W4088	AOAH+81	HIGH ALARM
W4089	AOAH+82	H+/L- (CONTROL OUT OF RANGE)
W4090	AOAH+83	LOW ALARM
W4091		
W4092	AOSPR375	SETPOINT R375
W4093	AOOUR375	OUTPUT
W4094	AOPR375	PROPORTIONAL VALUE
W4095	AOINR375	INTEGRAL
W4096	AODER375	DERIVATIVE
W4097	AOAH+81	HIGH ALARM
W4098	AOAH+82	H+/L- (CONTROL OUT OF RANGE)
W4099	AOAH+83	LOW ALARM
W4100		
W4101	AOSPR376	SETPOINT R376
W4102	AOOUR376	OUTPUT

W4103	AOPR376	PROPORTIONAL VALUE
W4104	AOINR376	INTEGRAL
W4105	AODER376	DERIVATIVE
W4106	AOAH+81	HIGH ALARM
W4107	AOAH+82	H+/L- (CONTROL OUT OF RANGE)
W4108	AOAH+83	LOW ALARM
W4109		
W4110	AOSPR377	SETPOINT R377
W4111	AOOUR377	OUTPUT
W4112	AOPR377	PROPORTIONAL VALUE
W4113	AOINR377	INTEGRAL
W4114	AODER377	DERIVATIVE
W4115	AOAH+81	HIGH ALARM
W4116	AOAH+82	H+/L- (CONTROL OUT OF RANGE)
W4117	AOAH+83	LOW ALARM
W4118		
W4119	AOSPR378	SETPOINT R378
W4120	AOOUR378	OUTPUT
W4121	AOPR378	PROPORTIONAL VALUE
W4122	AOINR378	INTEGRAL
W4123	AODER378	DERIVATIVE
W4124	AOAH+81	HIGH ALARM
W4125	AOAH+82	H+/L- (CONTROL OUT OF RANGE)
W4126	AOAH+83	LOW ALARM
W4127		
W4128	AOSPR379	SETPOINT R379
W4129	AOOUR379	OUTPUT
W4130	AOPR379	PROPORTIONAL VALUE
W4131	AOINR379	INTEGRAL
W4132	AODER379	DERIVATIVE
W4133	AOAH+81	HIGH ALARM
W4134	AOAH+82	H+/L- (CONTROL OUT OF RANGE)
W4135	AOAH+83	LOW ALARM
W4136		
W4137	AOSPR380	SETPOINT R380
W4138	AOOUR380	OUTPUT
W4139	AOPR380	PROPORTIONAL VALUE
W4140	AOINR380	INTEGRAL
W4141	AODER380	DERIVATIVE
W4142	AOAH+81	HIGH ALARM
W4143	AOAH+82	H+/L- (CONTROL OUT OF RANGE)
W4144	AOAH+83	LOW ALARM
W4145		
W4146	AOSPR381	SETPOINT R381
W4147	AOOUR381	OUTPUT
W4148	AOPR381	PROPORTIONAL VALUE
W4149	AOINR381	INTEGRAL
W4150	AODER381	DERIVATIVE
W4151	AOAH+18	HIGH ALARM
W4152	AOAH+19	H+/L- (CONTROL OUT OF RANGE)
W4153	AOAH+20	LOW ALARM
W4154		

W4155		
W4156		
W4157		
W4158		
W4159		
W4160		
W4161		
W4162		
W4163		
W4164		
W4165		
W4166		
W4167		
W4168		
W4169		
W4170		
W4171		
W4172		
W4173		
W4174		
W4175		
W4176		
W4177		
W4178		
W4179		
W4180		
W4181		
W4182	AOSPR385	SETPOINT R385
W4183	AOOUR385	OUTPUT
W4184	AOPR385	PROPORTIONAL VALUE
W4185	AOINR385	INTEGRAL
W4186	AODER385	DERIVATIVE
W4187	AOAH+54	HIGH ALARM
W4188	AOAH+55	H+/L- (CONTROL OUT OF RANGE)
W4189	AOAH+56	LOW ALARM
W4190		
W4191	AOSPR386	SETPOINT R386
W4192	AOOUR386	OUTPUT
W4193	AOPR386	PROPORTIONAL VALUE
W4194	AOINR386	INTEGRAL
W4195	AODER386	DERIVATIVE
W4196	AOAH+63	HIGH ALARM
W4197	AOAH+64	H+/L- (CONTROL OUT OF RANGE)
W4198	AOAH+65	LOW ALARM
W4199		
W4200	AOSPR387	SETPOINT R387
W4201	AOOUR387	OUTPUT
W4202	AOPR387	PROPORTIONAL VALUE
W4203	AOINR387	INTEGRAL
W4204	AODER387	DERIVATIVE
W4205	AOAH+72	HIGH ALARM
W4206	AOAH+73	H+/L- (CONTROL OUT OF RANGE)

W4207	AOAH+74	LOW ALARM
W4208		
W4209	AOSPR388	SETPOINT R388
W4210	AOOUR388	OUTPUT
W4211	AOPR388	PROPORTIONAL VALUE
W4212	AOINR388	INTEGRAL
W4213	AODER388	DERIVATIVE
W4214	AOAH+81	HIGH ALARM
W4215	AOAH+82	H+/L- (CONTROL OUT OF RANGE)
W4216	AOAH+83	LOW ALARM
W4217		
W4218	AOSPR389	SETPOINT R389
W4219	AOOUR389	OUTPUT
W4220	AOPR389	PROPORTIONAL VALUE
W4221	AOINR389	INTEGRAL
W4222	AODER389	DERIVATIVE
W4223	AOAH+90	HIGH ALARM
W4224	AOAH+91	H+/L- (CONTROL OUT OF RANGE)
W4225	AOAH+92	LOW ALARM
W4226		
W4227	AOSPR390	SETPOINT R390
W4228	AOOUR390	OUTPUT
W4229	AOPR390	PROPORTIONAL VALUE
W4230	AOINR390	INTEGRAL
W4231	AODER390	DERIVATIVE
W4232	AOAH+99	HIGH ALARM
W4233	AOAH+100	H+/L- (CONTROL OUT OF RANGE)
W4234	AOAH+101	LOW ALARM
W4235		
W4236	AOSPR391	SETPOINT R391
W4237	AOOUR391	OUTPUT
W4238	AOPR391	PROPORTIONAL VALUE
W4239	AOINR391	INTEGRAL
W4240	AODER391	DERIVATIVE
W4241	AOAH+108	HIGH ALARM
W4242	AOAH+109	H+/L- (CONTROL OUT OF RANGE)
W4243	AOAH+110	LOW ALARM
W4244		
W4245	AOSPR392	SETPOINT R392
W4246	AOOUR392	OUTPUT
W4247	AOPR392	PROPORTIONAL VALUE
W4248	AOINR392	INTEGRAL
W4249	AODER392	DERIVATIVE
W4250	AOAH+117	HIGH ALARM
W4251	AOAH+118	H+/L- (CONTROL OUT OF RANGE)
W4252	AOAH+119	LOW ALARM
W4253		
W4254	AOSPR393	SETPOINT R393
W4255	AOOUR393	OUTPUT
W4256	AOPR393	PROPORTIONAL VALUE
W4257	AOINR393	INTEGRAL
W4258	AODER393	DERIVATIVE

W4259	AOAH+0	HIGH ALARM
W4260	AOAH+1	H+/L- (CONTROL OUT OF RANGE)
W4261	AOAH+2	LOW ALARM
W4262		
W4263	AOSPR394	SETPOINT R394
W4264	AOOUR394	OUTPUT
W4265	AOPR394	PROPORTIONAL VALUE
W4266	AOINR394	INTEGRAL
W4267	AODER394	DERIVATIVE
W4268	AOAH+9	HIGH ALARM
W4269	AOAH+10	H+/L- (CONTROL OUT OF RANGE)
W4270	AOAH+11	LOW ALARM
W4271		
W4272	AOSPR395	SETPOINT R395
W4273	AOOUR395	OUTPUT
W4274	AOPR395	PROPORTIONAL VALUE
W4275	AOINR395	INTEGRAL
W4276	AODER395	DERIVATIVE
W4277	AOAH+18	HIGH ALARM
W4278	AOAH+19	H+/L- (CONTROL OUT OF RANGE)
W4279	AOAH+20	LOW ALARM
W4280		
W4281	AOSPR396	SETPOINT R396
W4282	AOOUR396	OUTPUT
W4283	AOPR396	PROPORTIONAL VALUE
W4284	AOINR396	INTEGRAL
W4285	AODER396	DERIVATIVE
W4286	AOAH+27	HIGH ALARM
W4287	AOAH+28	H+/L- (CONTROL OUT OF RANGE)
W4288	AOAH+29	LOW ALARM
W4289		
W4290	AOSPR397	SETPOINT R397
W4291	AOOUR397	OUTPUT
W4292	AOPR397	PROPORTIONAL VALUE
W4293	AOINR397	INTEGRAL
W4294	AODER397	DERIVATIVE
W4295	AOAH+36	HIGH ALARM
W4296	AOAH+37	H+/L- (CONTROL OUT OF RANGE)
W4297	AOAH+38	LOW ALARM
W4298		
W4299	AOSPR398	SETPOINT R398
W4300	AOOUR398	OUTPUT
W4301	AOPR398	PROPORTIONAL VALUE
W4302	AOINR398	INTEGRAL
W4303	AODER398	DERIVATIVE
W4304	AOAH+45	HIGH ALARM
W4305	AOAH+46	H+/L- (CONTROL OUT OF RANGE)
W4306	AOAH+47	LOW ALARM
W4307		
W4308	AOSPR399	SETPOINT R399
W4309	AOOUR399	OUTPUT
W4310	AOPR399	PROPORTIONAL VALUE

W4311	AOINR399	INTEGRAL
W4312	AODER398	DERIVATIVE
W4313	AOAH+54	HIGH ALARM
W4314	AOAH+55	H+/L- (CONTROL OUT OF RANGE)
W4315	AOAH+56	LOW ALARM
W4316		
W4317	AOSPR400	SETPOINT R400
W4318	AOOUR400	OUTPUT
W4319	AOPR400	PROPORTIONAL VALUE
W4320	AOINR400	INTEGRAL
W4321	AODER400	DERIVATIVE
W4322	AOAH+63	HIGH ALARM
W4323	AOAH+64	H+/L- (CONTROL OUT OF RANGE)
W4324	AOAH+65	LOW ALARM
W4325		
W4326	AOSPR401	SETPOINT R401
W4327	AOOUR401	OUTPUT
W4328	AOPR401	PROPORTIONAL VALUE
W4329	AOINR401	INTEGRAL
W4330	AODER401	DERIVATIVE
W4331	AOAH+72	HIGH ALARM
W4332	AOAH+73	H+/L- (CONTROL OUT OF RANGE)
W4333	AOAH+74	LOW ALARM
W4334		
W4335	AOSPR402	SETPOINT R402
W4336	AOOUR402	OUTPUT
W4337	AOPR402	PROPORTIONAL VALUE
W4338	AOINR402	INTEGRAL
W4339	AODER402	DERIVATIVE
W4340	AOAH+81	HIGH ALARM
W4341	AOAH+82	H+/L- (CONTROL OUT OF RANGE)
W4342	AOAH+83	LOW ALARM
W4343		
W4344	AOSPR403	SETPOINT R403
W4345	AOOUR403	OUTPUT
W4346	AOPR403	PROPORTIONAL VALUE
W4347	AOINR403	INTEGRAL
W4348	AODER403	DERIVATIVE
W4349	AOAH+90	HIGH ALARM
W4350	AOAH+91	H+/L- (CONTROL OUT OF RANGE)
W4351	AOAH+92	LOW ALARM
W4352		
W4353	AOSPR404	SETPOINT R404
W4354	AOOUR404	OUTPUT
W4355	AOPR404	PROPORTIONAL VALUE
W4356	AOINR404	INTEGRAL
W4357	AODER404	DERIVATIVE
W4358	AOAH+99	HIGH ALARM
W4359	AOAH+100	H+/L- (CONTROL OUT OF RANGE)
W4360	AOAH+101	LOW ALARM
W4361		
W4362		

W4363		
W4364		
W4365		
W4366		
W4367		
W4368		
W4369		
W4370		
W4371		
W4372		
W4373		
W4374		
W4375		
W4376		
W4377		
W4378		
W4379		
W4380	AOSPCRBRA	ELECTROMAGNETIC BRAKE SETPOINT FOR CHILL ROLL
W4381		
W4382		
W4383	AOLUBCLIP2	SETPOINT FOR " CHAIN WITHOUT LUBIRCATION"
W4384		
W4385	AOLUBCLIP1	SETPOINT FOR " CHAIN WITH LUBIRCATION"
W4386		
W4387	AOLUBTRAK1	SETPOINT FOR " TRACK WITH LUBRICATION"
W4388		
W4389		
W4390		SETPOINT OF TDO CURRENT TO CONTINUOUS LUBRICATION
W4391		TDO CURRENT MEASURE
W4392		
W4393	AOLUBTRAK2	SETPOINT FOR " TRACK WITHOUT LUBRICATION"
W4394		
W4395		
W4396		
W4397		
W4398		
W4399		

NO	TAG	DESCRIPTION
W4600	AIMER365	MEASURE R365
W4601	AIOUR365	OUTPUT
W4602	AISPR365	SETPOINT
W4603	AIMER366	MEASURE
W4604	AIOUR366	OUTPUT
W4605	AISPR366	SETPOINT
W4606		
W4607		
W4608		
W4609		
W4610		
W4611		
W4612		
W4613		
W4614		
W4615	AIMER370	MEASURE R370
W4616	AIOUR370	OUTPUT
W4617	AISPR370	SETPOINT
W4618	AIMER371	MEASURE R371
W4619	AIOUR371	OUTPUT
W4620	AISPR371	SETPOINT
W4621	AIMER372	MEASURE R372
W4622	AIOUR372	OUTPUT
W4623	AISPR372	SETPOINT
W4624	AIMER373	MEASURE R373
W4625	AIOUR373	OUTPUT
W4626	AISPR373	SETPOINT
W4627	AIMER374	MEASURE R374
W4628	AIOUR374	OUTPUT
W4629	AISPR374	SETPOINT
W4630	AIMER375	MEASURE R375
W4631	AIOUR375	OUTPUT
W4632	AISPR375	SETPOINT
W4633	AIMER376	MEASURE R376
W4634	AIOUR376	OUTPUT
W4635	AISPR376	SETPOINT
W4636	AIMER377	MEASURE R378
W4637	AIOUR377	OUTPUT
W4638	AISPR377	SETPOINT
W4639	AIMER378	MEASURE R379
W4640	AIOUR378	OUTPUT
W4641	AISPR378	SETPOINT
W4642	AIMER379	MEASURE R380
W4643	AIOUR379	OUTPUT
W4644	AISPR379	SETPOINT
W4645	AIMER380	MEASURE R381
W4646	AIOUR380	OUTPUT
W4647	AISPR380	SETPOINT
W4648	AIMER381	MEASURE R382
W4649	AIOUR381	OUTPUT
W4650	AISPR381	SETPOINT

W4651		
W4652		
W4653		
W4654		
W4655		
W4656		
W4657		
W4658		
W4659		
W4660	AIMER385	MEASURE R385
W4661	AIOUR385	OUTPUT
W4662	AISPR385	SETPOINT
W4663	AIMER386	MEASURE R386
W4664	AIOUR386	OUTPUT
W4665	AISPR386	SETPOINT
W4666	AIMER387	MEASURE R387
W4667	AIOUR387	OUTPUT
W4668	AISPR387	SETPOINT
W4669	AIMER388	MEASURE R388
W4670	AIOUR388	OUTPUT
W4671	AISPR388	SETPOINT
W4672	AIMER389	MEASURE R389
W4673	AIOUR389	OUTPUT
W4674	AISPR389	SETPOINT
W4675	AIMER390	MEASURE R390
W4676	AIOUR390	OUTPUT
W4677	AISPR390	SETPOINT
W4678	AIMER391	MEASURE R391
W4679	AIOUR391	OUTPUT
W4680	AISPR391	SETPOINT
W4681	AIMER392	MEASURE R392
W4682	AIOUR392	OUTPUT
W4683	AISPR392	SETPOINT
W4684	AIMER393	MEASURE R393
W4685	AIOUR393	OUTPUT
W4686	AISPR393	SETPOINT
W4687	AIMER394	MEASURE R394
W4688	AIOUR394	OUTPUT
W4689	AISPR394	SETPOINT
W4690	AIMER395	MEASURE R395
W4691	AIOUR395	OUTPUT
W4692	AISPR395	SETPOINT
W4693	AIMER396	MEASURE R396
W4694	AIOUR396	OUTPUT
W4695	AISPR396	SETPOINT
W4696	AIMER397	MEASURE R397
W4697	AIOUR397	OUTPUT
W4698	AISPR397	SETPOINT
W4699	AIMER398	MEASURE R398
W4700	AIOUR398	OUTPUT
W4701	AISPR398	SETPOINT
W4702	AIMER399	MEASURE R399

W4703	AIOUR399	OUTPUT
W4704	AISPR399	SETPOINT
W4705	AIMER400	MEASURE R400
W4706	AIOUR400	OUTPUT
W4707	AISPR400	SETPOINT
W4708	AIMER401	MEASURE R401
W4709	AIOUR401	OUTPUT
W4710	AISPR401	SETPOINT
W4711	AIMER402	MEASURE R402
W4712	AIOUR402	OUTPUT
W4713	AISPR402	SETPOINT
W4714	AIMER403	MEASURE R403
W4715	AIOUR403	OUTPUT
W4716	AISPR403	SETPOINT
W4717	AIMER404	MEASURE R404
W4718	AIOUR404	OUTPUT
W4719	AISPR404	SETPOINT
W4720		
W4721		
W4722		
W4723		
W4724		
W4725		
W4726		
W4727		
W4728		
W4729	AILUBCLIP1	1COUNTER MEASURE FOR CLIPS W/ LUB
W4730	AILUBCLIP2	2COUNTER MEASURE FOR CLIP W/OUT LUB
W4731	AILUBTRAK1	1COUNTER MEASURE FOR TRACK W/ LUB
W4732	AILUBTRAK2	2COUNTER MEASURE FOR TRACK W/OUT LUB
W4733		
W4734		
W4735		AUXILIARY 1 CURRENT (NOT USED)
W4736		AUXILIARY 2 CURRENT (NOT USED)
W4737		FPC FLOWMETER (NOT USED)
W4738		LINE SPEED
W4739		
W4740		
W4741		
W4742		
W4743		
W4744		
W4745		
W4746		
W4747		
W4748		
W4749		
W4750		SEE "WORD BIT"
W4751		SEE "WORD BIT"
W4752		SEE "WORD BIT"
W4753		SEE "WORD BIT"
W4754		SEE "WORD BIT"

W4755		SEE "WORD BIT"
W4756		SEE "WORD BIT"
W4757		SEE "WORD BIT"
W4758		SEE "WORD BIT"
W4759		SEE "WORD BIT"
W4760		SEE "WORD BIT"
W4761		SEE "WORD BIT"
W4762		SEE "WORD BIT"
W4763		SEE "WORD BIT"
W4764		SEE "WORD BIT"
W4765		SEE "WORD BIT"
W4766		SEE "WORD BIT"
W4767		SEE "WORD BIT"
W4768		SEE "WORD BIT"
W4769		SEE "WORD BIT"
W4770		SEE "WORD BIT"
W4771		SEE "WORD BIT"
W4772		SEE "WORD BIT"
W4773		SEE "WORD BIT"
W4774		SEE "WORD BIT"
W4775		SEE "WORD BIT"
W4776		SEE "WORD BIT"
W4777		SEE "WORD BIT"
W4778		SEE "WORD BIT"
W4779		SEE "WORD BIT"
W4780		SEE "WORD BIT"
W4781		SEE "WORD BIT"
W4782		SEE "WORD BIT"
W4783		SEE "WORD BIT"
W4784		SEE "WORD BIT"
W4785		SEE "WORD BIT"
W4786		SEE "WORD BIT"
W4787		SEE "WORD BIT"
W4788		SEE "WORD BIT"
W4789		SEE "WORD BIT"
W4790		SEE "WORD BIT"
W4791		SEE "WORD BIT"
W4792		SEE "WORD BIT"
W4793		SEE "WORD BIT"
W4794		SEE "WORD BIT"
W4795		SEE "WORD BIT"
W4796		SEE "WORD BIT"
W4797		SEE "WORD BIT"
W4798		SEE "WORD BIT"
W4799		SEE "WORD BIT"
W4800		SEE "WORD BIT"
W4801		SEE "WORD BIT"
W4802		SEE "WORD BIT"
W4803		SEE "WORD BIT"
W4804		SEE "WORD BIT"
W4805		SEE "WORD BIT"
W4806		SEE "WORD BIT"

W4807		FREE
W4808		FREE
W4809		FREE
W4810		FREE
W4811		FREE
W4812		FREE
W4813		FREE
W4814		FREE
W4815		FREE
W4816		FREE
W4817		FREE
W4818		FREE
W4819		FREE
W4820		FREE
W4821		FREE
W4822		FREE
W4823		FREE
W4824		FREE
W4825		FREE
W4826		FREE
W4827		FREE
W4828		FREE
W4829		FREE
W4830		FREE
W4831		FREE
W4832		FREE
W4833		FREE
W4834		FREE
W4835		FREE
W4836		FREE
W4837		FREE
W4838		FREE
W4839		FREE
W4840		FREE
W4841		FREE
W4842		FREE
W4843		FREE
W4844		FREE
W4845		FREE
W4846		FREE
W4847		FREE
W4848		FREE
W4849		FREE
W4850		FREE
W4851		FREE
W4852		FREE
W4853		FREE
W4854		FREE
W4855		FREE
W4856		FREE
W4857		FREE
W4858		FREE

W4859		FREE
W4860		FREE
W4861		FREE
W4862		FREE
W4863		FREE
W4864		FREE
W4865		FREE
W4866		FREE
W4867		FREE
W4868		FREE
W4869		FREE
W4870		FREE
W4871		FREE
W4872		FREE
W4873		FREE
W4874		FREE
W4875		FREE
W4876		FREE
W4877		FREE
W4878		FREE
W4879		FREE
W4880		FREE
W4881		FREE
W4882		FREE
W4883		FREE
W4884		FREE
W4885		FREE
W4886		FREE
W4887		FREE
W4888		FREE
W4889		FREE
W4890		FREE
W4891		FREE
W4892		FREE
W4893		FREE
W4894		FREE
W4895		FREE
W4896		FREE
W4897		FREE
W4898		FREE
W4899		FREE
W4900		FREE
W4901		FREE
W4902		FREE
W4903		FREE
W4904		FREE
W4905		FREE
W4906		FREE
W4907		FREE
W4908		FREE
W4909		FREE
W4910		FREE

W4911		FREE
W4912		FREE
W4913		FREE
W4914		FREE
W4915		FREE
W4916		FREE
W4917		FREE
W4918		FREE
W4919		FREE
W4920		FREE
W4921		FREE
W4922		FREE
W4923		FREE
W4924		FREE
W4925		FREE
W4926		FREE
W4927		FREE
W4928		FREE
W4929		FREE
W4930		FREE
W4931		FREE
W4932		FREE
W4933		FREE
W4934		FREE
W4935		FREE
W4936		FREE
W4937		FREE
W4938		FREE
W4939		FREE
W4940		FREE
W4941		FREE
W4942		FREE
W4943		FREE
W4944		FREE
W4945		FREE
W4946		FREE
W4947		FREE
W4948		FREE
W4949		FREE
W4950		FREE
W4951		FREE
W4952		FREE
W4953		FREE
W4954		FREE
W4955		FREE
W4956		FREE
W4957		FREE
W4958		FREE
W4959		FREE
W4960		FREE
W4961		FREE
W4962		FREE

W4963		FREE
W4964		FREE
W4965		FREE
W4966		FREE
W4967		FREE
W4968		FREE
W4969		FREE
W4970		FREE
W4971		FREE
W4972		FREE
W4973		FREE
W4974		FREE
W4975		FREE
W4976		FREE
W4977		FREE
W4978		FREE
W4979		FREE
W4980		FREE
W4981		FREE
W4982		FREE
W4983		FREE
W4984		FREE
W4985		FREE
W4986		FREE
W4987		FREE
W4988		FREE
W4989		FREE
W4990		FREE
W4991		FREE
W4992		FREE
W4993		FREE
W4994		FREE
W4995		FREE
W4996		FREE
W4997		FREE
W4998		FREE
W4999		FREE
W5000		FREE
W5001		FREE
W5002		FREE
W5003		FREE
W5004		FREE
W5005		FREE
W5006		FREE
W5007		FREE
W5008		FREE
W5009		FREE
W5010		FREE
W5011		FREE
W5012		FREE
W5013		FREE
W5014		FREE

W5015		FREE
W5016		FREE
W5017		FREE
W5018		FREE
W5019		FREE
W5020		FREE
W5021		FREE
W5022		FREE
W5023		FREE
W5024		FREE
W5025		FREE
W5026		FREE
W5027		FREE
W5028		FREE
W5029		FREE
W5030		FREE
W5031		FREE
W5032		FREE
W5033		FREE
W5034		FREE
W5035		FREE
W5036		FREE
W5037		FREE
W5038		FREE
W5039		FREE
W5040		FREE
W5041		FREE
W5042		FREE
W5043		FREE
W5044		FREE
W5045		FREE
W5046		FREE
W5047		FREE
W5048		FREE
W5049		FREE
W5050		COPY FROM W4603
W5051		FREE

W6000 [50]	R365	CHILL ROLL COOLING SKID
W6050 [50]	R366	WATER-BATH SKID
W6100 [50]	R370	MDO ZONE #1
W6150 [50]	R371	MDO ZONE #2
W6200 [50]	R372	MDO ZONE #3
W6250 [50]	R373	MDO ZONE #4
W6300 [50]	R374	MDO ZONE #5
W6350 [50]	R375	MDO ZONE #6
W6400 [50]	R376	MDO ZONE #7
W6450 [50]	R377	MDO ZONE #8
W6500 [50]	R378	MDO ZONE #9
W6550 [50]	R379	MDO ZONE #10
W6600 [50]	R380	MDO ZONE #11
W6650 [50]	R381	MDO ZONE #12
W6700 [50]	R385	TDO ZONE #1
W6750 [50]	R386	TDO ZONE #2
W6800 [50]	R387	TDO ZONE #3
W6850 [50]	R388	TDO ZONE #4
W6900 [50]	R389	TDO ZONE #5
W6950 [50]	R390	TDO ZONE #6
W7000 [50]	R391	TDO ZONE #7
W7050 [50]	R392	TDO ZONE #8
W7100 [50]	R393	TDO ZONE #9
W7150 [50]	R394	TDO ZONE #10
W7200 [50]	R395	TDO ZONE #11
W7250 [50]	R396	TDO ZONE #12
W7300 [50]	R397	TDO ZONE #13
W7350 [50]	R398	TDO ZONE #14
W7400 [50]	R399	TDO ZONE #15
W7450 [50]	R400	TDO ZONE #16
W7500 [50]	R401	TDO ZONE #17
W7550 [50]	R402	TDO ZONE #18
W7600 [50]	R403	TDO ZONE #19
W7650 [50]	R404	TDO ZONE #20
W7700 ~ 8999		FREE

W454	0	DEFECT MEASURE, R365	
W454	1	DEFECT MEASURE, R366	
W454	2		
W454	3		
W454	4		
W454	5	DEFECT MEASURE, R370	
W454	6	DEFECT MEASURE, R371	
W454	7	DEFECT MEASURE, R372	
W454	8	DEFECT MEASURE, R373	
W454	9	DEFECT MEASURE, R374	
W454	A	DEFECT MEASURE, R375	
W454	B	DEFECT MEASURE, R376	
W454	C	DEFECT MEASURE, R377	
W454	D	DEFECT MEASURE, R378	
W454	E	DEFECT MEASURE, R379	
W454	F	DEFECT MEASURE, R380	
W455	0	DEFECT MEASURE, R381	
W455	1		
W455	2		
W455	3		
W455	4	DEFECT MEASURE, R385	
W455	5	DEFECT MEASURE, R386	
W455	6	DEFECT MEASURE, R387	
W455	7	DEFECT MEASURE, R388	
W455	8	DEFECT MEASURE, R389	
W455	9	DEFECT MEASURE, R390	
W455	A	DEFECT MEASURE, R391	
W455	B	DEFECT MEASURE, R392	
W455	C	DEFECT MEASURE, R393	
W455	D	DEFECT MEASURE, R394	
W455	E	DEFECT MEASURE, R395	
W455	F	DEFECT MEASURE, R396	
W456	0	DEFECT MEASURE, R397	
W456	1	DEFECT MEASURE, R398	
W456	2	DEFECT MEASURE, R399	
W456	3	DEFECT MEASURE, R400	
W456	4	DEFECT MEASURE, R401	
W456	5	DEFECT MEASURE, R402	
W456	6	DEFECT MEASURE, R403	
W456	7	DEFECT MEASURE, R404	
W456	8		
W456	9		
W456	A		
W456	B		
W456	C		
W456	D		
W456	E		
W456	F		
W464	5	COPY FROM W454, 7	

W465	D	COPY FROM W454, 8	
W500	0	CONTACTOR ANSWER OF CHILL ROLL COOLING SKID, E160	IB7, 0
W500	1	CONTACTOR ANSWER OF WATER BATH COOLING SKID, E161	IB7, 2
W500	2	CONTACTOR ANSWER OF ELECTROMAGNETIC BRAKE, E162	I80, 5
W500	3		
W500	4		
W500	5		
W500	6		
W500	7		
W500	8		
W500	9	CONTACTOR ANSWER OF MDO OIL SKID ON, E169	IB7, 4
W500	A	CONTACTOR ANSWER OF MDO PUMP M1430.01, E170	I80, D
W500	B	CONTACTOR ANSWER OF MDO PUMP M1430.02, E171	I80, E
W500	C	CONTACTOR ANSWER OF MDO PUMP M1430.03, E172	I80, F
W500	D	CONTACTOR ANSWER OF MDO PUMP M1430.04, E173	I90, 0
W500	E	CONTACTOR ANSWER OF MDO PUMP M1430.05, E174	I90, 1
W500	F	CONTACTOR ANSWER OF MDO PUMP M1430.06, E175	I90, 2
W501	0	CONTACTOR ANSWER OF MDO PUMP M1430.07, E170	I90, 3
W501	1	CONTACTOR ANSWER OF MDO PUMP M1430.08, E171	I90, 4
W501	2	CONTACTOR ANSWER OF MDO PUMP M1430.09, E172	I90, 5
W501	3	CONTACTOR ANSWER OF MDO PUMP M1430.10, E173	I90, 6
W501	4	CONTACTOR ANSWER OF MDO PUMP M1430.11, E174	I90, 7
W501	5	CONTACTOR ANSWER OF MDO PUMP M1430.12, E175	I90, 8
W501	6		
W501	7		
W501	8		
W501	9	CONTACTOR OF TDO BLOWER M1520.01, E185	I81, 7
W501	A	CONTACTOR OF TDO BLOWER M1528.01, E186	I81, 1
W501	B	CONTACTOR OF TDO BLOWER M1520.02, E187	
W501	C	CONTACTOR OF TDO BLOWER M1520.03, E188	
W501	D	CONTACTOR OF TDO BLOWER M1520.04, E189	
W501	E	CONTACTOR OF TDO BLOWER M1520.05, E190	
W501	F	CONTACTOR OF TDO BLOWER M1520.06, E191	
W502	0	CONTACTOR OF TDO BLOWER M1520.07, E192	
W502	1	CONTACTOR OF TDO BLOWER M1520.08, E193	
W502	2	CONTACTOR OF TDO BLOWER M1520.09, E194	
W502	3	CONTACTOR OF TDO BLOWER M1520.10, E195	
W502	4	CONTACTOR OF TDO BLOWER M1520.11, E196	
W502	5	CONTACTOR OF TDO BLOWER M1520.12, E197	
W502	6	CONTACTOR OF TDO BLOWER M1520.13, E198	
W502	7	CONTACTOR OF TDO BLOWER M1520.14, E199	
W502	8	CONTACTOR OF TDO BLOWER M1520.15, E200	
W502	9	CONTACTOR OF TDO BLOWER M1520.16, E201	
W502	A	CONTACTOR OF TDO BLOWER M1520.17, E202	
W502	B	CONTACTOR OF TDO BLOWER M1520.18, E203	
W502	C	CONTACTOR OF TDO BLOWER M1520.19, E204	
W502	D	CONTACTOR OF TDO BLOWER M1520.20, E205	
W502	E	CONTACTOR OF TDO BLOWER M1520.21, E206	
W502	F	CONTACTOR OF TDO BLOWER M1520.22, E207	

W503	0	CONTACTOR OF TDO BLOWER M1520.01, E208
W503	1	CONTACTOR OF TDO BLOWER M1520.01, E209
W503	2	CONTACTOR OF TDO BLOWER M1520.01, E210
W503	3	CONTACTOR OF TDO BLOWER M1520.01, E211
W503	4	CONTACTOR OF TDO BLOWER M1520.01, E212
W503	5	CONTACTOR OF TDO BLOWER M1520.01, E213
W503	6	CONTACTOR OF TDO BLOWER M1520.01, E214
W503	7	CONTACTOR OF TDO BLOWER M1520.01, E215
W503	8	CONTACTOR OF TDO BLOWER M1520.01, E216
W503	9	CONTACTOR OF TDO BLOWER M1520.01, E217
W503	A	CONTACTOR OF TDO BLOWER M1520.01, E218
W503	B	CONTACTOR OF TDO BLOWER M1520.01, E219
W503	C	CONTACTOR OF TDO BLOWER M1520.01, E220
W503	D	CONTACTOR OF TDO BLOWER M1528.02, E221
W503	E	CONTACTOR OF TDO BLOWER M1528.03, E222
W503	F	CONTACTOR OF TDO BLOWER M1525.01, E223
W504	0	CONTACTOR OF TDO BLOWER M1530.01, E224
W504	1	
W504	2	
W504	3	
W504	4	
W504	5	
W504	6	
W504	7	
W504	8	
W504	9	
W504	A	
W504	B	
W504	C	
W504	D	
W504	E	
W504	F	
W505	0	
W505	1	
W505	2	
W505	3	
W505	4	
W505	5	
W505	6	
W505	7	
W505	8	
W505	9	
W505	A	
W505	B	
W505	C	
W505	D	
W505	E	
W505	F	

W506	0	CONTACTOR ANSWER OF CHILL ROLL EXHAUST HOOD	M1263.01	
W506	1	CONTACTOR ANSWER OF CHILL ROLL WATER REMOVAL	M1330.01	
W506	2	CONTACTOR ANSWER OF CHILL ROLL AIR KNIFE	M1330.02	
W506	3	CONTACTOR ANSWER OF CHILL ROLL WATER REMOVAL	M1330.03	
W506	4	CONTACTOR ANSWER OF CHILL ROLL WATER REMOVAL	M1310.03	
W506	5	CONTACTOR ANSWER OF CHILL ROLL WATER REMOVAL	M1301.01	
W506	6	CONTACTOR ANSWER OF CHILL ROLL BRAKE	Y1301.02	
W506	7	CONTACTOR ANSWER OF AUXILIARY #1	M1360.01	
W506	8			
W506	9			
W506	A	CONTACTOR ANSWER OF AUXILIARY #2	M1450.01	
W506	B			
W506	C			
W506	D			
W506	E	CONTACTOR ANSWER OF TDO CHAIN TENSION SYSTEM	M1515.01	
W506	F			
W507	0	CONTACTOR ANSWER OF VACUUM ROLL NO. 1 BLOWER	M1812.01	
W507	1	CONTACTOR ANSWER OF VACUUM ROLL NO. 2 BLOWER	M1825.01	
W507	2	CONTACTOR ANSWER OF OZONE EXHAUST NO. 1 BLOWER	M1831.01	
W507	3	CONTACTOR ANSWER OF OZONE EXHAUST NO. 2 BLOWER	M1831.02	
W507	4	CONTACTOR ANSWER OF AUXILIARY WINDER #3		
W507	5	CONTACTOR ANSWER OF OZONE EXHAUST NO. 3 BLOWER	M1831.03	
W507	6			
W507	7			
W507	8			
W507	9			
W507	A			
W507	B			
W507	C			
W507	D			
W507	E			
W507	F			
W508	0	CONTACTOR ANSWER OF OZONE TREATER #1 BLOWER		
W508	1	CONTACTOR ANSWER OF OZONE TREATER #2 BLOWER		
W508	2	CONTACTOR ANSWER OF OZONE TREATER #3 BLOWER		
W508	3	CONTACTOR ANSWER OF OZONE TREATER #4 BLOWER		
W508	4			
W508	5			
W508	6			
W508	7			
W508	8			
W508	9			
W508	A			
W508	B			
W508	C			
W508	D			
W508	E			
W508	F			
W509	0			

W509	1		
W509	2		
W509	3		
W509	4		
W509	5		
W509	6		
W509	7		
W509	8		
W509	9		
W509	A		
W509	B		
W509	C		
W509	D		
W509	E		
W509	F		
W510	0	OUTPUT OF CHILL ROLL COOLING SKID, E160	
W510	1	OUTPUT OF WATER BATH COOLING SKID, E161	
W510	2	OUTPUT OF ELECTROMAGNETIC BRAKE, E162	
W510	3		
W510	4		
W510	5		
W510	6		
W510	7		
W510	8		
W510	9		
W510	A	OUTPUT OF MDO PUMP M1430.01, E170	
W510	B	OUTPUT OF MDO PUMP M1430.02, E171	
W510	C	OUTPUT OF MDO PUMP M1430.03, E172	
W510	D	OUTPUT OF MDO PUMP M1430.04, E173	
W510	E	OUTPUT OF MDO PUMP M1430.05, E174	
W510	F	OUTPUT OF MDO PUMP M1430.06, E175	
W511	0	OUTPUT OF MDO PUMP M1430.07, E176	
W511	1	OUTPUT OF MDO PUMP M1430.08, E177	
W511	2	OUTPUT OF MDO PUMP M1430.09, E178	
W511	3	OUTPUT OF MDO PUMP M1430.10, E179	
W511	4	OUTPUT OF MDO PUMP M1430.11, E180	
W511	5	OUTPUT OF MDO PUMP M1430.12, E181	
W511	6		
W511	7		
W511	8		
W511	9	OUTPUT OF MDO PUMP M1520.01, E185	
W511	A	OUTPUT OF MDO PUMP M1528.01, E186	
W511	B	OUTPUT OF MDO PUMP M1520.02, E187	
W511	C	OUTPUT OF MDO PUMP M1430.03, E188	
W511	D	OUTPUT OF MDO PUMP M1430.04, E189	
W511	E	OUTPUT OF MDO PUMP M1430.05, E190	
W511	F	OUTPUT OF MDO PUMP M1520.06, E191	
W512	0	OUTPUT OF MDO PUMP M1520.07, E192	
W512	1	OUTPUT OF MDO PUMP M1520.08, E193	

W512	2	OUTPUT OF MDO PUMP M1520.09, E194	
W512	3	OUTPUT OF MDO PUMP M1520.10, E195	
W512	4	OUTPUT OF MDO PUMP M1520.11, E196	
W512	5	OUTPUT OF MDO PUMP M1520.12, E197	
W512	6	OUTPUT OF MDO PUMP M1520.13, E198	
W512	7	OUTPUT OF MDO PUMP M1520.14, E199	
W512	8	OUTPUT OF MDO PUMP M1520.15, E200	
W512	9	OUTPUT OF MDO PUMP M1520.16, E201	
W512	A	OUTPUT OF MDO PUMP M1520.17, E202	
W512	B	OUTPUT OF MDO PUMP M1520.18, E203	
W512	C	OUTPUT OF MDO PUMP M1520.19, E204	
W512	D	OUTPUT OF MDO PUMP M1520.20, E205	
W512	E	OUTPUT OF MDO PUMP M1520.21, E206	
W512	F	OUTPUT OF MDO PUMP M1520.22, E207	
W513	0	OUTPUT OF MDO PUMP M1520.23, E208	
W513	1	OUTPUT OF MDO PUMP M1520.24, E209	
W513	2	OUTPUT OF MDO PUMP M1520.25, E210	
W513	3	OUTPUT OF MDO PUMP M1520.26, E211	
W513	4	OUTPUT OF MDO PUMP M1520.27, E212	
W513	5	OUTPUT OF MDO PUMP M1520.28, E213	
W513	6	OUTPUT OF MDO PUMP M1520.29, E214	
W513	7	OUTPUT OF MDO PUMP M1520.30, E215	
W513	8	OUTPUT OF MDO PUMP M1520.31, E216	
W513	9	OUTPUT OF MDO PUMP M1520.32, E217	
W513	A	OUTPUT OF MDO PUMP M1520.33, E218	
W513	B	OUTPUT OF MDO PUMP M1520.34, E219	
W513	C	OUTPUT OF MDO PUMP M1520.35, E220	
W513	D	OUTPUT OF MDO PUMP M1520.36, E221	
W513	E	OUTPUT OF MDO PUMP M1528.03, E222	
W513	F	OUTPUT OF MDO PUMP M1525.01, E223	
W514	0	OUTPUT OF MDO PUMP M1530.01, E224	
W514	1		
W514	2		
W514	3		
W514	4		
W514	5		
W514	6		
W514	7		
W514	8		
W514	9		
W514	A		
W514	B		
W514	C		
W514	D		
W514	E		
W514	F		
W515	0		
W515	1		
W515	2		

W515	3		
W515	4		
W515	5		
W515	6		
W515	7		
W515	8		
W515	9		
W515	A		
W515	B		
W515	C		
W515	D		
W515	E		
W515	F		
W516	0	OUTPUT OF CHILL ROLL EXHAUST HOOD M1263.01	OC4, 0
W516	1	OUTPUT OF CHILL ROLL WATER REMOVAL 1330.01	OC4, 4
W516	2	OUTPUT OF CHILL ROLL WATER REMOVAL 1330.02	OC4, 1
W516	3	OUTPUT OF CHILL ROLL WATER REMOVAL 1330.03	OC4, 2
W516	4	OUTPUT OF CHILL ROLL WATER REMOVAL 1310.03	OC4, 3
W516	5	OUTPUT OF CHILL ROLL HORIZONTAL MOVEMENT M1301.01	
W516	6	OUTPUT OF CHILL ROLL BRAKE Y1301.02	
W516	7	OUTPUT OF AUXILIARY WINDER #1 M1360.01	
W516	8		
W516	9		
W516	A	OUTPUT OF AUXILIARY WINDER #2 M1450.01	
W516	B		
W516	C		
W516	D		
W516	E	OUTPUT OF TDO CHAIN TENSION SYSTEM M1515.01	
W516	F		
W517	0	OUTPUT OF VACUUM ROLL #1 BLOWER M1812.01	
W517	1	OUTPUT OF VACUUM ROLL #2 BLOWER M1825.01	
W517	2	OUTPUT OF OZONE EXHAUST BLOWER #1 M1831.01	
W517	3	OUTPUT OF OZONE EXHAUST BLOWER #2 M1831.02	
W517	4	OUTPUT OF AUXILIARY WINDER #3	
W517	5	OUTPUT OF OZONE EXHAUST BLOWER #3 M1831.03	
W517	6		
W517	7		
W517	8		
W517	9		
W517	A		
W517	B		
W517	C		
W517	D		
W517	E		
W517	F		
W518	0	OUTPUT OF OZONE TREATER BLOWER #1	
W518	1	OUTPUT OF OZONE TREATER BLOWER #2	
W518	2	OUTPUT OF OZONE TREATER BLOWER #3	
W518	3	OUTPUT OF OZONE TREATER BLOWER #4	

W518	4		
W518	5		
W518	6		
W518	7		
W518	8		
W518	9		
W518	A		
W518	B		
W518	C		
W518	D		
W518	E		
W518	F		
W519	0		
W519	1		
W519	2		
W519	3		
W519	4		
W519	5		
W519	6		
W519	7		
W519	8		
W519	9		
W519	A		
W519	B		
W519	C		
W519	D		
W519	E		
W519	F		
W520	0	IN XOR OUT OF CHILL ROLL COOLING SKID, E160	
W520	1	IN XOR OUT OF WATER BATH COOLING SKID, E161	
W520	2	IN XOR OUT OF ELECTROMAGNETIC BRAKE, E162	
W520	3		
W520	4		
W520	5		
W520	6		
W520	7		
W520	8		
W520	9		
W520	A	IN XOR OUT OF MDO PUMP M1430.01, E170	
W520	B	IN XOR OUT OF MDO PUMP M1430.02, E171	
W520	C	IN XOR OUT OF MDO PUMP M1430.03, E172	
W520	D	IN XOR OUT OF MDO PUMP M1430.04, E173	
W520	E	IN XOR OUT OF MDO PUMP M1430.05, E174	
W520	F	IN XOR OUT OF MDO PUMP M1430.06, E175	
W521	0	IN XOR OUT OF MDO PUMP M1430.07, E176	
W521	1	IN XOR OUT OF MDO PUMP M1430.08, E177	
W521	2	IN XOR OUT OF MDO PUMP M1430.09, E178	
W521	3	IN XOR OUT OF MDO PUMP M1430.10, E179	
W521	4	IN XOR OUT OF MDO PUMP M1430.11, E180	

W521	5	IN XOR OUT OF MDO PUMP M1430.12, E181	
W521	6		
W521	7		
W521	8		
W521	9	IN XOR OUT OF TDO BLOWER M1520.01, E185	
W521	A	IN XOR OUT OF TDO BLOWER M1528.01, E186	
W521	B	IN XOR OUT OF TDO BLOWER M1520.02, E187	
W521	C	IN XOR OUT OF TDO BLOWER M1520.03, E188	
W521	D	IN XOR OUT OF TDO BLOWER M1520.04, E189	
W521	E	IN XOR OUT OF TDO BLOWER M1520.05, E190	
W521	F	IN XOR OUT OF TDO BLOWER M1520.06, E191	
W522	0	IN XOR OUT OF TDO BLOWER M1520.07, E192	
W522	1	IN XOR OUT OF TDO BLOWER M1520.08, E193	
W522	2	IN XOR OUT OF TDO BLOWER M1520.09, E194	
W522	3	IN XOR OUT OF TDO BLOWER M1520.10, E195	
W522	4	IN XOR OUT OF TDO BLOWER M1520.11, E196	
W522	5	IN XOR OUT OF TDO BLOWER M1520.12, E197	
W522	6	IN XOR OUT OF TDO BLOWER M1520.13, E198	
W522	7	IN XOR OUT OF TDO BLOWER M1520.14, E199	
W522	8	IN XOR OUT OF TDO BLOWER M1520.15, E200	
W522	9	IN XOR OUT OF TDO BLOWER M1520.16, E201	
W522	A	IN XOR OUT OF TDO BLOWER M1520.17, E202	
W522	B	IN XOR OUT OF TDO BLOWER M1520.18, E203	
W522	C	IN XOR OUT OF TDO BLOWER M1520.19, E204	
W522	D	IN XOR OUT OF TDO BLOWER M1520.20, E205	
W522	E	IN XOR OUT OF TDO BLOWER M1520.21, E206	
W522	F	IN XOR OUT OF TDO BLOWER M1520.22, E207	
W523	0	IN XOR OUT OF TDO BLOWER M1520.23, E208	
W523	1	IN XOR OUT OF TDO BLOWER M1520.24, E209	
W523	2	IN XOR OUT OF TDO BLOWER M1520.25, E210	
W523	3	IN XOR OUT OF TDO BLOWER M1520.26, E211	
W523	4	IN XOR OUT OF TDO BLOWER M1520.27, E212	
W523	5	IN XOR OUT OF TDO BLOWER M1520.28, E213	
W523	6	IN XOR OUT OF TDO BLOWER M1520.29, E214	
W523	7	IN XOR OUT OF TDO BLOWER M1520.30, E215	
W523	8	IN XOR OUT OF TDO BLOWER M1520.31, E216	
W523	9	IN XOR OUT OF TDO BLOWER M1520.32, E217	
W523	A	IN XOR OUT OF TDO BLOWER M1520.33, E218	
W523	B	IN XOR OUT OF TDO BLOWER M1520.34, E219	
W523	C	IN XOR OUT OF TDO BLOWER M1520.35, E220	
W523	D	IN XOR OUT OF TDO BLOWER M1520.36, E221	
W523	E	IN XOR OUT OF TDO BLOWER M1528.03, E222	
W523	F	IN XOR OUT OF TDO BLOWER M1525.01, E223	
W524	0	IN XOR OUT OF TDO BLOWER M1530.01, E224	
W524	1		
W524	2		
W524	3		
W524	4		
W524	5		

W524	6		
W524	7		
W524	8		
W524	9		
W524	A		
W524	B		
W524	C		
W524	D		
W524	E		
W524	F		
W525	0		
W525	1		
W525	2		
W525	3		
W525	4		
W525	5		
W525	6		
W525	7		
W525	8		
W525	9		
W525	A		
W525	B		
W525	C		
W525	D		
W525	E		
W525	F		
W526	0	IN XOR OUT OF CHILL ROLL EXHAUST HOOD M1263.01	
W526	1	IN XOR OUT OF CHILL ROLL WATER REMOVAL M1330.01	
W526	2	IN XOR OUT OF CHILL ROLL WATER REMOVAL M1330.02	
W526	3	IN XOR OUT OF CHILL ROLL WATER REMOVAL M1330.03	
W526	4	IN XOR OUT OF CHILL ROLL WATER REMOVAL M1310.03	
W526	5	IN XOR OUT OF CHILL ROLL HORIZONTAL MOVEMENT M1301.01	
W526	6	IN XOR OUT OF CHILL ROLL BRAKE Y1301.02	
W526	7	IN XOR OUT OF AUXILIARY WINDER #1 M1360.01	
W526	8		
W526	9		
W526	A	IN XOR OUT OF AUXILIARY WINDER #2 M1450.01	
W526	B		
W526	C		
W526	D		
W526	E	IN XOR OUT OF TDO CHAIN TENSION SYSTEM M1515.01	
W526	F		
W527	0	IN XOR OUT OF VACUUM ROLL #1 BLOWER M1812.01	
W527	1	IN XOR OUT OF VACUUM ROLL #2 BLOWER M1825.01	
W527	2	IN XOR OUT OF OZONE EXHAUST BLOWER #1 M1831.01	
W527	3	IN XOR OUT OF OZONE EXHAUST BLOWER #2 M1831.02	
W527	4	IN XOR OUT OF AUXILIARY WINDER #3	
W527	5	IN XOR OUT OF OZONE EXHAUST BLOWER #3 M1831.03	
W527	6		

W527	7		
W527	8		
W527	9		
W527	A		
W527	B		
W527	C		
W527	D		
W527	E		
W527	F		
W528	0	IN XOR OUT OF OZONE TREATER #1 BLOWER	
W528	1	IN XOR OUT OF OZONE TREATER #2 BLOWER	
W528	2	IN XOR OUT OF OZONE TREATER #3 BLOWER	
W528	3	IN XOR OUT OF OZONE TREATER #4 BLOWER	
W528	4		
W528	5		
W528	6		
W528	7		
W528	8		
W528	9		
W528	A		
W528	B		
W528	C		
W528	D		
W528	E		
W528	F		
W529	0		
W529	1		
W529	2		
W529	3		
W529	4		
W529	5		
W529	6		
W529	7		
W529	8		
W529	9		
W529	A		
W529	B		
W529	C		
W529	D		
W529	E		
W529	F		
W530	0	DEFECT OF CHILL ROLL COOLING SKID, E160	
W530	1	DEFECT OF WATER BATH COOLING SKID, E161	
W530	2	DEFECT OF CHILL ROLL BRAKE, E162	
W530	3		
W530	4		
W530	5		
W530	6		
W530	7		

W530	8		
W530	9		
W530	A	DEFECT OF MDO PUMP M1430.01,	E170
W530	B	DEFECT OF MDO PUMP M1430.02,	E171
W530	C	DEFECT OF MDO PUMP M1430.03,	E172
W530	D	DEFECT OF MDO PUMP M1430.04,	E173
W530	E	DEFECT OF MDO PUMP M1430.05,	E174
W530	F	DEFECT OF MDO PUMP M1430.06,	E175
W531	0	DEFECT OF MDO PUMP M1430.07,	E176
W531	1	DEFECT OF MDO PUMP M1430.08,	E177
W531	2	DEFECT OF MDO PUMP M1430.09,	E178
W531	3	DEFECT OF MDO PUMP M1430.10,	E179
W531	4	DEFECT OF MDO PUMP M1430.11,	E180
W531	5	DEFECT OF MDO PUMP M1430.12,	E181
W531	6		
W531	7		
W531	8		
W531	9	DEFECT OF TDO BLOWER M1520.01	E185
W531	A	DEFECT OF TDO BLOWER M1528.01	E186
W531	B	DEFECT OF TDO BLOWER M1520.02	E187
W531	C	DEFECT OF TDO BLOWER M1520.03	E188
W531	D	DEFECT OF TDO BLOWER M1520.04	E189
W531	E	DEFECT OF TDO BLOWER M1520.05	E190
W531	F	DEFECT OF TDO BLOWER M1520.06	E191
W532	0	DEFECT OF TDO BLOWER M1520.07	E192
W532	1	DEFECT OF TDO BLOWER M1520.08	E193
W532	2	DEFECT OF TDO BLOWER M1520.09	E194
W532	3	DEFECT OF TDO BLOWER M1520.10	E195
W532	4	DEFECT OF TDO BLOWER M1520.11	E196
W532	5	DEFECT OF TDO BLOWER M1520.12	E197
W532	6	DEFECT OF TDO BLOWER M1520.13	E198
W532	7	DEFECT OF TDO BLOWER M1520.14	E199
W532	8	DEFECT OF TDO BLOWER M1520.15	E200
W532	9	DEFECT OF TDO BLOWER M1520.16	E201
W532	A	DEFECT OF TDO BLOWER M1520.17	E202
W532	B	DEFECT OF TDO BLOWER M1520.18	E203
W532	C	DEFECT OF TDO BLOWER M1520.19	E204
W532	D	DEFECT OF TDO BLOWER M1520.20	E205
W532	E	DEFECT OF TDO BLOWER M1520.21	E206
W532	F	DEFECT OF TDO BLOWER M1520.22	E207
W533	0	DEFECT OF TDO BLOWER M1520.23	E208
W533	1	DEFECT OF TDO BLOWER M1520.24	E209
W533	2	DEFECT OF TDO BLOWER M1520.25	E210
W533	3	DEFECT OF TDO BLOWER M1520.26	E211
W533	4	DEFECT OF TDO BLOWER M1520.27	E212
W533	5	DEFECT OF TDO BLOWER M1520.28	E213
W533	6	DEFECT OF TDO BLOWER M1520.29	E214
W533	7	DEFECT OF TDO BLOWER M1520.30	E215
W533	8	DEFECT OF TDO BLOWER M1520.31	E216

W533	9	DEFECT OF TDO BLOWER M1520.32	E217	
W533	A	DEFECT OF TDO BLOWER M1520.33	E218	
W533	B	DEFECT OF TDO BLOWER M1520.34	E219	
W533	C	DEFECT OF TDO BLOWER M1520.35	E220	
W533	D	DEFECT OF TDO BLOWER M1520.36	E221	
W533	E	DEFECT OF TDO BLOWER M1528.03	E222	
W533	F	DEFECT OF TDO BLOWER M1525.01	E223	
W534	0	DEFECT OF TDO BLOWER M1530.01	E224	
W534	1			
W534	2			
W534	3			
W534	4			
W534	5			
W534	6			
W534	7			
W534	8			
W534	9			
W534	A			
W534	B			
W534	C			
W534	D			
W534	E			
W534	F			
W535	0			
W535	1			
W535	2			
W535	3			
W535	4			
W535	5			
W535	6			
W535	7			
W535	8			
W535	9			
W535	A			
W535	B			
W535	C			
W535	D			
W535	E			
W535	F			
W536	0	DEFECT OF EXHAUST HOOD M1263.01		
W536	1	DEFECT OF CHILL ROLL WATER REMOVAL	M1330.01	
W536	2	DEFECT OF CHILL ROLL AIR KNIFE BLOWER	M1330.02	
W536	3	DEFECT OF CHILL ROLL WATER REMOVAL	M1330.03	
W536	4	DEFECT OF CHILL ROLL WATER REMOVAL	M1310.03	
W536	5	DEFECT OF CHILL ROLL HORIZONTAL MOVEMENT	M1301.01	
W536	6	DEFECT OF CHILL ROLL BRAKE	Y1301.02	
W536	7	DEFECT OF AUXILIARY WINDER #1 MOTOR	M1360.01	
W536	8			
W536	9			

W536	A	DEFECT OF AUXILIARY WINDER #2 MOTOR	M1450.01	
W536	B			
W536	C			
W536	D			
W536	E	DEFECT OF CHAIN TENSION SYSTEM	M1515.01	
W536	F			
W537	0	DEFECT OF VACUUM ROLL #1	M1812.01	
W537	1	DEFECT OF VACUUM ROLL #2	M1825.01	
W537	2	DEFECT OF OZONE EXHAUST BLOWER #1	M1831.01	
W537	3	DEFECT OF OZONE EXHAUST BLOWER #2	M1831.02	
W537	4	DEFECT OF AUXILIARY WINDER #3		
W537	5	DEFECT OF OZONE EXHAUST BLOWER #3	M1831.03	
W537	6			
W537	7			
W537	8			
W537	9			
W537	A			
W537	B			
W537	C			
W537	D			
W537	E			
W537	F			
W538	0	DEFECT OF OZONE TREATER #1 BLOWER		
W538	1	DEFECT OF OZONE TREATER #2 BLOWER		
W538	2	DEFECT OF OZONE TREATER #3 BLOWER		
W538	3	DEFECT OF OZONE TREATER #4 BLOWER		
W538	4			
W538	5			
W538	6			
W538	7			
W538	8			
W538	9			
W538	A			
W538	B			
W538	C			
W538	D			
W538	E			
W538	F			

W4400	0	DOSTE 160	START/STOP GAZ HEATER CR C1340
W4400	1	DOSTE 161	START/STOP GAZ HEATER CR C1350
W4400	2	DOSTE 162	START/STOP ELEC. BRAKE Y1301.02
W4400	3		
W4400	4		
W4400	5		
W4400	6		
W4400	7		
W4400	8		
W4400	9	DOSTE 169	START/STOP GAZ HEATER C1340.13, E169
W4400	A	DOSTE 170	START/STOP MDO PUMP E170
W4400	B	DOSTE 171	START/STOP MDO PUMP E171
W4400	C	DOSTE 172	START/STOP MDO PUMP E172
W4400	D	DOSTE 173	START/STOP MDO PUMP E173
W4400	E	DOSTE 174	START/STOP MDO PUMP E174
W4400	F	DOSTE 175	START/STOP MDO PUMP E175
W4401	0	DOSTE 176	START/STOP MDO PUMP E176
W4401	1	DOSTE 177	START/STOP MDO PUMP E177
W4401	2	DOSTE 178	START/STOP MDO PUMP E178
W4401	3	DOSTE 179	START/STOP MDO PUMP E179
W4401	4	DOSTE 180	START/STOP MDO PUMP E180
W4401	5	DOSTE 181	START/STOP MDO PUMP E176
W4401	6		
W4401	7		
W4401	8		
W4401	9	DOSTE 185	START/STOP TDO BLOWER E185
W4401	A	DOSTE 186	START/STOP TDO BLOWER E186
W4401	B	DOSTE 187	START/STOP TDO BLOWER E187
W4401	C	DOSTE 188	START/STOP TDO BLOWER E188
W4401	D	DOSTE 189	START/STOP TDO BLOWER E189
W4401	E	DOSTE 190	START/STOP TDO BLOWER E190
W4401	F	DOSTE 191	START/STOP TDO BLOWER E191
W4402	0	DOSTE 192	START/STOP TDO BLOWER E192
W4402	1	DOSTE 193	START/STOP TDO BLOWER E193
W4402	2	DOSTE 194	START/STOP TDO BLOWER E194
W4402	3	DOSTE 195	START/STOP TDO BLOWER E195
W4402	4	DOSTE 196	START/STOP TDO BLOWER E196
W4402	5	DOSTE 197	START/STOP TDO BLOWER E197
W4402	6	DOSTE 198	START/STOP TDO BLOWER E198
W4402	7	DOSTE 199	START/STOP TDO BLOWER E199
W4402	8	DOSTE 200	START/STOP TDO BLOWER E200
W4402	9	DOSTE 201	START/STOP TDO BLOWER E201
W4402	A	DOSTE 202	START/STOP TDO BLOWER E202
W4402	B	DOSTE 203	START/STOP TDO BLOWER E203
W4402	C	DOSTE 204	START/STOP TDO BLOWER E204
W4402	D	DOSTE 205	START/STOP TDO BLOWER E205
W4402	E	DOSTE 206	START/STOP TDO BLOWER E206
W4402	F	DOSTE 207	START/STOP TDO BLOWER E207
W4403	0	DOSTE 208	START/STOP TDO BLOWER E208

W4403	1	DOSTE 209	START/STOP TDO BLOWER E209
W4403	2	DOSTE 210	START/STOP TDO BLOWER E210
W4403	3	DOSTE 211	START/STOP TDO BLOWER E211
W4403	4	DOSTE 212	START/STOP TDO BLOWER E212
W4403	5	DOSTE 213	START/STOP TDO BLOWER E213
W4403	6	DOSTE 214	START/STOP TDO BLOWER E214
W4403	7	DOSTE 215	START/STOP TDO BLOWER E215
W4403	8	DOSTE 216	START/STOP TDO BLOWER E216
W4403	9	DOSTE 217	START/STOP TDO BLOWER E217
W4403	A	DOSTE 218	START/STOP TDO BLOWER E218
W4403	B	DOSTE 219	START/STOP TDO BLOWER E219
W4403	C	DOSTE 220	START/STOP TDO BLOWER E220
W4403	D	DOSTE 221	START/STOP INLET E221
W4403	E	DOSTE 222	START/STOP TDO OUTLET E222
W4403	F	DOSTE 223	START/STOP TDO OUTLET E223
W4404	0	DOSTE 224	START/STOP TDO OUTLET E224
W4404	1	DOSTE 225	START/STOP TDO BURNER E225 ZONE 1
W4404	2	DOSTE 226	START/STOP TDO BURNER E226 ZONE 2
W4404	3	DOSTE 227	START/STOP TDO BURNER E227 ZONE 3
W4404	4	DOSTE 228	START/STOP TDO BURNER E228 ZONE 4
W4404	5	DOSTE 229	START/STOP TDO BURNER E229 ZONE 5
W4404	6	DOSTE 230	START/STOP TDO BURNER E230 ZONE 6
W4404	7	DOSTE 231	START/STOP TDO BURNER E231 ZONE 7
W4404	8	DOSTE 232	START/STOP TDO BURNER E232 ZONE 8
W4404	9	DOSTE 233	START/STOP TDO BURNER E233 ZONE 9
W4404	A	DOSTE 234	START/STOP TDO BURNER E234 ZONE 10
W4404	B	DOSTE 235	START/STOP TDO BURNER E235 ZONE 11
W4404	C	DOSTE 236	START/STOP TDO BURNER E236 ZONE 12
W4404	D	DOSTE 237	START/STOP TDO BURNER E237 ZONE 13
W4404	E	DOSTE 238	START/STOP TDO BURNER E238 ZONE 14
W4404	F	DOSTE 239	START/STOP TDO BURNER E239 ZONE 15
W4405	0	DOSTE 240	START/STOP TDO BURNER E240 ZONE 16
W4405	1	DOSTE 241	START/STOP TDO BURNER E241
W4405	2	DOSTE 242	START/STOP TDO BURNER E242
W4405	3	DOSTE 243	START/STOP TDO BURNER E243
W4405	4	DOSTE 244	START/STOP TDO BURNER E244
W4405	5		START/STOP GAS SUPPLY E245
W4405	6		
W4405	7		
W4405	8		
W4405	9		
W4405	A		
W4405	B		
W4405	C		
W4405	D		
W4405	E		
W4405	F		
W4406	0		
W4406	1		

W4406	2		
W4406	3		
W4406	4		
W4406	5		
W4406	6		
W4406	7		
W4406	8		
W4406	9	DOSTE 185	BLOWER ZONE 1 HIGH SPEED E185
W4406	A		
W4406	B	DOSTE 187	BLOWER ZONE 2 HIGH SPEED E187
W4406	C	DOSTE 188	BLOWER ZONE 3 HIGH SPEED E188
W4406	D	DOSTE 189	BLOWER ZONE 4 HIGH SPEED E189
W4406	E	DOSTE 190	BLOWER ZONE 5 HIGH SPEED E190
W4406	F	DOSTE 191	BLOWER ZONE 6 HIGH SPEED E191
W4407	0	DOSTE 192	BLOWER ZONE 7 HIGH SPEED E192
W4407	1	DOSTE 193	BLOWER ZONE 8 HIGH SPEED E193
W4407	2	DOSTE 194	BLOWER ZONE 9 HIGH SPEED E194
W4407	3	DOSTE 195	BLOWER ZONE 10L HIGH SPEED E195
W4407	4	DOSTE 196	BLOWER ZONE 10R HIGH SPEED E196
W4407	5	DOSTE 197	BLOWER ZONE 11L HIGH SPEED E197
W4407	6	DOSTE 198	BLOWER ZONE 11R HIGH SPEED E198
W4407	7	DOSTE 199	BLOWER ZONE 12L HIGH SPEED E199
W4407	8	DOSTE 200	BLOWER ZONE 12R HIGH SPEED E200
W4407	9	DOSTE 201	BLOWER ZONE 13L HIGH SPEED E201
W4407	A	DOSTE 202	BLOWER ZONE 13R HIGH SPEED E202
W4407	B	DOSTE 203	BLOWER ZONE 14L HIGH SPEED E203
W4407	C	DOSTE 204	BLOWER ZONE 14R HIGH SPEED E204
W4407	D	DOSTE 205	BLOWER ZONE 15L HIGH SPEED E205
W4407	E	DOSTE 206	BLOWER ZONE 15R HIGH SPEED E206
W4407	F	DOSTE 207	BLOWER ZONE 16L HIGH SPEED E207
W4408	0	DOSTE 208	BLOWER ZONE 16R HIGH SPEED E208
W4408	1	DOSTE 209	BLOWER ZONE 17L HIGH SPEED E209
W4408	2	DOSTE 210	BLOWER ZONE 17R HIGH SPEED E210
W4408	3	DOSTE 211	BLOWER ZONE 18L HIGH SPEED E211
W4408	4	DOSTE 212	BLOWER ZONE 18R HIGH SPEED E212
W4408	5	DOSTE 213	BLOWER ZONE 19L HIGH SPEED E213
W4408	6	DOSTE 214	BLOWER ZONE 19R HIGH SPEED E214
W4408	7	DOSTE 215	BLOWER ZONE 20L HIGH SPEED E215
W4408	8	DOSTE 216	BLOWER ZONE 20R HIGH SPEED E216
W4408	9	DOSTE 217	BLOWER ZONE 21L HIGH SPEED E217
W4408	A	DOSTE 218	BLOWER ZONE 21R HIGH SPEED E218
W4408	B	DOSTE 219	BLOWER ZONE 22L HIGH SPEED E219
W4408	C	DOSTE 220	BLOWER ZONE 22R HIGH SPEED E220
W4408	D		
W4408	E		
W4408	F		
W4409	0		
W4409	1		
W4409	2		

W4409	3		
W4409	4		
W4409	5		
W4409	6		
W4409	7		
W4409	8		
W4409	9		
W4409	A		
W4409	B		
W4409	C		
W4409	D		
W4409	E		
W4409	F		
W4410	0	DOAM+0	AUTO/MANU R365
W4410	1	DOAM+1	AUTO/MANU R366
W4410	2	DOAM+2	
W4410	3	DOAM+3	
W4410	4	DOAM+4	
W4410	5	DOAM+5	AUTO/MANU R370
W4410	6	DOAM+6	AUTO/MANU R371
W4410	7	DOAM+7	AUTO/MANU R372
W4410	8	DOAM+8	AUTO/MANU R373
W4410	9	DOAM+9	AUTO/MANU R374
W4410	A	DOAM+10	AUTO/MANU R375
W4410	B	DOAM+11	AUTO/MANU R376
W4410	C	DOAM+12	AUTO/MANU R377
W4410	D	DOAM+13	AUTO/MANU R378
W4410	E	DOAM+14	AUTO/MANU R379
W4410	F	DOAM+15	AUTO/MANU R380
W4411	0	DOAM+16	AUTO/MANU R381
W4411	1	DOAM+17	
W4411	2	DOAM+18	
W4411	3	DOAM+19	
W4411	4	DOAM+20	AUTO/MANU R385
W4411	5	DOAM+21	AUTO/MANU R386
W4411	6	DOAM+22	AUTO/MANU R387
W4411	7	DOAM+23	AUTO/MANU R388
W4411	8	DOAM+24	AUTO/MANU R389
W4411	9	DOAM+25	AUTO/MANU R390
W4411	A	DOAM+26	AUTO/MANU R391
W4411	B	DOAM+27	AUTO/MANU R392
W4411	C	DOAM+28	AUTO/MANU R393
W4411	D	DOAM+29	AUTO/MANU R394
W4411	E	DOAM+30	AUTO/MANU R395
W4411	F	DOAM+31	AUTO/MANU R396
W4412	0	DOAM+32	AUTO/MANU R397
W4412	1	DOAM+33	AUTO/MANU R398
W4412	2	DOAM+34	AUTO/MANU R399
W4412	3	DOAM+35	AUTO/MANU R400

W4412	4	DOAM+36	AUTO/MANU R401
W4412	5	DOAM+37	AUTO/MANU R402
W4412	6	DOAM+38	AUTO/MANU R403
W4412	7	DOAM+39	AUTO/MANU R404
W4412	8		
W4412	9		
W4412	A		
W4412	B		
W4412	C		
W4412	D		
W4412	E		
W4412	F		
W4413	0		
W4413	1		
W4413	2		
W4413	3		
W4413	4		
W4413	5		
W4413	6		
W4413	7		
W4413	8		
W4413	9		
W4413	A		
W4413	B		
W4413	C		
W4413	D		
W4413	E		
W4413	F		
W4414	0		
W4414	1		
W4414	2		
W4414	3		
W4414	4		
W4414	5		
W4414	6		
W4414	7		
W4414	8		
W4414	9		
W4414	A		
W4414	B		
W4414	C		
W4414	D		
W4414	E		
W4414	F		
W4415	0	DOLUBCLIP	START/STOP CHAIN LUBRICATION
W4415	1	DOLUBTRAK	START/STOP TRACK LUBRICATION
W4415	2	DOGAUGE	START/STOP GAUGE CONTROL OF CHILL ROLL SPEED
W4415	3		
W4415	4		

W4415	5	BINCTDO	TDO TEMPERATURE SETPOINT IN AUTOMATIC
W4415	6		
W4415	7		
W4415	8		
W4415	9		
W4415	A		
W4415	B		
W4415	C		
W4415	D		
W4415	E		
W4415	F		
W4416	0	CRS	START CHILL ROLL EQUIPMENT
W4416	1	MDOS	START MDO EQUIPMENT
W4416	2	TDOSBLO	START TDO BLOWERS
W4416	3	TDOSBUR	START TDO BURNERS
W4416	4		
W4416	5	CRSO	STOP CHILL ROLL EQUIPMENT
W4416	6	MDOSO	STOP MDO EQUIPMENT
W4416	7	TDOSOBLO	STOP TDO BLOWERS
W4416	8	TDOSBUR	STOP TDO BURNERS
W4416	9		
W4416	A		
W4416	B		
W4416	C		
W4416	D		
W4416	E		
W4416	F		
W4417	0		
W4417	1		
W4417	2		
W4417	3		
W4417	4		
W4417	5		
W4417	6		
W4417	7		
W4417	8		
W4417	9		
W4417	A		
W4417	B		
W4417	C		
W4417	D		
W4417	E		
W4417	F		
W4418	0		
W4418	1		
W4418	2		
W4418	3		
W4418	4		
W4418	5		

W4418	6		
W4418	7		
W4418	8		
W4418	9		
W4418	A		
W4418	B		
W4418	C		
W4418	D		
W4418	E		
W4418	F		
W4419	0		
W4419	1		
W4419	2		
W4419	3		
W4419	4		
W4419	5		
W4419	6		
W4419	7		
W4419	8		
W4419	9		
W4419	A		
W4419	B		
W4419	C		
W4419	D		
W4419	E		
W4419	F		
W4420	0	DORED	RELEASE DEFECT
W4420	1	DOREL	RELEASE KLAXON
W4420	2		
W4420	3		
W4420	4		
W4420	5		
W4420	6		
W4420	7		
W4420	8		
W4420	9		
W4420	A		
W4420	B		
W4420	C		
W4420	D		
W4420	E		
W4420	F		
W4421	0		
W4421	1		
W4421	2		
W4421	3		
W4421	4		
W4421	5		
W4421	6		

W4421	7		
W4421	8		
W4421	9		
W4421	A		
W4421	B		
W4421	C		
W4421	D		
W4421	E		
W4421	F		
W4422	0		
W4422	1		
W4422	2		
W4422	3		
W4422	4		
W4422	5		
W4422	6		
W4422	7		
W4422	8		
W4422	9		
W4422	A		
W4422	B		
W4422	C		
W4422	D		
W4422	E		
W4422	F		

BIT NO.	TAG NAME	DESCRIPTION
W4750 0	RE+0	CHILL ROLL GAZ HEATER C 1340 E160
W4750 1	RE+1	CHILL ROLL GAZ HEATER C 1340 E161
W4750 2	RE+2	CONTACTOR ANSWER OF CHILL ROLL BRAKE E162
W4750 3	RE+3	
W4750 4	RE+4	
W4750 5	RE+5	
W4750 6	RE+6	
W4750 7	RE+7	
W4750 8	RE+8	
W4750 9	RE+9	MDO GAZ HEATER C 1430.13 E169
W4750 A	RE+10	MDO PUMP ZONE 1 M 1430.01 E170
W4750 B	RE+11	MDO PUMP ZONE 2 M 1430.02 E171
W4750 C	RE+12	MDO PUMP ZONE 3 M 1430.03 E172
W4750 D	RE+13	MDO PUMP ZONE 4 M 1430.04 E173
W4750 E	RE+14	MDO PUMP ZONE 5 M 1430.05 E174
W4750 F	RE+15	MDO PUMP ZONE 6 M 1430.06 E175
W4751 0	RE+16	MDO PUMP ZONE 7 M 1430.07 E176
W4751 1	RE+17	MDO PUMP ZONE 8 M 1430.08 E177
W4751 2	RE+18	MDO PUMP STRETCHING ZONE 1 M 1430.09 E178
W4751 3	RE+19	MDO PUMP STRETCHING ZONE 2 M 1430.10 E179
W4751 4	RE+20	MDO PUMP STRETCHING ZONE 3 M 1430.11 E180
W4751 5	RE+21	MDO PUMP LAST ZONE 1430.12 E181
W4751 6	RE+22	
W4751 7	RE+23	
W4751 8	RE+24	
W4751 9	RE+25	TDO BLOWER M 1520.01 ZONE 1 E185 BLOWER STATUS
W4751 A	RE+26	TDO INLET BLOWER M 1528.01 E186
W4751 B	RE+27	TDO BLOWER M 1520.02 ZONE 2 E187
W4751 C	RE+28	TDO BLOWER M 1520.03 ZONE 3 E188
W4751 D	RE+29	TDO BLOWER M 1520.04 ZONE 4 E189
W4751 E	RE+30	TDO BLOWER M 1520.05 ZONE 5 E190
W4751 F	RE+31	TDO BLOWER M 1520.06 ZONE 6 E191
W4752 0	RE+32	TDO BLOWER M 1520.07 ZONE 7 E192
W4752 1	RE+33	TDO BLOWER M 1520.08 ZONE 8 E193
W4752 2	RE+34	TDO BLOWER M 1520.09 ZONE 9 E194
W4752 3	RE+35	TDO BLOWER M 1520.10 ZONE 10 E195
W4752 4	RE+36	TDO BLOWER M 1520.11 ZONE 10 E196
W4752 5	RE+37	TDO BLOWER M 1520.12 ZONE 11 E197
W4752 6	RE+38	TDO BLOWER M 1520.13 ZONE 11 E198
W4752 7	RE+39	TDO BLOWER M 1520.14 ZONE 12 E199
W4752 8	RE+40	TDO BLOWER M 1520.15 ZONE 12 E200
W4752 9	RE+41	TDO BLOWER M 1520.16 ZONE 13 E201
W4752 A	RE+42	TDO BLOWER M 1520.17 ZONE 13 E202
W4752 B	RE+43	TDO BLOWER M 1520.18 ZONE 14 E203
W4752 C	RE+44	TDO BLOWER M 1520.19 ZONE 14 E204
W4752 D	RE+45	TDO BLOWER M 1520.20 ZONE 15 E205
W4752 E	RE+46	TDO BLOWER M 1520.21 ZONE 15 E206
W4752 F	RE+47	TDO BLOWER M 1520.22 ZONE 16 E207

W4753	0	RE+48	TDO BLOWER M 1520.23 ZONE 16 E208
W4753	1	RE+49	TDO BLOWER M 1520.24 ZONE 17 E209
W4753	2	RE+50	TDO BLOWER M 1520.25 ZONE 17 E210
W4753	3	RE+51	TDO BLOWER M 1520.26 ZONE 18 E211
W4753	4	RE+52	TDO BLOWER M 1520.27 ZONE 18 E212
W4753	5	RE+53	TDO BLOWER M 1520.28 ZONE 19 E213
W4753	6	RE+54	TDO BLOWER M 1520.29 ZONE 19 E214
W4753	7	RE+55	TDO BLOWER M 1520.30 ZONE 20 E215
W4753	8	RE+56	TDO BLOWER M 1520.31 ZONE 20 E216
W4753	9	RE+57	TDO BLOWER M 1520.32 ZONE 21 E217
W4753	A	RE+58	TDO BLOWER M 1520.33 ZONE 21 E218
W4753	B	RE+59	TDO BLOWER M 1520.34 ZONE 22 E219
W4753	C	RE+60	TDO BLOWER M 1520.35 ZONE 22 E220
W4753	D	RE+61	TDO INLET BLOWER M 1528.02 ZONE E221
W4753	E	RE+62	TDO OUTLET BLOWER M 1528.03 E222
W4753	F	RE+63	TDO OUTLET BLOWER M 1525.01 E223
W4754	0	RE+64	TDO OUTLET BLOWER M 1530.01 E224
W4754	1	RE+65	TDO BURNER ZONE 1 M 1540.01 E225
W4754	2	RE+66	TDO BURNER ZONE 2 M 1540.02 E226
W4754	3	RE+67	TDO BURNER ZONE 3 M 1540.03 E227
W4754	4	RE+68	TDO BURNER ZONE 4 M 1540.04 E228
W4754	5	RE+69	TDO BURNER ZONE 5 M 1540.05 E229
W4754	6	RE+70	TDO BURNER ZONE 6 M 1540.06 E230
W4754	7	RE+71	TDO BURNER ZONE 7 M 1540.07 E231
W4754	8	RE+72	TDO BURNER ZONE 8 M 1540.08 E232
W4754	9	RE+73	TDO BURNER ZONE 9 M 1540.09 E233
W4754	A	RE+74	TDO BURNER ZONE 10 M 1540.10 E234
W4754	B	RE+75	TDO BURNER ZONE 11 M 1540.11 E235
W4754	C	RE+76	TDO BURNER ZONE 12 M 1540.12 E236
W4754	D	RE+77	TDO BURNER ZONE 13 M 1540.13 E237
W4754	E	RE+78	TDO BURNER ZONE 14 M 1540.14 E238
W4754	F	RE+79	TDO BURNER ZONE 15 M 1540.15 E239
W4755	0	RE+80	TDO BURNER ZONE 16 M 1540.16 E240
W4755	1	RE+81	TDO BURNER ZONE 17 M 1540.17 E241
W4755	2	RE+82	TDO BURNER ZONE 18 M 1540.18 E242
W4755	3	RE+83	TDO BURNER ZONE 19 M 1540.19 E243
W4755	4	RE+84	TDO BURNER ZONE 20 M 1540.20 E244
W4755	5	RE+85	
W4755	6	RE+86	
W4755	7	RE+87	
W4755	8	RE+88	
W4755	9	RE+89	
W4755	A	RE+90	
W4755	B	RE+91	
W4755	C	RE+92	
W4755	D	RE+93	
W4755	E	RE+94	
W4755	F	RE+95	
W4756	0	RE+96	CHILL ROLL EXHAUST HOOD M1263-01

W4756	1	RE+97	CHILL ROLL WATER REMOVAL M1330-01
W4756	2	RE+98	CHILL ROLL WATER REMOVAL M1310-01
W4756	3	RE+99	CHILL ROLL WATER REMOVAL M1310-02
W4756	4	RE+100	CHILL ROLL WATER REMOVAL M1310-03
W4756	5	RE+101	CHILL ROLL HORIZONTAL MOVEMENT M1301-01
W4756	6	RE+102	CHILL ROLL BRAKE Y1301-02
W4756	7	RE+103	CHILL ROLL AUXILIARY WINDER 1 M1360-01
W4756	8	RE+104	
W4756	9	RE+105	
W4756	A	RE+106	CHILL ROLL AUXILIARY WINDER M1450-01
W4756	B	RE+107	
W4756	C	RE+108	
W4756	D	RE+109	
W4756	E	RE+110	CONTACTOR ANSWER OF TDO CHAIN TENSION
W4756	F	RE+111	
W4757	0	RE+112	PRS FAN ROLL 2 M1812.01
W4757	1	RE+113	PRS FAN ROLL 11 M1812.01
W4757	2	RE+114	PRS FAN ROLL OZONE EXTRA M1831-01 COR. 1
W4757	3	RE+115	PRS FAN ROLL OZONE EXTRA M1831-02 COR. 2
W4757	4	RE+116	AUXILIARY WINDER 2 M1450.01
W4757	5	RE+117	PRS FAN ROLL OZONE EXTRA M1831-03 COR. 3
W4757	6	RE+118	
W4757	7	RE+119	RECLAIM MATERIAL GRINDER M2607-01
W4757	8	RE+120	RECLAIM MATERIAL GRINDER TRANSPORTER M2508-01
W4757	9		
W4757	A		
W4757	B		
W4757	C		
W4757	D		
W4757	E		
W4757	F		
W4758	0		
W4758	1		
W4758	2		
W4758	3		
W4758	4		
W4758	5		
W4758	6		
W4758	7		
W4758	8		
W4758	9		
W4758	A		
W4758	B		
W4758	C		
W4758	D		
W4758	E		
W4758	F		
W4760	0	DIFAE 160	FAULT CHILL ROLL GAZ HEATER C 1340 E160
W4760	1	DIFAE 161	FAULT CHILL ROLL GAZ HEATER C 1350 E161

W4760	2	DIFAE 162	FAULT CHILL ROLL BRAKE Y 1301.02	E162
W4760	3			
W4760	4			
W4760	5			
W4760	6			
W4760	7			
W4760	8			
W4760	9	DIFAE 169	FAULT MDO PUMP GAZ HEATER C 1430.13	E169
W4760	A	DIFAE 170	FAULT MDO PUMP ZONE 1 M 1430.01	E170
W4760	B	DIFAE 171	FAULT MDO PUMP ZONE 2 M 1430.02	E171
W4760	C	DIFAE 172	FAULT MDO PUMP ZONE 3 M 1430.03	E172
W4760	D	DIFAE 173	FAULT MDO PUMP ZONE 4 M 1430.04	E173
W4760	E	DIFAE 174	FAULT MDO PUMP ZONE 5 M 1430.05	E174
W4760	F	DIFAE 175	FAULT MDO PUMP ZONE 6 M 1430.06	E175
W4761	0	DIFAE 176	FAULT MDO PUMP ZONE 7 M 1430.07	E176
W4761	1	DIFAE 177	FAULT MDO PUMP ZONE 8 M 1430.08	E177
W4761	2	DIFAE 178	FAULT MDO PUMP STRET. 1 M1430.09	E178
W4761	3	DIFAE 179	FAULT MDO PUMP STRET. 2 M1430.10	E179
W4761	4	DIFAE 180	FAULT MDO PUMP STRET. 3 M1430.11	E180
W4761	5	DIFAE 181	FAULT MDO PUMP ZONE 12 M1430.06	E181
W4761	6	DIFAE 182		
W4761	7	DIFAE 183		
W4761	8	DIFAE 184		
W4761	9	DIFAE 185	FAULT TDO BLOWER ZONE 1 M1520.01	E185
W4761	A	DIFAE 186	FAULT INLET BLOWER M1520.01	E186
W4761	B	DIFAE 187	FAULT TDO BLOWER ZONE 2 M1520.02	E187
W4761	C	DIFAE 188	FAULT TDO BLOWER ZONE 3 M1520.03	E188
W4761	D	DIFAE 189	FAULT TDO BLOWER ZONE 4 M1520.04	E189
W4761	E	DIFAE 190	FAULT TDO BLOWER ZONE 5 M1520.05	E190
W4761	F	DIFAE 191	FAULT TDO BLOWER ZONE 6 M1520.06	E191
W4762	0	DIFAE 192	FAULT TDO BLOWER ZONE 7 M1520.07	E192
W4762	1	DIFAE 193	FAULT TDO BLOWER ZONE 8 M1520.08	E193
W4762	2	DIFAE 194	FAULT TDO BLOWER ZONE 9 M1520.09	E194
W4762	3	DIFAE 195	FAULT TDO BLOWER ZONE 10 M1520.10	E195
W4762	4	DIFAE 196	FAULT TDO BLOWER ZONE 10 M1520.11	E196
W4762	5	DIFAE 197	FAULT TDO BLOWER ZONE 11 M1520.12	E197
W4762	6	DIFAE 198	FAULT TDO BLOWER ZONE 11 M1520.13	E198
W4762	7	DIFAE 199	FAULT TDO BLOWER ZONE 12 M1520.14	E199
W4762	8	DIFAE 200	FAULT TDO BLOWER ZONE 12 M1520.15	E200
W4762	9	DIFAE 201	FAULT TDO BLOWER ZONE 13 M1520.16	E201
W4762	A	DIFAE 202	FAULT TDO BLOWER ZONE 13 M1520.17	E202
W4762	B	DIFAE 203	FAULT TDO BLOWER ZONE 14 M1520.18	E203
W4762	C	DIFAE 204	FAULT TDO BLOWER ZONE 14 M1520.19	E204
W4762	D	DIFAE 205	FAULT TDO BLOWER ZONE 15 M1520.20	E205
W4762	E	DIFAE 206	FAULT TDO BLOWER ZONE 15 M1520.21	E206
W4762	F	DIFAE 207	FAULT TDO BLOWER ZONE 16 M1520.22	E207
W4763	0	DIFAE 208	FAULT TDO BLOWER ZONE 16 M1520.23	E208
W4763	1	DIFAE 209	FAULT TDO BLOWER ZONE 17 M1520.24	E209
W4763	2	DIFAE 210	FAULT TDO BLOWER ZONE 17 M1520.25	E210

W4763	3	DIFAE 211	FAULT TDO BLOWER ZONE 18 M1520.26 E211
W4763	4	DIFAE 212	FAULT TDO BLOWER ZONE 18 M1520.27 E212
W4763	5	DIFAE 213	FAULT TDO BLOWER ZONE 19 M1520.28 E213
W4763	6	DIFAE 214	FAULT TDO BLOWER ZONE 19 M1520.29 E214
W4763	7	DIFAE 215	FAULT TDO BLOWER ZONE 20 M1520.30 E215
W4763	8	DIFAE 216	FAULT TDO BLOWER ZONE 20 M1520.31 E216
W4763	9	DIFAE 217	FAULT TDO BLOWER ZONE 21 M1520.32 E217
W4763	A	DIFAE 218	FAULT TDO BLOWER ZONE 21 M1520.33 E218
W4763	B	DIFAE 219	FAULT TDO BLOWER ZONE 22 M1520.34 E219
W4763	C	DIFAE 220	FAULT TDO BLOWER ZONE 22 M1520.35 E220
W4763	D	DIFAE 221	FAULT TDO INLET BLOWER M1528.02 E224
W4763	E	DIFAE 222	FAULT TDO OUTLET BLOWER M1520.03 E222
W4763	F	DIFAE 223	FAULT TDO OUTLET BLOWER M1520.22 E223
W4764	0	DIFAE 224	FAULT TDO OUTLET BLOWER M1530.01 E224
W4764	1	DIFAE 225	FAULT TDO ZONE 1 BURNER M1540.01 E225
W4764	2	DIFAE 226	FAULT TDO ZONE 2 BURNER M1540.02 E226
W4764	3	DIFAE 227	FAULT TDO ZONE 3 BURNER M1540.03 E227
W4764	4	DIFAE 228	FAULT TDO ZONE 4 BURNER M1540.04 E228
W4764	5	DIFAE 229	FAULT TDO ZONE 5 BURNER M1540.05 E229
W4764	6	DIFAE 230	FAULT TDO ZONE 6 BURNER M1540.06 E230
W4764	7	DIFAE 231	FAULT TDO ZONE 7 BURNER M1540.07 E231
W4764	8	DIFAE 232	FAULT TDO ZONE 8 BURNER M1540.08 E232
W4764	9	DIFAE 233	FAULT TDO ZONE 9 BURNER M1540.09 E233
W4764	A	DIFAE 234	FAULT TDO ZONE 10 BURNER M1540.10 E234
W4764	B	DIFAE 235	FAULT TDO ZONE 11 BURNER M1540.10 E235
W4764	C	DIFAE 236	FAULT TDO ZONE 12 BURNER M1540.12 E236
W4764	D	DIFAE 237	FAULT TDO ZONE 13 BURNER M1540.13 E237
W4764	E	DIFAE 238	FAULT TDO ZONE 14 BURNER M1540.14 E238
W4764	F	DIFAE 239	FAULT TDO ZONE 15 BURNER M1540.15 E239
W4765	0	DIFAE 240	FAULT TDO ZONE 16 BURNER M1540.16 E240
W4765	1	DIFAE 241	FAULT TDO ZONE 17 BURNER M1540.17 E241
W4765	2	DIFAE 242	FAULT TDO ZONE 18 BURNER M1540.18 E242
W4765	3	DIFAE 243	FAULT TDO ZONE 19 BURNER M1540.19 E243
W4765	4	DIFAE 244	FAULT TDO ZONE 20 BURNER M1540.20 E244
W4765	5		
W4765	6		
W4765	7		
W4765	8		
W4765	9		
W4765	A		
W4765	B		
W4765	C		
W4765	D		
W4765	E		
W4765	F		
W4766	0	DIFM 126301	DEFECT OF CHILL ROLL EXHAUST HOOD M1263.01
W4766	1	DIFM 133001	DEFECT OF CHILL ROLL WATER REMOVAL M1330.01
W4766	2	DIFM 131001	DEFECT OF CHILL ROLL WATER REMOVAL M1330.02
W4766	3	DIFM 131002	DEFECT OF CHILL ROLL WATER REMOVAL M1330.03

W4766	4	DIFM 131003	DEFECT OF CHILL ROLL WATER REMOVAL M1310.03
W4766	5	DIFM 130101	DEFECT OF HORIZONTAL MOVEMENT M1301.01
W4766	6	DIFM 130102	DEFECT OF CHILL ROLL BRAKE Y1301.02
W4766	7	DIFM 136001	DEFECT OF AUXILIARY WINDER #1 M1360.01
W4766	8		
W4766	9		
W4766	A	DIFM 145001	DEFECT OF AUXILIARY WINDER #2 M1450.01
W4766	B		
W4766	C		
W4766	D		
W4766	E	DIFM 151501	DEFECT OF TDO CHAIN TENSION SYSTEM M1515.01
W4766	F		
W4767	0	DIFM 181201	DEFECT OF VACUUM ROLL #1 M1812.01
W4767	1	DIFM 181501	DEFECT OF VACUUM ROLL #2 M1825.01
W4767	2	DIFM 183101	DEFECT OF OZONE EXHAUST BLOWER #1 M1831.01
W4767	3	DIFM 183102	DEFECT OF OZONE EXHAUST BLOWER #2 M1831.02
W4767	4	DIFM 1860A1	DEFECT OF AUXILIARY WINDER #3
W4767	5	DIFM 183103	DEFECT OF OZONE EXHAUST BLOWER #3 M1831.03
W4767	6		
W4767	7		
W4767	8		
W4767	9		
W4767	A		
W4767	B		
W4767	C		
W4767	D		
W4767	E		
W4767	F		
W4768	0		
W4768	1		
W4768	2		
W4768	3		
W4768	4		
W4768	5		
W4768	6		
W4768	7		
W4768	8		
W4768	9		
W4768	A		
W4768	B		
W4768	C		
W4768	D		
W4768	E		
W4768	F		
W4770	0	ZS 130103	CHILL ROLL HAND CRANK ENGAGE ZS 1301-03
W4770	1	SV 131011	ROLL CARRIAGE FILM REMOVAL POSITION (ENG)
W4770	2	SV 131013	RUBBER ROLL WATER REMOVAL POSITION (ENG)
W4770	3	SV 131012	CHROMED ROLL WATER REMOVAL POSITION (ENG)
W4770	4	SV 131009	CHILL ROLL AIR KNIFE ENGAGE SV 1310.09

W4770	5	SV 131010	CHILL ROLL EDGE PINNING ON SV 1310.09
W4770	6	ZS 130104	CHILL ROLL ON HOME POSITION ZS 1301.04
W4770	7	ZS 130105	CHILL ROLL HIGH LOW SPEED ZS 1301.05
W4770	8	ZS 130106	CHILL ROLL IN WORKING POSITION ZS 1301.06
W4770	9	TSH 136003	HIGH TEMP. ALARM AUX. WINDER 1 TSH 1360.03
W4770	A	LSL 135003	CHILL ROLL MDO LOW LEVEL TANK LSL 1350.03
W4770	B	AUX1LENG	CHILL ROLL AUX. WINDER 1 ENGAGE
W4770	C	WBON	CHILL ROLL WATER BATH ON
W4770	D	WBAUTO	CHILL ROLL WATER BATH AUTO
W4770	E	AUX1RET	CHILL ROLL AUX. WINDER 1 RETRACT
W4770	F	PESCR	PROCESS STOP CHILL
W4771	0	ROLL1ENG	MDO NIP ROLL 1 IN WORK POS. ZSH 1404.06.07
W4771	1	ROLL2ENG	MDO NIP ROLL 2 IN WORK POS. ZSH 1404.08.09
W4771	2	ROLL3ENG	MDO NIP ROLL 3 IN WORK POS. ZSH 1404.10.11
W4771	3	INLET	MDO PRES. ROLL INLET IN POS. ZSE 1404.12.13
W4771	4	OUTLET	MDO PRES. ROLL OUTLET IN POS. ZSE 1404.14.15
W4771	5	DR1HOME	DRAW ROLL 1 IN HOME POSITION ZSH 1402.07
W4771	6	DR1WORK	DRAW ROLL 1 IN WORKING POSITION
W4771	7	DR2HOME	DRAW ROLL 2 IN HOME POSITION ZSH 1402.15
W4771	8	DR2WORK	DRAW ROLL 2 IN WORKING POSITION
W4771	9	DR3HOME	DRAW ROLL 3 IN HOME POSITION ZSH 1402.15
W4771	A	DR3WORK	DRAW ROLL 3 IN WORKING POSITION
W4771	B		
W4771	C		
W4771	D	ZTMDO	BREAK FILM MDO ZT 1420.01 ST 1420.02
W4771	E	BYPASSMDO	BYPASS MDO
W4771	F	PESMDO	PROCESS STOP MDO
W4772	0	TSH 145003	AUXILIARY WINDER 2 TSH 1450.03
W4772	1	AUX2ENG	AUX WINDER 2 ENGAGE SV 1450.05
W4772	2	AUX2RET	AUX WINDER 2 RETRACT SV 1450.04
W4772	3		
W4772	4		
W4772	5	DICLIPOFF	TDO AIR ON CLIPS SZ 1511.03 OFF
W4772	6	DICLIPON	AIR ON CLIPS SV 1511.03 ON
W4772	7	DICLIPAUTO	O AIR ON CLIPS SV 1511.03 AUTO
W4772	8	ZT 153102	WEB BREAK BEFORE COOLING ZONE ZT 1531.02
W4772	9	ZT 153101	WEB BREAK AFTER STRET. ZONE ZT 1531.01
W4772	A	BYPASSAUTO	BYPASS TDO
W4772	B	ZS 151506	SECURITY SWITCH ZS 1515.06 (RIGHT)
W4772	C	ZS 151507	SECURITY SWITCH ZS 1515.07 (LEFT)
W4772	D	PSL 151503	LOW PRES. CHAIN TENSION (B305) PSL 1515.03
W4772	E	LSL 151502	LOW LEVEL CHAIN TENSION (B302) LSL 1515.02
W4772	F	PESTD0	PROCESS STOP TDO
W4773	0	FSL 183106	CORONA #1 OZONE EXHAUST FLOW LOW FSL 1831.06
W4773	1	FSL 183107	CORONA #2 OZONE EXHAUST FLOW LOW FSL 1831.07
W4773	2	SPL 182009	CORONA ELECTRODE #1 LOW PRESSURE PSL 1820.09
W4773	3	PSL 182019	CORONA ELECTRODE #2 LOW PRESSURE PSL 1820.19
W4773	4	PSL 182014	CORONA ELECTRODE #3 LOW PRESSURE PSL 1820.14
W4773	5	CO1ENG	CORONA ELECTRODE #1 ENGAGED

W4773	6	CO2ENG	CORONA ELECTRODE #2 ENGAGED
W4773	7	CO3ENG	CORONA ELECTRODE #3 ENGAGED
W4773	8		
W4773	9		
W4773	A	SPR1ENG	SPREADER ROLL #1 ENGAGED, SV 1840.01
W4773	B	SPR2ENG	SPREADER ROLL #2 ENGAGED, SV 1840.03
W4773	C	SPR3ENG	SPREADER ROLL #3 ENGAGED, SV 1840.05
W4773	D	BYPASSPRS	PRS BYPASS
W4773	E	ZTPRS	PRS WEB BREAKER ZT 1840.10
W4773	F	PESPRS	PRS PROCESS STOP
W4774	0	OPKNIENG	PRS RIGHT KNIFE (ENGAGE) SV 1850.03
W4774	1	DRIKNIENG	PRS LEFT KNIFE (ENGAGE) SV 1850.04
W4774	2	OPROLLENG	LEFT NIP ROLL (ENGAGE) SV 1850.01
W4774	3	DRIROLLENG	RIGHT NIP ROLL (ENGAGE) SV 1850.02
W4774	4	AUX3ENG	PRS AUX. WINDER 3 (ENGAGE) SV 1860.01.02
W4774	5	GE1R	PRS GENERATOR 1 (G1820.01) RUNNING
W4774	6	GE1F	PRS GENERATOR 1 (G1820.01) FAULT
W4774	7	GE2R	PRS GENERATOR 2 (G1820.02) RUNNING
W4774	8	GE2F	PRS GENERATOR 2 (G1820.02) FAULT
W4774	9	GE3R	PRS GENERATOR 3 (G1820.03) RUNNING
W4774	A	GE3F	PRS GENERATOR 3 (G1820.03) FAULT
W4774	B	GE4R	PRS GENERATOR 4 (G1820.04) RUNNING
W4774	C	GE4F	PRS GENERATOR 4 (G1820.04) FAULT
W4774	D	FSL 183108	CORONA #3 OZONE EXHAUST FLOW LOW FSL 1831.03
W4774	E	TSHAUX3	PRS AUX WINDER 3 HIGH TEMP. ALARM
W4774	F		
W4775	0	ROLL6CPENG	ROLL 6 (NIP #1) CORONA PROXIMITY (ENG) SV 1820.20
W4775	1	ROLL8CPENG	ROLL 8 (NIP #3) CORONA PROXIMITY (ENG) SV 1820.15
W4775	2		
W4775	3	ROTCR	CHILL ROLL ROTATION
W4775	4	ROTMDO	ROTATION MDO SLOW
W4775	5	ROTMDO	ROTATION MDO FAST1
W4775	6	ROTMDOF	ROTATION MDO FAST2
W4775	7	ROTTDO	ROTATION TDO
W4775	8		
W4775	9	BINCTDO	TDO IN TEMPERATURE AUTOMATIC CONTROL
W4775	A	SPR2ENG	SPREADER ROLL1 ENGAGED, SV 1840.02
W4775	B	SPR4ENG	SPREADER ROLL2 ENGAGED, SV 1840.04
W4775	C	SPR6ENG	SPREADER ROLL3 ENGAGED, SV 1840.06
W4775	D		
W4775	E		
W4775	F		
W4776	0	FACR	FAULT VIEW CHILL ROLL
W4776	1	FAMDO1	FAULT VIEW MDO 1
W4776	2	FAMDO2	FAULT VIEW MDO 2
W4776	3	FATDO1	FAULT VIEW TDO 1
W4776	4	FATDO2	FAULT VIEW TDO 2
W4776	5	FATDO3	FAULT VIEW TDO 3
W4776	6	FATDO4	FAULT VIEW TDO 4

W4776	7	FAPRS	FAULT VIEW PRS
W4776	8		
W4776	9	GES	GENERAL EMERGENCY STOP OF THE LINE
W4776	A	CRLEG	ONE EQUIPMENT RUNNING ON CHILL ROLL
W4776	B	MDOLEQ	ONE EQUIPMENT RUNNING ON MDO
W4776	C	TDOLEQ	ONE EQUIPMENT RUNNING ON TDO
W4776	D	CRALEQ	ALL EQUIPMENT RUNNING ON CHILL ROLL
W4776	E	MDOALLEQ	ALL EQUIPMENT RUNNING ON MDO
W4776	F	TDOALLEQ	ALL EQUIPMENT RUNNING ON TDO
W4777	0	CRT	TEMPERATURE H+, L- CHILL ROLL
W4777	1	MDOT	TEMPERATURE H+, L- MDO
W4777	2	TDOT	TEMPERATURE H+, L- TDO
W4777	3		
W4777	4	TDO1BUR	ONE BURNER "ON" ON TDO
W4777	5	TDOALLBUR	ALL BURNER "ON" ON TDO
W4777	6		
W4777	7		SELECT SWITCH "> 60 MICRO FOR SCREEN
W4777	8		
W4777	9		
W4777	A		
W4777	B		
W4777	C		
W4777	D		
W4777	E		
W4777	F		
W4778	0	CRI	INTERLOCK CHILL ROLL
W4778	1	MDO1I	INTERLOCK MDO 1
W4778	2	MDO2I	INTERLOCK MDO 2
W4778	3	MDO3I	INTERLOCK MDO 3
W4778	4	TDOI	INTERLOCK TDO
W4778	5	PRS1I	INTERLOCK PRS 1
W4778	6	PRS2I	INTERLOCK PRS 2
W4778	7		
W4778	8		
W4778	9		
W4778	A		
W4778	B		
W4778	C		
W4778	D		
W4778	E		
W4778	F		
W4779	0		
W4779	1		
W4779	2		
W4779	3		
W4779	4		
W4779	5		
W4779	6		
W4779	7		

W4779	8		
W4779	9		
W4779	A		
W4779	B		
W4779	C		
W4779	D		
W4779	E		
W4779	F		
W4780	0		
W4780	1	INTE225	INTERLOCK BURNER 1 ZONE 1 M 1450.01 (E225)
W4780	2	INTE226	INTERLOCK BURNER 2 ZONE 2 M 1450.02 (E226)
W4780	3	INTE227	INTERLOCK BURNER 3 ZONE 3 M 1450.03 (E227)
W4780	4	INTE228	INTERLOCK BURNER 4 ZONE 4 M 1450.04 (E228)
W4780	5	INTE229	INTERLOCK BURNER 5 ZONE 5 M 1450.05 (E229)
W4780	6	INTE230	INTERLOCK BURNER 6 ZONE 6 M 1450.06 (E230)
W4780	7	INTE231	INTERLOCK BURNER 7 ZONE 7 M 1450.07 (E231)
W4780	8	INTE232	INTERLOCK BURNER 8 ZONE 8 M 1450.08 (E232)
W4780	9	INTE233	INTERLOCK BURNER 9 ZONE 9 M 1450.09 (E233)
W4780	A	INTE234	INTERLOCK BURNER 10 ZONE 10 M 1450.10 (E234)
W4780	B	INTE235	INTERLOCK BURNER 11 ZONE 11 M 1450.11 (E235)
W4780	C	INTE236	INTERLOCK BURNER 12 ZONE 12 M 1450.12 (E236)
W4780	D	INTE237	INTERLOCK BURNER 13 ZONE 13 M 1450.13 (E237)
W4780	E	INTE238	INTERLOCK BURNER 14 ZONE 14 M 1450.14 (E238)
W4780	F	INTE239	INTERLOCK BURNER 15 ZONE 15 M 1450.15 (E239)
W4781	0	INTE240	INTERLOCK BURNER 16 ZONE 16 M 1450.16 (E240)
W4781	1	INTE241	INTERLOCK BURNER 17 ZONE 17 M 1450.17 (E241)
W4781	2	INTE242	INTERLOCK BURNER 18 ZONE 18 M 1450.18 (E242)
W4781	3	INTE243	INTERLOCK BURNER 19 ZONE 19 M 1450.19 (E243)
W4781	4	INTE244	INTERLOCK BURNER 20 ZONE 20 M 1450.20 (E244)
W4781	5		
W4781	6		
W4781	7		
W4781	8		
W4781	9		
W4781	A		
W4781	B		
W4781	C		
W4781	D		
W4781	E		
W4781	F		
W4785	0	DIAM+0	AUTO/MANU R365
W4785	1	DILO+0	LOCKED
W4785	2	DIAC+0	ALARM H+, L-
W4785	3	DIAHR365	ALARM H
W4785	4	DIAL+0	ALARM L
W4785	5	DIDER365	DEFECT MEASURE
W4785	6	DIA+0	ALL ALARM
W4785	7		
W4785	8	DIAM+8	AUTO/MANU R366

W4785	9	DILO+8	LOCKED
W4785	A	DIAC+8	ALARM H+, L-
W4785	B	DIAHR366	ALARM H
W4785	C	DIAL+8	ALARM L
W4785	D	DIDER366	DEFECT MEASURE
W4785	E	DIA+8	ALL ALARM
W4785	F		
W4786	0		
W4786	1		
W4786	2		
W4786	3		
W4786	4		
W4786	5		
W4786	6		
W4786	7		
W4786	8		
W4786	9		
W4786	A		
W4786	B		
W4786	C		
W4786	D		
W4786	E		
W4786	F		
W4787	0		
W4787	1		
W4787	2		
W4787	3		
W4787	4		
W4787	5		
W4787	6		
W4787	7		
W4787	8		
W4787	9		
W4787	A		
W4787	B		
W4787	C		
W4787	D		
W4787	E		
W4787	F		
W4788	0		
W4788	1		
W4788	2		
W4788	3		
W4788	4		
W4788	5		
W4788	6		
W4788	7		
W4788	8		
W4788	9		

W4788	A		
W4788	B		
W4788	C		
W4788	D		
W4788	E		
W4788	F		
W4789	0	DIAM+64	AUTO/MANU R370
W4789	1	DILO+64	LOCKED
W4789	2	DIAC+64	ALARM H+, L-
W4789	3	DIAHR370	ALARM H
W4789	4	DIAL+64	ALARM L
W4789	5	DIDER370	DEFECT MEASURE
W4789	6	DIA+72	ALL ALARM
W4789	7		
W4789	8	DIAM+72	AUTO/MANU R371
W4789	9	DILO+72	LOCKED
W4789	A	DIAC+72	ALARM H+, L-
W4789	B	DIAHR371	ALARM H
W4789	C	DIAL+72	ALARM L
W4789	D	DIDER371	DEFECT MEASURE
W4789	E	DIA+72	ALL ALARM
W4789	F		
W4790	0	DIAM+80	AUTO/MANU R372
W4790	1	DILO+80	LOCKED
W4790	2	DIAC+80	ALARM H+, L-
W4790	3	DIAHR372	ALARM H
W4790	4	DIAL+80	ALARM L
W4790	5	DIDER372	DEFECT MEASURE
W4790	6	DIA+80	ALL ALARM
W4790	7		
W4790	8	DIAM+88	AUTO/MANU R373
W4790	9	DILO+88	LOCKED
W4790	A	DIAC+88	ALARM H+, L-
W4790	B	DIAHR373	ALARM H
W4790	C	DIAL+88	ALARM L
W4790	D	DIDER373	DEFECT MEASURE
W4790	E	DIA+88	ALL ALARM
W4790	F		
W4791	0	DIAM+96	AUTO/MANU R374
W4791	1	DILO+96	LOCKED
W4791	2	DIAC+96	ALARM H+, L-
W4791	3	DIAHR374	ALARM H
W4791	4	DIAL+96	ALARM L
W4791	5	DIDER374	DEFECT MEASURE
W4791	6	DIA+96	ALL ALARM
W4791	7		
W4791	8	DIAM+96	AUTO/MANU R375
W4791	9	DILO+96	LOCKED
W4791	A	DIAC+96	ALARM H+, L-

W4791	B	DIAHR375	ALARM H
W4791	C	DIAL+96	ALARM L
W4791	D	DIDER375	DEFECT MEASURE
W4791	E	DIA+96	ALL ALARM
W4791	F		
W4792	0	DIAM+104	AUTO/MANU R376
W4792	1	DILO+104	LOCKED
W4792	2	DIAC+104	ALARM H+, L-
W4792	3	DIAHR376	ALARM H
W4792	4	DIAL+104	ALARM L
W4792	5	DIDER376	DEFECT MEASURE
W4792	6	DIA+104	ALL ALARM
W4792	7		
W4792	8	DIAM+112	AUTO/MANU R377
W4792	9	DILO+112	LOCKED
W4792	A	DIAC+112	ALARM H+, L-
W4792	B	DIAHR377	ALARM H
W4792	C	DIAL+112	ALARM L
W4792	D	DIDER377	DEFECT MEASURE
W4792	E	DIA+112	ALL ALARM
W4792	F		
W4793	0	DIAM+128	AUTO/MANU R378
W4793	1	DILO+128	LOCKED
W4793	2	DIAC+128	ALARM H+, L-
W4793	3	DIAHR378	ALARM H
W4793	4	DIAL+128	ALARM L
W4793	5	DIDER378	DEFECT MEASURE
W4793	6	DIA+128	ALL ALARM
W4793	7		
W4793	8	DIAM+136	AUTO/MANU R379
W4793	9	DILO+136	LOCKED
W4793	A	DIAC+136	ALARM H+, L-
W4793	B	DIAHR379	ALARM H
W4793	C	DIAL+136	ALARM L
W4793	D	DIDER379	DEFECT MEASURE
W4793	E	DIA+136	ALL ALARM
W4793	F		
W4794	0	DIAM+144	AUTO/MANU R380
W4794	1	DILO+144	LOCKED
W4794	2	DIAC+144	ALARM H+, L-
W4794	3	DIAHR380	ALARM H
W4794	4	DIAL+144	ALARM L
W4794	5	DIDER380	DEFECT MEASURE
W4794	6	DIA+144	ALL ALARM
W4794	7		
W4794	8	DIAM+152	AUTO/MANU R381
W4794	9	DILO+152	LOCKED
W4794	A	DIAC+152	ALARM H+, L-
W4794	B	DIAHR381	ALARM H

W4794	C	DIAL+152	ALARM L
W4794	D	DIDER381	DEFECT MEASURE
W4794	E	DIA+152	ALL ALARM
W4794	F		
W4795	0		
W4795	1		
W4795	2		
W4795	3		
W4795	4		
W4795	5		
W4795	6		
W4795	7		
W4795	8		
W4795	9		
W4795	A		
W4795	B		
W4795	C		
W4795	D		
W4795	E		
W4795	F		
W4796	0		
W4796	1		
W4796	2		
W4796	3		
W4796	4		
W4796	5		
W4796	6		
W4796	7		
W4796	8	DIAM+184	AUTO/MANU R385
W4796	9	DILO+184	LOCKED
W4796	A	DIAC+184	ALARM H+, L-
W4796	B	DIAHR385	ALARM H
W4796	C	DIAL+184	ALARM L
W4796	D	DIDER385	DEFECT MEASURE
W4796	E	DIA+184	ALL ALARM
W4796	F		
W4797	0	DIAM+192	AUTO/MANU R386
W4797	1	DILO+192	LOCKED
W4797	2	DIAC+192	ALARM H+, L-
W4797	3	DIAHR386	ALARM H
W4797	4	DIAL+192	ALARM L
W4797	5	DIDER386	DEFECT MEASURE
W4797	6	DIA+192	ALL ALARM
W4797	7		
W4797	8	DIAM+200	AUTO/MANU R387
W4797	9	DILO+200	LOCKED
W4797	A	DIAC+200	ALARM H+, L-
W4797	B	DIAHR387	ALARM H
W4797	C	DIAL+200	ALARM L

W4797	D	DIDER387	DEFECT MEASURE
W4797	E	DIA+200	ALL ALARM
W4797	F		
W4798	0	DIAM+208	AUTO/MANU R388
W4798	1	DILO+208	LOCKED
W4798	2	DIAC+208	ALARM H+, L-
W4798	3	DIAHR388	ALARM H
W4798	4	DIAL+208	ALARM L
W4798	5	DIDER388	DEFECT MEASURE
W4798	6	DIA+208	ALL ALARM
W4798	7		
W4798	8	DIAM+216	AUTO/MANU R389
W4798	9	DILO+216	LOCKED
W4798	A	DIAC+216	ALARM H+, L-
W4798	B	DIAHR389	ALARM H
W4798	C	DIAL+216	ALARM L
W4798	D	DIDER389	DEFECT MEASURE
W4798	E	DIA+216	ALL ALARM
W4798	F		
W4799	0	DIAM+224	AUTO/MANU R390
W4799	1	DILO+224	LOCKED
W4799	2	DIAC+224	ALARM H+, L-
W4799	3	DIAHR390	ALARM H
W4799	4	DIAL+224	ALARM L
W4799	5	DIDER390	DEFECT MEASURE
W4799	6	DIA+224	ALL ALARM
W4799	7		
W4799	8	DIAM+232	AUTO/MANU R391
W4799	9	DILO+232	LOCKED
W4799	A	DIAC+232	ALARM H+, L-
W4799	B	DIAHR391	ALARM H
W4799	C	DIAL+232	ALARM L
W4799	D	DIDER391	DEFECT MEASURE
W4799	E	DIA+232	ALL ALARM
W4799	F		
W4800	0	DIAM+240	AUTO/MANU R392
W4800	1	DILO+240	LOCKED
W4800	2	DIAC+240	ALARM H+, L-
W4800	3	DIAHR392	ALARM H
W4800	4	DIAL+240	ALARM L
W4800	5	DIDER392	DEFECT MEASURE
W4800	6	DIA+240	ALL ALARM
W4800	7		
W4800	8	DIAM+248	AUTO/MANU R393
W4800	9	DILO+248	LOCKED
W4800	A	DIAC+248	ALARM H+, L-
W4800	B	DIAHR393	ALARM H
W4800	C	DIAL+248	ALARM L
W4800	D	DIDER393	DEFECT MEASURE

W4800	E	DIA+248	ALL ALARM
W4800	F		
W4801	0	DIAM+256	AUTO/MANU R394
W4801	1	DILO+256	LOCKED
W4801	2	DIAC+256	ALARM H+, L-
W4801	3	DIAHR394	ALARM H
W4801	4	DIAL+256	ALARM L
W4801	5	DIDER394	DEFECT MEASURE
W4801	6	DIA+256	ALL ALARM
W4801	7		
W4801	8	DIAM+264	AUTO/MANU R395
W4801	9	DILO+264	LOCKED
W4801	A	DIAC+264	ALARM H+, L-
W4801	B	DIAHR395	ALARM H
W4801	C	DIAL+264	ALARM L
W4801	D	DIDER395	DEFECT MEASURE
W4801	E	DIA+264	ALL ALARM
W4801	F		
W4802	0	DIAM+272	AUTO/MANU R396
W4802	1	DILO+272	LOCKED
W4802	2	DIAC+272	ALARM H+, L-
W4802	3	DIAHR396	ALARM H
W4802	4	DIAL+272	ALARM L
W4802	5	DIDER396	DEFECT MEASURE
W4802	6	DIA+272	ALL ALARM
W4802	7		
W4802	8	DIAM+280	AUTO/MANU R397
W4802	9	DILO+280	LOCKED
W4802	A	DIAC+280	ALARM H+, L-
W4802	B	DIAHR397	ALARM H
W4802	C	DIAL+280	ALARM L
W4802	D	DIDER397	DEFECT MEASURE
W4802	E	DIA+280	ALL ALARM
W4802	F		
W4803	0	DIAM+288	AUTO/MANU R398
W4803	1	DILO+288	LOCKED
W4803	2	DIAC+288	ALARM H+, L-
W4803	3	DIAHR398	ALARM H
W4803	4	DIAL+288	ALARM L
W4803	5	DIDER398	DEFECT MEASURE
W4803	6	DIA+288	ALL ALARM
W4803	7		
W4803	8	DIAM+296	AUTO/MANU R399
W4803	9	DILO+296	LOCKED
W4803	A	DIAC+296	ALARM H+, L-
W4803	B	DIAHR399	ALARM H
W4803	C	DIAL+296	ALARM L
W4803	D	DIDER399	DEFECT MEASURE
W4803	E	DIA+296	ALL ALARM

W4803	F		
W4804	0	DIAM+304	AUTO/MANU R400
W4804	1	DILO+304	LOCKED
W4804	2	DIAC+304	ALARM H+, L-
W4804	3	DIAHR400	ALARM H
W4804	4	DIAL+304	ALARM L
W4804	5	DIDER400	DEFECT MEASURE
W4804	6	DIA+304	ALL ALARM
W4804	7		
W4804	8	DIAM+312	AUTO/MANU R401
W4804	9	DILO+312	LOCKED
W4804	A	DIAC+312	ALARM H+, L-
W4804	B	DIAHR401	ALARM H
W4804	C	DIAL+312	ALARM L
W4804	D	DIDER401	DEFECT MEASURE
W4804	E	DIA+312	ALL ALARM
W4804	F		
W4805	0	DIAM+320	AUTO/MANU R402
W4805	1	DILO+320	LOCKED
W4805	2	DIAC+320	ALARM H+, L-
W4805	3	DIAHR402	ALARM H
W4805	4	DIAL+320	ALARM L
W4805	5	DIDER402	DEFECT MEASURE
W4805	6	DIA+320	ALL ALARM
W4805	7		
W4805	8	DIAM+328	AUTO/MANU R403
W4805	9	DILO+328	LOCKED
W4805	A	DIAC+328	ALARM H+, L-
W4805	B	DIAHR403	ALARM H
W4805	C	DIAL+328	ALARM L
W4805	D	DIDER403	DEFECT MEASURE
W4805	E	DIA+328	ALL ALARM
W4805	F		
W4806	0	DIAM+336	AUTO/MANU R404
W4806	1	DILO+336	LOCKED
W4806	2	DIAC+336	ALARM H+, L-
W4806	3	DIAHR404	ALARM H
W4806	4	DIAL+336	ALARM L
W4806	5	DIDER404	DEFECT MEASURE
W4806	6	DIA+336	ALL ALARM
W4806	7		
W4806	8		
W4806	9		
W4806	A		
W4806	B		
W4806	C		
W4806	D		
W4806	E		
W4806	F		

W4807 0		
W4807 1		
W4807 2		
W4807 3		
W4807 4		
W4807 5		
W4807 6		
W4807 7		
W4807 8		
W4807 9		
W4807 A		
W4807 B		
W4807 C		
W4807 D		
W4807 E		
W4807 F		
W4808 0		
W4808 1		
W4808 2		
W4808 3		
W4808 4		
W4808 5		
W4808 6		
W4808 7		
W4808 8		
W4808 9		
W4808 A		
W4808 B		
W4808 C		
W4808 D		
W4808 E		
W4808 F		

W9000	COPY FROM W4760, SEE "WORD BIT"
W9001	COPY FROM W4761, SEE "WORD BIT"
W9002	COPY FROM W4762, SEE "WORD BIT"
W9003	COPY FROM W4763, SEE "WORD BIT"
W9004	COPY FROM W4764, SEE "WORD BIT"
W9005	COPY FROM W4765, SEE "WORD BIT"
W9006	COPY FROM W4766, SEE "WORD BIT"
W9007	COPY FROM W4767, SEE "WORD BIT"
W9008, 0	COPY FROM W4785, 3
W9008, 1	COPY FROM W4785, 5
W9008, 2	COPY FROM W4785, B
W9008, 3	COPY FROM W4785, D
W9008, 4	COPY FROM W4789, 3
W9008, 5	COPY FROM W4789, 5
W9008, 6	COPY FROM W4789, B
W9008, 7	COPY FROM W4789, D
W9008, 8	COPY FROM W4790, 3
W9008, 9	COPY FROM W4790, 5
W9008, A	COPY FROM W4790, B
W9008, B	COPY FROM W4790, D
W9008, C	COPY FROM W4791, 3
W9008, D	COPY FROM W4791, 5
W9008, E	COPY FROM W4791, B
W9008, F	COPY FROM W4791, D
W9009, 0	COPY FROM W4792, 3
W9009, 1	COPY FROM W4792, 5
W9009, 2	COPY FROM W4792, B
W9009, 3	COPY FROM W4792, D
W9009, 4	COPY FROM W4793, 3
W9009, 5	COPY FROM W4793, 5
W9009, 6	COPY FROM W4793, B
W9009, 7	COPY FROM W4793, D
W9009, 8	COPY FROM W4794, 3
W9009, 9	COPY FROM W4794, 5
W9009, A	COPY FROM W4794, B
W9009, B	COPY FROM W4794, D
W9009, C	
W9009, D	
W9009, E	COPY FROM W4796, B
W9009, F	COPY FROM W4796, D
W9010, 0	COPY FROM W4797, 3
W9010, 1	COPY FROM W4797, 5
W9010, 2	COPY FROM W4797, B
W9010, 3	COPY FROM W4797, D
W9010, 4	COPY FROM W4798, 3
W9010, 5	COPY FROM W4798, 5
W9010, 6	COPY FROM W4798, B
W9010, 7	COPY FROM W4798, D
W9010, 8	COPY FROM W4799, 3
W9010, 9	COPY FROM W4799, 5
W9010, A	COPY FROM W4799, B
W9010, B	COPY FROM W4799, D

W9010, C	COPY FROM W4800, 3
W9010, D	COPY FROM W4800, 5
W9010, E	COPY FROM W4800, B
W9010, F	COPY FROM W4800, D
W9011, 0	COPY FROM W4801, 3
W9011, 1	COPY FROM W4801, 5
W9011, 2	COPY FROM W4801, B
W9011, 3	COPY FROM W4801, D
W9011, 4	COPY FROM W4802, 3
W9011, 5	COPY FROM W4802, 5
W9011, 6	COPY FROM W4802, B
W9011, 7	COPY FROM W4802, D
W9011, 8	COPY FROM W4803, 3
W9011, 9	COPY FROM W4803, 5
W9011, A	COPY FROM W4803, B
W9011, B	COPY FROM W4803, D
W9011, C	COPY FROM W4804, 3
W9011, D	COPY FROM W4804, 5
W9011, E	COPY FROM W4804, B
W9011, F	COPY FROM W4804, D
W9012, 0	COPY FROM W4805, 3
W9012, 1	COPY FROM W4805, 5
W9012, 2	COPY FROM W4805, B
W9012, 3	COPY FROM W4805, C
W9012, 4	COPY FROM W4806, 3
W9012, 5	COPY FROM W4806, 4
W9012, 6	
W9012, 7	
W9012, 8	
W9012, 9	
W9012, A	
W9012, B	
W9012, C	
W9012, D	
W9012, E	
W9012, F	
W9013, 0	COPY FROM B235
W9013, 1	COPY FROM W4770, A
W9013, 2	COPY FROM W4771, D
W9013, 3	COPY FROM B285
W9013, 4	COPY FROM W4772, 8
W9013, 5	COPY FROM W4772, 9
W9013, 6	COPY FROM W4772, B
W9013, 7	COPY FROM W4772, C
W9013, 8	COPY FROM B305
W9013, 9	COPY FROM B302
W9013, A	COPY FROM B366
W9013, B	COPY FROM B410
W9013, C	COPY FROM B369
W9013, D	COPY FROM B372
W9013, E	COPY FROM B375
W9013, F	COPY FROM B378

W9014, 0	COPY FROM W4773, E
W9014, 1	COPY FROM W4774, 6
W9014, 2	COPY FROM W4774, 8
W9014, 3	COPY FROM W4774, A
W9014, 4	COPY FROM W4774, C
W9014, 5	COPY FROM W4774, D
W9014, 6	COPY FROM W4774, E
W9014, 7	
W9014, 8	
W9014, 9	
W9014, A	
W9014, B	
W9014, C	
W9014, D	
W9014, E	
W9014, F	
W9015, 0	COPY FROM W4770, F
W9015, 1	COPY FROM W4771, F
W9015, 2	COPY FROM W4772, F
W9015, 3	COPY FROM W4773, F
W9015, 4	
W9015, 5	
W9015, 6	
W9015, 7	
W9015, 8	
W9015, 9	
W9015, A	
W9015, B	
W9015, C	
W9015, D	
W9015, E	
W9015, F	
W9016	COPY FROM W4421 (ALL DEFECT DC MOTOR)
W9017, 0	COPY FROM B278
W9017, 1	COPY FROM B312
W9017, 2	COPY FROM B398
W9017, 3	
W9017, 4	
W9017, 5	
W9017, 6	
W9017, 7	
W9017, 8	
W9017, 9	
W9017, A	
W9017, B	
W9017, C	
W9017, D	
W9017, E	
W9017, F	
W9018	
W9019	
W9020	

W9021	
W9022	
W9023	
W9024	
W9025	
W9026	
W9027	
W9028	
W9029	
W9030	
W9031	
W9032	
W9033	
W9034	
W9035	
W9036	
W9037	
W9038	
W9039	
W9040	
W9041	
W9042	
W9043	
W9044	
W9045	
W9046	
W9047	
W9048	
W9049	
W9050	COPY FROM W9000
W9051	COPY FROM W9001
W9052	COPY FROM W9002
W9053	COPY FROM W9003
W9054	COPY FROM W9004
W9055	COPY FROM W9005
W9056	COPY FROM W9006
W9057	COPY FROM W9007
W9058	COPY FROM W9008
W9059	COPY FROM W9009
W9060	COPY FROM W9010
W9061	COPY FROM W9011
W9062	COPY FROM W9012
W9063	COPY FROM W9013
W9064	COPY FROM W9014
W9065	COPY FROM W9015
W9066	COPY FROM W9016
W9067	COPY FROM W9017
W9068	
W9069	
W9070 ~ 9499	FREE
W9500	OFFSET POINT TDO ZONE 1 R385 (NOT USED)

W9501	OFFSET POINT TDO ZONE 2 R386 (NOT USED)
W9502	OFFSET POINT TDO ZONE 3 R387 (NOT USED)
W9503	OFFSET POINT TDO ZONE 4 R388 (NOT USED)
W9504	OFFSET POINT TDO ZONE 5 R389 (NOT USED)
W9505	OFFSET POINT TDO ZONE 6 R390 (NOT USED)
W9506	OFFSET POINT TDO ZONE 7 R391 (NOT USED)
W9507	OFFSET POINT TDO ZONE 8 R392 (NOT USED)
W9508	OFFSET POINT TDO ZONE 9 R393 (NOT USED)
W9509	
W9510	
W9511	
W9512	
W9513	
W9514	
W9515	
W9516	
W9517	
W9518	
W9519	
W9520	
W9521	
W9522	
W9523	
W9524	
W9525	
W9526	
W9527	
W9528	
W9529	
W9530	
W9531	
W9532	
W9533	
W9534	
W9535	
W9536	
W9537	
W9538	
W9539	
W9540	
W9541	
W9542	
W9543	
W9544	
W9545	
W9546	
W9547	
W9548	
W9549	
W9550	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 120 < SPEED <= 130
W9551	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9552	VALUE OFFSET, SETPOINT TDO ZONE 3 R387

W9553	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9554	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9555	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9556	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9557	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9558	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9559	
W9560	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 130 < SPEED <= 140
W9561	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9562	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9563	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9564	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9565	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9566	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9567	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9568	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9569	
W9570	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 140 < SPEED <= 150
W9571	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9572	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9573	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9574	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9575	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9576	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9577	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9578	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9579	
W9580	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 150 < SPEED <= 160
W9581	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9582	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9583	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9584	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9585	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9586	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9587	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9588	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9589	
W9590	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 160 < SPEED <= 170
W9591	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9592	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9593	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9594	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9595	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9596	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9597	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9598	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9599	
W9600	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 170 < SPEED <= 180
W9601	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9602	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9603	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9604	VALUE OFFSET, SETPOINT TDO ZONE 5 R389

W9605	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9606	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9607	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9608	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9609	
W9610	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 180 < SPEED <= 190
W9611	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9612	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9613	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9614	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9615	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9616	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9617	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9618	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9619	
W9620	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 190 < SPEED <= 200
W9621	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9622	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9623	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9624	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9625	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9626	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9627	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9628	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9629	
W9630	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 200 < SPEED <= 210
W9631	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9632	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9633	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9634	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9635	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9636	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9637	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9638	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9639	
W9640	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 210 < SPEED <= 220
W9641	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9642	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9643	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9644	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9645	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9646	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9647	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9648	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9649	
W9650	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 220 < SPEED <= 230
W9651	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9652	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9653	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9654	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9655	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9656	VALUE OFFSET, SETPOINT TDO ZONE 7 R391

W9657	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9658	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9659	
W9660	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 230 < SPEED <= 240
W9661	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9662	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9663	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9664	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9665	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9666	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9667	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9668	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9669	
W9670	VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 240 < SPEED <= 250
W9671	VALUE OFFSET, SETPOINT TDO ZONE 2 R386
W9672	VALUE OFFSET, SETPOINT TDO ZONE 3 R387
W9673	VALUE OFFSET, SETPOINT TDO ZONE 4 R388
W9674	VALUE OFFSET, SETPOINT TDO ZONE 5 R389
W9675	VALUE OFFSET, SETPOINT TDO ZONE 6 R390
W9676	VALUE OFFSET, SETPOINT TDO ZONE 7 R391
W9677	VALUE OFFSET, SETPOINT TDO ZONE 8 R392
W9678	VALUE OFFSET, SETPOINT TDO ZONE 9 R393
W9679 ~ 9999	FREE

TEMPERATURE REGULATOR 50 WORD

F13\WORD6

	W100XX
00 [50]	ACTUAL VALUE (MEASURE)
01 [51]	SETPOINT
02 [52]	FREE
03 [53]	ALARM H
04 [54]	ALARM VALUE ABOVE SETPOINT (H+)
05 [55]	ALARM VALUE ABOVE SETPOINT (L-)
06 [56]	ALARM L
07 [57]	10
08 [58]	REAL OUTPUT
09 [59]	7, GENERAL GAIN
10 [60]	I
11 [61]	800, THRESHOLD INHIBIT INTEGRAL
12 [62]	D
13 [63]	P
14 [64]	1, OUTPUT GAIN
15 [65]	0
16 [66]	300, RAMP INCREMENT
17 [67]	MEASURE VALUE FOR LAST TIME (T-1)
18 [68]	I VALUE, AFTER CALCULATION
19 [69]	I VALUE, AFTER CALCULATION
20 [70]	ANALOG OUTPUT
21 [71]	STATUS LOOP
22 [72]	OUTPUT (MANUAL)
23 [73]	OUTPUT COUNTER
24 [74]	OUTPUT +- 10,000 PTS
25 [75]	OUTPUT +- 10,000 PTS
26 [76]	RESERVE CONTROL LOOP
27 [77]	TIME SAMPLE FOR DERIVATIVE
28 [78]	ERROR, THE DIFFERENCE BTWN SETPOINT AND ACTUAL VALUE
29 [79]	ERROR, THE DIFFERENCE BTWN SETPOINT AND ACTUAL VALUE
30 [80]	OUTPUT IN PERCENT (%)
31 [81]	FREE
32 [82]	D VALUE, AFTER CALCULATION
33 [83]	D VALUE, AFTER CALCULATION
34 [84]	P GAIN, AFTER CALCULATION
35 [85]	P GAIN, AFTER CALCULATION
36 [86]	PID ACTION
37 [87]	PID ACTION
38 [88]	FREE
39 [89]	FREE
40 [90]	FREE
41 [91]	FREE
42 [92]	FREE
43 [93]	COOLING OUTPUT
44 [94]	HEATER OUTPUT
45 [95]	COUNTER COOLING
46 [96]	COUNTER HEATING
47 [97]	30, GAIN COOLING

48 [98]	30, GAIN HEATING
49 [99]	

NO.	COMMENT
T 0	SCM 2222 CARD
T 1	TIMER FOR CHILL ROLL FORWARD STEP 1
T 2	TIMER FOR CHILL ROLL FORWARD STEP 2
T 3	TIMER FOR CHILL ROLL FORWARD STEP 3
T 4	TIMER FOR CHILL ROLL BACKWARD STEP 0
T 5	TIMER FOR CHILL ROLL BACKWARD STEP 1
T 6	TIMER FOR CHILL ROLL BACKWARD STEP 4
T 7	
T 8	
T 9	
T 10	TIMER TAM 1360,03 AUXILIARY WINDER 1
T 11	TIMER LSL 1360,05 WATER BATH
T 12	TIMER TAH 1650,03 AUXILIARY WINDER 2
T 13	TIMER LSL 1515,02 CHAIN TENSION SYSTEM
T 14	TIMER OSL 1515,03 CHAIN TENSION SYSTEM
T 15	
T 16	
T 17	
T 18	
T 19	TIMER LOW FLOW ALARM FSL 1831,08
T 20	TIMER LOW FLOW ALARM FSL 1831,06
T 21	TIMER LOW FLOW ALARM FSL 1831,07
T 22	TIMER LOW PRESSURE ALARM PSL 1820,07
T 23	TIMER LOW PRESSURE ALARM PSL 1820,13
T 24	TIMER LOW PRESSURE ALARM PSL 1820,16
T 25	
T 26	
T 27	
T 28	
T 29	
T 30	TIMER FOR AEM 811 CONFIGURATION
T 31	
T 32	
T 33	
T 34	
T 35	TIMER FOR CLOSING AUXILIARY WINDER 3 SECURITY FINGER
T 36	TIMER FOR OPENING AUXILIARY WINDER 3 SECURITY FINGER
T 37	
T 38	
T 39	
T 40	TIMER FOR AIR KNIFE BLOWER TURN OFF DELAY DUE TO MDO BUNK
T 41	
T 42	
T 43	
T 44	
T 45	
T 46	
T 47	
T 48	
T 49	

T 50	TIMER FOR STARTING MDO EQUIPMENT
T 51	TIMER FOR STARTING CHILL ROLL EQUIPMENT
T 52	TIMER FOR STARTING MDO EQUIPMENT
T 53	
T 54	
T 55	
T 56	
T 57	
T 58	
T 59	
T 60	
T 61	
T 62	
T 63	
T 64	FILTER OF WEB BREAK DETECTION
T 65	FILTER OF WEB BREAK DETECTION
T 66	
T 67	
T 68	
T 69	
T 70	
T 71	
T 72	
T 73	
T 74	
T 75	
T 76	
T 77	
T 78	
T 79	
T 80	
T 81	
T 82	
T 83	
T 84	
T 85	
T 86	
T 87	
T 88	
T 89	
T 90	
T 91	
T 92	
T 93	
T 94	
T 95	
T 96	
T 97	
T 98	
T 99	
T 100	
T 101	

T 102	
T 103	
T 104	
T 105	
T 106	
T 107	
T 108	
T 109	
T 110	
T 111	
T 112	
T 113	
T 114	
T 115	
T 116	
T 117	
T 118	
T 119	
T 120	
T 121	
T 122	
T 123	
T 124	
T 125	
T 126	
T 127	
T 128	

TEMPERATURE CONTROL 16BIT

**21,0 **71,0	AUTO/MANU (MANU -> "1")
**21,1 **71,1	TEMPERATURE CONTROL LOCKED
**21,2 **71,2	ALARM H+ OR L- (TEMP OUT OF RANGE)
**21,3 **71,3	ALARM H
**21,4 **71,4	ALARM L
**21,5 **71,5	DEFECT MEASURE
21,6 **71,6	ALL ALARM (21, 2+**21, 4+**21, 5)
**21,7 **71,7	FAULT CONTROL LOOP
**21,8 **71,8	HEATING => ON
**21,9 **71,9	SAMPLE TIME SELECT
**21,A **71,A	START CONTROL LOOP
**21,B **71,B	REVERSE CONTROL LOOP
**21,C **71,C	COOLING VALVE => ON
**21,D **71,D	BIT OUTPUT 100; -100
**21,E **71,E	
**21,F **71,F	TEMPERATURE NOT DEFECT (O.K.)

TEMPERATURE CONTROL 50 WORDS

W6000	[50]	R365	CHILL ROLL COOLING SKID
W6050	[50]	R366	WATER BATH SKID
W6100	[50]	R370	MDO ZONE 1
W6150	[50]	R371	MDO ZONE 2
W6200	[50]	R372	MDO ZONE 3
W6250	[50]	R373	MDO ZONE 4
W6300	[50]	R374	MDO ZONE 5
W6350	[50]	R375	MDO ZONE 6
W6400	[50]	R376	MDO ZONE 7
W6450	[50]	R377	MDO ZONE 8
W6500	[50]	R378	MDO ZONE 9
W6550	[50]	R379	MDO ZONE 10
W6600	[50]	R380	MDO ZONE 11
W6650	[50]	R381	MDO ZONE 12
W6700	[50]	R385	TDO ZONE 1
W6750	[50]	R386	TDO ZONE 2
W6800	[50]	R387	TDO ZONE 3
W6850	[50]	R388	TDO ZONE 4
W6900	[50]	R389	TDO ZONE 5
W6950	[50]	R390	TDO ZONE 6
W7000	[50]	R391	TDO ZONE 7
W7050	[50]	R392	TDO ZONE 8
W7100	[50]	R393	TDO ZONE 9
W7150	[50]	R394	TDO ZONE 10
W7200	[50]	R395	TDO ZONE 11
W7250	[50]	R396	TDO ZONE 12
W7300	[50]	R397	TDO ZONE 13
W7350	[50]	R398	TDO ZONE 14
W7400	[50]	R399	TDO ZONE 15
W7450	[50]	R400	TDO ZONE 16
W7500	[50]	R401	TDO ZONE 17
W7550	[50]	R402	TDO ZONE 18
W7600	[50]	R403	TDO ZONE 19
W7650	[50]	R404	TDO ZONE 20
W7700	[50]		

TEMPERATURE CONTROL & DATA WORD

W6000	[50]	R307	SAT. EXT 1 ADAPTER
W6050	[50]	R308	SAT. EXT 1 FILTER
W6100	[50]	R309	SAT. EXT 1 MELT LINE
W6150	[50]	R317	SAT. EXT 2 ADAPTER
W6200	[50]	R318	SAT. EXT 2 FILTER
W6250	[50]	R319	SAT. EXT 2 MELT LINE
W6300	[50]	R324	MAIN EXT 1 ADAPTER
W6350	[50]	R325	MAIN EXT 1 FILTER ZONE #1
W6400	[50]	R326	MAIN EXT 1 FILTER ZONE #2
W6450	[50]	R327	MAIN EXT 1 FILTER ZONE #3
W6500	[50]		
W6550	[50]		
W6600	[50]	R330	MAIN EXT 1 MELT LINE #1
W6650	[50]	R331	MAIN EXT 1 MELT LINE #2
W6700	[50]	R332	MAIN EXT 1 MELT LINE #3
W6750	[50]	R333	MAIN EXT 1 MELT LINE #4
W6800	[50]	R344	MAIN EXT 2 ADAPTER
W6850	[50]	R345	MAIN EXT 2 FILTER ZONE #1
W6900	[50]	R346	MAIN EXT 2 FILTER ZONE #2
W6950	[50]	R347	MAIN EXT 2 FILTER ZONE #3
W7000	[50]	R348	MAIN EXT 2 MELT LINE #1
W7050	[50]	R349	MAIN EXT 2 MELT LINE #2
W7100	[50]	R350	MAIN EXT 2 STATIC MIXER
W7150	[50]	R351	MAIN EXT 2 STATIC MIXER CONNECTION
W7200	[50]	R352	MAIN EXT 2 CONNECTION BOX
W7250	[50]	R355	DIE ZONE #1
W7300	[50]	R356	DIE ZONE #2
W7350	[50]	R357	DIE ZONE #3
W7400	[50]	R358	DIE ZONE #4
W7450	[50]	R359	DIE ZONE #5
W7500	[50]	R360	DIE ZONE #6
W7550	[50]	R361	DIE ZONE #7
W7600	[50]	R200	HOPPER WEIGH REGULATION
W7650	[50]		
W7700	[50]		
W7750	[50]		
W7800	[50]		
W7850	[50]		
W7900	[50]		
W7950	[50]		
W8000	[50]	R300	SAT. EXT 1 ZONE #1
W8050	[50]	R301	SAT. EXT 1 ZONE #2
W8100	[50]	R302	SAT. EXT 1 ZONE #3
W8150	[50]	R303	SAT. EXT 1 ZONE #4
W8200	[50]	R304	SAT. EXT 1 ZONE #5
W8250	[50]	R305	SAT. EXT 1 ZONE #6
W8300	[50]	R306	SAT. EXT 1 ZONE #7
W8350	[50]	R310	SAT. EXT 2 ZONE #1
W8400	[50]	R311	SAT. EXT 2 ZONE #2
W8450	[50]	R312	SAT. EXT 2 ZONE #3
W8500	[50]	R313	SAT. EXT 2 ZONE #4

W8550	[50]	R314	SAT. EXT 2 ZONE #5
W8600	[50]	R315	SAT. EXT 2 ZONE #6
W8650	[50]	R316	SAT. EXT 2 ZONE #7
W8700	[50]		
W8750	[50]		
W8800	[50]		
W8850	[50]		
W8900	[50]		
W8950	[50]		
W9000	[50]	R320	MAIN EXT. 1 ZONE #1
W9050	[50]	R321	MAIN EXT. 1 ZONE #2
W9100	[50]	R322	MAIN EXT. 1 ZONE #3
W9150	[50]	R323	MAIN EXT. 1 ZONE #4
W9200	[50]	R340	MAIN EXT. 2 ZONE #1
W9250	[50]	R341	MAIN EXT. 2 ZONE #2
W9300	[50]	R342	MAIN EXT. 2 ZONE #3
W9350	[50]	R343	MAIN EXT. 2 ZONE #4
W9400	[50]		
W9450	[50]		
W9500	[50]		

TEMPERATURE REGULATOR 50 WORDS
W100XX

00 (50)	ACTUAL VALUE (MEASURE)	
01 (51)	SETPOINT	
02 (52)	FREE	
03 (53)	ALARM H	
04 (54)	ALARM VALUE ABOVE SETPOINT (H+)	
05 (55)	ALARM VALUE BELOW SETPOINT (L-)	
06 (56)	ALARM L	
07 (57)	10	
08 (58)	REAL OUTPUT	
09 (59)	7. GENERAL GAIN	
10 (60)	I	
11 (61)	800, THRESHOLD INHIBIT INTEGRAL	
12 (62)	D	
13 (63)	P	
14 (64)	1. OUTPUT GAIN	
15 (65)	O	
16 (66)	300, RAMP INCREMENT	
17 (67)	MEASURE VALUE FOR LAST TIME (T-1)	
18 (68)	I VALUE AFTER CALCULATION	
19 (69)	I VALUE AFTER CALCULATION	
20 (70)	ANALOG OUTPUT	
21 (71)	BIT STATUS FOR CONTROL LOOP	
22 (72)	OUTPUT (MANUAL)	
23 (73)	OUTPUT COUNTER	
24 (74)	OUTPUT +/- 10,000 PTS	
25 (75)	OUTPUT +/- 10,000 PTS	
26 (76)	RECEIVE CONTROL LOOP	
27 (77)	TIME SAMPLE FOR DERIVATIVE	
28 (78)	[ERROR] THE DIFFERENCE BETWEEN SETPOINT AND ACTUAL VALUE	
29 (79)	[ERROR] THE DIFFERENCE BETWEEN SETPOINT AND ACTUAL VALUE	
30 (80)	OUTPUT IN PERCENT (%) W10020/10	
31 (81)	FREE	
32 (82)	D VALUE AFTER CALCULATION	
33 (83)	D VALUE AFTER CALCULATION	
34 (84)	P GAIN AFTER CALCULATION	
35 (85)	P GAIN AFTER CALCULATION	
36 (86)	PID ACTION	
37 (87)	PID ACTION	
38 (88)	FREE	
39 (89)	FREE	
40 (90)	FREE	
41 (91)	FREE	
42 (92)	FREE	
43 (93)	COOLING OUTPUT	
44 (94)	HEATER OUTPUT	
45 (95)	COUNTER COOLING	
46 (96)	COUNTER HEATING	

47 (97)	30, GAIN COOLING	
48 (98)	30, GAIN HEATING	
49 (99)		
xx21, 0	AUTO/MANUAL (MANUAL -> 1)	B2000
xx21, 1	TEMPERATURE CONTROL LOCKED	B2001
xx21, 2	ALARM H+ OR L- (TEMP OUT OF RANGE)	
xx21, 3	ALARM H	
xx21, 4	ALARM L	
xx21, 5	DEFECT MEASURE	
xx21, 6	ALL ALARM (21.2 + 21.3 + 21.4 + 21.5)	
xx21, 7	FAULT CONTROL LOOP	
xx21, 8		
xx21, 9	SAMPLE TIME SELECT (60 OR 1)	
xx21, A	START CONTROL LOOP	
xx21, B	REVERSE CONTROL LOOP	
xx21, C		
xx21, D	BIT OUTPUT 100; -100	
xx21, E		
xx21, F	TEMPERATURE NOT DEFECT (OK)	B2015