

Procedure to check the Primary Thyristor assembly

Date: 07/01/2019



1. Turn Multimeter to Ohm
2. Check $R_{u1-u2} \approx 15 \text{ ohm}$
 $R_{u3-u4} \approx 15 \text{ ohm}$
3. $R_{b1-b2} > 250 \text{ kohm}$
 $R_{b3-b4} > 250 \text{ Kohm}$
 $R_{b2-b3} \leq 0.5 \text{ ohm}$
4. If they are not above value, unscrew them and check.
5. If they are still not above value, Contact Supervisor or engineer to double check.