

F12 I/O LIST

F12\INPUTBIT.DOC

I/O WORD	DESCRIPTION	SYMBOL	PAGE # (DRAW')
I81,0	EXT. 1 RUNNING F16		68
I81,1	EXT. 2 RUNNING F16		68
I81,2	SAT. 1 RUNNING F16		68
I81,3	SAT. 2 RUNNING F16		68
I81,4	PRODUC. STRETCH. F16		68
I81,5	(FREE)		68
I81,6	PRIMARY PRESSURE SWITCH		68
I81,7	MELT LINE OVER TEMPERATURE OIL SKID	C1240	68
I81,8	MELT LINE HIGH LEVEL-DEFECT OIL SKID	C1240	69
I81,9	MELT LINE LOW LEVEL-DEFECT OIL SKID	C1240	69
I81,A	ASK START CONAIR PUMP (FROM F8) F8 (*ONLY LINE #1)		69
I81,B	ADDITIVE RECIEVER FULL		69
I81,C	AUX 1 SR1 L10+3		69
I81,D	ADDITIVE LOW		69
I81,E	AUX1 SR1 L20+3		69
I81,F	AUX1 SR1 L23+2		69
I82,0	HEATER ZONE 1 EXT. 1 F21	H1200-01	72
I82,1	HEATER ZONE 2 EXT. 1 F21	H1200-02	72
I82,2	HEATER ZONE 3 EXT. 1 F21	H1200-03	72
I82,3	HEATER ZONE 4 EXT. 1 F21	H1200-04	72
I82,4	COOLING PUMP EXT. 1 F21	M1200-05	72
I82,5	MIXING SCREEN F21	M1114-01	72
I82,6	ROTARY ARM F21	M1114-02	72
I82,7	HEATER ZONE 1 EXT. 2 F21	H1200-06	72
I82,8	HEATER ZONE 1 EXT. 2 F21	H1200-07	73
I82,9	HEATER ZONE 2 EXT. 2 F21	H1200-08	73
I82,A	HEATER ZONE 3 EXT. 2 F21	H1200-09	73
I82,B	COOLING PUMP EXT. 2 F21	H1200-11	73
I82,C	VACUUM PUMP,HOMO/RECLAIM GAYLORD ADDITIVE F21	M1107-01	73
I82,D	MDO DANCER ROLL REACH BOTTOM		73
I82,E	MELT LINE 1 ZONE 1 F21	H1200-12	73
I82,F	MELT LINE 1 ZONE 2 F21	H1200-13	73
I83,0	SAT. EXT. 1 HEATER ZONE 1 F22	H1210-01	76
I83,1	SAT. EXT. 1 HEATER ZONE 2 F22	H1210-02	76
I83,2	SAT. EXT. 1 HEATER ZONE 3 F22	H1210-03	76
I83,3	SAT. EXT. 1 HEATER ZONE 4 F22	H1210-04	76
I83,4	SAT. EXT. 1 HEATER ZONE 5 F22	H1210-05	76
I83,5	SAT. EXT. 1 HEATER ZONE 6 F22	H1210-06	76
I83,6	SAT. EXT. 1 HEATER ZONE 7 F22	H1210-07	76
I83,7	ADAPT. SAT. EXT. 1 F22	H1210-29	76
I83,8	COOLING FAN ZONE 1 F22	M1210-08	77
I83,9	COOLING FAN ZONE 2 F22	M1210-09	77

B80 = RELEASE DEFECT (PC1/PC2)

I83,A	COOLING FAN ZONE 3 F22	M1210-10	77
-------	------------------------	----------	----

I83,B	COOLING FAN ZONE 4	F22	M1210-11	77
I83,C	COOLING FAN ZONE 5	F22	M1210-12	77
I83,D	COOLING FAN ZONE 6	F22	M1210-13	77
I83,E	COOLING FAN ZONE 7	F22	M1210-14	77
I83,F	(FREE)			77
I84,0	HEATING OF DIVERTER	F23	H1250-01	80
I84,1	DIE HEATER ZONE 1	F23	H1260-01	80
I84,2	DIE HEATER ZONE 2	F23	H1260-02	80
I84,3	DIE HEATER ZONE 3	F23	H1260-03	80
I84,4	DIE HEATER ZONE 4	F23	H1260-04	80
I84,5	DIE HEATER ZONE 5	F23	H1260-05	80
I84,6	DIE HEATER ZONE 6	F23	H1260-06	80
I84,7	DIE HEATER ZONE 7	F23	H1260-07	80
I84,8	(FREE)			81
I84,9	(FREE)			81
I84,A	(FREE)			81
I84,B	(FREE)			81
I84,C	(FREE)			81
I84,D	STATIC MIXER HEATING	F23	H1251-01	81
I84,E	STATIC MIXER CONNECTIONS	F23	H1251-02	81
I84,F	SAT. 1 HEATING FILTER	F23	H1232-01	81
I85,0	EXT. 1 GEAR BOX FLOW - LOW	EXT. 1	FSL1200-21	84
I85,1	EXT. 1 GEAR BOX PRESSURE - LOW	EXT. 1	PSL1200-22	84
I85,2	GEAR BOX EXT. 1 OIL FILTER - HIGH PRESSURE	EXT. 1	DPSH1200-23	84
I85,3	GEAR BOX EXT. 1 OIL FILTER - HIGH PRESSURE	EXT. 1	DPSH1200-24	84
I85,4	COOLING CIRCUIT EXT. 1 FLOW SWITCH - LOW	EXT. 1	FSL1200-25	84
I85,5	GEAR BOX EXT. 2 FLOW SWITCH - LOW	EXT. 2	FSL1200-26	84
I85,6	GEAR BOX EXT. 2 PRESSURE SWITCH - LOW	EXT. 2	PSL1200-27	84
I85,7	GEAR BOX EXT. 2 OIL FILTER - HIGH PRESSURE	EXT. 2	DPSH1200-28	84
I85,8	GEAR BOX EXT. 2 OIL FILTER - HIGH PRESSURE	EXT. 2	DPSH1200-29	85
I85,9	COOLING CIRCUIT EXT. 2 FLOW SWITCH - LOW	EXT. 2	FSL1200-30	85
I85,A	MELT LINE AGGREGATE FLOW SWITCH - LOW	OIL SKID	FSL1240-10	85
I85,B	ADDITIVE DOSING HOPPER LOW LEVEL	CONAIR	LAL1112-01	85
I85,C	HOMO DOSING HOPPER LOW LEVEL	CONAIR	LAL1106-01	85
I85,D	RECLAIM DOSING HOPPER LOW LEVEL	CONAIR	LAL1106-02	85
I85,E	GEAR BOX SAT. EXT. 1 FLOW LOW	SAT. 1	FSL1210-35	85

I85,F	GEAR BOX SAT. EXT. 1 PRESSURE LOW	SAT. 1	PSL1210-36	85
I86,0	FEEDING VALVE - OPEN	F29		88
I86,1	FEEDING VALVE - CLOSED	F29		88
I86,2	4 EXTRUDERS STOP	F29		88
I86,3	MELT LINE OIL SKID STOP	F35		88
I86,4	MAIN EXT. AIR FLOW SWITCH			
I86,5	SECONDARY EXT. AIR FLOW SWITCH			
I86,6	EXTRUDER 1 HARDWARE INTERLOCK MAIN SR17 L40+29			
I86,7	EXTRUDER 1 HARDWARE INTERLOCK MAIN SR17 L40+29			
I86,8	EXTRUDER 1 HARDWARE INTERLOCK MAIN SR17 L40+30			
I86,9	EXTRUDER 1 HARDWARE INTERLOCK MAIN SR17 L40+30			89
I86,A	EXTRUDER 1 HARDWARE INTERLOCK MAIN SR17 L40+32			89
I86,B	EXTRUDER 1 HARDWARE INTERLOCK MAIN SR17 L40+33			89
I86,C	EXTRUDER 1 HARDWARE INTERLOCK MAIN SR17 L40+34			89

I86,D	EXTRUDER 1 HARDWARE INTERLOCK MAIN SR17 L40+33			89
I86,E	EXTRUDER 1 HARDWARE INTERLOCK MAIN SR17 L40+36			89
I86,F	(FREE)			89
I87,0	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+58			92
I87,1	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+59			92
I87,2	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+61			92
I87,3	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+61			92
I87,4	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+63			92
I87,5	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+63			92
I87,6	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+65			92
I87,7	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+65			92
I87,8	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+65			93
I87,9	EXTRUDER 2 HARDWARE INTERLOCK MAIN SR17 L40+67			93
I87,A	(FREE)			93
I87,B	(FREE)			93
I87,C	SYSTEM RUNNING HOMO DRYER	C1103-01		93
I87,D	SYSTEM DEFECT HOMO DRYER	C1103-01		93
I87,E	TEMPERATURE OK HOMO DRYER	C1103-01		93
I87,F	SYSTEM RUNNING RECLAIM DRYER	C1103-02		93
I91,0	MIXING HOPPER EMPTY F8			70
I91,1	MIXING HOPPER HIGH LEVEL F8			70
I91,2	FREE			70
I91,3	FREE F5	M1106-01		70
I91,4	FREE F5	M1106-02		70
I91,5	FREE F5	M1106-02		70
I91,6	FREE F5	M1112-01		70
I91,7	FREE F5	M1112-01		70
I91,8	AUX1 SR3 L50+1 ? F8			
I91,9	AUX1 SR3 L50+1 F8			
I91,A	AUX1 SR3 L50+1 F8			
I91,B	AUX1 SR3 L50+1 F8			
I91,C	AUX1 SR3 L50+1 F8			
I91,D	AUX1 SR3 L50+1- MIXING HOPPER DEFECT F8			
I91,E	SAFETY DOOR SWITCHES F8			
I91,F	PRESSURE SWITCH PSL1200.27			
I92,0	MELT LINE 1 ZONE 3 F21	H1200-14		74
I92,1	MELT LINE 1 ZONE 4 F21	H1200-15		74
I92,2	FREE			74
I92,3	FREE			
I92,4	MOTOR CHANGE FILTER EXT. 1 F21	M1230-01		74
I92,5	FILTER ZONE 1 F21	H1230-02		74
I92,6	FILTER ZONE 2 F21	H1230-03		74
I92,7	FILTER ZONE 3 F21	H1230-04		74
I92,8	ADAPTER F21	H1230-05		75
I92,9	(FREE)			75
I92,A	(FREE)			
I92,B	MOTOR CHANGE FILTER EXT. 2 F21	M1231-01		75
I92,C	FILTER ZONE 1 F21	H1231-02		75
I92,D	FILTER ZONE 2 F21	H1231-03		75
I92,E	FILTER ZONE 3 F21	H1231-04		75
I92,F	ADAPTER F21	H1231-05		75

I93,0	(FREE)			78
I93,1	SAT. EXT. 2 HEATER ZONE 1	F22	H1210-15	78
I93,2	SAT. EXT. 2 HEATER ZONE 2	F22	H1210-16	78
I93,3	SAT. EXT. 2 HEATER ZONE 3	F22	H1210-17	78
I93,4	SAT. EXT. 2 HEATER ZONE 4	F22	H1210-18	78
I93,5	SAT. EXT. 2 HEATER ZONE 5	F22	H1210-19	78
I93,6	SAT. EXT. 2 HEATER ZONE 6	F22	H1210-20	78
I93,7	SAT. EXT. 2 HEATER ZONE 7	F22	H1210-21	78
I93,8	ADAPT. SAT. EXT. 2	F22	H1210-30	79
I93,9	COOLING FAN ZONE 1	F22	M1210-22	79
I93,A	COOLING FAN ZONE 2	F22	M1210-23	79
I93,B	COOLING FAN ZONE 3	F22	M1210-24	79
I93,C	COOLING FAN ZONE 4	F22	M1210-25	79
I93,D	COOLING FAN ZONE 5	F22	M1210-26	79
I93,E	COOLING FAN ZONE 6	F22	M1210-27	79
I93,F	COOLING FAN ZONE 7	F22	M1210-28	79
I94,0	SAT. 2 HEATING FILTER	F23	H1232-02	82
I94,1	SAT. 1 HYDRAULIC PUMP FIR SCREEN CHANGER	F23	M1232-03	82
I94,2	SAT. 2 HYDRAULIC PUMP FIR SCREEN CHANGER	F23	M1232-04	82
I94,3	(FREE)			82
I94,4	HOPPER LOW LEVEL	HOMO DRYER	LSL1104-01	82
I94,5	HOPPER HIGH LEVEL	HOMO DRYER	LSH1104-02	82
I94,6	HOPPER LOW LEVEL	RECLAIM DRYER	LSL1104-03	82
I94,7	HOPPER HIGH LEVEL	RECLAIM DRYER	LSH1104-04	82
I94,8	HOPPER LOW LEVEL	SAT. 1 DRYER	LSL1123-01	83
I94,9	HOPPER HIGH LEVEL	SAT. 1 DRYER	LSH1123-02	83
I94,A	HOPPER LOW LEVEL	SAT. EXT. 1	LSL1124-01	83
I94,B	FREE		LSH1124-02	83
I94,C	HOPPER LOW LEVEL	SAT. 2 DRYER	LSL1123-03	83
I94,D	HOPPER HIGH LEVEL	SAT. 2 DRYER	LSH1123-04	83
I94,E	HOPPER LOW LEVEL	SAT. EXT. 2	LSL1124-03	83
I94,F	FREE		LSH1124-04	83
I95,0	GEAR BOX SAT. EXT. 1 OIL FILTER - HIGH PRESSURE	SAT. 1	DPS1210-37	86
I95,1	GEAR BOX SAT. EXT. 1 OIL FILTER - HIGH PRESSURE	SAT. 1	DPS1210-38	86
I95,2	GEAR BOX SAT. EXT. 2 FLOW SWITCH - LOW	SAT. 2	FSL1210-39	86
I95,3	GEAR BOX SAT. EXT. 2 PRESSURE SWITCH - LOW	SAT. 2	PSL1210-40	86
I95,4	GEAR BOX SAT. EXT. 2 OIL FILTER - HIGH PRESSURE	SAT. 2	DPS1210-41	86
I95,5	GEAR BOX SAT. EXT. 2 OIL FILTER - HIGH PRESSURE	SAT. 2	DPS1210-42	86
I95,6	(FREE)			86
I95,7	FEEDING VALVE OPEN (UNDER MIXING HOPPER)		ZS01114-02	86
I95,8	HYDR. PUMP SAT. 1 - START	SAT. 1		87
I95,9	HYDR. PUMP SAT. 1 - STOP	SAT. 1		87
I95,A	HYDR. PUMP SAT. 2 - START	SAT. 2		87
I95,B	HYDR. PUMP SAT. 2 - STOP	SAT. 2		87
I95,C	HYDR. PUMP EXT. 1 - START	EXT. 1		87
I95,D	HYDR. PUMP EXT. 1 - STOP	EXT. 1		87
I95,E	HYDR. PUMP EXT. 2 - START	EXT. 2		87

I95,F	HYDR. PUMP EXT. 2 - STOP	EXT. 2		87
I96,0	(FREE)			90
I96,1	(FREE)			90
I96,2	FREE			90
I96,3	FREE			90
I96,4	(FREE)			90
I96,5	(FREE)			90
I96,6	(FREE)			90
I96,7	(FREE)			90
I96,8	(FREE)			91
I96,9	(FREE)			91
I96,A	(FREE)			91
I96,B	(FREE)			91
I96,C	(FREE)			91
I96,D	(FREE)			91
I96,E	KLAXON TO F13 OF5,5			91
I96,F	(FREE)			91
I97,0	SYSTEM DEFECT	RECLAIM DRYER		94
I97,1	TEMPERATURE OK	RECLAIM DRYER		94
I97,2	SYSTEM RUNNING	SAT. 1 DRYER		94
I97,3	SYSTEM DEFECT	SAT. 1 DRYER		94
I97,4	TEMPERATURE OK	SAT. 1 DRYER		94
I97,5	SYSTEM RUNNING	SAT. 2 DRYER		94
I97,6	SYSTEM DEFECT	SAT. 2 DRYER		94
I97,7	TEMPERATURE OK	SAT. 2 DRYER		94
I97,8	FREE			95
I97,9	(FREE)			95
I97,A	(FREE)			
I97,B	KLAXON			95
I97,C	MAIN LOADING HOMO OR RECLAIM DRYER LOW LEVEL OR PUMP #4 OL TRIPPED			95
I97,D	RELEASE KLAXON			95
I97,E	FREE			95
I97,F	EMERGENCY STOP			95

F12 I/O LIST

F12\OUTPUT.DOC

I/O WORD	DESCRIPTION	SYMBOL	PAGE # (DRAW')
OW65,3	2ND MELT LINE 1ST PART, CTRL VALVE	TV1240-03	63
OW65,4	2ND MELT LINE 2ND PART, CTRL VALVE	TV1240-04	63
OW65,5	MELT LINE SAT. EXT. 1, CTRL VALVE	TV1245-01	63
OW65,6	MELT LINE SAT. EXT. 2, CTRL VALVE	TV1245-02	63
OW66,3	MAIN AUGUR 2, SPEED REF. (HOMOPOLYMER)	M1106-01	64
OW66,4	MAIN AUGUR 3, SPEED REF. (RECLAIM)	M1106-02	64
OW66,5	MAIN AUGUR 1, SPEED REF. (ADDITIVE)	M1112-01	64
OW66,6	AUGUR #1, SPEED REF. CONAIR		64
OW67,3	AUGUR #2, SPEED REF. CONAIR		65
OW67,4	AUGUR #3, SPEED REF. CONAIR		
OW67,5	AUGUR #4, SPEED REF. CONAIR		
OW67,6	AUGUR #5, SPEED REF. CONAIR		
OW80,3	FREE		67
OW80,4	FREE		67
OW80,5	FREE		67
OW80,6	FREE		67

OA0,0	EXT. 1 INTERLOCK TO F16 F16	B362	97
OA0,1	EXT. 2 INTERLOCK TO F16 F16	B470	97
OA0,2	SAT. 1 INTERLOCK TO F16 F16	B159	97
OA0,3	SAT. 2 INTERLOCK TO F16 F16	B259	97
OA0,4	MELT LINE OIL SKID PUMP INTERLOCK	C1240	97
OA0,5	MELT LINE OIL SKID PUMP START HEATER	C1240	97
OA0,6	MELT LINE OIL SKID INTERLOCK	C1240	97
OA0,7	MELT LINE OIL SKID START/STOP	C1240	97
OA0,8	FREE		97
OA0,9	FREE		97
OA0,A	FREE		97
OA0,B	FREE		98
OA0,C	KLAXON		98
OA0,D	ROTATING LIGHT		98
OA0,E	RELEASE KLAXON		98
OA0,F	RELEASE DEFECT		98
OA1,0	HEATER ZONE 1 EXT. 1 F21	H1200-01	101
OA1,1	HEATER ZONE 1 EXT. 2 F21	H1200-02	101
OA1,2	HEATER ZONE 1 EXT. 3 F21	H1200-03	101
OA1,3	HEATER ZONE 1 EXT. 4 F21	H1200-04	101
OA1,4	COOLING PUMP EXT. 1 F21	M1200-05	101
OA1,5	MIXING SCREW F21	M1114-01	101
OA1,6	ROTARY ARM F21	M1114-02	101
OA1,7	HEATER ZONE 1 EXT. 2 F21	H1200-06	101
OA1,8	HEATER ZONE 2 EXT. 2 F21	H1200-07	102
OA1,9	HEATER ZONE 3 EXT. 2 F21	H1200-08	102
OA1,A	HEATER ZONE 4 EXT. 2 F21	H1200-09	102

OA1,B	COOLING PUMP EXT. 2	F21	M1200-11	102
OA1,C	ADDITIVE VACUUM PUMP	F8	M1107-01	102
OA1,D	SIGNAL TO F13/WATER BATH THAT SEC. EXT. RUNNING			102
OA1,E	MELT LINE 1 ZONE 1	F21	H1200-12	102
OA1,F	MELT LINE 1 ZONE 2	F21	H1200-13	102
OA2,0	SAT. EXT. 1 HEATER Z1	F22	H1210-01	105
OA2,1	SAT. EXT. 1 HEATER Z2	F22	H1210-02	105
OA2,2	SAT. EXT. 1 HEATER Z3	F22	H1210-03	105
OA2,3	SAT. EXT. 1 HEATER Z4	F22	H1210-04	105
OA2,4	SAT. EXT. 1 HEATER Z5	F22	H1210-05	105
OA2,5	SAT. EXT. 1 HEATER Z6	F22	H1210-06	105
OA2,6	SAT. EXT. 1 HEATER Z7	F22	H1210-07	105
OA2,7	ADAPTER SAT. EXT. 1	F22	H1210-29	105
OA2,8	COOLING FAN Z1	F22	M1210-08	106
OA2,9	COOLING FAN Z2	F22	M1210-09	106
OA2,A	COOLING FAN Z3	F22	M1210-10	106
OA2,B	COOLING FAN Z4	F22	M1210-11	106
OA2,C	COOLING FAN Z5	F22	M1210-12	106
OA2,D	COOLING FAN Z6	F22	M1210-13	106
OA2,E	COOLING FAN Z7	F22	M1210-14	106
OA2,F	(FREE)			106
OA3,0	HEATING OF DIVERTER	F23	H1250-01	109
OA3,1	DIE HEATER Z1	F23	H1260-01	109
OA3,2	DIE HEATER Z2	F23	H1260-02	109
OA3,3	DIE HEATER Z3	F23	H1260-03	109
OA3,4	DIE HEATER Z4	F23	H1260-04	109
OA3,5	DIE HEATER Z5	F23	H1260-05	109
OA3,6	DIE HEATER Z6	F23	H1260-06	109
OA3,7	DIE HEATER Z7	F23	H1260-07	109
OA3,8	(FREE)			110
OA3,9	(FREE)			110
OA3,A	(FREE)			110
OA3,B	(FREE)			110
OA3,C	(FREE)			110
OA3,D	STATIC MIXER HEATING	F23	H1251-01	110
OA3,E	STATIC MIXER CONNECTIONS	F23	H1251-02	110
OA3,F	SAT. 1 HEATING FILTER	F23	H1232-01	110
OA4,0	HEATER ZONE 1 EXT. 1	F21	H1200-01	113
OA4,1	HEATER ZONE 2 EXT. 1	F21	H1200-02	113
OA4,2	HEATER ZONE 3 EXT. 1	F21	H1200-03	113
OA4,3	HEATER ZONE 4 EXT. 1	F21	H1200-04	113
OA4,4	HEATER ZONE 1 EXT. 2	F21	H1200-06	113
OA4,5	HEATER ZONE 2 EXT. 2	F21	H1200-07	113
OA4,6	HEATER ZONE 3 EXT. 2	F21	H1200-08	113
OA4,7	HEATER ZONE 4 EXT. 2	F21	H1200-09	113
OA4,8	MELT LINE 1 Z1	F21	H1200-12	114
OA4,9	MELT LINE 1 Z2	F21	H1200-13	114
OA4,A	MELT LINE 1 Z3	F21	H1200-14	114
OA4,B	MELT LINE 1 Z4	F21	H1200-15	114
OA4,C	FILTER ZONE 1	F21	H1230-02	114
OA4,D	FILTER ZONE 1	F21	H1230-03	114
OA4,E	FILTER ZONE 1	F21	H1230-04	114
OA4,F	ADAPTER	F21	H1230-05	114

OA5,0	SAT. EXT. 2 Z1	F22	H1210-15	117
OA5,1	SAT. EXT. 2 Z2	F22	H1210-16	117
OA5,2	SAT. EXT. 2 Z3	F22	H1210-17	117
OA5,3	SAT. EXT. 2 Z4	F22	H1210-18	117
OA5,4	SAT. EXT. 2 Z5	F22	H1210-19	117
OA5,5	SAT. EXT. 2 Z6	F22	H1210-20	117
OA5,6	SAT. EXT. 2 Z7	F22	H1210-21	117
OA5,7	ADAPTER SAT. EXT. 2	F22	H1210-30	117
OA5,8	(FREE)			118
OA5,9	(FREE)			
OA5,A	(FREE)			
OA5,B	(FREE)			
OA5,C	HEATING OF DIVERTER	F23	H1250-01	118
OA5,D	DIE HEATER Z1	F23	H1260-01	118
OA5,E	DIE HEATER Z2	F23	H1260-02	118
OA5,F	DIE HEATER Z3	F23	H1260-03	118
OA6,0	FREE		C1103-01	121
OA6,1	FREE		C1103-02	121
OA6,2	FREE		C1122-01	121
OA6,3	FREE		C1122-02	121
OA6,4	HOMO DRYING HOPPER HI LEVEL TO PCC	4A	LSH1104-02	121
OA6,5	RECLAIM DRYING HOPPER HI LEVEL TO PCC	4A	LSH1104-04	121
OA6,6	SAT. 1 DRYING HOPPER LOW LEVEL TO PCC	4A	LSL1123-01	121
OA6,7	SAT. 1 DRYING HOPPER HI LEVEL TO PCC	4A	LSH1123-02	121
OA6,8	HOPPER LOW LEVEL	SAT. EXT. 1	LSL1124-01	122
OA6,9	FREE		LSH1124-02	122
OA6,A	HOPPER LOW LEVEL	SAT. 2 DRYER	LSL1123-03	122
	TO PCC 4A			
OA6,B	HOPPER HIGH LEVEL	SAT. 2 DRYER	LSH1123-04	122
	TO PCC 4A			
OA6,C	HOPPER LOW LEVEL	SAT. EXT. 2	LSL1124-03	122
	4A			
OA6,D	FREE		LSH1124-04	122
OA6,E	LOW LEVEL	HOMO DRYER	LSL1104-01	122
	TO PCC 4A			
OA6,F	LOW LEVEL	RECLAIM DRYER	LSL1104-03	122
	TO PCC			
OA7,0	FEEDING VALVE OPEN - LIGHT	F29	1.25E+13	125
OA7,1	HIGH LEVEL HOMO SILO - LIGHT	F26	1.25E+16	125
OA7,2	HIGH LEVEL RECLAIM MAT - LIGHT	F26	1.25E+19	125
OA7,3	HIGH LEVEL COPOL. SAT. 1 - LIGHT	F26	1.25E+22	125
OA7,4	HIGH LEVEL COPOL. SAT. 2 - LIGHT	F26	1.25E+25	125
OA7,5	FEEDING ZONE COOLING VALVE	EXT. 1	SV1200.10	125
OA7,6	EXHAUST VALV FOR MAIN EXT.	CONAIR	125Y29	125
	ADDITIVE VACUUM PUMP			
OA7,7	ALARM LIGHT IN CTRL ROOM (EXCEPT LINE #1)			
OA7,8	START	HOMO DRYER	C1103-01	126
OA7,9	STOP	HOMO DRYER	C1103-01	126
OA7,A	START	RECLAIM DRYER	C1103-02	126
OA7,B	STOP	RECLAIM DRYER	C1103-02	126
OA7,C	START	SAT. 1 DRYER	C1122-01	126
OA7,D	STOP	SAT. 1 DRYER	C1122-01	126

OA7,E	START	SAT. 2 DRYER	C1122-02	126
OA7,F	STOP	SAT. 2 DRYER	C1122-02	126
OB0,0	(FREE)			99
OB0,1	DEFECT OF PUMP #4 (MAIN LOADING)			99
OB0,2	FREE			99
OB0,3	START/STOP AUGER 2	HOMO		99
OB0,4	FREE			99
OB0,5	START/STOP AUGER 3	RECLAIM		99
OB0,6	FREE			99
OB0,7	START/STOP AUGER 1	ADDITIVE		99
OB0,8	AUGER MOTOR #1 RUN			100
OB0,9	AUGER MOTOR #2 RUN			100
OB0,A	AUGER MOTOR #3 RUN			100
OB0,B	AUGER MOTOR #4 RUN			100
OB0,C	AUGER MOTOR #5 RUN			100

OB0,D	MIXER MOTOR RUN			100
OB0,E	FREE			100
OB0,F	FREE			100
OB1,0	MELT LINE 1 ZONE 3	F21	H1200-14	103
OB1,1	MELT LINE 1 ZONE 4	F21	H1200-15	103
OB1,2	(FREE)			103
OB1,3	(FREE)			
OB1,4	MOTOR CHANGE FILTER EXT. 1	F21	M1230-01	103
OB1,5	FILTER ZONE 1	F21	H1230-02	103
OB1,6	FILTER ZONE 2	F21	H1230-03	103
OB1,7	FILTER ZONE 3	F21	H1230-04	103
OB1,8	ADAPTER	F21	H1230-05	104
OB1,9	(FREE)			104
OB1,A	(FREE)			
OB1,B	EXT. 2 SCREEN CHANGER	F21	M1231-01	104
OB1,C	FILTER ZONE 1	F21	H1231-02	104
OB1,D	FILTER ZONE 2	F21	H1231-03	104
OB1,E	FILTER ZONE 3	F21	H1231-04	104
OB1,F	ADAPTER	F21	H1231-05	104
OB2,0	(FREE)			107
OB2,1	SAT. EXT. 2 HEATER Z1	F22	H1210-15	107
OB2,2	SAT. EXT. 2 HEATER Z2	F22	H1210-16	107
OB2,3	SAT. EXT. 2 HEATER Z3	F22	H1210-17	107
OB2,4	SAT. EXT. 2 HEATER Z4	F22	H1210-18	107
OB2,5	SAT. EXT. 2 HEATER Z5	F22	H1210-19	107
OB2,6	SAT. EXT. 2 HEATER Z6	F22	H1210-20	107
OB2,7	SAT. EXT. 2 HEATER Z7	F22	H1210-21	107
OB2,8	ADAPTER SAT. EXT. 2	F22	H1210-30	108
OB2,9	COOLING FAN Z1	F22	M1210-22	108
OB2,A	COOLING FAN Z2	F22	M1210-23	108
OB2,B	COOLING FAN Z3	F22	M1210-24	108
OB2,C	COOLING FAN Z4	F22	M1210-25	108
OB2,D	COOLING FAN Z5	F22	M1210-26	108
OB2,E	COOLING FAN Z6	F22	M1210-27	108

OB2,F	COOLING FAN Z7	F22	M1210-28	108
OB3,0	SAT. 2 HEATING FILTER	F23	H1232-32	111
OB3,1	HYDRAULIC PUMP SAT. 1 SCREEN CHANGER	F23	M1232-03	111
OB3,2	HYDRAULIC PUMP SAT. 2 SCREEN CHANGER	F23	M1232-04	111
OB3,3	FREE			
OB3,4	(FREE)			111
OB3,5	(FREE)			111
OB3,6	#1 HOPPER VACUUM VALVE "1" → VACUUM	CONAIR		
OB3,7	#1 HOPPER DUMP VALVE "1" → OPEN	CONAIR		
OB3,8	#2 HOPPER VACUUM VALVE	CONAIR		

OB3,9	#2 HOPPER DUMP VALVE	CONAIR		
OB3,A	#3 HOPPER VACUUM VALVE	CONAIR		
OB3,B	#3 HOPPER DUMP VALVE	CONAIR		
OB3,C	#4 HOPPER VACUUM VALVE	CONAIR		
OB3,D	#4 HOPPER DUMP VALVE	CONAIR		
OB3,E	#5 HOPPER VACUUM VALVE	CONAIR		
OB3,F	#5 HOPPER DUMP VALVE	CONAIR		
OB4,0	FILTER ZONE 1	F21	H1231-02	115
OB4,1	FILTER ZONE 2	F21	H1231-03	115
OB4,2	FILTER ZONE 3	F21	H1231-04	115
OB4,3	ADAPTER	F21	H1231-05	115
OB4,4	(FREE)			115
OB4,5	(FREE)			
OB4,6				115
OB4,7	(FREE)			115
OB4,8	SAT. EXT. 1 Z1	F22	H1210-01	116
OB4,9	SAT. EXT. 1 Z2	F22	H1210-02	116
OB4,A	SAT. EXT. 1 Z3	F22	H1210-03	116
OB4,B	SAT. EXT. 1 Z4	F22	H1210-04	116
OB4,C	SAT. EXT. 1 Z5	F22	H1210-05	116
OB4,D	SAT. EXT. 1 Z6	F22	H1210-06	116
OB4,E	SAT. EXT. 1 Z7	F22	H1210-07	116
OB4,F	ADAPTER SAT. EXT. 1	F22	H1210-29	116
OB5,0	DIE HEATER Z4	F23	H1260-04	119
OB5,1	DIE HEATER Z5	F23	H1260-05	119
OB5,2	DIE HEATER Z6	F23	H1260-06	119
OB5,3	DIE HEATER Z7	F23	H1260-07	119
OB5,4	STATIC MIXER CONNECTIONS	F23	H1251-01	119
OB5,5	STATIC MIXER CONNECTIONS	F23	H1251-02	119
OB5,6	SAT. 1 HEATING FILTER	F23	H1232-01	119
OB5,7	SAT. 2 HEATING FILTER	F23	H1232-02	119
OB5,8	(FREE)			120
OB5,9	(FREE)			120
OB5,A	(FREE)			120
OB5,B	(FREE)			120
OB5,C	(FREE)			120
OB5,D	(FREE)			120

OB5,E	(FREE)		120
OB5,F	(FREE)		120
OB6,0	(FREE)		123
OB6,1	(FREE)		123
OB6,2	(FREE)		123
OB6,3	(FREE)		123
OB6,4	(FREE)		123
OB6,5	(FREE)		123
OB6,6	(FREE)		123
OB6,7	(FREE)		123
OB6,8	(FREE)		124
OB6,9	(FREE)		124
OB6,A	(FREE)		124
OB6,B	(FREE)		124
OB6,C	(FREE)		124
OB6,D	(FREE)		124
OB6,E	(FREE)		124
OB6,F	(FREE)		124
OB7,0	FEEDING VALVE	SV1114-01	127
OB7,1	ADDITIVE VACUUM PUMP FILTER RIGHT BAG → OPEN	SV10	127
OB7,2	2ND MELT LINE 1 PART	SV1240-03	127
OB7,3	2ND MELT LINE 2 PART	SV1240-04	127
OB7,4	MELT LINE SAT. EXT. 1	SV1245-01	127
OB7,5	MELT LINE SAT. EXT. 2	SV1245-02	127
OB7,6	EXT. 1 FEEDING ZONE COOLING	SV1200-00	127
OB7,7	EXT. 1 Z1 COOLING	SV1200-01	127
OB7,8	EXT. 1 Z2 COOLING	SV1200-02	128
OB7,9	EXT. 1 Z3 COOLING	SV1200-03	128
OB7,A	EXT. 1 Z4 COOLING	SV1200-04	128
OB7,B	ADDITIVE VACUUM PUMP FILTER LEFT BAG → OPEN	SV11	128
OB7,C	COOLING EXT. 2 Z1	SV1200-06	128
OB7,D	COOLING EXT. 2 Z2	SV1200-07	128
OB7,E	COOLING EXT. 2 Z3	SV1200-08	128
OB7,F	COOLING EXT. 2 Z4	SV1200-09	128

F12 I/O LIST

F12\INPUTWD.DOC

I/O WORD	DESCRIPTION	SYMBOL	PAGE # (DRAW')
IW01,3	MAIN EXT. ZONE 1, TEMP. MEASUREMENT	TE1200-01	32
IW01,4	MAIN EXT. ZONE 2, TEMP. MEASUREMENT	TE1200-02	32
IW01,5	MAIN EXT. ZONE 3, TEMP. MEASUREMENT	TE1200-03	32
IW01,6	MAIN EXT. ZONE 4, TEMP. MEASUREMENT	TE1200-04	32
IW02,3	FILTER ADAPTATOR, TEMP. MEASUREMENT	TE1230-05	33
IW02,4	FILTER HEATER 1, TEMP. MEASUREMENT	TE1230-02	33
IW02,5	FILTER HEATER 2, TEMP. MEASUREMENT	TE1230-03	33
IW02,6	FILTER HEATER 3, TEMP. MEASUREMENT	TE1230-04	33
IW03,3	1ST MELT LINE ZONE 1, TEMP. MEASUREMENT	TE1200-12	34
IW03,4	1ST MELT LINE ZONE 2, TEMP. MEASUREMENT	TE1200-13	34
IW03,5	1ST MELT LINE ZONE 3, TEMP. MEASUREMENT	TE1200-14	34
IW03,6	1ST MELT LINE ZONE 4, TEMP. MEASUREMENT	TE1200-15	34
IW04,3	2ND EXT. ZONE 1, TEMP. MEASUREMENT	TE1200-06	35
IW04,4	2ND EXT. ZONE 2, TEMP. MEASUREMENT	TE1200-07	35
IW04,5	2ND EXT. ZONE 3, TEMP. MEASUREMENT	TE1200-08	35
IW04,6	2ND EXT. ZONE 4, TEMP. MEASUREMENT	TE1200-09	35
IW05,3	FILTER ADAPTATOR, TEMP. MEASUREMENT	TE1231-05	36
IW05,4	FILTER HEATER 1, TEMP. MEASUREMENT	TE1231-02	36
IW05,5	FILTER HEATER 2, TEMP. MEASUREMENT	TE1231-03	36
IW05,6	FILTER HEATER 3, TEMP. MEASUREMENT	TE1231-04	36
IW06,3	STATIC MIXER HEATER, TEMP. MEASUREMENT	TE1251-01	37
IW06,4	STATIC MIXER CONNECT. TEMP. MEASUREMENT	TE1251-02	37
IW06,5	HEATING OF DIVERTER, TEMP. MEASUREMENT	TE1250-01	37
IW06,6	DIE ZONE 1, TEMP. MEASUREMENT	TE1260-01	37
IW07,3	(FREE)		
IW07,4	(FREE)		
IW07,5	(FREE)		
IW07,6	(FREE)		
IW40,3	DIE ZONE 6, TEMP. MEASUREMENT	TE1260-06	40
IW40,4	DIE ZONE 7, TEMP. MEASUREMENT	TE1260-07	40
IW40,5	2ND MELT LINE - 1 PART, TEMP. MEASUREMENT	TE1240-03	40
IW40,6	2ND MELT LINE - 2 PART, TEMP. MEASUREMENT	TE1240-04	40
IW41,3	DIE ZONE 2, TEMP. MEASUREMENT	TE1260-02	41
IW41,4	DIE ZONE 3, TEMP. MEASUREMENT	TE1260-03	41
IW41,5	DIE ZONE 4, TEMP. MEASUREMENT	TE1260-04	41
IW41,6	DIE ZONE 5, TEMP. MEASUREMENT	TE1260-05	41
IW42,3	SAT. EXT. 1 ZONE 1, TEMP. MEASUREMENT	TE1210-01	42
IW42,4	SAT. EXT. 1 ZONE 2, TEMP. MEASUREMENT	TE1210-02	42
IW42,5	SAT. EXT. 1 ZONE 3, TEMP. MEASUREMENT	TE1210-03	42
IW42,6	SAT. EXT. 1 ZONE 4, TEMP. MEASUREMENT	TE1210-04	42
IW43,3	SAT. EXT. 1 ZONE 5, TEMP. MEASUREMENT	TE1210-05	43
IW43,4	SAT. EXT. 1 ZONE 6, TEMP. MEASUREMENT	TE1210-06	43
IW43,5	SAT. EXT. 1 ZONE 7, TEMP. MEASUREMENT	TE1210-07	43

IW43,6	SAT. EXT. 1 ADAPT., TEMP. MEASUREMENT	TE1210-29	43
IW44,3	SAT. EXT. 1 FILTER, TEMP. MEASUREMENT	TE1232-01	44
IW44,4	SAT. EXT. 1 MELT LINE, TEMP. MEASUREMENT	TE1245-01	44
IW44,5	(FREE)		44
IW44,6	(FREE)		44
IW45,3	SAT. EXT. 2 ZONE 1, TEMP. MEASUREMENT	TE1210-15	45
IW45,4	SAT. EXT. 2 ZONE 2, TEMP. MEASUREMENT	TE1210-16	45
IW45,5	SAT. EXT. 2 ZONE 3, TEMP. MEASUREMENT	TE1210-17	45
IW45,6	SAT. EXT. 2 ZONE 4, TEMP. MEASUREMENT	TE1210-18	45
IW46,3	SAT. EXT. 2 ZONE 5, TEMP. MEASUREMENT	TE1210-19	46
IW46,4	SAT. EXT. 2 ZONE 6, TEMP. MEASUREMENT	TE1210-20	46
IW46,5	SAT. EXT. 2 ZONE 7, TEMP. MEASUREMENT	TE1210-21	46
IW46,6	SAT. EXT. 2 ADAPT., TEMP. MEASUREMENT	TE1210-30	46
IW47,3	SAT. EXT. 2 FILTER, TEMP. MEASUREMENT	TE1232-02	47
IW47,4	SAT. EXT. 2 MELT LINE, TEMP. MEASUREMENT	TE1245-02	47
IW47,5	(FREE)		47
IW47,6	(FREE)		47
IW62,3	MELT TEMP. AFTER PRIMARY EXT. T510 IF IW62,2,0 = 0	TE1200-16	57
IW62,3	MELT PRESS. AFTER SECOND EXT. P514 IF IW62,2,0 = 1	PE1200-20	58
IW62,4	MELT PRESS. AFTER PRIMARY EXT. P511 IF IW62,2,1 = 0	PE1200-17	57
IW62,4	MAIN EXT. MELT TEMP. BEFORE DIE T515 IF IW62,2,1 = 1	TE1250-02	58
IW62,5	MELT PRESS. BEFORE SECOND EXT. P512 IF IW62,2,2 = 0	PE1200-18	57
IW62,5	MELT PRESS. BEFORE DIE P516 IF IW62,2,2 = 1	TE1250-03	58
IW62,6	MELT TEMP. AFTER SECOND EXT. T513 IF IW62,2,3 = 0	TE1200-19	57
IW62,6	WEIGHING OF DOSING HOPPER R200 IF IW62,2,3 = 1	WT1115	58
IW63,3	MELT PRESS. AFTER SAT. EXT. 1 P501 IF IW63,3.0 = 0	PE1210-31	59
IW63,3	MELT TEMP. BEFORE DIE T502 IF IW63,3.0 = 1	TE1235-01	60
IW63,4	MELT TEMP. AFTER SAT. EXT. 1 T500 IF IW63,3.1 = 0	TE1210-32	59
IW63,4	MELT PRESS. BEFORE DIE P503 IF IW63,3.1 = 1	PE1235-03	60
IW63,5	MELT PRESS. AFTER SAT. EXT. 2 P505 IF IW63,3.2 = 0	PE1210-33	59
IW63,5	MELT TEMP. BEFORE DIE T506 IF IW63,3.2 = 1	TE1235-02	60
IW63,6	MELT TEMP. AFTER SAT. EXT. 2 T504 IF IW63,3.3 = 0	TE1210-34	59
IW63,6	MELT PRESS. BEFORE DIE P507 IF IW63,3.3 = 1	PE1235-04	60

IW64,3	HOPPER #1 WEIGH MEASURE	CONAIR	61
--------	-------------------------	--------	----

	IF IW64,3,0 = 0		
IW64,3	HOPPER #5 WEIGH MEASURE	CONAIR	62
	IF IW64,3,0 = 1		
IW64,4	HOPPER #2 WEIGH MEASURE	CONAIR	61
	IF IW64,3,0 = 0		
IW64,5	HOPPER #3 WEIGH MEASURE	CONAIR	61
	IF IW64,3,0 = 0		
IW64,6	HOPPER #4 WEIGH MEASURE	CONAIR	61
	IF IW64,3,0 = 0		

TEMPERATURE REGULATOR 50 WORD

F12\WORD4.DOC

	W100XX
00 [50]	ACTUAL VALUE (MEASURE)
01 [51]	SETPOINT
02 [52]	FREE
03 [53]	ALARM H
04 [54]	ALARM VALUE ABOVE SETPOINT (H+)
05 [55]	ALARM VALUE ABOVE SETPOINT (L-)
06 [56]	ALARM L
07 [57]	10
08 [58]	REAL OUTPUT
09 [59]	7, GENERAL GAIN
10 [60]	I
11 [61]	800, THRESHOLD INHIBIT INTEGRAL
12 [62]	D
13 [63]	P
14 [64]	1, OUTPUT GAIN
15 [65]	0
16 [66]	300, RAMP INCREMENT
17 [67]	MEASURE VALUE FOR LAST TIME (T-1)
18 [68]	I VALUE, AFTER CALCULATION
19 [69]	I VALUE, AFTER CALCULATION
20 [70]	ANALOG OUTPUT
21 [71]	STATUS LOOP
22 [72]	OUTPUT (MANUAL)
23 [73]	OUTPUT COUNTER
24 [74]	OUTPUT -+ 10,000 PTS
25 [75]	OUTPUT -+ 10,000 PTS
26 [76]	RESERVE CONTROL LOOP
27 [77]	TIME SAMPLE FOR DERIVATIVE
28 [78]	ERROR, THE DIFFERENCE BTWN SETPOINT AND ACTUAL VALUE
29 [79]	ERROR, THE DIFFERENCE BTWN SETPOINT AND ACTUAL VALUE
30 [80]	OUTPUT IN PERCENT (%)
31 [81]	FREE
32 [82]	D VALUE, AFTER CALCULATION
33 [83]	D VALUE, AFTER CALCULATION
34 [84]	P GAIN, AFTER CALCULATION
35 [85]	P GAIN, AFTER CALCULATION
36 [86]	PID ACTION
37 [87]	PID ACTION
38 [88]	FREE
39 [89]	FREE
40 [90]	FREE
41 [91]	FREE
42 [92]	FREE
43 [93]	COOLING OUTPUT
44 [94]	HEATER OUTPUT
45 [95]	COUNTER COOLING
46 [96]	COUNTER HEATING
47 [97]	30, GAIN COOLING
48 [98]	30, GAIN HEATING
49 [99]	

**21,0 **71,0	AUTO/MANU (MANU -> "1")
**21,1 **71,1	TEMPERATURE CONTROL LOCKED
**21,2 **71,2	ALARM H+ OR L- (TEMP OUT OF RANGE)
**21,3 **71,3	ALARM H
**21,4 **71,4	ALARM L
**21,5 **71,5	DEFECT MEASURE
21,6 **71,6	ALL ALARM (21, 2+**21, 4+**21, 5)
**21,7 **71,7	FAULT CONTROL LOOP
**21,8 **71,8	HEATING => ON
**21,9 **71,9	SAMPLE TIME SELECT
**21,A **71,A	START CONTROL LOOP
**21,B **71,B	REVERSE CONTROL LOOP
**21,C **71,C	COOLING VALVE => ON
**21,D **71,D	BIT OUTPUT 100; -100
**21,E **71,E	
**21,F **71,F	TEMPERATURE NOT DEFECT (O.K.)

F12_TIMER.DOC

F12\TIMER.DOC

T 0	TIMER FOR SAT. EXT. 1 LOW LEVEL ALARM
T 1	TIMER FOR SAT. EXT. 1 DPSH
T 2	TIMER FOR SAT. EXT. 1 DPSH
T 3	TIMER FOR SAT. EXT. 2 DPSH
T 4	TIMER FOR SAT. EXT. 2 DPSH
T 5	TIMER FOR SAT. EXT. 1 LOW PRESSURE ALARM
T 6	TIMER FOR SAT. EXT. 1 FSL
T 7	TIMER FOR SAT. EXT. 2 FSL
T 8	TIMER FOR SAT. EXT. 2 PSL
T 9	TIMER FOR MAIN EXT. 1 DPSH
T 10	TIMER FOR MAIN EXT. 1 DPSH
T 11	TIMER FOR MAIN EXT. 1 FSL
T 12	TIMER FOR MAIN EXT. 1 PSL
T 13	TIMER FOR SAT. EXT. 1 LSL
T 14	TIMER FOR MAIN EXT. 1 FSL
T 15	TIMER FOR MAIN EXT. 2 FSL
T 16	TIMER FOR MAIN EXT. 2 PSL
T 17	TIMER FOR MAIN EXT. 2 DPSH
T 18	TIMER FOR MAIN EXT. 2 DPSH
T 19	TIMER FOR MAIN EXT. 1 FSL
T 20	TIMER FOR MAIN EXT. 1 SV
T 21	TIMER FOR MAIN EXT. 1 LSL
T 22	TIMER FOR FSL
T 23	TIMER FOR DUMP VALVE #1 OPEN (CONAIR BLENDER)
T 24	TIMER FOR DUMP VALVE #2 OPEN (CONAIR BLENDER)
T 25	TIMER FOR DUMP VALVE #3 OPEN (CONAIR BLENDER)
T 26	TIMER FOR DUMP VALVE #4 OPEN (CONAIR BLENDER)
T 27	TIMER FOR DUMP VALVE #5 OPEN (CONAIR BLENDER)
T 28	
T 29	
T 30	TIMER FOR CONFIGURATION AEM811
T 31	TIMER FOR CONFIGURATION AEM811
T 32	TIMER FOR CONFIGURATION AEM811
T 33	TIMER FOR VACUUM VALVE #1 OPEN (CONAIR BLENDER)
T 34	TIMER FOR VACUUM VALVE #2 OPEN (CONAIR BLENDER)
T 35	TIMER FOR VACUUM VALVE #3 OPEN (CONAIR BLENDER)
T 36	TIMER FOR VACUUM VALVE #4 OPEN (CONAIR BLENDER)
T 37	TIMER FOR VACUUM VALVE #5 OPEN (CONAIR BLENDER)
T 38	
T 39	
T 40	
T 41	
T 42	SAT. EXT. 1 HOPPER LOW LEVEL (LSL1124.03)
T 43	TIMER FOR CLEAN LEFT BAG FILTER FOR HOPPER #1 (CONAIR BLENDER)
T 44	TIMER FOR CLEAN LEFT BAG FILTER FOR HOPPER #2 (CONAIR BLENDER)
T 45	TIMER FOR CLEAN LEFT BAG FILTER FOR HOPPER #3 (CONAIR BLENDER)
T 46	TIMER FOR CLEAN LEFT BAG FILTER FOR HOPPER #4 (CONAIR BLENDER)
T 47	TIMER FOR CLEAN LEFT BAG FILTER FOR HOPPER #5 (CONAIR BLENDER)
T 48	
T 49	
T 50	TIMER START SAT. EXT. 1 EQUIP
T 51	TIMER START SAT. EXT. 1 FILTER
T 52	TIMER START SAT. EXT. 1 MELT LINE

T 53	TIMER START SAT. EXT. 2 EQUIP
T 54	TIMER START SAT. EXT. 2 FILTER
T 55	TIMER START SAT. EXT. 2 MELT LINE
T 56	TIMER MAIN EXT. 1 EQUIP
T 57	TIMER MAIN EXT. 1 FILTER
T 58	TIMER MAIN EXT. 1 MELT LINE
T 59	TIMER MAIN EXT. 2 EQUIP
T 60	TIMER MAIN EXT. 2 FILTER
T 61	TIMER MAIN EXT. 2 MELT LINE
T 62	TIMER START DIE
T 63	TIMER START BOILER FOR MAIN MELT LINE AND SAT. 1 & 2 MELT LINE
T 64	
T 65	
T 66	MAIN EXT. 1 NOT RUNNING CHECKING TIME
T 67	
T 68	
T 69	
T 70	
T 71	
T 72	COPOLYMER DRYER HIGH LEVEL (LSH1123.02) DELAY TIME
T 73	
T 74	
T 75	
T 76	HOMO DRYER HIGH LEVEL (LSH1104.02) DELAY TIME
T 77	RECLAIM DRYER HIGH LEVEL (LSH1104.04) DELAY TIME
T 78	
T 79	
T 80	ALARM H[501] DELAY TIME
T 81	ALARM H[503] DELAY TIME
T 82	ALARM H[505] DELAY TIME
T 83	ALARM H[507] DELAY TIME
T 84	ALARM H[511] DELAY TIME
T 85	ALARM H[512] DELAY TIME
T 86	ALARM H[514] DELAY TIME
T 87	ALARM H[516] DELAY TIME
T 88	DELAY MOTOR O/L ALARM HOPPER #1 (CONAIR BLENDER)
T 89	DELAY MOTOR O/L ALARM HOPPER #2 (CONAIR BLENDER)
T 90	DELAY MOTOR O/L ALARM HOPPER #3 (CONAIR BLENDER)
T 91	DELAY MOTOR O/L ALARM HOPPER #4 (CONAIR BLENDER)
T 92	DELAY MOTOR O/L ALARM HOPPER #5 (CONAIR BLENDER)
T 93	
T 94	
T 95	
T 96	
T 97	
T 98	
T 99	
T 100	
T 101	
T 102	
T 103	
T 104	
T 105	TIMER FOR HOPPER #1 CALIBRATION (CONAIR BLENDER)
T 106	TIMER FOR HOPPER #2 CALIBRATION (CONAIR BLENDER)
T 107	TIMER FOR HOPPER #3 CALIBRATION (CONAIR BLENDER)

T 108	TIMER FOR HOPPER #4 CALIBRATION (CONAIR BLENDER)
T 109	TIMER FOR HOPPER #5 CALIBRATION (CONAIR BLENDER)
T 110	TIMER FOR UNLOADING RESIN FROM GAYLORD (CONAIR BLENDER)
T 111	TIME FROM LOW TO HIGH LEVEL WHILE RUN MAX. SPEED (CONAIR)
T 112	TIME FROM HIGH TO LOW LEVEL WHILE ALL AUGUR STOP (CONAIR)
T 113	T111/2 (CONAIR)
T 114	TIMER FOR STOPPING AUGUR (CONAIR)
T 115	TIMER FOR CLEAN RIGHT BAG FILTER (CONAIR)
T 116	
T 117	
T 118	
T 119	
T 120	
T 121	
T 122	
T 123	
T 124	
T 125	
T 126	
T 127	
T 128	

NO	CONTENTS
W 0	CONFIGURATION OF SCM2222
W 1	CONFIGURATION OF SCM2222
W 2	CONFIGURATION OF SCM2222
W 3	CONFIGURATION OF SCM2222
W 4	CONFIGURATION OF SCM2222
W 5	CONFIGURATION OF SCM2222
W 6	CONFIGURATION OF SCM2222
W 7	CONFIGURATION OF SCM2222
W 8	CONFIGURATION OF SCM2222
W 9	CONFIGURATION OF SCM2222
W 10	CONFIGURATION OF SCM2222
W 11	CONFIGURATION OF SCM2222
W 12	CONFIGURATION OF SCM2222
W 13	CONFIGURATION OF SCM2222
W 14	CONFIGURATION OF SCM2222
W 15	CONFIGURATION OF SCM2222
W 16	CONFIGURATION OF SCM2222
W 17	CONFIGURATION OF SCM2222
W 18	CONFIGURATION OF SCM2222
W 19	CONFIGURATION OF SCM2222
W 20	CONFIGURATION OF SCM2222
W 21	CONFIGURATION OF SCM2222
W 22	CONFIGURATION OF SCM2222
W 23	CONFIGURATION OF SCM2222
W 24	CONFIGURATION OF SCM2222
W 25	CONFIGURATION OF SCM2222
W 26	CONFIGURATION OF SCM2222
W 27	CONFIGURATION OF SCM2222
W 28	SYSTEM OPERATING TIME
W 29	
W 30	
W 31	
W 32	
W 33	
W 34	
W 35	
W 36	
W 37	
W 38	
W 39	
W 40	
W 41	
W 42	
W 43	
W 44	
W 45	
W 46	
W 47	
W 48	
W 49	

W 50	
W 51	
W 52	
W 53	
W 54	
W 55	
W 56	
W 57	
W 58	
W 59	
W 60	
W 61	
W 62	
W 63	
W 64	
W 65	
W 66	
W 67	
W 68	
W 69	
W 70	
W 71	
W 72	
W 73	
W 74	
W 75	
W 76	
W 77	
W 78	
W 79	
W 80	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 81	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 82	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 83	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 84	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 85	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 86	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 87	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 88	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 89	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 90	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 91	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 92	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 93	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 94	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 95	CONFIGURATION OF SCM2222 CARD MODBUS SR0
W 96	
W 97	FREE
W 98	
W 99	
W 100	READ SCM2222, COPY FROM W110
W 101	

W 102	
W 103	
W 104	INDEX FOR MODBUS IN SR0
W 105	
W 106	WORD FOR READ CODE
W 107	WORD FOR READ CODE
W 108	FREE
W 109	FREE
W 110	WORD FOR READ CODE
W 111	WORD FOR READ CODE
W 112	WORD FOR READ CODE
W 113	WORD FOR READ CODE
W 114	WORD FOR READ CODE
W 115	WORD FOR READ CODE
W 116	FREE
W 117	FREE
W 118	FREE
W 119	FREE
W 120	FREE
W 121	FREE
W 122	FREE
W 123	FREE
W 124	FREE
W 125	FREE
W 126	FREE
W 127	FREE
W 128	FREE
W 129	FREE
W 130	FREE
W 131	FREE
W 132	FREE
W 133	FREE
W 134	FREE
W 135	FREE
W 136	FREE
W 137	FREE
W 138	FREE
W 139	FREE
W 140	FREE
W 141	FREE
W 142	FREE
W 143	FREE
W 144	FREE
W 145	FREE
W 146	FREE
W 147	FREE
W 148	FREE
W 149	FREE
W 150	FREE
W 151	FREE
W 152	FREE
W 153	FREE

W 154	FREE
W 155	FREE
W 156	FREE
W 157	FREE
W 158	FREE
W 159	FREE
W 160	FREE
W 161	FREE
W 162	FREE
W 163	FREE
W 164	FREE
W 165	FREE
W 166	FREE
W 167	FREE
W 168	FREE
W 169	FREE
W 170	FREE
W 171	FREE
W 172	FREE
W 173	WORD FOR READ CODE
W 174	WORD FOR READ CODE
W 175	WORD FOR READ CODE
W 176	WORD FOR READ CODE
W 177	WORD FOR READ CODE
W 178	WORD FOR READ CODE
W 179	WORD FOR READ CODE
W 180	WORD FOR READ CODE
W 181	WORD FOR READ CODE
W 182	WORD FOR READ CODE
W 183	WORD FOR READ CODE
W 184	WORD FOR READ CODE
W 185	WORD FOR READ CODE
W 186	WORD FOR READ CODE
W 187	WORD FOR READ CODE
W 188	WORD FOR READ CODE
W 189	WORD FOR READ CODE
W 190	WORD FOR READ CODE
W 191	WORD FOR READ CODE
W 192	WORD FOR READ CODE
W 193	WORD FOR READ CODE
W 194	WORD FOR READ CODE
W 195	WORD FOR READ CODE
W 196	WORD FOR READ CODE
W 197	WORD FOR READ CODE
W 198	WORD FOR READ CODE
W 199	WORD FOR READ CODE
W 200	WORD FOR READ CODE
W 201	WORD FOR READ CODE
W 202	WORD FOR READ CODE
W 203	WORD FOR READ CODE
W 204	WORD FOR READ CODE
W 205	WORD FOR READ CODE

W 206	WORD FOR READ CODE
W 207	WORD FOR READ CODE
W 208	WORD FOR READ CODE
W 209	WORD FOR READ CODE
W 210	WORD FOR READ CODE SR1 L1+1
W 211	FREE
W 212	FREE
W 213	FREE
W 214	FREE
W 215	FREE
W 216	FREE
W 217	FREE
W 218	FREE
W 219	FREE
W 220	FREE
W 221	FREE
W 222	FREE
W 223	FREE
W 224	FREE
W 225	FREE
W 226	FREE
W 227	FREE
W 228	FREE
W 229	FREE
W 230	FREE
W 231	FREE
W 232	FREE
W 233	FREE
W 234	FREE
W 235	FREE
W 236	FREE
W 237	FREE
W 238	FREE
W 239	FREE
W 240	FREE
W 241	FREE
W 242	FREE
W 243	FREE
W 244	FREE
W 245	FREE
W 246	FREE
W 247	FREE
W 248	FREE
W 249	FREE
W 250	FREE
W 251	FREE
W 252	FREE
W 253	FREE
W 254	FREE
W 255	FREE
W 256	FREE
W 257	FREE

W 258	FREE
W 259	FREE
W 260	FREE
W 261	FREE
W 262	FREE
W 263	FREE
W 264	FREE
W 265	FREE
W 266	FREE
W 267	FREE
W 268	FREE
W 269	FREE
W 270	FREE
W 271	FREE
W 272	FREE
W 273	FREE
W 274	FREE
W 275	FREE
W 276	FREE
W 277	FREE
W 278	FREE
W 279	FREE
W 280	FREE
W 281	FREE
W 282	FREE
W 283	FREE
W 284	FREE
W 285	FREE
W 286	FREE
W 287	FREE
W 288	WORD FOR READ CODE
W 289	WORD FOR READ CODE
W 290	WORD FOR READ CODE
W 291	WORD FOR READ CODE
W 292	WORD FOR READ CODE
W 293	WORD FOR READ CODE
W 294	WORD FOR READ CODE
W 295	WORD FOR READ CODE
W 296	WORD FOR READ CODE
W 297	WORD FOR READ CODE
W 298	WORD FOR READ CODE
W 299	WORD FOR READ CODE
W 300	WORD FOR READ CODE
W 301	WORD FOR READ CODE
W 302	WORD FOR READ CODE
W 303	WORD FOR READ CODE
W 304	WORD FOR READ CODE
W 305	WORD FOR READ CODE
W 306	WORD FOR READ CODE
W 307	WORD FOR READ CODE
W 308	WORD FOR READ CODE
W 309	WORD FOR READ CODE

W 400	COUNTER FOR INDEX USED IN AUX0,SR0
W 401	COUNTER FOR INDEX USED IN AUX0,SR0
W 402	COUNTER FOR MODBUS
W 403	FREE
W 404	FREE
W 405	FREE
W 406	FREE
W 407	FREE
W 408	FREE
W 409	FREE
W 410	FREE
W 411	FREE
W 412	FREE
W 413	FREE
W 414	FREE
W 415	FREE
W 416	FREE
W 417	FREE
W 418	FREE
W 419	FREE
W 420	SEE "WORD BIT"
W 421	SEE "WORD BIT"
W 422	SEE "WORD BIT"
W 423	SEE "WORD BIT"
W 424	FREE
W 425	MASK '0000 0000 1111 1111'
W 426	FREE
W 427	FREE
W 428	FREE
W 429	FREE
W 430	R300, R301
W 431	R300, R301
W 432	R302, R303
W 433	R302, R303
W 434	R304, R305
W 435	R304, R305
W 436	R306, R307
W 437	R306, R307
W 438	R308, R309
W 439	R308, R309
W 440	R310, R311
W 441	R310, R311
W 442	R312, R313
W 443	R312, R313
W 444	R314, R315
W 445	R314, R315
W 446	R316, R317
W 447	R316, R317
W 448	R318, R319
W 449	R318, R319
W 450	R320, R321

W 451	R320, R321
W 452	R322, R323
W 453	R322, R323
W 454	R324, R325
W 455	R324, R325
W 456	R326, R327
W 457	R326, R327
W 458	R330, R331
W 459	R330, R331
W 460	R332, R333
W 461	R332, R333
W 462	R340, R341
W 463	R340, R341
W 464	R342, R343
W 465	R342, R343
W 466	R344, R345
W 467	R344, R345
W 468	R346, R347
W 469	R346, R347
W 470	R348, R349
W 471	R348, R349
W 472	R350, R351
W 473	R350, R351
W 474	R352, R353
W 475	R352, R353
W 476	R354, R355
W 477	R354, R355
W 478	R356, R357
W 479	R356, R357
W 480	R358, R359
W 481	R358, R359
W 482	R360, R361
W 483	R360, R361
W 484	FREE
W 485	FREE
W 486	FREE
W 487	FREE
W 488	FREE
W 489	FREE
W 490	FREE
W 491	FREE
W 492	FREE
W 493	FREE
W 494	FREE
W 495	FREE
W 496	FREE
W 497	FREE
W 498	FREE
W 499	FREE
W 500	SEE "WORD BIT"
W 501	SEE "WORD BIT"
W 502	SEE "WORD BIT"

W 503	SEE "WORD BIT"
W 504	SEE "WORD BIT"
W 505	SEE "WORD BIT"
W 506	SEE "WORD BIT"
W 507	SEE "WORD BIT"
W 508	SEE "WORD BIT"
W 509	SEE "WORD BIT"
W 510	SEE "WORD BIT"
W 511	SEE "WORD BIT"
W 512	SEE "WORD BIT"
W 513	SEE "WORD BIT"
W 514	SEE "WORD BIT"
W 515	SEE "WORD BIT"
W 516	SEE "WORD BIT"
W 517	SEE "WORD BIT"
W 518	SEE "WORD BIT"
W 519	SEE "WORD BIT"
W 520	SEE "WORD BIT"
W 521	SEE "WORD BIT"
W 522	SEE "WORD BIT"
W 523	SEE "WORD BIT"
W 524	SEE "WORD BIT"
W 525	SEE "WORD BIT"
W 526	SEE "WORD BIT"
W 527	SEE "WORD BIT"
W 528	SEE "WORD BIT"
W 529	SEE "WORD BIT"
W 530	SEE "WORD BIT"
W 531	SEE "WORD BIT"
W 532	SEE "WORD BIT"
W 533	SEE "WORD BIT"
W 534	SEE "WORD BIT"
W 535	SEE "WORD BIT"
W 536	SEE "WORD BIT"
W 537	SEE "WORD BIT"
W 538	SEE "WORD BIT"
W 539	SEE "WORD BIT"
W 540	FREE
W 541	FREE
W 542	FREE
W 543	FREE
W 544	FREE
W 545	FREE
W 546	FREE
W 547	FREE
W 548	FREE
W 549	FREE
W 550	COUNTER FOR SATELLITE EXTRUDER1 HEATER E100
W 551	COUNTER FOR SATELLITE EXTRUDER1 HEATER E101
W 552	COUNTER FOR SATELLITE EXTRUDER1 HEATER E102
W 553	COUNTER FOR SATELLITE EXTRUDER1 HEATER E103
W 554	COUNTER FOR SATELLITE EXTRUDER1 HEATER E104

W 555	COUNTER FOR SATELLITE EXTRUDER1 HEATER E105
W 556	COUNTER FOR SATELLITE EXTRUDER1 HEATER E106
W 557	COUNTER FOR SATELLITE EXTRUDER1 HEATER E107
W 558	COUNTER FOR SATELLITE EXTRUDER1 HEATER E108
W 559	COUNTER FOR SATELLITE EXTRUDER1 HEATER E110
W 560	COUNTER FOR SATELLITE EXTRUDER1 HEATER E111
W 561	COUNTER FOR SATELLITE EXTRUDER1 HEATER E112
W 562	COUNTER FOR SATELLITE EXTRUDER1 HEATER E113
W 563	COUNTER FOR SATELLITE EXTRUDER1 HEATER E114
W 564	COUNTER FOR SATELLITE EXTRUDER1 HEATER E115
W 565	COUNTER FOR SATELLITE EXTRUDER1 HEATER E116
W 566	COUNTER FOR SATELLITE EXTRUDER1 HEATER E117
W 567	COUNTER FOR SATELLITE EXTRUDER1 HEATER E118
W 568	COUNTER FOR SATELLITE EXTRUDER1 HEATER E120
W 569	COUNTER FOR SATELLITE EXTRUDER1 HEATER E121
W 570	COUNTER FOR SATELLITE EXTRUDER1 HEATER E122
W 571	COUNTER FOR SATELLITE EXTRUDER1 HEATER E123
W 572	COUNTER FOR SATELLITE EXTRUDER1 HEATER E124
W 573	COUNTER FOR SATELLITE EXTRUDER1 HEATER E125
W 574	COUNTER FOR SATELLITE EXTRUDER1 HEATER E126
W 575	COUNTER FOR SATELLITE EXTRUDER1 HEATER E127
W 576	COUNTER FOR SATELLITE EXTRUDER1 HEATER E128
W 577	COUNTER FOR PRI. EXTRUDER MELT LINE ZONE 1 E130
W 578	COUNTER FOR PRI. EXTRUDER MELT LINE ZONE 2 E131
W 579	COUNTER FOR PRI. EXTRUDER MELT LINE ZONE 3 E132
W 580	COUNTER FOR PRI. EXTRUDER MELT LINE ZONE 4 E133
W 581	COUNTER FOR MAIN EXTRUDER2 HEATER E140
W 582	COUNTER FOR MAIN EXTRUDER2 HEATER E141
W 583	COUNTER FOR MAIN EXTRUDER2 HEATER E142
W 584	COUNTER FOR MAIN EXTRUDER2 HEATER E143
W 585	COUNTER FOR MAIN EXTRUDER2 HEATER E144
W 586	COUNTER FOR MAIN EXTRUDER2 HEATER E145
W 587	COUNTER FOR MAIN EXTRUDER2 HEATER E146
W 588	COUNTER FOR MAIN EXTRUDER2 HEATER E147
W 589	COUNTER FOR MAIN EXTRUDER2 PUMP E148
W 590	COUNTER FOR MELTLINE FILTER HEATER E149
W 591	COUNTER FOR MELTLINE FILTER HEATER E150
W 592	COUNTER FOR MELTLINE FILTER HEATER E151
W 593	COUNTER FOR MELTLINE FILTER HEATER E152
W 594	COUNTER FOR MELTLINE FILTER HEATER E156
W 595	COUNTER FOR MELTLINE FILTER HEATER E153
W 596	COUNTER FOR MELTLINE FILTER HEATER E155
W 597	COUNTER FOR MELTLINE FILTER HEATER E157
W 598	COUNTER FOR MELTLINE FILTER HEATER E158
W 599	COUNTER FOR MELTLINE FILTER HEATER E159
W 600	COUNTER SATELLITE EXTRUDER1 HYDRAULIC PUMP
W 601	COUNTER SATELLITE EXTRUDER1 HYDRAULIC PUMP
W 602	COUNTER MAIN EXTRUDER1 HYDRAULIC PUMP
W 603	COUNTER MAIN EXTRUDER1 HYDRAULIC PUMP
W 604	FREE
W 605	FREE
W 606	FREE

W 607	COUNTER DOSERING AND STORAGE HEATER E001
W 608	COUNTER DOSERING AND STORAGE HEATER E002
W 609	COUNTER DOSERING AND STORAGE HEATER E006
W 610	COUNTER DOSERING AND STORAGE HEATER E007
W 611	COUNTER DOSERING AND STORAGE HEATER E010
W 612	COUNTER DOSERING AND STORAGE HEATER E011
W 613	COUNTER FOR DETECT START FAILURE, ADDITIVE PUMP, E012
W 614	FREE
W 615	FREE
W 616	FREE
W 617	FREE
W 618	FREE
W 619	FREE
W 620	FREE
W 621	FREE
W 622	FREE
W 623	FREE
W 624	FREE
W 625	COUNTER SAT EXT1 COOLING FAN ZONE1
W 626	COUNTER SAT EXT1 COOLING FAN ZONE2
W 627	COUNTER SAT EXT1 COOLING FAN ZONE3
W 628	COUNTER SAT EXT1 COOLING FAN ZONE4
W 629	COUNTER SAT EXT1 COOLING FAN ZONE5
W 630	COUNTER SAT EXT1 COOLING FAN ZONE6
W 631	COUNTER SAT EXT1 COOLING FAN ZONE7
W 632	COUNTER SAT EXT2 COOLING FAN ZONE1
W 633	COUNTER SAT EXT2 COOLING FAN ZONE3
W 634	COUNTER SAT EXT2 COOLING FAN ZONE3
W 635	COUNTER SAT EXT2 COOLING FAN ZONE4
W 636	COUNTER SAT EXT2 COOLING FAN ZONE5
W 637	COUNTER SAT EXT2 COOLING FAN ZONE6
W 638	COUNTER SAT EXT2 COOLING FAN ZONE7
W 639	FREE
W 640	FREE
W 641	FREE
W 642	FREE
W 643	FREE
W 644	FREE
W 645	FREE
W 646	FREE
W 647	FREE
W 648	FREE
W 649	FREE
W 650	FREE
W 651	FREE
W 652	FREE
W 653	FREE
W 654	FREE
W 655	FREE
W 656	FREE
W 657	FREE
W 658	FREE

W 659	FREE
W 660	FREE
W 661	FREE
W 662	FREE
W 663	FREE
W 664	FREE
W 665	FREE
W 666	FREE
W 667	FREE
W 668	FREE
W 669	FREE
W 670	FREE
W 671	FREE
W 672	FREE
W 673	FREE
W 674	FREE
W 675	FREE
W 676	FREE
W 677	FREE
W 678	FREE
W 679	FREE
W 680	FREE
W 681	FREE
W 682	FREE
W 683	FREE
W 684	FREE
W 685	FREE
W 686	FREE
W 687	FREE
W 688	FREE
W 689	FREE
W 690	FREE
W 691	FREE
W 692	FREE
W 693	FREE
W 694	FREE
W 695	FREE
W 696	FREE
W 697	FREE
W 698	FREE
W 699	FREE
W 700	FREE
W 701	FREE
W 702	FREE
W 703	FREE
W 704	FREE
W 705	FREE
W 706	FREE
W 707	FREE
W 708	FREE
W 709	FREE
W 710	FREE

W 711	FREE
W 712	FREE
W 713	FREE
W 714	FREE
W 715	FREE
W 716	FREE
W 717	FREE
W 718	FREE
W 719	FREE
W 720	FREE
W 721	FREE
W 722	FREE
W 723	FREE
W 724	FREE
W 725	FREE
W 726	FREE
W 727	FREE
W 728	FREE
W 729	FREE
W 730	FREE
W 731	FREE
W 732	FREE
W 733	FREE
W 734	FREE
W 735	FREE
W 736	FREE
W 737	FREE
W 738	FREE
W 739	FREE
W 740	FREE
W 741	FREE
W 742	FREE
W 743	FREE
W 744	FREE
W 745	FREE
W 746	FREE
W 747	FREE
W 748	FREE
W 749	FREE
W 750	FREE
W 751	FREE
W 752	FREE
W 753	FREE
W 754	FREE
W 755	FREE
W 756	FREE
W 757	FREE
W 758	FREE
W 759	FREE
W 760	FREE
W 761	FREE
W 762	FREE

W 763	FREE
W 764	FREE
W 765	FREE
W 766	FREE
W 767	FREE
W 768	FREE
W 769	FREE
W 770	FREE
W 771	FREE
W 772	FREE
W 773	FREE
W 774	FREE
W 775	FREE
W 776	FREE
W 777	FREE
W 778	FREE
W 779	FREE
W 780	FREE
W 781	FREE
W 782	FREE
W 783	FREE
W 784	FREE
W 785	FREE
W 786	FREE
W 787	FREE
W 788	FREE
W 789	FREE
W 790	FREE
W 791	FREE
W 792	FREE
W 793	FREE
W 794	FREE
W 795	FREE
W 796	FREE
W 797	FREE
W 798	FREE
W 799	FREE
W 800	FREE
W 801	FREE
W 802	FREE
W 803	FREE
W 804	FREE
W 805	FREE
W 806	FREE
W 807	FREE
W 808	FREE
W 809	FREE
W 810	FREE
W 811	FREE
W 812	FREE
W 813	FREE
W 814	FREE

W 815	FREE
W 816	FREE
W 817	FREE
W 818	FREE
W 819	FREE
W 820	FREE
W 821	FREE
W 822	FREE
W 823	FREE
W 824	FREE
W 825	FREE
W 826	FREE
W 827	FREE
W 828	FREE
W 829	FREE
W 830	FREE
W 831	FREE
W 832	FREE
W 833	FREE
W 834	FREE
W 835	FREE
W 836	FREE
W 837	FREE
W 838	FREE
W 839	FREE
W 840	FREE
W 841	FREE
W 842	FREE
W 843	FREE
W 844	FREE
W 845	FREE
W 846	FREE
W 847	FREE
W 848	FREE
W 849	FREE
W 850	FREE
W 851	FREE
W 852	FREE
W 853	FREE
W 854	FREE
W 855	FREE
W 856	FREE
W 857	FREE
W 858	FREE
W 859	FREE
W 860	FREE
W 861	FREE
W 862	FREE
W 863	FREE
W 864	FREE
W 865	FREE
W 866	FREE

W 867	FREE
W 868	FREE
W 869	FREE
W 870	FREE
W 871	FREE
W 872	FREE
W 873	FREE
W 874	FREE
W 875	FREE
W 876	FREE
W 877	FREE
W 878	FREE
W 879	FREE
W 880	FREE
W 881	FREE
W 882	FREE
W 883	FREE
W 884	FREE
W 885	FREE
W 886	FREE
W 887	FREE
W 888	FREE
W 889	FREE
W 890	FREE
W 891	FREE
W 892	FREE
W 893	FREE
W 894	FREE
W 895	FREE
W 896	FREE
W 897	FREE
W 898	FREE
W 899	FREE
W 900	FREE
W 901	FREE
W 902	FREE
W 903	FREE
W 904	FREE
W 905	FREE
W 906	FREE
W 907	FREE
W 908	FREE
W 909	FREE
W 910	FREE
W 911	FREE
W 912	FREE
W 913	FREE
W 914	FREE
W 915	FREE
W 916	FREE
W 917	FREE
W 918	FREE

W 919	FREE
W 920	FREE
W 921	FREE
W 922	FREE
W 923	FREE
W 924	FREE
W 925	FREE
W 926	FREE
W 927	FREE
W 928	FREE
W 929	FREE
W 930	FREE
W 931	FREE
W 932	FREE
W 933	FREE
W 934	FREE
W 935	FREE
W 936	FREE
W 937	FREE
W 938	FREE
W 939	FREE
W 940	FREE
W 941	FREE
W 942	FREE
W 943	FREE
W 944	FREE
W 945	FREE
W 946	FREE
W 947	FREE
W 948	FREE
W 949	FREE
W 950	FREE
W 951	FREE
W 952	FREE
W 953	FREE
W 954	FREE
W 955	FREE
W 956	FREE
W 957	FREE
W 958	FREE
W 959	FREE
W 960	FREE
W 961	FREE
W 962	FREE
W 963	FREE
W 964	FREE
W 965	FREE
W 966	FREE
W 967	FREE
W 968	FREE
W 969	FREE
W 970	FREE

W 971	FREE
W 972	FREE
W 973	FREE
W 974	FREE
W 975	FREE
W 976	FREE
W 977	FREE
W 978	FREE
W 979	FREE
W 980	FREE
W 981	FREE
W 982	FREE
W 983	FREE
W 984	FREE
W 985	FREE
W 986	FREE
W 987	FREE
W 988	FREE
W 989	FREE
W 990	FREE
W 991	FREE
W 992	FREE
W 993	FREE
W 994	FREE
W 995	FREE
W 996	FREE
W 997	FREE
W 998	FREE
W 999	FREE
W 1000	FREE
W 1001	FREE
W 1002	FREE
W 1003	FREE
W 1004	FREE
W 1005	FREE
W 1006	FREE
W 1007	FREE
W 1008	FREE
W 1009	FREE
	"ALL WORD SHOWN BELOW ARE FOR CONAIR BLENDER"
W 1010	CURRENT WEIGH FOR HOPPER #1
W 1012	CURRENT WEIGH FOR HOPPER #2
W 1014	CURRENT WEIGH FOR HOPPER #3
W 1016	CURRENT WEIGH FOR HOPPER #4
W 1018	CURRENT WEIGH FOR HOPPER #5
DW1000	HOPPER 1- SR20 L30
DW1002	HOPPER 2- SR20 L30+2
DW1004	HOPPER 3- SR20 L30+3
DW1006	HOPPER 4- SR20 L30+4
DW1008	HOPPER 5- SR20 L30+5
DW 1060	HOPPER #1 MIN. SPEED

DW 1062	HOPPER #2 MIN. SPEED
DW 1064	HOPPER #3 MIN. SPEED
DW 1066	HOPPER #4 MIN. SPEED
DW 1068	HOPPER #5 MIN. SPEED
W 1100	STATUS INDEX FOR HOPPER #1 AND ALL
W 1101	STATUS INDEX FOR HOPPER #2
W 1102	STATUS INDEX FOR HOPPER #3
W 1103	STATUS INDEX FOR HOPPER #4
W 1104	STATUS INDEX FOR HOPPER #5
W 1121	RECIPE RATIO FOR HOPPER #1
W 1122	RECIPE RATIO FOR HOPPER #2
W 1123	RECIPE RATIO FOR HOPPER #3
W 1124	RECIPE RATIO FOR HOPPER #4
W 1125	RECIPE RATIO FOR HOPPER #5
W 1129	STATUS INDEX
DW 1150	MIN. RECIPE SPEED
DW 1160	MAX. RECIPE SPEED
DW 1170	HOPPER #1 WEIGHT RATIO ACCORDING TO RECIPE
DW 1172	HOPPER #2 WEIGHT RATIO ACCORDING TO RECIPE
DW 1174	HOPPER #3 WEIGHT RATIO ACCORDING TO RECIPE
DW 1176	HOPPER #4 WEIGHT RATIO ACCORDING TO RECIPE
DW 1178	HOPPER #5 WEIGHT RATIO ACCORDING TO RECIPE
W 1199	STATUS INDEX
W 1201	SPEED REF FOR MOTOR #1
W 1202	SPEED REF FOR MOTOR #2
W 1203	SPEED REF FOR MOTOR #3
W 1204	SPEED REF FOR MOTOR #4
W 1205	SPEED REF FOR MOTOR #5
W 1206	COPY FROM W1201,WHILE [W1100=35]
W 1207	COPY FROM W1202,WHILE [W1100=35]
W 1208	COPY FROM W1203,WHILE [W1100=35]
W 1209	COPY FROM W1204,WHILE [W1100=35]
W 1210	COPY FROM W1205,WHILE [W1100=35]
W 1270	TIME VALUE FROM LOW TO HIGH LEVEL WHILE AUGER SPEED MAX.
W 1272	W1270/2
W 1276	TIME VALUE FROM HIGH TO LOW LEVEL WHILE AUGUR STOP
W 1300	PROPORTIONAL BAND
W 1301	INTEGRAL GAIN
W 1330	STATUS INDEX FOR HOPPER #1
W 1350	WEIGH REFERENCE
W 1351	WEIGH MEASURE
DW 1352	ERROR BETWEEN REF AND MEASURE
DW 1354	P OUTPUT LIMITATION
DW 1356	I OUTPUT LIMITATION
DW 1358	P+I OUTPUT
DW 1360	HOPPER #1 MAX. SPEED
DW 1362	HOPPER #2 MAX. SPEED
DW 1364	HOPPER #3 MAX. SPEED
DW 1366	HOPPER #4 MAX. SPEED
DW 1368	HOPPER #5 MAX. SPEED
W 1400	STATUS REGISTER

DW 1412	WEIGHT REF (LBS/HR) HOPPER #1
DW 1414	WEIGHT REF (LBS/SEC)
DW 1416	WEIGHT REF INCREMENT (LBS/SEC)
DW 1418	WEIGHT WHEN AUGER STOP AT LAST TIMES
W 1420	WEIGHT REF INCREMENT
W 1421	WEIGHT MEASURE INCREMENT
DW 1422	ERROR BETWEEN REFERENCE AND MEASUREMENT
DW 1424	PROPORTIONAL OUTPUT
DW 1426	INTEGRAL OUTPUT
DW 1428	P+I OUTPUT
DW 1432	WEIGHT REF (LBS/HR) HOPPER #2
DW 1434	WEIGHT REF (LBS/SEC)
DW 1436	WEIGHT REF INCREMENT (LBS/SEC)
DW 1438	WEIGHT WHEN AUGER STOP AT LAST TIMES
W 1440	WEIGHT REF INCREMENT
W 1441	WEIGHT MEASURE INCREMENT
DW 1442	ERROR BETWEEN REFERENCE AND MEASUREMENT
DW 1444	PROPORTIONAL OUTPUT
DW 1446	INTEGRAL OUTPUT
DW 1448	P+I OUTPUT
DW 1452	WEIGHT REF (LBS/HR) HOPPER #3
DW 1454	WEIGHT REF (LBS/SEC)
DW 1456	WEIGHT REF INCREMENT (LBS/SEC)
DW 1458	WEIGHT WHEN AUGER STOP AT LAST TIMES
W 1460	WEIGHT REF INCREMENT
W 1461	WEIGHT MEASURE INCREMENT
DW 1462	ERROR BETWEEN REFERENCE AND MEASUREMENT
DW 1464	PROPORTIONAL OUTPUT
DW 1466	INTEGRAL OUTPUT
DW 1468	P+I OUTPUT
DW 1472	WEIGHT REF (LBS/HR) HOPPER #4
DW 1474	WEIGHT REF (LBS/SEC)
DW 1476	WEIGHT REF INCREMENT (LBS/SEC)
DW 1478	WEIGHT WHEN AUGER STOP AT LAST TIMES
W 1480	WEIGHT REF INCREMENT
W 1481	WEIGHT MEASURE INCREMENT
DW 1482	ERROR BETWEEN REFERENCE AND MEASUREMENT
DW 1484	PROPORTIONAL OUTPUT
DW 1486	INTEGRAL OUTPUT
DW 1488	P+I OUTPUT
W 1501	PREVIOUS WEIGHT IN HOPPER #1
W 1502	PREVIOUS WEIGHT IN HOPPER #2
W 1503	PREVIOUS WEIGHT IN HOPPER #3
W 1504	PREVIOUS WEIGHT IN HOPPER #4
W 1505	PREVIOUS WEIGHT IN HOPPER #5
W 1506	CURRENT WEIGHT IN HOPPER #1
W 1507	CURRENT WEIGHT IN HOPPER #2

W 1508	CURRENT WEIGHT IN HOPPER #3
W 1509	CURRENT WEIGHT IN HOPPER #4
W 1510	CURRENT WEIGHT IN HOPPER #5
W 1511	HOPPER #1 PI OUTPUT
W 1512	HOPPER #2 PI OUTPUT
W 1513	HOPPER #3 PI OUTPUT
W 1514	HOPPER #4 PI OUTPUT
W 1515	HOPPER #5 PI OUTPUT
W 1550	PI OUTPUT LIMITATION
DW 1552	WEIGHT REF (LBS/HR) HOPPER #5
DW 1554	WEIGHT REF (LBS/SEC)
DW 1556	WEIGHT REF INCREMENT (LBS/SEC)
DW 1558	WEIGHT WHEN AUGER STOP AT LAST TIMES
W 1560	WEIGHT REF INCREMENT
DW 1561	WEIGHT MEASURE INCREMENT
DW 1562	ERROR BETWEEN REFERENCE AND MEASUREMENT
DW 1564	PROPORTIONAL OUTPUT
DW 1566	INTEGRAL OUTPUT
DW 1568	P+I OUTPUT
DW 1570	COPY FROM W1506,HOPPER #1
DW 1572	COPY FROM W1507,HOPPER #2
DW 1574	COPY FROM W1508,HOPPER #3
DW 1580	COPY FROM W1501,HOPPER #1
DW 1582	COPY FROM W1502,HOPPER #2
DW 1584	COPY FROM W1503,HOPPER #3
DW 1600	TOTAL ACCUMULATIVE WEIGHT
DW 1610	HOPPER #1 ACCUMULATIVE WEIGHT
DW 1612	HOPPER #2 ACCUMULATIVE WEIGHT
DW 1614	HOPPER #3 ACCUMULATIVE WEIGHT
DW 1616	HOPPER #4 ACCUMULATIVE WEIGHT
DW 1618	HOPPER #5 ACCUMULATIVE WEIGHT
W 1621	ACCUMULATIVE WEIGHT FOR HOPPER #1
W 1622	ACCUMULATIVE WEIGHT FOR HOPPER #2
W 1623	ACCUMULATIVE WEIGHT FOR HOPPER #3
W 1624	ACCUMULATIVE WEIGHT FOR HOPPER #4
W 1625	ACCUMULATIVE WEIGHT FOR HOPPER #5
W 1626	TOTAL ACCUMULATIVE WEIGHT
W 1630	
DW 1698	CONSUMPTION RATE (LINE SPEED) AFTER CALCULATE
DW 1700	CONSUMPTION RATE (LINE SPEED) AFTER CALCULATE
DW 1900	20% THROUGHPUT OF HOPPER #1
DW 1902	20% THROUGHPUT OF HOPPER #2
DW 1904	20% THROUGHPUT OF HOPPER #3
DW 1906	20% THROUGHPUT OF HOPPER #4
DW 1908	20% THROUGHPUT OF HOPPER #5
DW 1910	90% THROUGHPUT OF HOPPER #1
DW 1912	90% THROUGHPUT OF HOPPER #2
DW 1914	90% THROUGHPUT OF HOPPER #3
DW 1916	90% THROUGHPUT OF HOPPER #4
DW 1918	90% THROUGHPUT OF HOPPER #5

WORD	CONTENT
W 420 0	R 300 DEFECT MEASURE
W 420 1	R 301 DEFECT MEASURE
W 420 2	R 302 DEFECT MEASURE
W 420 3	R 303 DEFECT MEASURE
W 420 4	R 304 DEFECT MEASURE
W 420 5	R 305 DEFECT MEASURE
W 420 6	R 306 DEFECT MEASURE
W 420 7	R 307 DEFECT MEASURE
W 420 8	R 308 DEFECT MEASURE
W 420 9	R 309 DEFECT MEASURE
W 420 A	R 310 DEFECT MEASURE
W 420 B	R 311 DEFECT MEASURE
W 420 C	R 312 DEFECT MEASURE
W 420 D	R 313 DEFECT MEASURE
W 420 E	R 314 DEFECT MEASURE
W 420 F	R 315 DEFECT MEASURE
W 421 0	R 316 DEFECT MEASURE
W 421 1	R 317 DEFECT MEASURE
W 421 2	R 318 DEFECT MEASURE
W 421 3	R 319 DEFECT MEASURE
W 421 4	R 320 DEFECT MEASURE
W 421 5	R 321 DEFECT MEASURE
W 421 6	R 322 DEFECT MEASURE
W 421 7	R 323 DEFECT MEASURE
W 421 8	R 324 DEFECT MEASURE
W 421 9	R 325 DEFECT MEASURE
W 421 A	R 326 DEFECT MEASURE
W 421 B	R 327 DEFECT MEASURE
W 421 C	R 328 DEFECT MEASURE
W 421 D	R 329 DEFECT MEASURE
W 421 E	R 330 DEFECT MEASURE
W 421 F	R 331 DEFECT MEASURE
W 422 0	R 332 DEFECT MEASURE
W 422 1	R 333 DEFECT MEASURE
W 422 2	R 334 DEFECT MEASURE
W 422 3	R 335 DEFECT MEASURE
W 422 4	R 336 DEFECT MEASURE
W 422 5	R 337 DEFECT MEASURE
W 422 6	R 338 DEFECT MEASURE
W 422 7	R 339 DEFECT MEASURE
W 422 8	R 340 DEFECT MEASURE
W 422 9	R 341 DEFECT MEASURE
W 422 A	R 342 DEFECT MEASURE
W 422 B	R 343 DEFECT MEASURE
W 422 C	R 344 DEFECT MEASURE
W 422 D	R 345 DEFECT MEASURE
W 422 E	R 346 DEFECT MEASURE
W 422 F	R 347 DEFECT MEASURE
W 423 0	R 348 DEFECT MEASURE
W 423 1	R 349 DEFECT MEASURE

W 423 2	R 350 DEFECT MEASURE
W 423 3	R 351 DEFECT MEASURE
W 423 4	R 352 DEFECT MEASURE
W 423 5	R 353 DEFECT MEASURE
W 423 6	R 354 DEFECT MEASURE
W 423 7	R 355 DEFECT MEASURE
W 423 8	R 356 DEFECT MEASURE
W 423 9	R 357 DEFECT MEASURE
W 423 A	R 358 DEFECT MEASURE
W 423 B	R 359 DEFECT MEASURE
W 423 C	R 360 DEFECT MEASURE
W 423 D	R 361 DEFECT MEASURE
W 423 E	FREE
W 423 F	FREE
W 500 0	E 100 SAT. EXT1 HEATING ZONE 1, CONTACTOR ANSWER.
W 500 1	E 101 SAT. EXT1 HEATING ZONE 2, CONTACTOR ANSWER.
W 500 2	E 102 SAT. EXT1 HEATING ZONE 3, CONTACTOR ANSWER.
W 500 3	E 103 SAT. EXT1 HEATING ZONE 4, CONTACTOR ANSWER.
W 500 4	E 104 SAT. EXT1 HEATING ZONE 5, CONTACTOR ANSWER.
W 500 5	E 105 SAT. EXT1 HEATING ZONE 6, CONTACTOR ANSWER.
W 500 6	E 106 SAT. EXT1 HEATING ZONE 7, CONTACTOR ANSWER.
W 500 7	E 107 SAT. EXT1 ADAPTER, CONTACTOR ANSWER.
W 500 8	E 108 SAT. EXT1 FILTER, CONTACTOR ANSWER
W 500 9	FREE
W 500 A	E 110 SAT. EXT2 HEATING ZONE 1, CONTACTOR ANSWER.
W 500 B	E 111 SAT. EXT2 HEATING ZONE 2, CONTACTOR ANSWER.
W 500 C	E 112 SAT. EXT2 HEATING ZONE 3, CONTACTOR ANSWER.
W 500 D	E 113 SAT. EXT2 HEATING ZONE 4, CONTACTOR ANSWER.
W 500 E	E 114 SAT. EXT2 HEATING ZONE 5, CONTACTOR ANSWER.
W 500 F	E 115 SAT. EXT2 HEATING ZONE 6, CONTACTOR ANSWER.
W 501 0	E 116 SAT. EXT2 HEATING ZONE 7, CONTACTOR ANSWER.
W 501 1	E 117 SAT. EXT2 HEATING ADAPTER, CONTACTOR ANSWER.
W 501 2	E 118 SAT. EXT2 HEATING FILTER, CONTACTOR ANSWER.
W 501 3	FREE
W 501 4	E 120 EXT. 1 HEATING ZONE 1, CONTACTOR ANSWER
W 501 5	E 121 EXT. 1 HEATING ZONE 2, CONTACTOR ANSWER
W 501 6	E 122 EXT. 1 HEATING ZONE 3, CONTACTOR ANSWER
W 501 7	E 123 EXT. 1 HEATING ZONE 4, CONTACTOR ANSWER
W 501 8	E 124 EXT. 1 ADAPTER, CONTACTOR ANSWER
W 501 9	E 125 EXT. 1 FILTER ZONE 1, CONTACTOR ANSWER
W 501 A	E 126 EXT. 1 FILTER ZONE 1, CONTACTOR ANSWER
W 501 B	E 127 EXT. 1 FILTER ZONE 1, CONTACTOR ANSWER
W 501 C	E 128 EXT. 1 COOLING PUMP, CONTACTOR ANSWER
W 501 D	FREE
W 501 E	E 130 PRIMARY EXT. MELT LINE ZONE 1, CONTACTOR ANSWER
W 501 F	E 131 PRIMARY EXT. MELT LINE ZONE 2, CONTACTOR ANSWER
W 502 0	E 132 PRIMARY EXT. MELT LINE ZONE 3, CONTACTOR ANSWER
W 502 1	E 133 PRIMARY EXT. MELT LINE ZONE 4, CONTACTOR ANSWER
W 502 2	FREE

W 502 3	FREE
W 502 4	FREE
W 502 5	FREE
W 502 6	FREE
W 502 7	FREE
W 502 8	E 140 SEC. EXT. HEATING ZONE 1
W 502 9	E 141 SEC. EXT. HEATING ZONE 2
W 502 A	E 142 SEC. EXT. HEATING ZONE 3
W 502 B	E 143 SEC. EXT. HEATING ZONE 4
W 502 C	E 144 SEC. EXT. ADAPTER ZONE
W 502 D	E 145 SEC. EXT. FILTER ZONE 1
W 502 E	E 146 SEC. EXT. FILTER ZONE 2
W 502 F	E 147 SEC. EXT. FILTER ZONE 3
W 503 0	E 148 SEC. EXT. COOLING PUMP
W 503 1	E 149 SEC. EXT. STATIC MIXER CONNECTION ZONE
W 503 2	E 150 SEC. EXT. STATIC MIXER HEATING ZONE 1
W 503 3	E 151 SEC. EXT. HEATING ZONE 1
W 503 4	FREE
W 503 5	E 153 DIE HEATING ZONE 1
W 503 6	E 154 DIE HEATING ZONE 2
W 503 7	E 155 DIE HEATING ZONE 3
W 503 8	E 156 DIE HEATING ZONE 4
W 503 9	E 157 DIE HEATING ZONE 5
W 503 A	E 158 DIE HEATING ZONE 6
W 503 B	E 159 DIE HEATING ZONE 7
W 503 C	FREE
W 503 D	FREE
W 503 E	FREE
W 503 F	FREE
W 505 0	E 001 HOMO DRYER MOTOR RUNNING, CONTACTOR ANSWER
W 505 1	E 002 RECLAIM DRYER MOTOR RUNNING, CONTACTOR ANSWER
W 505 2	FREE
W 505 3	FREE
W 505 4	FREE
W 505 5	E 006 MIXING SCREW, CONTACTOR ANSWER
W 505 6	E 007 ROTARY ARM, CONTACTOR ANSWER
W 505 7	FREE
W 505 8	FREE
W 505 9	E 010 COPOLYMER DRYER MOTOR RUNNING, CONTACTOR ANSWER
W 505 A	E 011 SAT2 DRYER MOTOR RUNNING, CONTACTOR ANSWER
W 505 B	E 012 ADDITIVE VACUUM PUMP RUNNING, CONTACTOR ANSWER
W 505 C	FREE
W 505 D	FREE
W 505 E	FREE
W 505 F	FREE
W 507 0	SAT 1 HYDRAULIC PUMP, CONTACTOR ANSWER
W 507 1	SAT 2 HYDRAULIC PUMP, CONTACTOR ANSWER
W 507 2	EXT 1 HYDRAULIC PUMP, CONTACTOR ANSWER
W 507 3	EXT 2 HYDRAULIC PUMP, CONTACTOR ANSWER
W 507 4	FREE
W 507 5	FREE

W 507 6	FREE
W 507 7	FREE
W 507 8	FREE
W 507 9	FREE
W 507 A	FREE
W 507 B	FREE
W 507 C	FREE
W 507 D	FREE
W 507 E	FREE
W 507 F	FREE
W 508 0	SAT 1 COOLING FAN ZONE 1, CONTACTOR ANSWER
W 508 1	SAT 1 COOLING FAN ZONE 2, CONTACTOR ANSWER
W 508 2	SAT 1 COOLING FAN ZONE 3, CONTACTOR ANSWER
W 508 3	SAT 1 COOLING FAN ZONE 4, CONTACTOR ANSWER
W 508 4	SAT 1 COOLING FAN ZONE 5, CONTACTOR ANSWER
W 508 5	SAT 1 COOLING FAN ZONE 6, CONTACTOR ANSWER
W 508 6	SAT 1 COOLING FAN ZONE 7, CONTACTOR ANSWER
W 508 7	SAT 2 COOLING FAN ZONE 1, CONTACTOR ANSWER
W 508 8	SAT 2 COOLING FAN ZONE 2, CONTACTOR ANSWER
W 508 9	SAT 2 COOLING FAN ZONE 3, CONTACTOR ANSWER
W 508 A	SAT 2 COOLING FAN ZONE 4, CONTACTOR ANSWER
W 508 B	SAT 2 COOLING FAN ZONE 5, CONTACTOR ANSWER
W 508 C	SAT 2 COOLING FAN ZONE 6, CONTACTOR ANSWER
W 508 D	SAT 2 COOLING FAN ZONE 7, CONTACTOR ANSWER
W 508 E	EXT 1 ZONE 1 COOLING VALVE, CONTACTOR ANSWER
W 508 F	EXT 1 ZONE 2 COOLING VALVE, CONTACTOR ANSWER
W 509 0	EXT 1 ZONE 3 COOLING VALVE, CONTACTOR ANSWER
W 509 1	EXT 1 ZONE 4 COOLING VALVE, CONTACTOR ANSWER
W 509 2	EXT 2 ZONE 1 COOLING VALVE, CONTACTOR ANSWER
W 509 3	EXT 2 ZONE 2 COOLING VALVE, CONTACTOR ANSWER
W 509 4	EXT 2 ZONE 3 COOLING VALVE, CONTACTOR ANSWER
W 509 5	EXT 2 ZONE 4 COOLING VALVE, CONTACTOR ANSWER
W 509 6	FREE
W 509 7	FREE
W 509 8	FREE
W 509 9	FREE
W 509 A	FREE
W 509 B	FREE
W 509 C	FREE
W 509 D	FREE
W 509 E	FREE
W 509 F	FREE
W 510 0	E 100 SAT1 HEATING ZONE 1, OUTPUT BIT
W 510 1	E 101 SAT1 HEATING ZONE 2, OUTPUT BIT
W 510 2	E 102 SAT1 HEATING ZONE 3, OUTPUT BIT
W 510 3	E 103 SAT1 HEATING ZONE 4, OUTPUT BIT
W 510 4	E 104 SAT1 HEATING ZONE 5, OUTPUT BIT
W 510 5	E 105 SAT1 HEATING ZONE 6, OUTPUT BIT
W 510 6	E 106 SAT1 HEATING ZONE 7, OUTPUT BIT
W 510 7	E 107 SAT1 ADAPTER, OUTPUT BIT
W 510 8	E 108 SAT1 FILTER, OUTPUT BIT
W 510 9	FREE

W 510 A	E 110 SAT2 HEATING ZONE 1, OUTPUT BIT
W 510 B	E 111 SAT2 HEATING ZONE 2, OUTPUT BIT
W 510 C	E 112 SAT2 HEATING ZONE 3, OUTPUT BIT
W 510 D	E 113 SAT2 HEATING ZONE 4, OUTPUT BIT
W 510 E	E 114 SAT2 HEATING ZONE 5, OUTPUT BIT
W 510 F	E 115 SAT2 HEATING ZONE 6, OUTPUT BIT
W 511 0	E 116 SAT2 HEATING ZONE 7, OUTPUT BIT
W 511 1	E 117 SAT2 ADAPTER, OUTPUT BIT
W 511 2	E 118 SAT2 FILTER, OUTPUT BIT
W 511 3	FREE
W 511 4	E 120 EXT1 HEATING ZONE 1, OUTPUT BIT
W 511 5	E 121 EXT1 HEATING ZONE 2, OUTPUT BIT
W 511 6	E 122 EXT1 HEATING ZONE 3, OUTPUT BIT
W 511 7	E 123 EXT1 HEATING ZONE 4, OUTPUT BIT
W 511 8	E 124 EXT1 ADAPTER, OUTPUT BIT
W 511 9	E 125 EXT1 FILTER ZONE 1, OUTPUT BIT
W 511 A	E 126 EXT1 FILTER ZONE 2, OUTPUT BIT
W 511 B	E 127 EXT1 FILTER ZONE 3, OUTPUT BIT
W 511 C	E 128 EXT1 COOLING PUMP, OUTPUT BIT
W 511 D	FREE
W 511 E	E 130 EXT1 MELT LINE ZONE 1
W 511 F	E 131 EXT1 MELT LINE ZONE 2
W 512 0	E 132 EXT1 MELT LINE ZONE 3
W 512 1	E 133 EXT1 MELT LINE ZONE 4
W 512 2	FREE
W 512 3	FREE
W 512 4	FREE
W 512 5	FREE
W 512 6	FREE
W 512 7	FREE
W 512 8	E 140 EXT2 HEATING ZONE 1, OUTPUT BIT
W 512 9	E 141 EXT2 HEATING ZONE 2, OUTPUT BIT
W 512 A	E 142 EXT2 HEATING ZONE 3, OUTPUT BIT
W 512 B	E 143 EXT2 HEATING ZONE 4, OUTPUT BIT
W 512 C	E 144 EXT2 ADAPTER 1, OUTPUT BIT
W 512 D	E 145 EXT2 FILTER ZONE 1, OUTPUT BIT
W 512 E	E 146 EXT2 FILTER ZONE 2, OUTPUT BIT
W 512 F	E 147 EXT2 FILTER ZONE 3, OUTPUT BIT
W 513 0	E 148 EXT2 COOLING PUMP, OUTPUT BIT
W 513 1	E 149 EXT2 STATIC MIXER CONNECTION ZONE, OUTPUT BIT
W 513 2	E 150 EXT2 STATIC MIXER, OUTPUT BIT
W 513 3	E 151 EXT2 DIVERTER HEATING ZONE, OUTPUT BIT
W 513 4	FREE
W 513 5	E 153 DIE HEATING ZONE 1
W 513 6	E 154 DIE HEATING ZONE 2
W 513 7	E 155 DIE HEATING ZONE 3
W 513 8	E 156 DIE HEATING ZONE 4
W 513 9	E 157 DIE HEATING ZONE 5
W 513 A	E 158 DIE HEATING ZONE 6
W 513 B	E 159 DIE HEATING ZONE 7
W 513 C	FREE
W 513 D	FREE

W 513 E	FREE
W 513 F	FREE
W 515 0	E 001 HOMO DRYER START - OUTPUT BIT
W 515 1	E 002 RECLAIM DRYER START - OUTPUT BIT
W 515 2	FREE
W 515 3	FREE
W 515 4	FREE
W 515 5	E 006 MIXING SCREW START - OUTPUT BIT
W 515 6	E 007 ROTARY ARM START - OUTPUT BIT
W 515 7	FREE
W 515 8	FREE
W 515 9	E 010 SAT1 DRYER START - OUTPUT BIT
W 515 A	E 011 SAT2 DRYER START - OUTPUT BIT
W 515 B	E 012 ADDITIVE PUMP - OUTPUT BIT
W 515 C	FREE
W 515 D	FREE
W 515 E	FREE
W 515 F	FREE
W 516 0- W 516 F	FREE
W 517 0	HYDRAULIC PUMP SAT 1 SCREEN CHANGER
W 517 1	HYDRAULIC PUMP SAT 2 SCREEN CHANGER
W 517 2	MOTOR CHANGE FILTER EXT. 1
W 517 3	MOTOR CHANGE FILTER EXT. 2
W 517 4- W 517 F	FREE
W 518 0	COOLING FAN ZONE 1 SAT 1
W 518 1	COOLING FAN ZONE 2 SAT 1
W 518 2	COOLING FAN ZONE 3 SAT 1
W 518 3	COOLING FAN ZONE 4 SAT 1
W 518 4	COOLING FAN ZONE 5 SAT 1
W 518 5	COOLING FAN ZONE 6 SAT 1
W 518 6	COOLING FAN ZONE 7 SAT 1
W 518 7	COOLING FAN ZONE 1 SAT 2
W 518 8	COOLING FAN ZONE 2 SAT 2
W 518 9	COOLING FAN ZONE 3 SAT 2
W 518 A	COOLING FAN ZONE 4 SAT 2
W 518 B	COOLING FAN ZONE 5 SAT 2
W 518 C	COOLING FAN ZONE 6 SAT 2
W 518 D	COOLING FAN ZONE 7 SAT 2
W 518 E	FREE
W 518 F	FREE
W 519 0- W 519 F	FREE
W 520 0	E 100 START FAILURE DETECTED.
W 520 1	E 101 START FAILURE DETECTED.
W 520 2	E 102 START FAILURE DETECTED.
W 520 3	E 103 START FAILURE DETECTED.
W 520 4	E 104 START FAILURE DETECTED
W 520 5	E 105 START FAILURE DETECTED
W 520 6	E 106 START FAILURE DETECTED
W 520 7	E 107 START FAILURE DETECTED
W 520 8	E 108 START FAILURE DETECTED
W 520 9	FREE
W 520 A	E 110 START FAILURE DETECTED

W 520 B	E 111 START FAILURE DETECTED
W 520 C	E 112 START FAILURE DETECTED
W 520 D	E 113 START FAILURE DETECTED
W 520 E	E 114 START FAILURE DETECTED
W 520 F	E 115 START FAILURE DETECTED
W 521 0	E 116 START FAILURE DETECTED
W 521 1	E 117 START FAILURE DETECTED
W 521 2	E 118 START FAILURE DETECTED
W 521 3	FREE
W 521 4	E 120 START FAILURE DETECTED
W 521 5	E 121 START FAILURE DETECTED
W 521 6	E 122 START FAILURE DETECTED
W 521 7	E 123 START FAILURE DETECTED
W 521 8	E 124 START FAILURE DETECTED
W 521 9	E 125 START FAILURE DETECTED
W 521 A	E 126 START FAILURE DETECTED
W 521 B	E 127 START FAILURE DETECTED
W 521 C	E 128 START FAILURE DETECTED
W 521 D	FREE
W 521 E	E 130 START FAILURE DETECTED
W 521 F	E 131 START FAILURE DETECTED
	E 132 START FAILURE DETECTED
W 522 0	E 133 START FAILURE DETECTED
W 522 1	E 134 START FAILURE DETECTED
W 522 2	FREE
W 522 3	FREE
W 522 4	FREE
W 522 5	FREE
W 522 6	FREE
W 522 7	FREE
W 522 8	E 140 START FAILURE DETECTED
W 522 9	E 141 START FAILURE DETECTED
W 522 A	E 142 START FAILURE DETECTED
W 522 B	E 143 START FAILURE DETECTED
W 522 C	E 144 START FAILURE DETECTED
W 522 D	E 145 START FAILURE DETECTED
W 522 E	E 146 START FAILURE DETECTED
W 522 F	E 410 START FAILURE DETECTED
W 523 0	E 148 START FAILURE DETECTED
W 523 1	E 149 START FAILURE DETECTED
W 523 2	E 150 START FAILURE DETECTED
W 523 3	E 151 START FAILURE DETECTED
W 523 4	FREE
W 523 5	E 153 START FAILURE DETECTED
W 523 6	E 154 START FAILURE DETECTED
W 523 7	E 155 START FAILURE DETECTED
W 523 8	E 156 START FAILURE DETECTED
W 523 9	E 157 START FAILURE DETECTED
W 523 A	E 158 START FAILURE DETECTED
W 523 B	E 159 START FAILURE DETECTED
W 523 C	FREE
W 523 D	FREE
W 523 E	FREE

W 523 F	FREE
W 525 0	E 001 START FAILURE DETECTED.
W 525 1	E 002 START FAILURE DETECTED.
W 525 2	FREE
W 525 3	FREE
W 525 4	FREE
W 525 5	E 006 START FAILURE DETECTED.
W 525 6	E 007 START FAILURE DETECTED.
W 525 7	FREE
W 525 8	FREE
W 525 9	E 010 START FAILURE DETECTED.
W 525 A	E 011 START FAILURE DETECTED.
W 525 B	E 012 START FAILURE DETECTED.
W 525 C	FREE
W 525 D	FREE
W 525 E	FREE
W 525 F	FREE
W 527 0	SAT1 HYDRAULIC PUMP, START FAILURE DETECTED.
W 527 1	SAT2 HYDRAULIC PUMP, START FAILURE DETECTED.
W 527 2	EXT1 HYDRAULIC PUMP, START FAILURE DETECTED.
W 527 3	EXT2 HYDRAULIC PUMP, START FAILURE DETECTED.
W 527 4	FREE
W 527 5	FREE
W 527 6	FREE
W 527 7	FREE
W 527 8	FREE
W 527 9	FREE
W 527 A	FREE
W 527 B	FREE
W 527 C	FREE
W 527 D	FREE
W 527 E	FREE
W 527 F	FREE
W 528 0	SAT1 COOLING FAN 1, START FAILURE DETECTED
W 528 1	SAT1 COOLING FAN 2, START FAILURE DETECTED
W 528 2	SAT1 COOLING FAN 3, START FAILURE DETECTED
W 528 3	SAT1 COOLING FAN 4, START FAILURE DETECTED
W 528 4	SAT1 COOLING FAN 5, START FAILURE DETECTED
W 528 5	SAT1 COOLING FAN 6, START FAILURE DETECTED
W 528 6	SAT1 COOLING FAN 7, START FAILURE DETECTED
W 528 7	SAT2 COOLING FAN 1, START FAILURE DETECTED
W 528 8	SAT2 COOLING FAN 2, START FAILURE DETECTED
W 528 9	SAT2 COOLING FAN 3, START FAILURE DETECTED
W 528 A	SAT2 COOLING FAN 4, START FAILURE DETECTED
W 528 B	SAT2 COOLING FAN 5, START FAILURE DETECTED
W 528 C	SAT2 COOLING FAN 6, START FAILURE DETECTED
W 528 D	SAT2 COOLING FAN 7, START FAILURE DETECTED
W 528 E	FREE
W 528 F	FREE
W 530 0	E 100 START FAILURE MORE THAN 4 SEC.
W 530 1	E 101 START FAILURE MORE THAN 4 SEC.

W 530 2	E 102 START FAILURE MORE THAN 4 SEC.
W 530 3	E 103 START FAILURE MORE THAN 4 SEC.
W 530 4	E 104 START FAILURE MORE THAN 4 SEC.
W 530 5	E 105 START FAILURE MORE THAN 4 SEC.
W 530 6	E 106 START FAILURE MORE THAN 4 SEC.
W 530 7	E 107 START FAILURE MORE THAN 4 SEC.
W 530 8	E 108 START FAILURE MORE THAN 4 SEC.
W 530 9	FREE
W 530 A	E 110 START FAILURE MORE THAN 4 SEC.
W 530 B	E 111 START FAILURE MORE THAN 4 SEC.
W 530 C	E 112 START FAILURE MORE THAN 4 SEC.
W 530 D	E 113 START FAILURE MORE THAN 4 SEC.
W 530 E	E 114 START FAILURE MORE THAN 4 SEC.
W 530 F	E 115 START FAILURE MORE THAN 4 SEC.
W 531 0	E 116 START FAILURE MORE THAN 4 SEC.
W 531 1	E 117 START FAILURE MORE THAN 4 SEC.
W 531 2	E 118 START FAILURE MORE THAN 4 SEC.
W 531 3	FREE
W 531 4	E 120 START FAILURE MORE THAN 4 SEC.
W 531 5	E 121 START FAILURE MORE THAN 4 SEC.
W 531 6	E 122 START FAILURE MORE THAN 4 SEC.
W 531 7	E 123 START FAILURE MORE THAN 4 SEC.
W 531 8	E 124 START FAILURE MORE THAN 4 SEC.
W 531 9	E 125 START FAILURE MORE THAN 4 SEC.
W 531 A	E 126 START FAILURE MORE THAN 4 SEC.
W 531 B	E 127 START FAILURE MORE THAN 4 SEC.
W 531 C	E 128 START FAILURE MORE THAN 4 SEC.
W 531 D	FREE
W 531 E	E 130 START FAILURE MORE THAN 4 SEC.
W 531 F	E 131 START FAILURE MORE THAN 4 SEC.
W 532 0	E 132 START FAILURE MORE THAN 4 SEC.
W 532 1	E 133 START FAILURE MORE THAN 4 SEC.
W 532 2	FREE
W 532 3	FREE
W 532 4	FREE
W 532 5	FREE
W 532 6	FREE
W 532 7	FREE
W 532 8	E 140 START FAILURE MORE THAN 4 SEC.
W 532 9	E 141 START FAILURE MORE THAN 4 SEC.
W 532 A	E 142 START FAILURE MORE THAN 4 SEC.
W 532 B	E 143 START FAILURE MORE THAN 4 SEC.
W 532 C	E 144 START FAILURE MORE THAN 4 SEC.
W 532 D	E 145 START FAILURE MORE THAN 4 SEC.
W 532 E	E 146 START FAILURE MORE THAN 4 SEC.
W 532 F	E 147 START FAILURE MORE THAN 4 SEC.
W 533 0	E 148 START FAILURE MORE THAN 4 SEC.
W 533 1	E 149 START FAILURE MORE THAN 4 SEC.
W 533 2	E 150 START FAILURE MORE THAN 4 SEC.
W 533 3	E 151 START FAILURE MORE THAN 4 SEC.
W 533 4	FREE
W 533 5	E 153 START FAILURE MORE THAN 4 SEC.

W 533 6	E 154 START FAILURE MORE THAN 4 SEC.
W 533 7	E 155 START FAILURE MORE THAN 4 SEC.
W 533 8	E 156 START FAILURE MORE THAN 4 SEC.
W 533 9	E 157 START FAILURE MORE THAN 4 SEC.
W 533 A	E 158 START FAILURE MORE THAN 4 SEC.
W 533 B	E 159 START FAILURE MORE THAN 4 SEC.
W 533 C	FREE
W 533 D	FREE
W 533 E	FREE
W 533 F	FREE
W 535 0	E 001 START FAILURE MORE THAN 4 SEC.
W 535 1	E 002 START FAILURE MORE THAN 4 SEC.
W 535 2	FREE
W 535 3	FREE
W 535 4	FREE
W 535 5	E 006 START FAILURE MORE THAN 4 SEC.
W 535 6	E 007 START FAILURE MORE THAN 4 SEC.
W 535 7	FREE
W 535 8	FREE
W 535 9	E 010 START FAILURE MORE THAN 4 SEC.
W 535 A	E 011 START FAILURE MORE THAN 4 SEC.
W 535 B	E 012 START FAILURE MORE THAN 4 SEC.
W 535 C	FREE
W 535 D	FREE
W 535 E	FREE
W 535 F	FREE
W 537 0	SAT 1 HYDRAULIC PUMP START FAILURE MORE THAN 4 SEC
W 537 1	SAT 2 HYDRAULIC PUMP START FAILURE MORE THAN 4 SEC
W 537 2	MAIN EXT. HYDRAULIC PUMP START FAILURE MORE THAN 4 SEC
W 537 3	SEC EXT. HYDRAULIC PUMP START FAILURE MORE THAN 4 SEC
W 537 4- W 537 F	FREE
W 538 0	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 1	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 2	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 3	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 4	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 5	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 6	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 7	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 8	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 9	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 A	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 B	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 C	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 D	SAT1 COOLING FAN 1, START FAILURE MORE THAN 4 SEC.
W 538 E	FREE
W 538 F	FREE
W 539 0	SATELLITE EXTRUDER1 HYDRAULIC PUMP
W 539 1	SATELLITE EXTRUDER2 HYDRAULIC PUMP
W 539 2	MAIN EXTRUDER1 HYDRAULIC PUMP

W 539 3	MAIN EXTRUDER2 HYDRAULIC PUMP
W 539 4	FREE
W 539 5	FREE
W 539 6	FREE
W 539 7	FREE
W 539 8	FREE
W 539 9	FREE
W 539 A	FREE
W 539 B	FREE
W 539 C	FREE
W 539 D	FREE
W 539 E	FREE
W 539 F	FREE

W 4529	AOAH4+63	HIGH ALARM
W 4530	AOAH4+64	H+/L-
W 4531	AOAH4+65	LOW ALARM
W 4532	FREE	
W 4533	AOAHT500	ALARM H T500
W 4534	AOALT500	ALARM L T500
W 4535	AOAHP501	ALARM H P501
W 4536	AOALP501	ALARM L P501
W 4537	AOAHT502	ALARM H T502
W 4538	AOALT502	ALARM L T502
W 4539	AOAHP503	ALARM H P503
W 4540	AOALP503	ALARM L P503
W 4541	AOAHT504	ALARM H T504
W 4542	AOALT504	ALARM L T504
W 4543	AOAHP505	ALARM H P505
W 4544	AOALP505	ALARM L P505
W 4545	AOAHT506	ALARM H T506
W 4546	AOALT506	ALARM L T506
W 4547	AOAHP507	ALARM H P507
W 4548	AOALP507	ALARM L P507
W 4549	AOAHT510	ALARM H T510
W 4550	AOALT510	ALARM L T510
W 4551	AOAHP511	ALARM H P511
W 4552	AOALP511	ALARM L P511
W 4553	AOAHP512	ALARM H P512
W 4554	AOALP512	ALARM L P512
W 4555	AOAHT513	ALARM H T513
W 4556	AOALT513	ALARM L T513
W 4557	AOAHP514	ALARM H P514
W 4558	AOALP514	ALARM L P514
W 4559	AOAHT515	ALARM H T515
W 4560	AOALT515	ALARM L T515
W 4561	AOAHP516	ALARM H P516
W 4562	AOALP516	ALARM L P516
W 4563	FREE	
W 4564	FREE	
W 4565	FREE	
W 4566	FREE	
W 4567	FREE	
W 4568	FREE	
W 4569	FREE	
W 4570	FREE	
W 4571	HOMO	RATIO FOR M1112.01 R205
W 4572	RECLAIM	RATIO FOR M1106.01 R203
W 4573	ADDITIVE	RATIO FOR M1106.02 R204
W 4574	FREE	
W 4575	FREE	
W 4576	FREE	
W 4577	FREE	
W 4578	FREE	
W 4579	FREE	
W 4580	FREE	
W 4581	FREE	
W 4582	DIFFERENTIAL PRESSURE OF P511 & P512	
W 4583	DIFFERENTIAL PRESSURE OF P514 & P516	

W 4584	DIFFERENTIAL PRESSURE OF P501 & P503	
W 4585	DIFFERENTIAL PRESSURE OF P505 & P507	
W 4586	FREE	
W 4587	FREE	
W 4588	FREE	
W 4589	FREE	
W 4590	FREE	
W 4591	FREE	
W 4592	FREE	
W 4593	FREE	
W 4594	FREE	
W 4595	FREE	
W 4596	FREE	
W 4597	FREE	
W 4598	FREE	
W 4599	FREE	
W 4600		SEE "WORD BIT"
W 4601		SEE "WORD BIT"
W 4602		SEE "WORD BIT"
W 4603		SEE "WORD BIT"
W 4604		SEE "WORD BIT"
W 4605		SEE "WORD BIT"
W 4606		SEE "WORD BIT"
W 4607		SEE "WORD BIT"
W 4608		SEE "WORD BIT"
W 4609		SEE "WORD BIT"
W 4610		SEE "WORD BIT"
W 4611		SEE "WORD BIT"
W 4612		SEE "WORD BIT"
W 4613		SEE "WORD BIT"
W 4614		SEE "WORD BIT"
W 4615		SEE "WORD BIT"
W 4616		SEE "WORD BIT"
W 4617		SEE "WORD BIT"
W 4618		SEE "WORD BIT"
W 4619		SEE "WORD BIT"
W 4620		SEE "WORD BIT"
W 4621		SEE "WORD BIT"
W 4622		SEE "WORD BIT"
W 4623		SEE "WORD BIT"
W 4624	FREE	
W 4625	FREE	
W 4626	FREE	
W 4627	FREE	
W 4628	FREE	
W 4629	FREE	
W 4630	FREE	
W 4631	ARAMS+0	AUGER SPEED(%) FOR HOPPER #1 (CONAIR)
W 4632	ARAMS+1	AUGER SPEED(%) FOR HOPPER #2 (CONAIR)
W 4633	ARAMS+2	AUGER SPEED(%) FOR HOPPER #3 (CONAIR)
W 4634	ARAMS+3	AUGER SPEED(%) FOR HOPPER #4 (CONAIR)
W 4635	ARAMS+4	AUGER SPEED(%) FOR HOPPER #5 (CONAIR)
W 4636	ARCONAIR+5	AUGER SPEED(%) - MANUAL SETPOINT FOR HOPPER #1 (CONAIR)
W 4637	ARCONAIR+6	AUGER SPEED(%) - MANUAL SETPOINT FOR HOPPER #2 (CONAIR)

W 4638	ARCONAIR+7	AUGER SPEED(%) - MANUAL SETPOINT FOR HOPPER #3 (CONAIR)
W 4639	ARCONAIR+8	AUGER SPEED(%) - MANUAL SETPOINT FOR HOPPER #4 (CONAIR)
W 4640	ARCONAIR+9	AUGER SPEED(%) - MANUAL SETPOINT FOR HOPPER #5 (CONAIR)
W 4641	ARDEBUG2+11	MAX. RECIPE AFTER CALCULATION FOR HOPPER #1 (CONAIR)
W 4642	ARDEBUG2+12	MAX. RECIPE AFTER CALCULATION FOR HOPPER #2 (CONAIR)
W 4643	ARDEBUG2+13	MAX. RECIPE AFTER CALCULATION FOR HOPPER #3 (CONAIR)
W 4644	ARDEBUG2+14	MAX. RECIPE AFTER CALCULATION FOR HOPPER #4 (CONAIR)
W 4645	ARDEBUG2+15	MAX. RECIPE AFTER CALCULATION FOR HOPPER #5 (CONAIR)
W 4646	ARDEBUG2+16	MIN. RECIPE AFTER CALCULATION FOR HOPPER #1 (CONAIR)
W 4647	ARDEBUG2+17	MIN. RECIPE AFTER CALCULATION FOR HOPPER #2 (CONAIR)
W 4648	ARDEBUG2+18	MIN. RECIPE AFTER CALCULATION FOR HOPPER #3 (CONAIR)
W 4649	ARDEBUG2+19	MIN. RECIPE AFTER CALCULATION FOR HOPPER #4 (CONAIR)
W 4650	ARDEBUG2+20	MIN. RECIPE AFTER CALCULATION FOR HOPPER #5 (CONAIR)
W 4651	AOTHUMAX	MAX. THROUGHPUT (CONAIR)
W 4652	AOTHUMIN	MIN. THROUGHPUT (CONAIR)
W 4653	AIHOPMAX1	HOPPER #1 MAX. THROUGHPUT
W 4654	AIHOPMAX2	HOPPER #2 MAX. THROUGHPUT
W 4655	AIHOPMAX3	HOPPER #3 MAX. THROUGHPUT
W 4656	AIHOPMAX4	HOPPER #4 MAX. THROUGHPUT
W 4657	AIHOPMAX5	HOPPER #5 MAX. THROUGHPUT
W 4658	AIHOPMIN1	HOPPER #1 MIN. THROUGHPUT
W 4659	AIHOPMIN2	HOPPER #2 MIN. THROUGHPUT
W 4660	AIHOPMIN3	HOPPER #3 MIN. THROUGHPUT
W 4661	AIHOPMIN4	HOPPER #4 MIN. THROUGHPUT
W 4662	AIHOPMIN5	HOPPER #5 MIN. THROUGHPUT
W 4663	AOREC1	RECIPE RATIO FOR HOPPER #1
W 4664	AOREC2	RECIPE RATIO FOR HOPPER #2
W 4665	AOREC3	RECIPE RATIO FOR HOPPER #3
W 4666	AOREC4	RECIPE RATIO FOR HOPPER #4
W 4667		THROUGHPUT MAX. TEMPORARY CALCULATING
W 4668		THROUGHPUT MIN. TEMPORARY CALCULATING
W 4669	ARCONAIR+18	HOPPER #1 THROUGHPUT
W 4670	ARCONAIR+19	HOPPER #2 THROUGHPUT
W 4671	ARCONAIR+20	HOPPER #3 THROUGHPUT
W 4672	ARCONAIR+21	HOPPER #4 THROUGHPUT
W 4673	ARCONAIR+22	HOPPER #5 THROUGHPUT
W 4674	AOREC5	RECIPE RATIO FOR HOPPER #5
W 4675	ARDEBUG2+45	TOTAL THROUGHPUT
W 4676	WEIGHT ON HOPPER 2 CONAIR-SR20 L30+2	
W 4677	WEIGHT ON HOPPER 3 CONAIR-SR20 L30+2	
W 4678	WEIGHT ON HOPPER 4 CONAIR	
W 4679	FREE	
W 4680	FREE	

W 4681	FREE	
W 4682	FREE	
W 4683	FREE	
W 4684	FREE	
W 4685	FREE	
W 4686	FREE	
W 4687	FREE	
W 4688	FREE	
W 4689	FREE	
W 4690	FREE	
W 4691	FREE	
W 4692	FREE	
W 4693	FREE	
W 4694	FREE	
W 4695	FREE	
W 4696	FREE	
W 4697	FREE	
W 4698	FREE	
		FIX DMACS-ANALOG INPUT
W 4700	AIMER300	MEASURE R300
W 4701	AIOUR300	OUTPUT
W 4702	AISPR300	SET POINT
W 4703	AIMER301	MEASURE R301
W 4704	AIOUR301	OUTPUT
W 4705	AISPR301	SET POINT
W 4706	AIMER302	MEASURE R302
W 4707	AIOUR302	OUTPUT
W 4708	AISPR302	SET POINT
W 4709	AIMER303	MEASURE R303
W 4710	AIOUR303	OUTPUT
W 4711	AISPR303	SET POINT
W 4712	AIMER304	MEASURE R304
W 4713	AIOUR304	OUTPUT
W 4714	AISPR304	SET POINT
W 4715	AIMER305	MEASURE R305
W 4716	AIOUR305	OUTPUT
W 4717	AISPR305	SET POINT
W 4718	AIMER306	MEASURE R306
W 4719	AIOUR306	OUTPUT
W 4720	AISPR306	SET POINT
W 4721	AIMER307	MEASURE R307
W 4722	AIOUR307	OUTPUT
W 4723	AISPR307	SET POINT
W 4724	AIMER308	MEASURE R308
W 4725	AIOUR308	OUTPUT
W 4726	AISPR308	SET POINT
W 4727	AIMER309	MEASURE R309
W 4728	AIOUR309	OUTPUT
W 4729	AISPR309	SET POINT
W 4730	AIMER310	MEASURE R310
W 4731	AIOUR310	OUTPUT
W 4732	AISPR310	SET POINT
W 4733	AIMER311	MEASURE R311
W 4734	AIOUR311	OUTPUT
W 4735	AISPR311	SET POINT
W 4736	AIMER312	MEASURE R312
W 4737	AIOUR312	OUTPUT
W 4738	AISPR312	SET POINT

W 4739	AIMER313	MEASURE	R313
W 4740	AIOUR313	OUTPUT	
W 4741	AISPR313	SET POINT	
W 4742	AIMER314	MEASURE	R314
W 4743	AIOUR314	OUTPUT	
W 4744	AISPR314	SET POINT	
W 4745	AIMER315	MEASURE	R315
W 4746	AIOUR315	OUTPUT	
W 4747	AISPR315	SET POINT	
W 4748	AIMER316	MEASURE	R316
W 4749	AIOUR316	OUTPUT	
W 4750	AISPR316	SET POINT	
W 4751	AIMER317	MEASURE	R317
W 4752	AIOUR317	OUTPUT	
W 4753	AISPR317	SET POINT	
W 4754	AIMER318	MEASURE	R318
W 4755	AIOUR318	OUTPUT	
W 4756	AISPR318	SET POINT	
W 4757	AIMER319	MEASURE	R319
W 4758	AIOUR319	OUTPUT	
W 4759	AISPR319	SET POINT	
W 4760	AIMER320	MEASURE	R320
W 4761	AIOUR320	OUTPUT	
W 4762	AISPR320	SET POINT	
W 4763	AIMER321	MEASURE	R321
W 4764	AIOUR321	OUTPUT	
W 4765	AISPR321	SET POINT	
W 4766	AIMER322	MEASURE	R322
W 4767	AIOUR322	OUTPUT	
W 4768	AISPR322	SET POINT	
W 4769	AIMER323	MEASURE	R323
W 4770	AIOUR323	OUTPUT	
W 4771	AISPR323	SET POINT	
W 4772	AIMER324	MEASURE	R324
W 4773	AIOUR324	OUTPUT	
W 4774	AISPR324	SET POINT	
W 4775	AIMER325	MEASURE	R325
W 4776	AIOUR325	OUTPUT	
W 4777	AISPR325	SET POINT	
W 4778	AIMER326	MEASURE	R326
W 4779	AIOUR326	OUTPUT	
W 4780	AISPR326	SET POINT	
W 4781	AIMER327	MEASURE	R327
W 4782	AIOUR327	OUTPUT	
W 4783	AISPR327	SET POINT	
W 4784	FREE		
W 4785	FREE		
W 4786	FREE		
W 4787	FREE		
W 4788	HOPPER 1 WEIGHT- SR20 L30+1		
W 4789	HOPPER 4 WEIGHT		
W 4790	AIMER330	MEASURE	R330
W 4791	AIOUR330	OUTPUT	
W 4792	AISPR330	SET POINT	
W 4793	AIMER331	MEASURE	R331
W 4794	AIOUR331	OUTPUT	
W 4795	AISPR331	SET POINT	
W 4796	AIMER332	MEASURE	R332

W 4797	AIOUR332	OUTPUT
W 4798	AISPR332	SET POINT
W 4799	AIMER333	MEASURE R333
W 4800	AIOUR333	OUTPUT
W 4801	AISPR333	SET POINT
W 4802	FREE	
W 4803	FREE	
W 4804	FREE	
W 4805	FREE	
W 4806	FREE	
W 4807	AIMER340	MEASURE R340
W 4808	AIOUR340	OUTPUT
W 4809	AISPR340	SET POINT
W 4810	AIMER341	MEASURE R341
W 4811	AIOUR341	OUTPUT
W 4812	AISPR341	SET POINT
W 4813	AIMER342	MEASURE R342
W 4814	AIOUR342	OUTPUT
W 4815	AISPR342	SET POINT
W 4816	AIMER343	MEASURE R343
W 4817	AIOUR343	OUTPUT
W 4818	AISPR343	SET POINT
W 4819	AIMER344	MEASURE R344
W 4820	AIOUR344	OUTPUT
W 4821	AISPR344	SET POINT
W 4822	AIMER345	MEASURE R345
W 4823	AIOUR345	OUTPUT
W 4824	AISPR345	SET POINT
W 4825	AIMER346	MEASURE R346
W 4826	AIOUR346	OUTPUT
W 4827	AISPR346	SET POINT
W 4828	AIMER347	MEASURE R347
W 4829	AIOUR347	OUTPUT
W 4830	AISPR347	SET POINT
W 4831	AIMER348	MEASURE R348
W 4832	AIOUR348	OUTPUT
W 4833	AISPR348	SET POINT
W 4834	AIMER349	MEASURE R349
W 4835	AIOUR349	OUTPUT
W 4836	AISPR349	SET POINT
W 4837	AIMER350	MEASURE R350
W 4838	AIOUR350	OUTPUT
W 4839	AISPR350	SET POINT
W 4840	AIMER351	MEASURE R351
W 4841	AIOUR351	OUTPUT
W 4842	AISPR351	SET POINT
W 4843	AIMER352	MEASURE R352
W 4844	AIOUR352	OUTPUT
W 4845	AISPR352	SET POINT
W 4846	AIMER353	MEASURE R353
W 4847	AIOUR353	OUTPUT
W 4848	AISPR353	SET POINT
W 4849	AIMER354	MEASURE R354
W 4850	AIOUR354	OUTPUT
W 4851	AISPR354	SET POINT
W 4852	AIMER355	MEASURE R355
W 4853	AIOUR355	OUTPUT
W 4854	AISPR355	SET POINT

W 4855	AIMER356	MEASURE	R356
W 4856	AIOUR356	OUTPUT	
W 4857	AISPR356	SET POINT	
W 4858	AIMER357	MEASURE	R357
W 4859	AIOUR357	OUTPUT	
W 4860	AISPR357	SET POINT	
W 4861	AIMER358	MEASURE	R358
W 4862	AIOUR358	OUTPUT	
W 4863	AISPR358	SET POINT	
W 4864	AIMER359	MEASURE	R359
W 4865	AIOUR359	OUTPUT	
W 4866	AISPR359	SET POINT	
W 4867	AIMER360	MEASURE	R360
W 4868	AIOUR360	OUTPUT	
W 4869	AISPR360	SET POINT	
W 4870	AIMER361	MEASURE	R361
W 4871	AIOUR361	OUTPUT	
W 4872	AISPR361	SET POINT	
W 4873	E003 MAIN HOPPER SCREW AUTHORIZATION		
W 4874	E004 HOMO SCREW SPEED		
W 4875	E002 PRODUCT C SCREW SPEED		
W 4876	AIMER200	MEASURE	R200
W 4877	AIOUR200	OUTPUT	
W 4878	AISPR200	SET POINT	
W 4879			
W 4880	AIT500	MEASURE	T500
W 4881	AIP501	MEASURE	P501
W 4882	AIT502	MEASURE	T502
W 4883	AIP503	MEASURE	P503
W 4884	AIT504	MEASURE	T504
W 4885	AIP505	MEASURE	P505
W 4886	AIT506	MEASURE	T506
W 4887	AIP507	MEASURE	P507
W 4888	AIT510	MEASURE	T510
W 4889	AIP511	MEASURE	P511
W 4890	AIT512	MEASURE	T512
W 4891	AIP513	MEASURE	P513
W 4892	AIP514	MEASURE	P514
W 4893	AIT515	MEASURE	T515
W 4894	AIP516	MEASURE	P516
W		FREE	
W		SEE "WORD BIT"	
W		FREE	
W 5200		PERCENTAGE OF (RECLAIM+HOMO+ADDI) SETTING	
W		FREE	
W 5881		P501 MEASURE, BEFORE VALUE TRANSFER	
W 5882			
W 5883		P503 MEASURE, BEFORE VALUE TRANSFER	
W 5884			
W 5885		P505 MEASURE, BEFORE VALUE TRANSFER	
W 5886			
W 5887		P507 MEASURE, BEFORE VALUE TRANSFER	
W 5888			
W 5889		P511 MEASURE, BEFORE VALUE TRANSFER	
W 5890		P512 MEASURE, BEFORE VALUE TRANSFER	
W 5891			
W 5892		P514 MEASURE, BEFORE VALUE TRANSFER	
W 5893			

W 5894		P516 MEASURE, BEFORE VALUE TRANSFER
W		FREE

FIX-DMACS DIGITAL OUTPUT/INPUT BITS

F12\WORDBIT2.DOC

W 4600 0	DOSTE 100	START/STOP SAT EXTRUDER1
W 4600 1	DOSTE 101	START/STOP SAT EXTRUDER1
W 4600 2	DOSTE 102	START/STOP SAT EXTRUDER1
W 4600 3	DOSTE 103	START/STOP SAT EXTRUDER1
W 4600 4	DOSTE 104	START/STOP SAT EXTRUDER1
W 4600 5	DOSTE 105	START/STOP SAT EXTRUDER1
W 4600 6	DOSTE 106	START/STOP SAT EXTRUDER1
W 4600 7	DOSTE 107	START/STOP SAT EXTRUDER1
W 4600 8	DOSTE 108	START/STOP SAT EXTRUDER1
W 4600 9		
W 4600 A	DOSTE 110	START/STOP SAT EXTRUDER2
W 4600 B	DOSTE 111	START/STOP SAT EXTRUDER2
W 4600 C	DOSTE 112	START/STOP SAT EXTRUDER2
W 4600 D	DOSTE 113	START/STOP SAT EXTRUDER2
W 4600 E	DOSTE 114	START/STOP SAT EXTRUDER2
W 4600 F	DOSTE 115	START/STOP SAT EXTRUDER2
W 4601 0	DOSTE 116	START/STOP SAT EXTRUDER2
W 4601 1	DOSTE 117	START/STOP SAT EXTRUDER2
W 4601 2	DOSTE 118	START/STOP SAT EXTRUDER2
W 4601 3		
W 4601 4	DOSTE 120	START/STOP MAIN EXTRUDER1
W 4601 5	DOSTE 121	START/STOP MAIN EXTRUDER1
W 4601 6	DOSTE 122	START/STOP MAIN EXTRUDER1
W 4601 7	DOSTE 123	START/STOP MAIN EXTRUDER1
W 4601 8	DOSTE 124	START/STOP MAIN EXTRUDER1
W 4601 9	DOSTE 125	START/STOP MAIN EXTRUDER1
W 4601 A	DOSTE 126	START/STOP MAIN EXTRUDER1
W 4601 B	DOSTE 127	START/STOP MAIN EXTRUDER1
W 4601 C	DOSTE 128	MAIN EXTRUDER1 PUMP
W 4601 D		
W 4601 E	DOSTE 130	START/STOP BETWEEN MAIN EX1 & MAIN EX2
W 4601 F	DOSTE 131	START/STOP BETWEEN MAIN EX1 & MAIN EX2
W 4602 0	DOSTE 132	START/STOP BETWEEN MAIN EX1 & MAIN EX2
W 4602 1	DOSTE 133	START/STOP BETWEEN MAIN EX1 & MAIN EX2
W 4602 2	DOSTE 134	START/STOP MELT LINE OIL SKID PUMP M1240.02
W 4602 3	DOSTE 135	START/STOP MELT LINE OIL SKID 1240.02
W 4602 4		
W 4602 5		
W 4602 6		
W 4602 7		
W 4602 8	DOSTE 140	START/STOP MAIN EX2
W 4602 9	DOSTE 141	START/STOP MAIN EX2
W 4602 A	DOSTE 142	START/STOP MAIN EX2
W 4602 B	DOSTE 143	START/STOP MAIN EX2
W 4602 C	DOSTE 144	START/STOP MAIN EX2
W 4602 D	DOSTE 145	START/STOP MAIN EX2
W 4602 E	DOSTE 146	START/STOP MAIN EX2
W 4602 F	DOSTE 147	START/STOP MAIN EX2
W 4603 0	DOSTE 148	MAIN EX2 PUMP
W 4603 1	DOSTE 149	START/STOP EXT2 STATIC MIXER CONNECTION ZONE
W 4603 2	DOSTE 150	START/STOP EXT2 STATIC MIXER HEATING ZONE
W 4603 3	DOSTE 151	START/STOP EXT2 DIVERTER HEATING ZONE

W 4603 4		
W 4603 5	DOSTE 153	START/STOP DIE HEATER ZONE1
W 4603 6	DOSTE 154	START/STOP DIE HEATER ZONE2
W 4603 7	DOSTE 155	START/STOP DIE HEATER ZONE3
W 4603 8	DOSTE 156	START/STOP DIE HEATER ZONE4
W 4603 9	DOSTE 157	START/STOP DIE HEATER ZONE5
W 4603 A	DOSTE 158	START/STOP DIE HEATER ZONE6
W 4603 B	DOSTE 159	START/STOP DIE HEATER ZONE7
W 4603 C		
W 4603 D		
W 4603 E		
W 4603 F		
W 4604 0	DOSTE R303	BIT START CONTROL LOOP SATELLITE EX1 MELT LINE
W 4604 1	DOSTE R319	BIT START CONTROL LOOP SATELLITE EX2 MELT LINE
W 4604 2	DOSTE R348	BIT START CONTROL LOOP MAIN EX1 MELT LINE
W 4604 3	DOSTE R349	BIT START CONTROL LOOP MAIN EX2 MELT LINE
W 4604 4		
W 4604 5		
W 4604 6		
W 4604 7		
W 4604 8		
W 4604 9		
W 4604 A		
W 4604 B		
W 4604 C		
W 4604 D		
W 4604 E		
W 4604 F		
W 4605 0	DOSTE 1	START/STOP HOMO DRYER
W 4605 1	DOSTE 2	START/STOP RECLAIM DRYER
W 4605 2	DOSTE 3	START/STOP MOTOR
W 4605 3	DOSTE 4	START/STOP MOTOR
W 4605 4	DOSTE 5	START/STOP MOTOR
W 4605 5	DOSTE 6	START/STOP MOTOR, MIXING SCREW
W 4605 6	DOSTE 7	START/STOP MOTOR, ROTARY ARM
W 4605 7	DOSTE 8	START/STOP FEEDING VALVE FOR MIXING HOPPER
W 4605 8		
W 4605 9	DOSTE 10	START/STOP SAT1 DRYER
W 4605 A	DOSTE 11	START/STOP SAT2 DRYER
W 4605 B	DOSTE 12	START/STOP ADDITIVE PUMP
W 4605 C		
W 4605 D		
W 4605 E		
W 4605 F		
W 4606 0		
W 4606 1		
W 4606 2		FEEDING SYSTEM START/STOP
W 4606 3		
W 4606 4		
W 4606 5		
W 4606 6		
W 4606 7		
W 4606 8		
W 4606 9		
W 4606 A		

W 4606 B		
W 4606 C		
W 4606 D		
W 4606 E		
W 4606 F		
W 4607 0	DRCONAIR+0	RUN SYSTEM CONAIR
W 4607 1	DRCONLOW+1	LOW LEVEL IN HOPPER #1 CONAIR
W 4607 2	DRCONLOW+2	LOW LEVEL IN HOPPER #2 CONAIR
W 4607 3	DRCONLOW+3	LOW LEVEL IN HOPPER #3 CONAIR
W 4607 4	DRCONLOW+4	LOW LEVEL IN HOPPER #4 CONAIR
W 4607 5	DRCONLOW+5	LOW LEVEL IN HOPPER #5 CONAIR
W 4607 6	DRCHECK+6 DRDOORS+6	DOOR LOCK OPEN CONAIR
W 4607 7	DRRECIPE+7 DRINVALID +7	RECIPE UNACCEPTABLE CONAIR
W 4607 8		
W 4607 9	DRCONRESET+9	RESET THROUGHPUT CONAIR
W 4607 A	DRHIGH+10	HIGH LEVEL IN HOPPER #5 CONAIR
W 4607 B	DRHIGH+11	HIGH LEVEL IN HOPPER #1 CONAIR
W 4607 C	DRHIGH+12	HIGH LEVEL IN HOPPER #2 CONAIR
W 4607 D	DRHIGH+13	HIGH LEVEL IN HOPPER #3 CONAIR
W 4607 E	DRHIGH+14	HIGH LEVEL IN HOPPER #4 CONAIR
W 4607 F		
W 4608 0	DRCONLOW+16	LOW LEVEL IN MIXING HOPPER CONAIR
W 4608 1	DRHIGH+17	HIGH LEVEL IN MIXING HOPPER CONAIR
W 4608 2	DRCONAIR+18	MOTOR #1 RUN CONAIR
W 4608 3	DRCONAIR+19	MOTOR #2 RUN CONAIR
W 4608 4	DRCONAIR+20	MOTOR #3 RUN CONAIR
W 4608 5	DRCONAIR+21	MOTOR #4 RUN CONAIR
W 4608 6	DRCONAIR+22	MOTOR #5 RUN CONAIR
W 4608 7	DIFAM1	DEFECT OF CONAIR AUGER MOTOR #1 CONAIR
W 4608 8	DIFAM2	DEFECT OF CONAIR AUGER MOTOR #2 CONAIR
W 4608 9	DIFAM3	DEFECT OF CONAIR AUGER MOTOR #3 CONAIR
W 4608 A	DIFAM4	DEFECT OF CONAIR AUGER MOTOR #4 CONAIR
W 4608 B	DIFAM5	DEFECT OF CONAIR AUGER MOTOR #5 CONAIR
W 4608 C	DRAAMS+0	RUN SYSTEM IN MANUAL CONAIR
W 4608 D	DRCONAIR+29	MIXER MOTOR DEFECT CONAIR
W 4608 E	DRCONAIR+30	MIXER MOTOR RUN CONAIR
W 4608 F		
W 4609 0	DRTOO+0 DRLONG+0	HOPPER #1 FILL TOO LONG TIME CONAIR
W 4609 1	DRTOO+1 DRLONG+1	HOPPER #2 FILL TOO LONG TIME CONAIR
W 4609 2	DRTOO+2 DRLONG+2	HOPPER #3 FILL TOO LONG TIME CONAIR
W 4609 3	DRTOO+3 DRLONG+3	HOPPER #4 FILL TOO LONG TIME CONAIR
W 4609 4	DRTOO+4 DRLONG+4	HOPPER #5 FILL TOO LONG TIME CONAIR
W 4609 5	DRFILL+0	HOPPER #1 - FILLING CONAIR
W 4609 6	DRFILL+1	HOPPER #2 - FILLING CONAIR
W 4609 7	DRFILL+2	HOPPER #3 - FILLING CONAIR
W 4609 8	DRFILL+3	HOPPER #4 - FILLING CONAIR
W 4609 9	DRFILL+4	HOPPER #5 - FILLING CONAIR
W 4609 A		

W 4609 B		
W 4609 C		
W 4609 D		
W 4609 E		
W 4609 F		
W 4610 0	DOAMR 300	AUTO(0)/MANU(1) FOR TEMPERATURE CONTROL LOOP
W 4610 1	DOAMR 301	AUTO(0)/MANU(1)
W 4610 2	DOAMR 302	AUTO(0)/MANU(1)
W 4610 3	DOAMR 303	AUTO(0)/MANU(1)
W 4610 4	DOAMR 304	AUTO(0)/MANU(1)
W 4610 5	DOAMR 305	AUTO(0)/MANU(1)
W 4610 6	DOAMR 306	AUTO(0)/MANU(1)
W 4610 7	DOAMR 307	AUTO(0)/MANU(1)
W 4610 8	DOAMR 308	AUTO(0)/MANU(1)
W 4610 9	DOAMR 309	AUTO(0)/MANU(1)
W 4610 A	DOAMR 310	AUTO(0)/MANU(1)
W 4610 B	DOAMR 311	AUTO(0)/MANU(1)
W 4610 C	DOAMR 312	AUTO(0)/MANU(1)
W 4610 D	DOAMR 313	AUTO(0)/MANU(1)
W 4610 E	DOAMR 314	AUTO(0)/MANU(1)
W 4610 F	DOAMR 315	AUTO(0)/MANU(1)
W 4611 0	DOAMR 316	AUTO(0)/MANU(1)
W 4611 1	DOAMR 317	AUTO(0)/MANU(1)
W 4611 2	DOAMR 318	AUTO(0)/MANU(1)
W 4611 3	DOAMR 319	AUTO(0)/MANU(1)
W 4611 4	DOAMR 320	AUTO(0)/MANU(1)
W 4611 5	DOAMR 321	AUTO(0)/MANU(1)
W 4611 6	DOAMR 322	AUTO(0)/MANU(1)
W 4611 7	DOAMR 323	AUTO(0)/MANU(1)
W 4611 8	DOAMR 324	AUTO(0)/MANU(1)
W 4611 9	DOAMR 325	AUTO(0)/MANU(1)
W 4611 A	DOAMR 326	AUTO(0)/MANU(1)
W 4611 B	DOAMR 327	AUTO(0)/MANU(1)
W 4611 C		
W 4611 D		
W 4611 E	DOAMR 330	AUTO(0)/MANU(1)
W 4611 F	DOAMR 331	AUTO(0)/MANU(1)
W 4612 0	DOAMR 332	AUTO(0)/MANU(1)
W 4612 1	DOAMR 333	AUTO(0)/MANU(1)
W 4612 2		
W 4612 3		
W 4612 4		
W 4612 5		
W 4612 6		
W 4612 7		
W 4612 8	DOAMR 340	AUTO(0)/MANU(1)
W 4612 9	DOAMR 341	AUTO(0)/MANU(1)
W 4612 A	DOAMR 342	AUTO(0)/MANU(1)
W 4612 B	DOAMR 343	AUTO(0)/MANU(1)
W 4612 C	DOAMR 344	AUTO(0)/MANU(1)
W 4612 D	DOAMR 345	AUTO(0)/MANU(1)
W 4612 E	DOAMR 346	AUTO(0)/MANU(1)
W 4612 F	DOAMR 347	AUTO(0)/MANU(1)
W 4613 0	DOAMR 348	AUTO(0)/MANU(1)

W 4613 1	DOAMR 349	AUTO(0)/MANU(1)
W 4613 2	DOAMR 350	AUTO(0)/MANU(1)
W 4613 3	DOAMR 351	AUTO(0)/MANU(1)
W 4613 4	DOAMR 352	AUTO(0)/MANU(1)
W 4613 5	DOAMR 353	AUTO(0)/MANU(1)
W 4613 6	DOAMR 354	AUTO(0)/MANU(1)
W 4613 7	DOAMR 355	AUTO(0)/MANU(1)
W 4613 8	DOAMR 356	AUTO(0)/MANU(1)
W 4613 9	DOAMR 357	AUTO(0)/MANU(1)
W 4613 A	DOAMR 358	AUTO(0)/MANU(1)
W 4613 B	DOAMR 359	AUTO(0)/MANU(1)
W 4613 C	DOAMR 360	AUTO(0)/MANU(1)
W 4613 D	DOAMR 361	AUTO(0)/MANU(1)
W 4613 E		
W 4613 F	DOAMR 200	AUTO(0)/MANU(1)
W 4620 0	SAT1S	START SATELLITE EX1 ALL ZONES
W 4620 1		
W 4620 2	MELT1 S	START SATELLITE EX1 MELT LINE ALL EQUIPMENTS
W 4620 3	SAT2S	START SATELLITE EX2 MELT LINE ALL EQUIPMENTS
W 4620 4		
W 4620 5	MELT2 S	START SAT2 MELT LINE ALL EQUIPMENTS
W 4620 6	PRIS	START PRIMARY EXT HEATING
W 4620 7		
W 4620 8	MBES	START MAIN EX1 MELT LINE
W 4620 9	SECS	START MAIN EX2 ALL ZONES
W 4620 A		
W 4620 B	MTDS	START MAIN EX2 MELT LINE TO DIE
W 4620 C	DIES	START DIE ALL EQUIPMENTS
W 4620 D		
W 4620 E		
W 4620 F		
W 4621 0	DOPU SAT1	PURGE SAT EX1
W 4621 1	DOPU SAT2	PURGE SAT EX2
W 4621 2	DOPU EXT	PURGE MAIN EXT 1&2
W 4621 3	DOSB SAT1	STANDBY SAT1
W 4621 4	DOSB SAT2	STANDBY SAT2
W 4621 5	DOSB EXT	STANDBY EXTRUDER 1&2
W 4621 6		
W 4621 7		
W 4621 8		
W 4621 9		
W 4621 A		
W 4621 B		
W 4621 C		
W 4621 D	DO REDE	RELEASE DEFECT
W 4621 E	DORE KLA	RELEASE KLAXON
W 4621 F		
W 4622 0	SAT1 SO	STOP SAT1 ALL EQUIP
W 4622 1		
W 4622 2	MELT1 SO	STOP SAT MELT LINE
W 4622 3		
W 4622 4		
W 4622 5		
W 4622 6	PRISO	STOP PRI EXT ALL EQUIPMENTS
W 4622 7		

W 4622 8	MBESO	STOP MELT BETWEEN EXT
W 4622 9	SEOSO	STOP SEC EXT ALL EQUIPMENTS
W 4622 A		
W 4622 B	MTDSO	STOP MELT TO DIE
W 4622 C	DIESO	STOP DIE
W 4622 D		
W 4622 E		
W 4622 F		
W 4623 0		
W 4623 1		
W 4623 2		
W 4623 3		
W 4623 4		
W 4623 5		
W 4623 6		
W 4623 7		
W 4623 8		
W 4623 9		
W 4623 A		
W 4623 B		
W 4623 C		
W 4623 D		
W 4623 E		
W 4623 F		
W 4920 0	DIREE 100	ANSWER CONTACTOR SAT EX1
W 4920 1	DIREE 101	ANSWER CONTACTOR SAT EX1
W 4920 2	DIREE 102	ANSWER CONTACTOR SAT EX1
W 4920 3	DIREE 103	ANSWER CONTACTOR SAT EX1
W 4920 4	DIREE 104	ANSWER CONTACTOR SAT EX1
W 4920 5	DIREE 105	ANSWER CONTACTOR SAT EX1
W 4920 6	DIREE 106	ANSWER CONTACTOR SAT EX1
W 4920 7	DIREE 107	ANSWER CONTACTOR SAT EX1
W 4920 8	DIREE 108	ANSWER CONTACTOR SAT EX1
W 4920 9		
W 4920 A	DIREE 110	ANSWER CONTACTOR SAT EX2
W 4920 B	DIREE 111	ANSWER CONTACTOR SAT EX2
W 4920 C	DIREE 112	ANSWER CONTACTOR SAT EX2
W 4920 D	DIREE 113	ANSWER CONTACTOR SAT EX2
W 4920 E	DIREE 114	ANSWER CONTACTOR SAT EX2
W 4920 F	DIREE 115	ANSWER CONTACTOR SAT EX2
W 4921 0	DIREE 116	ANSWER CONTACTOR SAT EX2
W 4921 1	DIREE 117	ANSWER CONTACTOR SAT EX2
W 4921 2	DIREE 118	ANSWER CONTACTOR SAT EX2
W 4921 3		
W 4921 4	DIREE 120	ANSWER CONTACTOR MAIN EX1
W 4921 5	DIREE 121	ANSWER CONTACTOR MAIN EX1
W 4921 6	DIREE 122	ANSWER CONTACTOR MAIN EX1
W 4921 7	DIREE 123	ANSWER CONTACTOR MAIN EX1
W 4921 8	DIREE 124	ANSWER CONTACTOR MAIN EX1
W 4921 9	DIREE 125	ANSWER CONTACTOR MAIN EX1
W 4921 A	DIREE 126	ANSWER CONTACTOR MAIN EX1
W 4921 B	DIREE 127	ANSWER CONTACTOR MAIN EX1
W 4921 C	DIREE 128	MAIN EX1 COOLING PUMP
W 4921 D	DIREE 129	
W 4921 E	DIREE 130	ANSWER CONTACTOR EXT1 MELT LINE ZONE 1

W 4921 F	DIREE 131	ANSWER CONTACTOR EXT1 MELT LINE ZONE 2
W 4922 0	DIREE 132	ANSWER CONTACTOR EXT1 MELT LINE ZONE 3
W 4922 1	DIREE 133	ANSWER CONTACTOR EXT1 MELT LINE ZONE 4
W 4922 2	DIREE 134	ANSWER CONTACTOR MELT LINE OIL SKID PUMP
W 4922 3	DIREE 135	ANSWER CONTACTOR MELT LINE OIL SKID HEATER
W 4922 4		
W 4922 5		
W 4922 6		
W 4922 7		
W 4922 8	DIREE 140	ANSWER CONTACTOR MAIN EX2
W 4922 9	DIREE 141	ANSWER CONTACTOR MAIN EX2
W 4922 A	DIREE 142	ANSWER CONTACTOR MAIN EX2
W 4922 B	DIREE 143	ANSWER CONTACTOR MAIN EX2
W 4922 C	DIREE 144	ANSWER CONTACTOR MAIN EX2
W 4922 D	DIREE 145	ANSWER CONTACTOR MAIN EX2
W 4922 E	DIREE 146	ANSWER CONTACTOR MAIN EX2
W 4922 F	DIREE 147	ANSWER CONTACTOR MAIN EX2
W 4923 0	DIREE 148	CONTACTOR ANSWER, MAIN EX2 COOLING PUMP
W 4923 1	DIREE 149	CONTACTOR ANSWER, STATIC MIXER CONNECTION ZONE
W 4923 2	DIREE 150	CONTACTOR ANSWER, STATIC MIXER
W 4923 3	DIREE 151	CONTACTOR ANSWER, DIVERTER
W 4923 4		
W 4923 5	DIREE 153	CONTACTOR ANSWER, DIE HEATER ZONE 1
W 4923 6	DIREE 154	CONTACTOR ANSWER, DIE HEATER ZONE 2
W 4923 7	DIREE 155	CONTACTOR ANSWER, DIE HEATER ZONE 3
W 4923 8	DIREE 156	CONTACTOR ANSWER, DIE HEATER ZONE 4
W 4923 9	DIREE 157	CONTACTOR ANSWER, DIE HEATER ZONE 5
W 4923 A	DIREE 158	CONTACTOR ANSWER, DIE HEATER ZONE 6
W 4923 B	DIREE 159	CONTACTOR ANSWER, DIE HEATER ZONE 7
W 4923 C		
W 4923 D		
W 4923 E		
W 4923 F		
W 4925 0	DIREE 1	ANSWER CONTACTOR, HOMO DRYER
W 4925 1	DIREE 2	ANSWER CONTACTOR, RECLAIM DRYER
W 4925 2	DIREE 3	ANSWER CONTACTOR, AUGER MOTOR M1106.01
W 4925 3	DIREE 4	ANSWER CONTACTOR, AUGER MOTOR M1106.02
W 4925 4	DIREE 5	ANSWER CONTACTOR, AUGER MOTOR M1112.01
W 4925 5	DIREE 6	ANSWER CONTACTOR, MIXING SCREW MOTOR
W 4925 6	DIREE 7	ANSWER CONTACTOR, ROTATING ARM MOTOR
W 4925 7	DIREE 8	ANSWER CONTACTOR, VALVE SV 1111.21
W 4925 8	DIREE 9	
W 4925 9	DIREE 10	
W 4925 A	DIREE 11	
W 4925 B	DIREE 12	
W 4925 C	DIREE 13	
W 4925 D		
W 4925 E		
W 4925 F		
W 4926 0		
W 4926 1		
W 4926 2		
W 4926 3		
W 4926 4		

W 4926 5		
W 4926 6		
W 4926 7		
W 4926 8		
W 4926 9		
W 4926 A		
W 4926 B		
W 4926 C		
W 4926 D		
W 4926 E		
W 4926 F		
W 4928 0	DICM 121008	CONTACTOR ANSWER, SAT1 FAN ZONE 1
W 4928 1	DICM 121009	CONTACTOR ANSWER, SAT1 FAN ZONE 2
W 4928 2	DICM 121010	CONTACTOR ANSWER, SAT1 FAN ZONE 3
W 4928 3	DICM 121011	CONTACTOR ANSWER, SAT1 FAN ZONE 4
W 4928 4	DICM 121012	CONTACTOR ANSWER, SAT1 FAN ZONE 5
W 4928 5	DICM 121013	CONTACTOR ANSWER, SAT1 FAN ZONE 6
W 4928 6	DICM 121014	CONTACTOR ANSWER, SAT1 FAN ZONE 7
W 4928 7	DICM 121022	CONTACTOR ANSWER, SAT2 FAN ZONE 1
W 4928 8	DICM 121023	CONTACTOR ANSWER, SAT2 FAN ZONE 2
W 4928 9	DICM 121024	CONTACTOR ANSWER, SAT2 FAN ZONE 3
W 4928 A	DICM 121025	CONTACTOR ANSWER, SAT2 FAN ZONE 4
W 4928 B	DICM 121026	CONTACTOR ANSWER, SAT2 FAN ZONE 5
W 4928 C	DICM 121027	CONTACTOR ANSWER, SAT2 FAN ZONE 6
W 4928 D	DICM 121028	CONTACTOR ANSWER, SAT2 FAN ZONE 7
W 4928 E	DISV 120001	CONTACTOR ANSWER, EXT1 COOLING VALVE ZONE 1
W 4928 F	DISV 120002	CONTACTOR ANSWER, EXT1 COOLING VALVE ZONE 2
W 4929 0	DISV 120003	CONTACTOR ANSWER, EXT1 COOLING VALVE ZONE 3
W 4929 1	DISV 120004	CONTACTOR ANSWER, EXT1 COOLING VALVE ZONE 4
W 4929 2	DISV 120005	CONTACTOR ANSWER, EXT2 COOLING VALVE ZONE 1
W 4929 3	DISV 120006	CONTACTOR ANSWER, EXT2 COOLING VALVE ZONE 2
W 4929 4	DISV 120007	CONTACTOR ANSWER, EXT2 COOLING VALVE ZONE 3
W 4929 5	DISV 120008	CONTACTOR ANSWER, EXT2 COOLING VALVE ZONE 4
W 4929 6		
W 4929 7	DISV 120000	CONTACTOR ANSWER, EXT1 COOLING VALVE SV1200.00
W 4929 8		
W 4929 9		
W 4929 A		
W 4929 B		
W 4929 C		
W 4929 D		
W 4929 E		
W 4929 F		
W 4930 0	DIFAE 100	DEFECT OF SAT EXT1 HEATER
W 4930 1	DIFAE 101	DEFECT OF SAT EXT1 HEATER
W 4930 2	DIFAE 102	DEFECT OF SAT EXT1 HEATER
W 4930 3	DIFAE 103	DEFECT OF SAT EXT1 HEATER
W 4930 4	DIFAE 104	DEFECT OF SAT EXT1 HEATER
W 4930 5	DIFAE 105	DEFECT OF SAT EXT1 HEATER
W 4930 6	DIFAE 106	DEFECT OF SAT EXT1 HEATER
W 4930 7	DIFAE 107	DEFECT OF SAT EXT1 HEATER
W 4930 8	DIFAE 108	DEFECT OF SAT EXT1 HEATER
W 4930 9		
W 4930 A	DIFAE 110	DEFECT OF SAT EXT2 HEATER
W 4930 B	DIFAE 111	DEFECT OF SAT EXT2 HEATER

W 4930 C	DIFAE 112	DEFECT OF SAT EXT2 HEATER
W 4930 D	DIFAE 113	DEFECT OF SAT EXT2 HEATER
W 4930 E	DIFAE 114	DEFECT OF SAT EXT2 HEATER
W 4930 F	DIFAE 115	DEFECT OF SAT EXT2 HEATER
W 4931 0	DIFAE 116	DEFECT OF SAT EXT2 HEATER
W 4931 1	DIFAE 117	DEFECT OF SAT EXT2 HEATER
W 4931 2	DIFAE 118	DEFECT OF SAT EXT2 HEATER
W 4931 3		
W 4931 4	DIFAE 120	DEFECT OF MAIN EXT1 HEATER
W 4931 5	DIFAE 121	DEFECT OF MAIN EXT1 HEATER
W 4931 6	DIFAE 122	DEFECT OF MAIN EXT1 HEATER
W 4931 7	DIFAE 123	DEFECT OF MAIN EXT1 HEATER
W 4931 8	DIFAE 124	DEFECT OF MAIN EXT1 HEATER
W 4931 9	DIFAE 125	DEFECT OF MAIN EXT1 HEATER
W 4931 A	DIFAE 126	DEFECT OF MAIN EXT1 HEATER
W 4931 B	DIFAE 127	DEFECT OF MAIN EXT1 HEATER
W 4931 C	DIFAE 128	DEFECT OF MAIN EXT1 COOLING PUMP
W 4931 D		
W 4931 E	DIFAE 130	DEFECT OF EXT1 MELT LINE ZONE 1
W 4931 F	DIFAE 131	DEFECT OF EXT1 MELT LINE ZONE 2
W 4932 0	DIFAE 132	DEFECT OF EXT1 MELT LINE ZONE 3
W 4932 1	DIFAE 133	DEFECT OF EXT1 MELT LINE ZONE 4
W 4932 2	DIFAE 134	DEFECT OF MELT LINE OIL SKID PUMP M1240.02
W 4932 3	DIFAE 135	DEFECT OF MELT LINE OIL SKID HEATER H1240.02
W 4932 4		
W 4932 5		
W 4932 6		
W 4932 7		
W 4932 8	DIFAE 140	DEFECT OF MAIN EXT2 HEATER ZONE 1
W 4932 9	DIFAE 141	DEFECT OF MAIN EXT2 HEATER ZONE 2
W 4932 A	DIFAE 142	DEFECT OF MAIN EXT2 HEATER ZONE 3
W 4932 B	DIFAE 143	DEFECT OF MAIN EXT2 HEATER ZONE 4
W 4932 C	DIFAE 144	DEFECT OF MAIN EXT2 ADAPTER
W 4932 D	DIFAE 145	DEFECT OF MAIN EXT2 FILTER ZONE 1
W 4932 E	DIFAE 146	DEFECT OF MAIN EXT2 FILTER ZONE 2
W 4932 F	DIFAE 147	DEFECT OF MAIN EXT2 FILTER ZONE 3
W 4933 0	DIFAE 148	DEFECT OF MAIN EXT2 COOLING PUMP
W 4933 1	DIFAE 149	DEFECT OF STATIC MIXER CONNECTION
W 4933 2	DIFAE 150	DEFECT OF STATIC MIXER HEATER
W 4933 3	DIFAE 151	DEFECT OF DIVERTER HEATING ZONE
W 4933 4		
W 4933 5	DIFAE 153	DEFECT OF DIE HEATER ZONE 1
W 4933 6	DIFAE 154	DEFECT OF DIE HEATER ZONE 2
W 4933 7	DIFAE 155	DEFECT OF DIE HEATER ZONE 3
W 4933 8	DIFAE 156	DEFECT OF DIE HEATER ZONE 4
W 4933 9	DIFAE 157	DEFECT OF DIE HEATER ZONE 5
W 4933 A	DIFAE 158	DEFECT OF DIE HEATER ZONE 6
W 4933 B	DIFAE 159	DEFECT OF DIE HEATER ZONE 7
W 4933 C		
W 4933 D		
W 4933 E		
W 4933 F		
W 4935 0	DIFAE 1	DEFECT OF HOMO DRYER
W 4935 1	DIFAE 2	DEFECT OF RECLAIM DRYER

W 4935 2	DIFAE 3	DEFECT OF AUGER MOTOR M1106.01
W 4935 3	DIFAE 4	DEFECT OF AUGER MOTOR M1106.02
W 4935 4	DIFAE 5	DEFECT OF AUGER MOTOR M1112.01
W 4935 5	DIFAE 6	DEFECT OF MIXING SCREW MOTOR M1114.01
W 4935 6	DIFAE 7	DEFECT OF ROTATING ARM MOTOR M1106.01
W 4935 7		
W 4935 8		
W 4935 9	DIFAE 10	DEFECT OF SAT1 DRYER
W 4935 A	DIFAE 11	DEFECT OF SAT2 DRYER
W 4935 B	DIFAE 12	DEFECT OF ADDITIVE PUMP
W 4935 C		
W 4935 D		
W 4935 E		
W 4935 F		
W 4936 0		
W 4936 1		
W 4936 2		
W 4936 3		
W 4936 4		
W 4936 5		
W 4936 6		
W 4936 7		
W 4936 8		
W 4936 9		
W 4936 A		
W 4936 B		
W 4936 C		
W 4936 D		
W 4936 E		
W 4936 F		
W 4938 0	DIFM 121008	DEFECT OF SAT1 COOLING FAN ZONE 1
W 4938 1	DIFM 121009	DEFECT OF SAT1 COOLING FAN ZONE 2
W 4938 2	DIFM 121010	DEFECT OF SAT1 COOLING FAN ZONE 3
W 4938 3	DIFM 121011	DEFECT OF SAT1 COOLING FAN ZONE 4
W 4938 4	DIFM 121012	DEFECT OF SAT1 COOLING FAN ZONE 5
W 4938 5	DIFM 121013	DEFECT OF SAT1 COOLING FAN ZONE 6
W 4938 6	DIFM 121014	DEFECT OF SAT1 COOLING FAN ZONE 7
W 4938 7	DIFM 121022	DEFECT OF SAT2 COOLING FAN ZONE 1
W 4938 8	DIFM 121023	DEFECT OF SAT2 COOLING FAN ZONE 2
W 4938 9	DIFM 121024	DEFECT OF SAT2 COOLING FAN ZONE 3
W 4938 A	DIFM 121025	DEFECT OF SAT2 COOLING FAN ZONE 4
W 4938 B	DIFM 121026	DEFECT OF SAT2 COOLING FAN ZONE 5
W 4938 C	DIFM 121027	DEFECT OF SAT2 COOLING FAN ZONE 6
W 4938 D	DIFM 121028	DEFECT OF SAT2 COOLING FAN ZONE 7
W 4938 E		
W 4938 F		
W 4939 0		
W 4939 1		
W 4939 2		
W 4939 3		
W 4939 4		
W 4939 5		
W 4939 6		
W 4939 7		
W 4939 8		

W 4939 9		
W 4939 A		
W 4939 B		
W 4939 C		
W 4939 D		
W 4939 E		
W 4939 F		
W 4940 0	FSL 120035	SAT EXT1 FLOW SWITCH LOW
W 4940 1	PSL 120036	SAT EXT1 PRESSURE LOW
W 4940 2	DPSH 121037	SAT EXT1 OIL FILTER
W 4940 3	DPSH 121038	SAT EXT1 OIL FILTER
W 4940 4	LSL 112401	SAT EXT1 HOPPER LOW LEVEL
W 4940 5		
W 4940 6		
W 4940 7		
W 4940 8	FSL 121033	SAT EXT2 FSL
W 4940 9	PSL 121040	SAT EXT2 PSL
W 4940 A	DPSH 121041	SAT EXT2 DPSH
W 4940 B	DPSH 121042	SAT EXT2 DPSH
W 4940 C	LSL 112403	SAT EXT2 HOPPER LSL
W 4940 D	FAL 124010	SAT EXT2 FLOW ALARM LOW
W 4940 E		
W 4940 F		
W 4941 0	FSL 120001	MAIN EXT1 FSL 1200.01
W 4941 1	PAL 120022	MAIN EXT1 PAL 1200.22
W 4941 2	DPSH 120023	MAIN EXT1 DPSH 1200.23
W 4941 3	DPAH 120024	MAIN EXT1 DPAH 1200.24
W 4941 4	FAL 120025	MAIN EXT1 FAL 1200.25
W 4941 5		MAIN EXT MIXING HOPPER LOW LEVEL
W 4941 6		
W 4941 7		
W 4941 8	FAL	MAIN EXT2 FAL 1200.26
W 4941 9	PAL	MAIN EXT2 PAL 1200.27
W 4941 A	DPAH	MAIN EXT2 DPAH 1200.28
W 4941 B	DPAH 120029	MAIN EXT2 DPAH 1200.29
W 4941 C	PAL 120030	MAIN EXT2 PAL 1200.30
W 4941 D	TAM 1240	MAIN EXT2 TAM 1240
W 4941 E	LAH 1240	MAIN EXT2 LAH 1240
W 4941 F	LAL 1240	MAIN EXT2 LAL 1240
W 4942 0		FAULT VIEW STORAGE EXTRUDER
W 4942 1		FAULT VIEW STORAGE SAT1
W 4942 2		FAULT VIEW STORAGE SAT2
W 4942 3		FAULT VIEW STORAGE PRI EXT
W 4942 4		FAULT VIEW STORAGE MELT.EXT
W 4942 5		FAULT VIEW STORAGE MELT.EXT
W 4942 6		FAULT VIEW STORAGE MELT TO DIE
W 4942 7		FAULT VIEW STORAGE MELT TO DIE
W 4942 8		FAULT VIEW STORAGE DIE
W 4942 9		FAULT VIEW STORAGE SAT1
W 4942 A		FAULT VIEW STORAGE SAT2
W 4942 B		
W 4942 C		
W 4942 D		
W 4942 E		
W 4942 F		

W 4943 0	LSL 112301	SAT EXT1 LSL 1123.01
W 4943 1	LAH 112302	SAT EXT1 LAH 1123.02
W 4943 2	LSL 110401	SAT EXT1 LSL 1104.01 HOMOPOLYMER
W 4943 3	LSH 110402	SAT EXT1 LSH 1104.02 HOMOPOLYMER
W 4943 4	LSL 110403	SAT EXT1 LSL 1104.03 RECLAIM MATERIAL
W 4943 5	LSH 110404	SAT EXT1 LSH 1104.04 RECLAIM MATERIAL
W 4943 6		
W 4943 7	LSH 112402	SAT EXT1 LSH 1124.02 SAT1 HOPPER HIGH LEVEL
W 4943 8		
W 4943 9	LSH 112404	MAIN EXT1 LSH 1124.04 SAT2 HOPPER HIGH LEVEL
W 4943 A		
W 4943 B	ZSO 111402	
W 4943 C		
W 4943 D	LAH 112304	SAT2 HOPPER HIGH LEVEL, LAH1123.04
W 4943 E	LAL 112303	SAT2 HOPPER LOW LEVEL, LAL1123.03
W 4943 F		
W 4944 0	SAT1 1EQ	SAT1 ONE OF EQUIPMENTS "ON"
W 4944 1	SAT2 1EQ	SAT2 ONE OF EQUIPMENTS "ON"
W 4944 2	MELT1 1EQ	SAT1 MELT LINE ONE OF EQUIPMENTS "ON"
W 4944 3	MELT2 1EQ	SAT2 MELT LINE ONE OF EQUIPMENTS "ON"
W 4944 4	PRI 1EQ	PRIMARY EXTRUDER, ONE OF EQUIPMENTS "ON"
W 4944 5	MBE 1EQ	MELT LINE BETWEEN EXT 1&2, ONE OF EQUIPMENTS "ON"
W 4944 6	SEC 1EQ	SECONDARY EXTRUDER, ONE OF EQUIPMENTS "ON"
W 4944 7	MTD 1EQ	EXT2 MELT LINE TO DIE, ONE OF EQUIPMENTS "ON"
W 4944 8	DIE 1EQ	DIE, ONE OF EQUIPMENTS "ON"
W 4944 9	SAT1 AEQ	SAT1, ALL EQUIPMENTS "ON"
W 4944 A	SAT2 AEQ	SAT2, ALL EQUIPMENTS "ON"
W 4944 B	MELT1 AEQ	SAT1 MELT LINE, ALL EQUIPMENTS "ON"
W 4944 C	MELT2 AEQ	SAT2 MELT LINE, ALL EQUIPMENTS "ON"
W 4944 D	PRI AEQ	PRIMARY EXTRUDER, ALL EQUIPMENTS "ON"
W 4944 E	MBE AEQ	MELT LINE BETWEEN EXT 1&2, ALL EQUIPMENTS "ON"
W 4944 F	SEC AEQ	SECONDARY EXTRUDER, ALL EQUIPMENTS "ON"
W 4945 0	MTD AEQ	EXT2 MELT LINE TO DIE, ALL EQUIPMENTS "ON"
W 4945 1	DIE AEQ	DIE, ALL EQUIPMENTS "ON"
W 4945 2	SAT1T	TEMPERATURE (H+, L-) OK, SAT1
W 4945 3	SAT2T	TEMPERATURE (H+, L-) OK, SAT2
W 4945 4	MELT1 T	TEMPERATURE (H+, L-) OK, SAT1 MELT LINE
W 4945 5	MELT2 T	TEMPERATURE (H+, L-) OK, SAT2 MELT LINE
W 4945 6	PRIT	TEMPERATURE (H+, L-) OK, PRIMARY EXTRUDER
W 4945 7	MBET	TEMPERATURE (H+, L-) OK, MELT LINE BETWEEN EXT 1&2
W 4945 8	SECT	TEMPERATURE (H+, L-) OK, SECONDARY EXTRUDER
W 4945 9	MTDT	TEMPERATURE (H+, L-) OK, EXT2 MELT LINE TO DIE
W 4945 A	DIET	TEMPERATURE (H+, L-) OK, DIE
W 4945 B		
W 4945 C		
W 4945 D		
W 4945 E		
W 4945 F		
W 4946 0	DIT E010	TEMPERATURE OK, SAT1 DRYER
W 4946 1	DIT E011	TEMPERATURE OK, SAT2 DRYER
W 4946 2	DIT E001	TEMPERATURE OK, HOMO DRYER
W 4946 3	DIT E002	TEMPERATURE OK, RECLAIM DRYER
W 4946 4		
W 4946 5	LSL 110403	RECLAIM DOSING HOPPER LOW LEVEL, LAL1106-02

W 4946 6	LSL 110401	HOMO DOSING HOPPER LOW LEVEL, LAL1106-01
W 4946 7	FALA	ADDITIVE DOSING HOPPER LOW LEVEL, LAL1112-01
W 4946 8		
W 4946 9		
W 4946 A		ALARM H FOR MIXING HOPPER WEIGH, R200
W 4946 B		ALARM L FOR MIXING HOPPER WEIGH, R200
W 4946 C		
W 4946 D		
W 4946 E		
W 4946 F		
W 4947 0	INT SAT1	SAT EXTRUDER 1 INTERLOCK
W 4947 1	INT SAT2	SAT EXTRUDER 2 INTERLOCK
W 4947 2	INT EXT1	MAIN EXTRUDER 1 INTERLOCK
W 4947 3	INT EXT2	MAIN EXTRUDER 2 INTERLOCK
W 4947 4		
W 4947 5		
W 4947 6		
W 4947 7		
W 4947 8		
W 4947 9		
W 4947 A		
W 4947 B		
W 4947 C		
W 4947 D		
W 4947 E		
W 4947 F		
W 4948 0		
W 4948 1		
W 4948 2		
W 4948 3		
W 4948 4		
W 4948 5		
W 4948 6		
W 4948 7		
W 4948 8		
W 4948 9		
W 4948 A		
W 4948 B		
W 4948 C		
W 4948 D		
W 4948 E		
W 4948 F		
W 4949 0		
W 4949 1		
W 4949 2		
W 4949 3		
W 4949 4		
W 4949 5		
W 4949 6		
W 4949 7		
W 4949 8		
W 4949 9		
W 4949 A		
W 4949 B		
W 4949 C		

W 4949 D		
W 4949 E		
W 4949 F		
W 4950 0	DIAM R300	AUTO(0) MANU(1) R300
W 4950 1	DILO R300	LOCKED
W 4950 2	DIAC R300	ALARM H+L-
W 4950 3	DIAH R300	ALARM H
W 4950 4	DIAL R300	ALARM L
W 4950 5	DIDE R300	MEASURE FAULT
W 4950 6	DIHLD R300	ALL ALARMS
W 4950 7		
W 4950 8	DIAM R301	AUTO(0) MANU(1) R301
W 4950 9	DILO R301	LOCKED
W 4950 A	DIAC R301	ALARM H+L-
W 4950 B	DIAH R301	ALARM H
W 4950 C	DIAL R301	ALARM L
W 4950 D	DIDE R301	MEASURE FAULT
W 4950 E	DIHLD R301	ALL ALARMS
W 4950 F		
W 4951 0	DIAM R302	AUTO(0) MANU(1) R302
W 4951 1	DILO R302	LOCKED
W 4951 2	DIAC R302	ALARM H+L-
W 4951 3	DIAH R302	ALARM H
W 4951 4	DIAL R302	ALARM L
W 4951 5	DIDE R302	MEASURE FAULT
W 4951 6	DIHLD R302	ALL ALARMS
W 4951 7		
W 4951 8	DIAM R303	AUTO(0) MANU(1) R303
W 4951 9	DILO R303	LOCKED
W 4951 A	DIAC R303	ALARM H+L-
W 4951 B	DIAH R303	ALARM H
W 4951 C	DIAL R303	ALARM L
W 4951 D	DIDE R303	MEASURE FAULT
W 4951 E	DIHLD R303	ALL ALARMS
W 4951 F		
W 4952 0	DIAM R304	AUTO(0) MANU(1) R304
W 4952 1	DILO R304	LOCKED
W 4952 2	DIAC R304	ALARM H+L-
W 4952 3	DIAH R304	ALARM H
W 4952 4	DIAL R304	ALARM L
W 4952 5	DIDE R304	MEASURE FAULT
W 4952 6	DIHLD R304	ALL ALARMS
W 4952 7		
W 4952 8	DIAM R305	AUTO(0) MANU(1) R305
W 4952 9	DILO R305	LOCKED
W 4952 A	DIAC R305	ALARM H+L-
W 4952 B	DIAH R305	ALARM H
W 4952 C	DIAL R305	ALARM L
W 4952 D	DIDE R305	MEASURE FAULT
W 4952 E	DIHLD R305	ALL ALARMS
W 4952 F		
W 4953 0	DIAM R306	AUTO(0) MANU(1) R306
W 4953 1	DILO R306	LOCKED
W 4953 2	DIAC R306	ALARM H+L-

W 4953 3	DIAH R306	ALARM H
W 4953 4	DIAL R306	ALARM L
W 4953 5	DIDE R306	MEASURE FAULT
W 4953 6	DIHLD R306	ALL ALARMS
W 4953 7		
W 4953 8	DIAM R307	AUTO(0) MANU(1) R307
W 4953 9	DILO R307	LOCKED
W 4953 A	DIAC R307	ALARM H+L-
W 4953 B	DIAH R307	ALARM H
W 4953 C	DIAL R307	ALARM L
W 4953 D	DIDE R307	MEASURE FAULT
W 4953 E	DIHLD R307	ALL ALARMS
W 4953 F		
W 4954 0	DIAM R308	AUTO(0) MANU(1) R308
W 4954 1	DILO R308	LOCKED
W 4954 2	DIAC R308	ALARM H+L-
W 4954 3	DIAH R308	ALARM H
W 4954 4	DIAL R308	ALARM L
W 4954 5	DIDE R308	MEASURE FAULT
W 4954 6	DIHLD R308	ALL ALARMS
W 4954 7		
W 4954 8	DIAM R309	AUTO(0) MANU(1) R309
W 4954 9	DILO R309	LOCKED
W 4954 A	DIAC R309	ALARM H+L-
W 4954 B	DIAH R309	ALARM H
W 4954 C	DIAL R309	ALARM L
W 4954 D	DIDE R309	MEASURE FAULT
W 4954 E	DIHLD R309	ALL ALARMS
W 4954 F		
W 4955 0	DIAM R310	AUTO(0) MANU(1) R310
W 4955 1	DILO R310	LOCKED
W 4955 2	DIAC R310	ALARM H+L-
W 4955 3	DIAH R310	ALARM H
W 4955 4	DIAL R310	ALARM L
W 4955 5	DIDE R310	MEASURE FAULT
W 4955 6	DIHLD R310	ALL ALARMS
W 4955 7		
W 4955 8	DIAM R311	AUTO(0) MANU(1) R311
W 4955 9	DILO R311	LOCKED
W 4955 A	DIAC R311	ALARM H+L-
W 4955 B	DIAH R311	ALARM H
W 4955 C	DIAL R311	ALARM L
W 4955 D	DIDE R311	MEASURE FAULT
W 4955 E	DIHLD R311	ALL ALARMS
W 4955 F		
W 4956 0	DIAM R312	AUTO(0) MANU(1) R312
W 4956 1	DILO R312	LOCKED
W 4956 2	DIAC R312	ALARM H+L-
W 4956 3	DIAH R312	ALARM H
W 4956 4	DIAL R312	ALARM L
W 4956 5	DIDE R312	MEASURE FAULT
W 4956 6	DIHLD R312	ALL ALARMS
W 4956 7		
W 4956 8	DIAM R313	AUTO(0) MANU(1) R313
W 4956 9	DILO R313	LOCKED

W 4956 A	DIAC R313	ALARM H+L-
W 4956 B	DIAH R313	ALARM H
W 4956 C	DIAL R313	ALARM L
W 4956 D	DIDE R313	MEASURE FAULT
W 4956 E	DIHLD R313	ALL ALARMS
W 4956 F		
W 4957 0	DIAM R314	AUTO(0) MANU(1) R314
W 4957 1	DILO R314	LOCKED
W 4957 2	DIAC R314	ALARM H+L-
W 4957 3	DIAH R314	ALARM H
W 4957 4	DIAL R314	ALARM L
W 4957 5	DIDE R314	MEASURE FAULT
W 4957 6	DIHLD R314	ALL ALARMS
W 4957 7		
W 4957 8	DIAM R315	AUTO(0) MANU(1) R315
W 4957 9	DILO R315	LOCKED
W 4957 A	DIAC R315	ALARM H+L-
W 4957 B	DIAH R315	ALARM H
W 4957 C	DIAL R315	ALARM L
W 4957 D	DIDE R315	MEASURE FAULT
W 4957 E	DIHLD R315	ALL ALARMS
W 4957 F		
W 4958 0	DIAM R316	AUTO(0) MANU(1) R316
W 4958 1	DILO R316	LOCKED
W 4958 2	DIAC R316	ALARM H+L-
W 4958 3	DIAH R316	ALARM H
W 4958 4	DIAL R316	ALARM L
W 4958 5	DIDE R316	MEASURE FAULT
W 4958 6	DIHLD R316	ALL ALARMS
W 4958 7		
W 4958 8	DIAM R317	AUTO(0) MANU(1) R317
W 4958 9	DILO R317	LOCKED
W 4958 A	DIAC R317	ALARM H+L-
W 4958 B	DIAH R317	ALARM H
W 4958 C	DIAL R317	ALARM L
W 4958 D	DIDE R317	MEASURE FAULT
W 4958 E	DIHLD R317	ALL ALARMS
W 4958 F		
W 4959 0	DIAM R318	AUTO(0) MANU(1) R318
W 4959 1	DILO R318	LOCKED
W 4959 2	DIAC R318	ALARM H+L-
W 4959 3	DIAH R318	ALARM H
W 4959 4	DIAL R318	ALARM L
W 4959 5	DIDE R318	MEASURE FAULT
W 4959 6	DIHLD R318	ALL ALARMS
W 4959 7		
W 4959 8	DIAM R319	AUTO(0) MANU(1) R319
W 4959 9	DILO R319	LOCKED
W 4959 A	DIAC R319	ALARM H+L-
W 4959 B	DIAH R319	ALARM H
W 4959 C	DIAL R319	ALARM L
W 4959 D	DIDE R319	MEASURE FAULT
W 4959 E	DIHLD R319	ALL ALARMS
W 4959 F		

W 4960 0	DIAM R320	AUTO(0) MANU(1) R320
W 4960 1	DILO R320	LOCKED
W 4960 2	DIAC R320	ALARM H+L-
W 4960 3	DIAH R320	ALARM H
W 4960 4	DIAL R320	ALARM L
W 4960 5	DIDE R320	MEASURE FAULT
W 4960 6	DIHLD R320	ALL ALARMS
W 4960 7		
W 4960 8	DIAM R321	AUTO(0) MANU(1) R321
W 4960 9	DILO R321	LOCKED
W 4960 A	DIAC R321	ALARM H+L-
W 4960 B	DIAH R321	ALARM H
W 4960 C	DIAL R321	ALARM L
W 4960 D	DIDE R321	MEASURE FAULT
W 4960 E	DIHLD R321	ALL ALARMS
W 4960 F		
W 4961 0	DIAM R322	AUTO(0) MANU(1) R322
W 4961 1	DILO R322	LOCKED
W 4961 2	DIAC R322	ALARM H+L-
W 4961 3	DIAH R322	ALARM H
W 4961 4	DIAL R322	ALARM L
W 4961 5	DIDE R322	MEASURE FAULT
W 4961 6	DIHLD R322	ALL ALARMS
W 4961 7		
W 4961 8	DIAM R323	AUTO(0) MANU(1) R323
W 4961 9	DILO R323	LOCKED
W 4961 A	DIAC R323	ALARM H+L-
W 4961 B	DIAH R323	ALARM H
W 4961 C	DIAL R323	ALARM L
W 4961 D	DIDE R323	MEASURE FAULT
W 4961 E	DIHLD R323	ALL ALARMS
W 4961 F		
W 4962 0	DIAM R324	AUTO(0) MANU(1) R324
W 4962 1	DILO R324	LOCKED
W 4962 2	DIAC R324	ALARM H+L-
W 4962 3	DIAH R324	ALARM H
W 4962 4	DIAL R324	ALARM L
W 4962 5	DIDE R324	MEASURE FAULT
W 4962 6	DIHLD R324	ALL ALARMS
W 4962 7		
W 4962 8	DIAM R325	AUTO(0) MANU(1) R325
W 4962 9	DILO R325	LOCKED
W 4962 A	DIAC R325	ALARM H+L-
W 4962 B	DIAH R325	ALARM H
W 4962 C	DIAL R325	ALARM L
W 4962 D	DIDE R325	MEASURE FAULT
W 4962 E	DIHLD R325	ALL ALARMS
W 4962 F		
W 4963 0	DIAM R326	AUTO(0) MANU(1) R326
W 4963 1	DILO R326	LOCKED
W 4963 2	DIAC R326	ALARM H+L-
W 4963 3	DIAH R326	ALARM H
W 4963 4	DIAL R326	ALARM L
W 4963 5	DIDE R326	MEASURE FAULT
W 4963 6	DIHLD R326	ALL ALARMS

W 4963 7		
W 4963 8	DIAM R327	AUTO(0) MANU(1) R327
W 4963 9	DILO R327	LOCKED
W 4963 A	DIAC R327	ALARM H+L-
W 4963 B	DIAH R327	ALARM H
W 4963 C	DIAL R327	ALARM L
W 4963 D	DIDE R327	MEASURE FAULT
W 4963 E	DIHLD R327	ALL ALARMS
W 4963 F		
W 4964 0	DIAM R328	AUTO(0) MANU(1) R328
W 4964 1	DILO R328	LOCKED
W 4964 2	DIAC R328	ALARM H+L-
W 4964 3	DIAH R328	ALARM H
W 4964 4	DIAL R328	ALARM L
W 4964 5	DIDE R328	MEASURE FAULT
W 4964 6	DIHLD R328	ALL ALARMS
W 4964 7		
W 4964 8	DIAM R329	AUTO(0) MANU(1) R329
W 4964 9	DILO R329	LOCKED
W 4964 A	DIAC R329	ALARM H+L-
W 4964 B	DIAH R329	ALARM H
W 4964 C	DIAL R329	ALARM L
W 4964 D	DIDE R329	MEASURE FAULT
W 4964 E	DIHLD R329	ALL ALARMS
W 4964 F		
W 4965 0	DIAM R330	AUTO(0) MANU(1) R330
W 4965 1	DILO R330	LOCKED
W 4965 2	DIAC R330	ALARM H+L-
W 4965 3	DIAH R330	ALARM H
W 4965 4	DIAL R330	ALARM L
W 4965 5	DIDE R330	MEASURE FAULT
W 4965 6	DIHLD R330	ALL ALARMS
W 4965 7		
W 4965 8	DIAM R331	AUTO(0) MANU(1) R331
W 4965 9	DILO R331	LOCKED
W 4965 A	DIAC R331	ALARM H+L-
W 4965 B	DIAH R331	ALARM H
W 4965 C	DIAL R331	ALARM L
W 4965 D	DIDE R331	MEASURE FAULT
W 4965 E	DIHLD R331	ALL ALARMS
W 4965 F		
W 4966 0	DIAM R332	AUTO(0) MANU(1) R332
W 4966 1	DILO R332	LOCKED
W 4966 2	DIAC R332	ALARM H+L-
W 4966 3	DIAH R332	ALARM H
W 4966 4	DIAL R332	ALARM L
W 4966 5	DIDE R332	MEASURE FAULT
W 4966 6	DIHLD R332	ALL ALARMS
W 4966 7		
W 4966 8	DIAM R333	AUTO(0) MANU(1) R333
W 4966 9	DILO R333	LOCKED
W 4966 A	DIAC R333	ALARM H+L-
W 4966 B	DIAH R333	ALARM H
W 4966 C	DIAL R333	ALARM L
W 4966 D	DIDE R333	MEASURE FAULT

W 4966 E	DIHLD R333	ALL ALARMS
W 4966 F		
W 4967 0		
W 4967 1		
W 4967 2		
W 4967 3		
W 4967 4		
W 4967 5		
W 4967 6		
W 4967 7		
W 4967 8		
W 4967 9		
W 4967 A		
W 4967 B		
W 4967 C		
W 4967 D		
W 4967 E		
W 4967 F		
W 4968 0		
W 4968 1		
W 4968 2		
W 4968 3		
W 4968 4		
W 4968 5		
W 4968 6		
W 4968 7		
W 4968 8		
W 4968 9		
W 4968 A		
W 4968 B		
W 4968 C		
W 4968 D		
W 4968 E		
W 4968 F		
W 4970 0	DIAM R340	AUTO(0) MANU(1) R340
W 4970 1	DILO R340	LOCKED
W 4970 2	DIAC R340	ALARM H+L-
W 4970 3	DIAH R340	ALARM H
W 4970 4	DIAL R340	ALARM L
W 4970 5	DIDE R340	MEASURE FAULT
W 4970 6	DIHLD R340	ALL ALARMS
W 4970 7		
W 4970 8	DIAM R341	AUTO(0) MANU(1) R341
W 4970 9	DILO R341	LOCKED
W 4970 A	DIAC R341	ALARM H+L-
W 4970 B	DIAH R341	ALARM H
W 4970 C	DIAL R341	ALARM L
W 4970 D	DIDE R341	MEASURE FAULT
W 4970 E	DIHLD R341	ALL ALARMS
W 4970 F		
W 4971 0	DIAM R342	AUTO(0) MANU(1) R342
W 4971 1	DILO R342	LOCKED
W 4971 2	DIAC R342	ALARM H+L-
W 4971 3	DIAH R342	ALARM H

W 4971 4	DIAL R342	ALARM L
W 4971 5	DIDE R342	MEASURE FAULT
W 4971 6	DIHLD R342	ALL ALARMS
W 4971 7		
W 4971 8	DIAM R343	AUTO(0) MANU(1) R343
W 4971 9	DILO R343	LOCKED
W 4971 A	DIAC R343	ALARM H+L-
W 4971 B	DIAH R343	ALARM H
W 4971 C	DIAL R343	ALARM L
W 4971 D	DIDE R343	MEASURE FAULT
W 4971 E	DIHLD R343	ALL ALARMS
W 4971 F		
W 4972 0	DIAM R344	AUTO(0) MANU(1) R344
W 4972 1	DILO R344	LOCKED
W 4972 2	DIAC R344	ALARM H+L-
W 4972 3	DIAH R344	ALARM H
W 4972 4	DIAL R344	ALARM L
W 4972 5	DIDE R344	MEASURE FAULT
W 4972 6	DIHLD R344	ALL ALARMS
W 4972 7		
W 4972 8	DIAM R345	AUTO(0) MANU(1) R345
W 4972 9	DILO R345	LOCKED
W 4972 A	DIAC R345	ALARM H+L-
W 4972 B	DIAH R345	ALARM H
W 4972 C	DIAL R345	ALARM L
W 4972 D	DIDE R345	MEASURE FAULT
W 4972 E	DIHLD R345	ALL ALARMS
W 4972 F		
W 4973 0	DIAM R346	AUTO(0) MANU(1) R346
W 4973 1	DILO R346	LOCKED
W 4973 2	DIAC R346	ALARM H+L-
W 4973 3	DIAH R346	ALARM H
W 4973 4	DIAL R346	ALARM L
W 4973 5	DIDE R346	MEASURE FAULT
W 4973 6	DIHLD R346	ALL ALARMS
W 4973 7		
W 4973 8	DIAM R347	AUTO(0) MANU(1) R347
W 4973 9	DILO R347	LOCKED
W 4973 A	DIAC R347	ALARM H+L-
W 4973 B	DIAH R347	ALARM H
W 4973 C	DIAL R347	ALARM L
W 4973 D	DIDE R347	MEASURE FAULT
W 4973 E	DIHLD R347	ALL ALARMS
W 4973 F		
W 4974 0	DIAM R348	AUTO(0) MANU(1) R348
W 4974 1	DILO R348	LOCKED
W 4974 2	DIAC R348	ALARM H+L-
W 4974 3	DIAH R348	ALARM H
W 4974 4	DIAL R348	ALARM L
W 4974 5	DIDE R348	MEASURE FAULT
W 4974 6	DIHLD R348	ALL ALARMS
W 4974 7		
W 4974 8	DIAM R349	AUTO(0) MANU(1) R349
W 4974 9	DILO R349	LOCKED
W 4974 A	DIAC R349	ALARM H+L-

W 4974 B	DIAH R349	ALARM H
W 4974 C	DIAL R349	ALARM L
W 4974 D	DIDE R349	MEASURE FAULT
W 4974 E	DIHLD R349	ALL ALARMS
W 4974 F		
W 4975 0	DIAM R350	AUTO(0) MANU(1) R350
W 4975 1	DILO R350	LOCKED
W 4975 2	DIAC R350	ALARM H+L-
W 4975 3	DIAH R350	ALARM H
W 4975 4	DIAL R350	ALARM L
W 4975 5	DIDE R350	MEASURE FAULT
W 4975 6	DIHLD R350	ALL ALARMS
W 4975 7		
W 4975 8	DIAM R351	AUTO(0) MANU(1) R351
W 4975 9	DILO R351	LOCKED
W 4975 A	DIAC R351	ALARM H+L-
W 4975 B	DIAH R351	ALARM H
W 4975 C	DIAL R351	ALARM L
W 4975 D	DIDE R351	MEASURE FAULT
W 4975 E	DIHLD R351	ALL ALARMS
W 4975 F		
W 4976 0	DIAM R352	AUTO(0) MANU(1) R352
W 4976 1	DILO R352	LOCKED
W 4976 2	DIAC R352	ALARM H+L-
W 4976 3	DIAH R352	ALARM H
W 4976 4	DIAL R352	ALARM L
W 4976 5	DIDE R352	MEASURE FAULT
W 4976 6	DIHLD R352	ALL ALARMS
W 4976 7		
W 4976 8	DIAM R353	AUTO(0) MANU(1) R353
W 4976 9	DILO R353	LOCKED
W 4976 A	DIAC R353	ALARM H+L-
W 4976 B	DIAH R353	ALARM H
W 4976 C	DIAL R353	ALARM L
W 4976 D	DIDE R353	MEASURE FAULT
W 4976 E	DIHLD R353	ALL ALARMS
W 4976 F		
W 4977 0	DIAM R354	AUTO(0) MANU(1) R354
W 4977 1	DILO R354	LOCKED
W 4977 2	DIAC R354	ALARM H+L-
W 4977 3	DIAH R354	ALARM H
W 4977 4	DIAL R354	ALARM L
W 4977 5	DIDE R354	MEASURE FAULT
W 4977 6	DIHLD R354	ALL ALARMS
W 4977 7		
W 4977 8	DIAM R355	AUTO(0) MANU(1) R355
W 4977 9	DILO R355	LOCKED
W 4977 A	DIAC R355	ALARM H+L-
W 4977 B	DIAH R355	ALARM H
W 4977 C	DIAL R355	ALARM L
W 4977 D	DIDE R355	MEASURE FAULT
W 4977 E	DIHLD R355	ALL ALARMS
W 4977 F		
W 4978 0	DIAM R356	AUTO(0) MANU(1) R356

W 4978 1	DILO R356	LOCKED
W 4978 2	DIAC R356	ALARM H+L-
W 4978 3	DIAH R356	ALARM H
W 4978 4	DIAL R356	ALARM L
W 4978 5	DIDE R356	MEASURE FAULT
W 4978 6	DIHLD R356	ALL ALARMS
W 4978 7		
W 4978 8	DIAM R357	AUTO(0) MANU(1) R357
W 4978 9	DILO R357	LOCKED
W 4978 A	DIAC R357	ALARM H+L-
W 4978 B	DIAH R357	ALARM H
W 4978 C	DIAL R357	ALARM L
W 4978 D	DIDE R357	MEASURE FAULT
W 4978 E	DIHLD R357	ALL ALARMS
W 4978 F		
W 4979 0	DIAM R358	AUTO(0) MANU(1) R358
W 4979 1	DILO R358	LOCKED
W 4979 2	DIAC R358	ALARM H+L-
W 4979 3	DIAH R358	ALARM H
W 4979 4	DIAL R358	ALARM L
W 4979 5	DIDE R358	MEASURE FAULT
W 4979 6	DIHLD R358	ALL ALARMS
W 4979 7		
W 4979 8	DIAM R359	AUTO(0) MANU(1) R359
W 4979 9	DILO R359	LOCKED
W 4979 A	DIAC R359	ALARM H+L-
W 4979 B	DIAH R359	ALARM H
W 4979 C	DIAL R359	ALARM L
W 4979 D	DIDE R359	MEASURE FAULT
W 4979 E	DIHLD R359	ALL ALARMS
W 4979 F		
W 4980 0	DIAM R360	AUTO(0) MANU(1) R360
W 4980 1	DILO R360	LOCKED
W 4980 2	DIAC R360	ALARM H+L-
W 4980 3	DIAH R360	ALARM H
W 4980 4	DIAL R360	ALARM L
W 4980 5	DIDE R360	MEASURE FAULT
W 4980 6	DIHLD R360	ALL ALARMS
W 4980 7		
W 4980 8	DIAM R362	AUTO(0) MANU(1) R361
W 4980 9	DILO R362	LOCKED
W 4980 A	DIAC R362	ALARM H+L-
W 4980 B	DIAH R362	ALARM H
W 4980 C	DIAL R362	ALARM L
W 4980 D	DIDE R362	MEASURE FAULT
W 4980 E	DIHLD R362	ALL ALARMS
W 4980 F		
W 4981 0		
W 4981 1		
W 4981 2		
W 4981 3		
W 4981 4		
W 4981 5		
W 4981 6		
W 4981 7		

W 4981 8	DIAM R200	AUTO(0) MANU(1) R200
W 4981 9	DILO R200	LOCKED
W 4981 A	DIAC R200	ALARM H+L-
W 4981 B	DIAH R200	ALARM H
W 4981 C	DIAL R200	ALARM L
W 4981 D	DIDE R200	MEASURE FAULT
W 4981 E	DIHLD R200	ALL ALARMS
W 4981 F		
W 4982 0	DIDE T500	DEFECT MEASURE, T500
W 4982 1	DIAH T500	ALARM H
W 4982 2	DIAL T500	ALARM L
W 4982 3	DIDE P501	DEFECT MEASURE, P501
W 4982 4	DIAH P501	ALARM H
W 4982 5	DIAL P501	ALARM L
W 4982 6	DIDE T502	DEFECT MEASURE, T502
W 4982 7	DIAH T502	ALARM H
W 4982 8	DIAL T502	ALARM L
W 4982 9	DIDE P503	DEFECT MEASURE, P503
W 4982 A	DIAH P503	ALARM H
W 4982 B	DIAL P503	ALARM L
W 4982 C	DIDE T504	DEFECT MEASURE, T504
W 4982 D	DIAH T504	ALARM H
W 4982 E	DIAL T504	ALARM L
W 4982 F	DIDE P505	DEFECT MEASURE, P505
W 4983 0	DIAH P505	ALARM H
W 4983 1	DIAL P505	ALARM L
W 4983 2	DIDE T506	DEFECT MEASURE, T506
W 4983 3	DIAH T506	ALARM H
W 4983 4	DIAL T506	ALARM L
W 4983 5	DIDE P507	DEFECT MEASURE, P507
W 4983 6	DIAH P507	ALARM H
W 4983 7	DIAL P507	ALARM L
W 4983 8	DIDE T510	DEFECT MEASURE, T510
W 4983 9	DIAH T510	ALARM H
W 4983 A	DIAL T510	ALARM L
W 4983 B	DIDE P511	DEFECT MEASURE, P511
W 4983 C	DIAH P511	ALARM H
W 4983 D	DIAL P511	ALARM L
W 4983 E	DIDE P512	DEFECT MEASURE, P512
W 4983 F	DIAH P512	ALARM H
W 4984 0	DIAL P512	ALARM L
W 4984 1	DIDE T513	DEFECT MEASURE, T513
W 4984 2	DIAH T513	ALARM H
W 4984 3	DIAL T513	ALARM L
W 4984 4	DIDE P514	DEFECT MEASURE, P514
W 4984 5	DIAH P514	ALARM H
W 4984 6	DIAL P514	ALARM L
W 4984 7	DIDE T515	DEFECT MEASURE, T515
W 4984 8	DIAH T515	ALARM H
W 4984 9	DIAL T515	ALARM L
W 4984 A	DIDE P516	DEFECT MEASURE, P516
W 4984 B	DIAH P516	ALARM H
W 4984 C	DIAL P516	ALARM L
W 4984 D		
W 4984 E		
W 4984 F		

W 6000 [50]	R307	SAT EXT1 ADAPTER
W 6050 [50]	R308	SAT EXT1 FILTER
W 6100 [50]	R309	SAT EXT1 MELT LINE
W 6150 [50]	R317	SAT EXT2 ADAPTER
W 6200 [50]	R318	SAT EXT2 FILTER
W 6250 [50]	R319	SAT EXT2 MELT LINE
W 6300 [50]	R324	MAIN EXT1 ADAPTER
W 6350 [50]	R325	MAIN EXT1 FILTER ZONE #1
W 6400 [50]	R326	MAIN EXT1 FILTER ZONE #2
W 6450 [50]	R327	MAIN EXT1 FILTER ZONE #3
W 6500 [50]		
W 6550 [50]		
W 6600 [50]	R330	MAIN EXT1 MELT LINE #1
W 6650 [50]	R331	MAIN EXT1 MELT LINE #2
W 6700 [50]	R332	MAIN EXT1 MELT LINE #3
W 6750 [50]	R333	MAIN EXT1 MELT LINE #4
W 6800 [50]	R344	MAIN EXT2 ADAPTER
W 6850 [50]	R345	MAIN EXT2 FILTER ZONE #1
W 6900 [50]	R346	MAIN EXT2 FILTER ZONE #2
W 6950 [50]	R347	MAIN EXT2 FILTER ZONE #3
W 7000 [50]	R348	MAIN EXT2 MELT LINE #1
W 7050 [50]	R349	MAIN EXT2 MELT LINE #2
W 7100 [50]	R350	MAIN EXT2 STATIC MIXER
W 7150 [50]	R351	MAIN EXT2 STATIC MIXER CONNECTION
W 7200 [50]	R352	MAIN EXT CONNECTION BOX
W 7250 [50]	R355	DIE ZONE #1
W 7300 [50]	R356	DIE ZONE #2
W 7350 [50]	R357	DIE ZONE #3
W 7400 [50]	R358	DIE ZONE #4
W 7450 [50]	R359	DIE ZONE #5
W 7500 [50]	R360	DIE ZONE #6
W 7550 [50]	R361	DIE ZONE #7
W 7600 [50]	R200	HOPPER WEIGH REGULATION
W 7650 [50]		
W 7700 [50]		
W 7750 [50]		
W 7800 [50]		
W 7850 [50]		
W 7900 [50]		
W 7950 [50]		
W 8000 [50]	R300	SAT EXT1 ZONE #1
W 8050 [50]	R301	SAT EXT1 ZONE #2
W 8100 [50]	R302	SAT EXT1 ZONE #3
W 8150 [50]	R303	SAT EXT1 ZONE #4
W 8200 [50]	R304	SAT EXT1 ZONE #5
W 8250 [50]	R305	SAT EXT1 ZONE #6
W 8300 [50]	R306	SAT EXT1 ZONE #7
W 8350 [50]	R310	SAT EXT2 ZONE #1
W 8400 [50]	R311	SAT EXT2 ZONE #2
W 8450 [50]	R312	SAT EXT2 ZONE #3
W 8500 [50]	R313	SAT EXT2 ZONE #4
W 8550 [50]	R314	SAT EXT2 ZONE #5
W 8600 [50]	R315	SAT EXT2 ZONE #6
W 8650 [50]	R316	SAT EXT2 ZONE #7
W 8700 [50]		
W 8750 [50]		
W 8800 [50]		

W 8850 [50]		
W 8900 [50]		
W 8950 [50]		
W 9000 [50]	R320	MAIN EXT1 ZONE #1
W 9050 [50]	R321	MAIN EXT1 ZONE #2
W 9100 [50]	R322	MAIN EXT1 ZONE #3
W 9150 [50]	R323	MAIN EXT1 ZONE #4
W 9200 [50]	R340	MAIN EXT2 ZONE #1
W 9250 [50]	R341	MAIN EXT2 ZONE #2
W 9300 [50]	R342	MAIN EXT2 ZONE #3
W 9350 [50]	R343	MAIN EXT2 ZONE #4
W 9400 [50]		
W 9450 [50]		
W 9500 [50]		

B 0	FREE
B 1	1 SEC PULSE
B 2	1 SEC PULSE BIT
B 3	100 MS PULSE
B 4	100 MS SYSTEM BIT
B 5	FREE
B 6	FREE
B 7	FREE
B 8	FREE
B 9	FREE
B 10	CONFIGURATION CARD AEM 413 RACK 0-1 TXT0
B 11	CONFIGURATION CARD AEM 413 RACK 0-2 TXT1
B 12	CONFIGURATION CARD AEM 413 RACK 0-3 TXT2
B 13	CONFIGURATION CARD AEM 413 RACK 0-4 TXT3
B 14	CONFIGURATION CARD AEM 413 RACK 0-5 TXT4
B 15	CONFIGURATION CARD AEM 413 RACK 0-6 TXT5
B 16	CONFIGURATION CARD AEM 413 RACK 0-7 TXT6
B 17	FREE
B 18	FREE
B 19	FREE
B 20	CONFIGURATION CARD AEM 413 RACK 4-0 TXT7
B 21	CONFIGURATION CARD AEM 413 RACK 4-1 TXT8
B 22	CONFIGURATION CARD AEM 413 RACK 4-2 TXT9
B 23	CONFIGURATION CARD AEM 413 RACK 4-3 TXT10
B 24	CONFIGURATION CARD AEM 413 RACK 4-4 TXT11
B 25	CONFIGURATION CARD AEM 413 RACK 4-5 TXT12
B 26	CONFIGURATION CARD AEM 413 RACK 4-6 TXT13
B 27	CONFIGURATION CARD AEM 413 RACK 4-7 TXT14
B 28	FREE
B 29	FREE
B 30	FREE
B 31	FREE
B 32	CONFIGURATION CARD AEM 811 RACK 6-2 TXT17
B 33	CONFIGURATION CARD AEM 811 RACK 6-2 TXT17
B 34	CONFIGURATION CARD AEM 811 RACK 6-3 TXT18
B 35	CONFIGURATION CARD AEM 811 RACK 6-3 TXT18
B 36	CONFIGURATION CARD AEM 811 RACK 6-3 TXT19
B 37	CONFIGURATION CARD AEM 811 RACK 6-3 TXT19
B 38	FREE
B 39	FREE
B 40	FREE
B 41	FREE
B 42	MODBUS CONFIGURED CARD SCM 2222 CHANNEL OK
B 43	COLD START AND WARM START
B 44	MODULE CONFIGURED
B 45	MODULE VALUES
B 46	FREE
B 47	EXCHANGE BLOCK TEXT FINISHED WITHOUT DEFECT
B 48	BIT DEFECT
B 49	RECEPTION MESSAGE
B 50	FREE
B 51	FREE
B 52	FREE
B 53	FREE

B 54	FREE
B 55	FREE
B 56	FREE
B 57	FREE
B 58	FREE
B 59	FREE
B 60	FREE
B 61	FREE
B 62	FREE
B 63	FREE
B 64	FREE
B 65	FREE
B 66	FREE
B 67	FREE
B 68	FREE
B 69	FREE
B 70	FREE
B 71	FREE
B 72	FREE
B 73	FREE
B 74	FREE
B 75	FREE
B 76	FREE
B 77	FREE
B 78	FREE
B 79	FREE
B 80	BIT RELEASE DEFECT
B 81	FREE
B 82	FREE
B 83	FREE
B 84	FREE
B 85	FREE
B 86	FREE
B 87	FREE
B 88	FREE
B 89	FREE
B 90	FREE
B 91	FREE
B 92	FREE
B 93	FREE
B 94	FREE
B 95	FREE
B 96	FREE
B 97	FREE
B 98	FREE
B 99	DIE HEATERS OVER 400 DEGREES MORE THAN 60 MINUTES THEN ALARM
B 100	LOW LEVEL ALARM SATELLITE EXT1
B 101	LOW LEVEL ALARM SATELLITE EXT1
B 102	LOW LEVEL ALARM SATELLITE EXT1
B 103	DIFFERENTIAL HIGH PRESSURE ALARM SATELLITE EXT1
B 104	DIFFERENTIAL HIGH PRESSURE ALARM SATELLITE EXT1
B 105	DIFFERENTIAL HIGH PRESSURE ALARM SATELLITE EXT1
B 106	DIFFERENTIAL HIGH PRESSURE ALARM SATELLITE EXT1
B 107	DIFFERENTIAL HIGH PRESSURE ALARM SATELLITE EXT1
B 108	DIFFERENTIAL HIGH PRESSURE ALARM SATELLITE EXT1

B 109	LOW PRESSURE ALARM SATELLITE EXT1
B 110	LOW PRESSURE ALARM SATELLITE EXT1
B 111	LOW PRESSURE ALARM SATELLITE EXT1
B 112	LOW FLOW ALARM SATELLITE EXT1
B 113	LOW FLOW ALARM SATELLITE EXT1
B 114	LOW FLOW ALARM SATELLITE EXT1
B 115	SATELLITE EXT1 HYDRAULIC GROUP
B 116	SATELLITE EXT1 HYDRAULIC GROUP
B 117	SAT EXT1 HEATER E100
B 118	SAT EXT1 HEATER E100
B 119	SAT EXT1 HEATER E100
B 120	SAT EXT1 HEATER E101
B 121	SAT EXT1 HEATER E101
B 122	SAT EXT1 HEATER E101
B 123	SAT EXT1 HEATER E102
B 124	SAT EXT1 HEATER E102
B 125	SAT EXT1 HEATER E102
B 126	SAT EXT1 HEATER E103
B 127	SAT EXT1 HEATER E103
B 128	SAT EXT1 HEATER E103
B 129	SAT EXT1 HEATER E104
B 130	SAT EXT1 HEATER E104
B 131	SAT EXT1 HEATER E104
B 132	SAT EXT1 HEATER E105
B 133	SAT EXT1 HEATER E105
B 134	SAT EXT1 HEATER E105
B 135	SAT EXT1 HEATER E106
B 136	SAT EXT1 HEATER E106
B 137	SAT EXT1 HEATER E106
B 138	SAT EXT1 ADAPTER E107
B 139	SAT EXT1 ADAPTER E107
B 140	SAT EXT1 ADAPTER E107
B 141	SAT EXT1 FILTER E108
B 142	SAT EXT1 FILTER E108
B 143	SAT EXT1 FILTER E108
B 144	SAT EXT1 BLOWER ZONE 1
B 145	SAT EXT1 BLOWER ZONE 1
B 146	SAT EXT1 BLOWER ZONE 2
B 147	SAT EXT1 BLOWER ZONE 2
B 148	SAT EXT1 BLOWER ZONE 3
B 149	SAT EXT1 BLOWER ZONE 3
B 150	SAT EXT1 BLOWER ZONE 4
B 151	SAT EXT1 BLOWER ZONE 4
B 152	SAT EXT1 BLOWER ZONE 5
B 153	SAT EXT1 BLOWER ZONE 5
B 154	SAT EXT1 BLOWER ZONE 6
B 155	SAT EXT1 BLOWER ZONE 6
B 156	SAT EXT1 BLOWER ZONE 7
B 157	SAT EXT1 BLOWER ZONE 7
B 158	SAT EXT1 INTERLOCK FOR DC DRIVE STEP 0
B 159	SAT EXT1 INTERLOCK FOR DC DRIVE STEP 1
B 160	FREE
B 161	PRIMARY EXT. AIR FLOW SWITCH ALARM AND INTERLOCK
B 162	PRIMARY EXT. AIR FLOW SWITCH ALARM AND INTERLOCK
B 163	PRIMARY EXT. AIR FLOW SWITCH ALARM AND INTERLOCK

B 164	FREE
B 165	FREE
B 166	FREE
B 167	FREE
B 168	FREE
B 169	FREE
B 170	FREE
B 171	SECONDARY EXT. AIR FLOW SWITCH ALARM AND INTERLOCK
B 172	SECONDARY EXT. AIR FLOW SWITCH ALARM AND INTERLOCK
B 173	SECONDARY EXT. AIR FLOW SWITCH ALARM AND INTERLOCK
B 174	FREE
B 175	FREE
B 176	FREE
B 177	FREE
B 178	FREE
B 179	FREE
B 180	FREE
B 181	FREE
B 182	FREE
B 183	FREE
B 184	FREE
B 185	FREE
B 186	FREE
B 187	FREE
B 188	FREE
B 189	FREE
B 190	FREE
B 191	FREE
B 192	FREE
B 193	FREE
B 194	FREE
B 195	FREE
B 196	FREE
B 197	FREE
B 198	FREE
B 199	FREE
B 200	DIFFERENTIAL HIGH PRESSURE ALARM SAT EXT2 DPSH STEP 0
B 201	DIFFERENTIAL HIGH PRESSURE ALARM SAT EXT2 DPSH STEP 1
B 202	DIFFERENTIAL HIGH PRESSURE ALARM SAT EXT2 DPSH STEP 2
B 203	DIFFERENTIAL HIGH PRESSURE ALARM SAT EXT2 DPSH STEP 0
B 204	DIFFERENTIAL HIGH PRESSURE ALARM SAT EXT2 DPSH STEP 1
B 205	DIFFERENTIAL HIGH PRESSURE ALARM SAT EXT2 DPSH STEP 2
B 206	LOW FLOW ALARM SAT EXT2
B 207	LOW FLOW ALARM SAT EXT2
B 208	LOW FLOW ALARM SAT EXT2
B 209	LOW PRESSURE ALARM SAT EXT2
B 210	LOW PRESSURE ALARM SAT EXT2
B 211	LOW PRESSURE ALARM SAT EXT2
B 212	SAT EXT2 HYDRAULIC GROUP
B 213	SAT EXT2 HYDRAULIC GROUP
B 214	SAT EXT2 HEATER E110
B 215	SAT EXT2 HEATER E110
B 216	SAT EXT2 HEATER E110
B 217	SAT EXT2 HEATER E111
B 218	SAT EXT2 HEATER E111

B 219	SAT EXT2 HEATER E111
B 220	SAT EXT2 HEATER E112
B 221	SAT EXT2 HEATER E112
B 222	SAT EXT2 HEATER E112
B 223	SAT EXT2 HEATER E113
B 224	SAT EXT2 HEATER E113
B 225	SAT EXT2 HEATER E113
B 226	SAT EXT2 HEATER E114
B 227	SAT EXT2 HEATER E114
B 228	SAT EXT2 HEATER E114
B 229	SAT EXT2 HEATER E115
B 230	SAT EXT2 HEATER E115
B 231	SAT EXT2 HEATER E115
B 232	SAT EXT2 HEATER E116
B 233	SAT EXT2 HEATER E116
B 234	SAT EXT2 HEATER E116
B 235	SAT EXT2 ADAPTER HEATER E117
B 236	SAT EXT2 ADAPTER HEATER E117
B 237	SAT EXT2 ADAPTER HEATER E117
B 238	SAT EXT2 FILTER HEATER E118
B 239	SAT EXT2 FILTER HEATER E118
B 240	SAT EXT2 FILTER HEATER E118
B 241	SAT EXT2 BLOWER ZONE 1
B 242	SAT EXT2 BLOWER ZONE 1
B 243	SAT EXT2 BLOWER ZONE 2
B 244	SAT EXT2 BLOWER ZONE 2
B 245	SAT EXT2 BLOWER ZONE 3
B 246	SAT EXT2 BLOWER ZONE 3
B 247	SAT EXT2 BLOWER ZONE 4
B 248	SAT EXT2 BLOWER ZONE 4
B 249	SAT EXT2 BLOWER ZONE 5
B 250	SAT EXT2 BLOWER ZONE 5
B 251	SAT EXT2 BLOWER ZONE 6
B 252	SAT EXT2 BLOWER ZONE 6
B 253	SAT EXT2 BLOWER ZONE 7
B 254	SAT EXT2 BLOWER ZONE 7
B 255	LOW LEVEL ALARM SAT EXT2
B 256	LOW LEVEL ALARM SAT EXT2
B 257	INTERLOCK SAT EXT2 NOT OK
B 258	INTERLOCK SAT EXT2 NOT OK
B 259	SAT EXT2 INTERLOCK OK
B 260	LSL 1124.03 RESET
B 261	LSL 1124.03 SET
B 262	LSL 1124.03 LAST FOR (T42) TIME
B 263	FREE
B 264	FREE
B 265	FREE
B 266	FREE
B 267	FREE
B 268	FREE
B 269	FREE
B 270	FREE
B 271	FREE
B 272	FREE
B 273	FREE

B 274	FREE
B 275	FREE
B 276	FREE
B 277	FREE
B 278	FREE
B 279	FREE
B 280	FREE
B 281	FREE
B 282	FREE
B 283	FREE
B 284	FREE
B 285	FREE
B 286	FREE
B 287	FREE
B 288	FREE
B 289	FREE
B 290	FREE
B 291	FREE
B 292	FREE
B 293	FREE
B 294	FREE
B 295	FREE
B 296	FREE
B 297	FREE
B 298	FREE
B 299	FREE
B 300	DIFFERENTIAL HIGH PRESSURE ALARM STEP 0
B 301	DIFFERENTIAL HIGH PRESSURE ALARM STEP 1
B 302	DIFFERENTIAL HIGH PRESSURE ALARM STEP 2
B 303	DIFFERENTIAL HIGH PRESSURE ALARM STEP 0
B 304	DIFFERENTIAL HIGH PRESSURE ALARM STEP 1
B 305	DIFFERENTIAL HIGH PRESSURE ALARM STEP 2
B 306	LOW FLOW ALARM
B 307	LOW FLOW ALARM
B 308	LOW FLOW ALARM
B 309	LOW PRESSURE ALARM
B 310	LOW PRESSURE ALARM
B 311	LOW PRESSURE ALARM
B 312	VALVE SV 1200.00
B 313	VALVE SV 1200.00
B 314	VALVE SV 1200.00
B 315	HYDRAULIC GROUP
B 316	HYDRAULIC GROUP
B 317	RELEASE DEFECT FSL 1200.25
B 318	MAIN EXT1 COOLING PUMP RUNNING M1200.05
B 319	MAIN EXT1 COOLING PUMP RUNNING FOR (T14)
B 320	LOW LEVEL ALARM LSL FROM HOPPER
B 321	LOW LEVEL ALARM LSL FROM HOPPER
B 322	LOW LEVEL ALARM LSL FROM HOPPER
B 323	MAIN EXT1 HEATER E120 STEP 0
B 324	MAIN EXT1 HEATER E120 STEP 1
B 325	MAIN EXT1 HEATER E120 STEP 2
B 326	MAIN EXT1 HEATER E121
B 327	MAIN EXT1 HEATER E121
B 328	MAIN EXT1 HEATER E121

B 329	MAIN EXT1 HEATER E122
B 330	MAIN EXT1 HEATER E122
B 331	MAIN EXT1 HEATER E122
B 332	MAIN EXT1 HEATER E123
B 333	MAIN EXT1 HEATER E123
B 334	MAIN EXT1 HEATER E123
B 335	MAIN EXT1 HEATER E124
B 336	MAIN EXT1 HEATER E124
B 337	MAIN EXT1 HEATER E124
B 338	MAIN EXT1 HEATER E125
B 339	MAIN EXT1 HEATER E125
B 340	MAIN EXT1 HEATER E125
B 341	MAIN EXT1 HEATER E126
B 342	MAIN EXT1 HEATER E126
B 343	MAIN EXT1 HEATER E126
B 344	MAIN EXT1 HEATER E127
B 345	MAIN EXT1 HEATER E127
B 346	MAIN EXT1 HEATER E127
B 347	MAIN EXT1 MELT LINE E130
B 348	MAIN EXT1 MELT LINE E130
B 349	MAIN EXT1 MELT LINE E130
B 350	MAIN EXT1 HEATER E131
B 351	MAIN EXT1 HEATER E131
B 352	MAIN EXT1 HEATER E131
B 353	MAIN EXT1 HEATER E132
B 354	MAIN EXT1 HEATER E132
B 355	MAIN EXT1 HEATER E132
B 356	MAIN EXT1 HEATER E133
B 357	MAIN EXT1 HEATER E133
B 358	MAIN EXT1 HEATER E133
B 359	MAIN EXT1 PUMP E168
B 360	MAIN EXT1 PUMP E168
B 361	MAIN EXT INTERLOCK NOT OK
B 362	MAIN EXT INTERLOCK OK
B 363	MAIN EXT1 LOW LEVEL ALARM FROM HOPPER
B 364	MAIN EXT1 LSH LEVEL ALARM FROM HOPPER
B 365	LSL MELT LINE
B 366	LSL MELT LINE
B 367	LSL MELT LINE
B 368	PRI LOST INTERLOACK WHILE RUNNING
B 369	SEC LOST INTERLOACK WHILE RUNNING
B 370	FREE
B 371	FREE
B 372	FREE
B 373	FREE
B 374	FREE
B 375	FREE
B 376	FREE
B 377	FREE
B 378	FREE
B 379	FREE
B 380	FREE
B 381	FREE
B 382	FREE
B 383	FREE

B 384	FREE
B 385	FREE
B 386	FREE
B 387	FREE
B 388	FREE
B 389	FREE
B 390	FREE
B 391	FREE
B 392	FREE
B 393	FREE
B 394	FREE
B 395	FREE
B 396	FREE
B 397	FREE
B 398	FREE
B 399	FREE
B 400	LOW LEVEL ALARM FSL STEP 0
B 401	LOW LEVEL ALARM FSL STEP 1
B 402	LOW LEVEL ALARM FSL STEP 2
B 403	LOW PRESSURE ALARM PSL
B 404	LOW PRESSURE ALARM PSL
B 405	LOW PRESSURE ALARM PSL
B 406	DIFFERENTIAL HIGH PRESSURE ALARM DPSH
B 407	DIFFERENTIAL HIGH PRESSURE ALARM DPSH
B 408	DIFFERENTIAL HIGH PRESSURE ALARM DPSH
B 409	DIFFERENTIAL HIGH PRESSURE ALARM DPSH
B 410	DIFFERENTIAL HIGH PRESSURE ALARM DPSH
B 411	DIFFERENTIAL HIGH PRESSURE ALARM DPSH
B 412	LOW FLOW ALARM FSL
B 413	LOW FLOW ALARM FSL
B 414	LOW FLOW ALARM FSL
B 415	MAIN EXT2 HEATER E140
B 416	MAIN EXT2 HEATER E140
B 417	MAIN EXT2 HEATER E140
B 418	MAIN EXT2 HEATER E141
B 419	MAIN EXT2 HEATER E141
B 420	MAIN EXT2 HEATER E141
B 421	MAIN EXT2 HEATER E142
B 422	MAIN EXT2 HEATER E142
B 423	MAIN EXT2 HEATER E142
B 424	MAIN EXT2 HEATER E143
B 425	MAIN EXT2 HEATER E143
B 426	MAIN EXT2 HEATER E143
B 427	MAIN EXT2 HEATER E144
B 428	MAIN EXT2 HEATER E144
B 429	MAIN EXT2 HEATER E144
B 430	MAIN EXT2 HEATER E145
B 431	MAIN EXT2 HEATER E145
B 432	MAIN EXT2 HEATER E145
B 433	MAIN EXT2 HEATER E146
B 434	MAIN EXT2 HEATER E146
B 435	MAIN EXT2 HEATER E146
B 436	MAIN EXT2 HEATER E147
B 437	MAIN EXT2 HEATER E147
B 438	MAIN EXT2 HEATER E147

B 439	MAIN EXT2 HEATER E149
B 440	MAIN EXT2 HEATER E149
B 441	MAIN EXT2 HEATER E149
B 442	MAIN EXT2 HEATER E150
B 443	MAIN EXT2 HEATER E150
B 444	MAIN EXT2 HEATER E150
B 445	MAIN EXT2 HEATER E151
B 446	MAIN EXT2 HEATER E151
B 447	MAIN EXT2 HEATER E151
B 448	MAIN EXT2 HEATER E153
B 449	MAIN EXT2 HEATER E153
B 450	MAIN EXT2 HEATER E153
B 451	MAIN EXT2 HEATER E154
B 452	MAIN EXT2 HEATER E154
B 453	MAIN EXT2 HEATER E154
B 454	MAIN EXT2 HEATER E155
B 455	MAIN EXT2 HEATER E155
B 456	MAIN EXT2 HEATER E155
B 457	MAIN EXT2 HEATER E156
B 458	MAIN EXT2 HEATER E156
B 459	MAIN EXT2 HEATER E156
B 460	MAIN EXT2 HEATER E157
B 461	MAIN EXT2 HEATER E157
B 462	MAIN EXT2 HEATER E157
B 463	MAIN EXT2 HEATER E158
B 464	MAIN EXT2 HEATER E158
B 465	MAIN EXT2 HEATER E158
B 466	MAIN EXT2 HEATER E159
B 467	MAIN EXT2 HEATER E159
B 468	MAIN EXT2 HEATER E159
B 469	MAIN EXT2 INTERLOCK NOT OK
B 470	MAIN EXT2 INTERLOCK OK
B 471	HYDRAULIC STEP 0
B 472	HYDRAULIC STEP 1
B 473	FREE
B 474	FREE
B 475	FAULT OF HYDRAULIC PUMP FOR MAIN EXT2 M1231.01
B 476	M1231.01 -> START
B 477	FREE
B 478	FREE
B 479	FREE
B 480	COPY FROM B780, START "SAT EXT1" EQUIPMENTS
B 481	COPY FROM B781, START "EXT1 FILTER" EQUIPMENTS
B 482	COPY FROM B786, START "MAIN EXT1" EQUIPMENTS
B 483	COPY FROM B788, START "EXT1 MELT LINE" EQUIPMENTS
B 484	COPY FROM B789, START "MAIN EXT2" EQUIPMENTS
B 485	COPY FROM B791, START "MAIN EXT2 MELT LINE" EQUIPMENTS
B 486	COPY FROM B792, START "DIE" EQUIPMENTS
B 487	FREE
B 488	FREE
B 489	FREE
B 490	STOP MAIN EXT SV 1200.00
B 491	main extruder-->running
B 492	MAIN EXT1 -> NOT RUNNING
B 493	ALL EXT NOT RUNNING

B 494	FREE
B 495	FREE
B 496	FREE
B 497	FREE
B 498	FREE
B 499	FREE
B 500	TEMPERATURE OK SAT EXT1 ZONE 1
B 501	TEMPERATURE OK SAT EXT1 ZONE 2
B 502	TEMPERATURE OK SAT EXT1 ZONE 3
B 503	TEMPERATURE OK SAT EXT1 ZONE 4
B 504	TEMPERATURE OK SAT EXT1 ZONE 5
B 505	TEMPERATURE OK SAT EXT1 ZONE 6
B 506	TEMPERATURE OK SAT EXT1 ZONE 7
B 507	TEMPERATURE OK SAT EXT1 ADAPTER
B 508	TEMPERATURE OK SAT EXT1 FILTER
B 509	TEMPERATURE OK SAT EXT1 MELT LINE
B 510	TEMPERATURE OK SAT EXT2 ZONE 1
B 511	TEMPERATURE OK SAT EXT2 ZONE 2
B 512	TEMPERATURE OK SAT EXT2 ZONE 3
B 513	TEMPERATURE OK SAT EXT2 ZONE 4
B 514	TEMPERATURE OK SAT EXT2 ZONE 5
B 515	TEMPERATURE OK SAT EXT2 ZONE 6
B 516	TEMPERATURE OK SAT EXT2 ZONE 7
B 517	TEMPERATURE OK SAT EXT2 ADAPTER
B 518	TEMPERATURE OK SAT EXT2 FILTER
B 519	TEMPERATURE OK SAT EXT2 MELT LINE
B 520	TEMPERATURE OK MAIN EXT1 ZONE 1
B 521	TEMPERATURE OK MAIN EXT1 ZONE 2
B 522	TEMPERATURE OK MAIN EXT1 ZONE 3
B 523	TEMPERATURE OK MAIN EXT1 ZONE 4
B 524	TEMPERATURE OK MAIN EXT1 ADAPTER
B 525	TEMPERATURE OK MAIN EXT1 ADAPTER
B 526	TEMPERATURE OK MAIN EXT1 FILTER
B 527	TEMPERATURE OK MAIN EXT1 ADAPTER
B 528	FREE
B 529	FREE
B 530	TEMP MAIN EXT1 MELT LINE R330
B 531	TEMP MAIN EXT1 MELT LINE R331
B 532	TEMP MAIN EXT1 MELT LINE R332
B 533	TEMP MAIN EXT1 MELT LINE R333
B 534	FREE
B 535	FREE
B 536	FREE
B 537	FREE
B 538	FREE
B 539	FREE
B 540	TEMPERATURE OK MAIN EXT2 ZONE 1
B 541	TEMPERATURE OK MAIN EXT2 ZONE 2
B 542	TEMPERATURE OK MAIN EXT2 ZONE 3
B 543	TEMPERATURE OK MAIN EXT2 ZONE 4
B 544	TEMPERATURE OK MAIN EXT2 ADAPTER
B 545	TEMPERATURE OK MAIN EXT2 ADAPTER
B 546	TEMPERATURE OK MAIN EXT2 FILTER
B 547	TEMPERATURE OK MAIN EXT2 ADAPTER
B 548	TEMPERATURE OK MAIN EXT2 MELT LINE

B 549	TEMPERATURE OK MAIN EXT2 MELT LINE
B 550	TEMP OK MAIN EXT2 STATIC MIXER
B 551	TEMP OK MAIN EXT2 STATIC MIXER CONNECTION
B 552	FREE
B 553	FREE
B 554	TEMP OK MAIN EXT2 R352
B 555	TEMP OK DIE ZONE 1
B 556	TEMP OK DIE ZONE 2
B 557	TEMP OK DIE ZONE 3
B 558	TEMP OK DIE ZONE 4
B 559	TEMP OK DIE ZONE 5
B 560	TEMP OK DIE ZONE 6
B 561	TEMP OK DIE ZONE 7
B 562	FREE
B 563	FREE
B 564	FREE
B 565	FREE
B 566	FREE
B 567	FREE
B 568	FREE
B 569	FREE
B 570	SAT1 TEMP OK
B 571	SAT2 TEMP OK
B 572	MAIN EXT1 TEMP OK
B 573	MAIN EXT2 TEMP OK
B 574	DIE TEMP OK
B 575	FREE
B 576	FREE
B 577	FREE
B 578	FREE
B 579	FREE
B 580	FREE
B 581	FREE
B 582	FREE
B 583	FREE
B 584	FREE
B 585	FREE
B 586	FREE
B 587	FREE
B 588	FREE
B 589	FREE
B 590	FREE
B 591	FREE
B 592	FREE
B 593	FREE
B 594	FREE
B 595	FREE
B 596	FREE
B 597	FREE
B 598	FREE
B 599	FREE
B 600	FREE
B 601	FREE
B 602	FREE
B 603	FREE

B 604	FREE
B 605	FREE
B 606	SAT 1 DRYER LSH1123.02 LEVEL SWITCH LOW
B 607	LSH 1123.02 LEVEL SWITCH HIGH
B 608	LEVEL SWITCH HIGH LAST FOR (T72) TIME
B 609	FREE
B 610	FREE
B 611	FREE
B 612	FREE
B 613	FREE
B 614	FREE
B 615	NOT LSH 1104.02, HOMO DRYING HOPPER HIGH LEVEL
B 616	LSH 1104.02, HOMO DRYING HOPPER HIGH LEVEL
B 617	LSH 1104.02, LAST FOR (T76) TIME
B 618	FREE
B 619	FREE
B 620	FREE
B 621	NOT LSH 1104.04, RECLAIM DRYING HOPPER HIGH LEVEL
B 622	LSH 1104.04, RECLAIM DRYING HOPPER HIGH LEVEL
B 623	LSH 1104.04, LAST FOR (T77) TIME
B 624	MIXING HOPPER FEEDING VALVE CLOSE
B 625	MIXING HOPPER FEEDING VALVE OPEN
B 626	FREE
B 627	FREE
B 628	FREE
B 629	FREE
B 630	FREE
B 631	ADDITIVE PUMP OFF M1107.01
B 632	ADDITIVE PUMP ON M1107.01
B 633	FREE
B 634	FREE
B 635	FREE
B 636	FREE
B 637	FREE
B 638	FREE
B 639	FREE
B 640	FREE
B 641	FREE
B 642	FREE
B 643	FREE
B 644	FREE
B 645	FREE
B 646	FREE
B 647	FREE
B 648	FREE
B 649	FREE
B 650	FREE
B 651	FREE
B 652	FREE
B 653	FREE
B 654	FREE
B 655	FREE
B 656	FREE
B 657	FREE
B 658	FREE

B 659	FREE
B 660	FREE
B 661	FREE
B 662	FREE
B 663	FREE
B 664	FREE
B 665	FREE
B 666	FREE
B 667	FREE
B 668	FREE
B 669	FREE
B 670	FREE
B 671	FREE
B 672	FREE
B 673	FREE
B 674	FREE
B 675	FREE
B 676	FREE
B 677	FREE
B 678	FREE
B 679	FREE
B 680	FREE
B 681	FREE
B 682	FREE
B 683	FREE
B 684	FREE
B 685	FREE
B 686	FREE
B 687	FREE
B 688	FREE
B 689	FREE
B 690	P511 TIMER DELAY ACTIONS FOR MAIN EXT. 1 INTERLOCK
B 691	P512 TIMER DELAY ACTIONS FOR MAIN EXT. 1 INTERLOCK
B 692	FREE
B 693	FREE
B 694	FREE
B 695	FREE
B 696	FREE
B 697	MELT LINE OVER TEMP
B 698	MELT LINE HIGH LEVEL-DEFECT
B 699	MELT LINE LOW LEVEL- DEFECT
B 700	ALARM H P501
B 701	ALARM H P503
B 702	ALARM H P505
B 703	ALARM H P507
B 704	ALARM H P511
B 705	ALARM H P512
B 706	ALARM H P514
B 707	ALARM H P516
B 708	FREE
B 709	FREE
B 710	FREE
B 711	FREE
B 712	FREE
B 713	FREE

B 714	FREE
B 715	FREE
B 716	FREE
B 717	FREE
B 718	FREE
B 719	FREE
B 720	FREE
B 721	FREE
B 722	FREE
B 723	FREE
B 724	FREE
B 725	FREE
B 726	FREE
B 727	FREE
B 728	FREE
B 729	FREE
B 730	FREE
B 731	FREE
B 732	FREE
B 733	FREE
B 734	FREE
B 735	FREE
B 736	FREE
B 737	FREE
B 738	FREE
B 739	FREE
B 740	FREE
B 741	FREE
B 742	FREE
B 743	FREE
B 744	FREE
B 745	FREE
B 746	FREE
B 747	FREE
B 748	FREE
B 749	FREE
B 750	FREE
B 751	FREE
B 752	FREE
B 753	FREE
B 754	FREE
B 755	FREE
B 756	FREE
B 757	FREE
B 758	FREE
B 759	FREE
B 760	BIT END OF STARTING SAT EXT1 EQUIP
B 761	BIT END OF STARTING SAT EXT1 FILTER
B 762	BIT END OF STARTING SAT EXT1 MELT LINE
B 763	BIT END OF STARTING SAT EXT2 EQUIP
B 764	BIT END OF STARTING SAT EXT2 FILTER
B 765	BIT END OF STARTING SAT EXT2 MELT LINE
B 766	BIT END OF STARTING MAIN EXT1 EQUIP
B 767	BIT END OF STARTING MAIN EXT1 FILTER
B 768	BIT END OF STARTING MAIN EXT1 MELT LINE

B 769	BIT END OF STARTING MAIN EXT2 EQUIP
B 770	BIT END OF STARTING MAIN EXT2 FILTER
B 771	BIT END OF STARTING MAIN EXT2 MELT LINE
B 772	BIT END OF STARTING DIE EQUIP
B 773	FREE
B 774	FREE
B 775	FREE
B 776	FREE
B 777	FREE
B 778	FREE
B 779	FREE
B 780	BIT START SAT EXT1 EQUIP
B 781	BIT START SAT EXT1 FILTER
B 782	BIT START SAT EXT1 MELT LINE
B 783	BIT START SAT EXT2 EQUIP
B 784	BIT START SAT EXT2 FILTER
B 785	BIT START SAT EXT2 MELT LINE
B 786	BIT START MAIN EXT1 EQUIP
B 787	BIT START MAIN EXT1 FILTER
B 788	BIT START MAIN EXT1 MELT LINE
B 789	BIT START MAIN EXT2 EQUIP
B 790	BIT START MAIN EXT2 FILTER
B 791	BIT START MAIN EXT2 MELT LINE
B 792	BIT START DIE EQUIP
B 793	BIT START FOR MAIN MELT LINE
B 794	FREE
B 795	FREE
B 796	FREE
B 797	FREE
B 798	FREE
B 799	FREE
B 800	BIT START SAT EXT1 E100
B 801	BIT START SAT EXT1 E101
B 802	BIT START SAT EXT1 E102
B 803	BIT START SAT EXT1 E103
B 804	BIT START SAT EXT1 E104
B 805	BIT START SAT EXT1 E105
B 806	BIT START SAT EXT1 E106
B 807	BIT START SAT EXT1 E107
B 808	BIT START SAT EXT1 E108
B 809	FREE
B 810	BIT START SAT EXT2 E110
B 811	BIT START SAT EXT2 E111
B 812	BIT START SAT EXT2 E112
B 813	BIT START SAT EXT2 E113
B 814	BIT START SAT EXT2 E114
B 815	BIT START SAT EXT2 E115
B 816	BIT START SAT EXT2 E116
B 817	BIT START SAT EXT2 E117
B 818	BIT START SAT EXT2 E118
B 819	FREE
B 820	BIT START MAIN EXT1 E120
B 821	BIT START MAIN EXT1 E121
B 822	BIT START MAIN EXT1 E122
B 823	BIT START MAIN EXT1 E123

B 824	BIT START MAIN EXT1 E124
B 825	BIT START MAIN EXT1 E125
B 826	BIT START MAIN EXT1 E126
B 827	BIT START MAIN EXT1 E127
B 828	BIT START MAIN EXT1 E128
B 829	FREE
B 830	BIT START MAIN EXT1 E130
B 831	BIT START MAIN EXT1 E131
B 832	BIT START MAIN EXT1 E132
B 833	BIT START MAIN EXT1 E133
B 834	BIT START BOILER E134
B 835	FREE
B 836	FREE
B 837	FREE
B 838	FREE
B 839	FREE
B 840	BIT START MAIN EXT2 E140
B 841	BIT START MAIN EXT2 E141
B 842	BIT START MAIN EXT2 E142
B 843	BIT START MAIN EXT2 E143
B 844	BIT START MAIN EXT2 E144
B 845	BIT START MAIN EXT2 E145
B 846	BIT START MAIN EXT2 E146
B 847	BIT START MAIN EXT2 E147
B 848	BIT START MAIN EXT2 E148
B 849	BIT START MAIN EXT2 E149
B 850	BIT START MAIN EXT2 E150
B 851	BIT START MAIN EXT2 E151
B 852	BIT TO SET BIT B771 (NOT USED)
B 853	BIT START DIE HEATER ZONE 1 E153
B 854	BIT START DIE HEATER ZONE 2 E154
B 855	BIT START DIE HEATER ZONE 3 E155
B 856	BIT START DIE HEATER ZONE 4 E156
B 857	BIT START DIE HEATER ZONE 5 E157
B 858	BIT START DIE HEATER ZONE 6 E158
B 859	BIT START DIE HEATER ZONE 7 E159
B 860	FREE
B 861	FREE
B 862	BIT START VALVE SV SAT EXT1 R309
B 863	BIT START VALVE SV SAT EXT2 R310
B 864	BIT START VALVE SV SAT EXT2 R348
B 865	BIT START VALVE SV SAT EXT2 R349
B 866	FREE
B 867	FREE
B 868	FREE
B 869	FREE
B 870	FAULT VIEW STORAGE EXTRUDER FOR KLAXON
B 871	FAULT VIEW STORAGE SAT1 EXTRUDER FOR KLAXON
B 872	FAULT VIEW STORAGE SAT2 EXTRUDER FOR KLAXON
B 873	LOW LEVEL ALARM FOR PCC MAIN LOADING FOR KLAXON
B 874	LOW LEVEL ALARM FOR PCC MAIN EXTRUDER LOW LEVEL ALARM FOR KLAXON
B 875	SAT2 MAGUIRE ALARM
B 876	FREE
B 877	FREE
B 878	FREE

B 879	FREE
B 880	FREE
B 881	FREE
B 882	FREE
B 883	FREE
B 884	FREE
B 885	FREE
B 886	FREE
B 887	FREE
B 888	FREE
B 889	FREE
B 890	FREE
B 891	FREE
B 892	FREE
B 893	FREE
B 894	FREE
B 895	FREE
B 896	FREE
B 897	FREE
B 898	FREE
B 899	SY6-->B899
B 900	PRIMARY EXTRUDER INTERLOCK FAILURE BITS FROM BLENDING
B 901	FAILURE BIT FOR LOW PRESSURE (B311) FOR MAIN EXT.
B 902	FREE
B 903	FAILURE BIT FOR LOW FLOW (B308) FOR MAIN EXT.
B 904	FAILURE BIT FOR P511 HIGH ALARM FOR MAIN EXTRUDER
B 905	FAILURE BIT FOR P512 HIGH ALARM FOR MAIN EXTRUDER
B 906	FAILURE BIT FOR PROCESS STOP (F29) FOR MAIN EXTRUDER
B 907	FAILURE BIT FOR COOLING PUMP FOR MAIN EXTRUDER
B 908	FAILURE BIT FOR PROCESS STOP FOR MAIN EXTRUDER
B 909	FAILURE BIT FOR FEEDING VALVE OPEN (MAIN MIXER) FOR MAIN EXTRUDER
B 910	FAILURE BIT FOR STANDBY EXTRUDER 1&2
B 911	FAILURE BIT FOR LOW PRESSURE ALARM (B405) FOR SECONDARY EXTRUDER
B 912	FAILURE BIT FOR LOW LEVEL ALARM FSL STEP 2 (B402)
B 913	FAILURE BIT FOR COOLING PUMP EXT.2 (I82,B)
B 914	P514 ALARM HIGH (W4984,5) FOR EXT 2
B 915	P516 ALARM HIGH (W4984,B) FOR EXT 2
B 916	FAILURE BIT FOR PROCESS STOP (F29) FOR EXT. 2
B 917	FAILURE BIT FOR EMERGENCY STOP (I97,F) FOR EXT 2
B 918	FAILURE BIT FOR FEEDING VALVE OPEN (MAIN MIXER) FOR EXT 2
B 919	FAILURE BIT FOR STANDBY EXTRUDER 1&2 (W4621,5)
B 920	FAILURE BIT FOR LOW FLOW (B114) FOR SAT 1
B 921	FAILURE BIT FOR P501 ALARM HIGH (W4982,4) FOR SAT 1
B 922	FAILURE BIT FOR P503 ALARM HIGH (4982,A) FOR SAT 1
B 923	FAILURE BIT FOR STANDBY MODE (W4621,3) FOR SAT 1
B 924	FAILURE BIT FOR LOW PRESSURE ALARM (B211) FOR SAT 2
B 925	FAILURE BIT FOR LOW FLOW ALARM (B208) FOR SAT 2
B 926	FAILURE BIT FOR P505 ALARM HIGH (W4983,0) FOR SAT 2
B 927	FAILURE BIT FOR P507 ALARM HIGH FOR SAT 2
B 928	FAILURE BIT FOR STANDBY MODE (W4621,4) FOR SAT 2
B 929	FREE
B 930	FAILURE BIT FOR LOW PRESSURE ALARM (B111) FOR SAT 1
B 931	EXTRUDERS RUNNING CHECK (FAILURE BITS) FOR SECONDARY EXT.
B 932	EXTRUDERS RUNNING CHECK (FAILURE BITS) FOR SAT 1

B 933	EXTRUDERS RUNNING CHECK (FAILURE BITS) FOR SAT 2
B 934	MDO DANCER ROLL REACHES BOTTOM
B 935	FREE
B 936	FREE
B 937	FREE
B 938	FAILURE BIT LOSING INTERLOCK (B362) FOR PRIMARY EXT.
B 939	FREE
B 940	FREE
B 941	FREE
B 942	FREE
B 943	FREE
B 944	FREE
B 945	FREE
B 946	FREE
B 947	FREE
B 948	FREE
B 949	FREE
B 950	FOREMOST BLENDING SYSTEM; SYSTEM ALARM
B 951	FREE
B 952	FREE
B 953	FREE
B 954	FREE
B 955	FREE
B 956	FREE
B 957	FREE
B 958	FREE
B 959	FREE
B 960	FREE
B 961	FREE
B 962	FREE
B 963	FREE
B 964	FREE
B 965	FREE
B 966	FREE
B 967	FREE
B 968	FREE
B 969	FREE
B 970	FREE
B 971	FREE
B 972	FREE
B 973	FREE
B 974	FREE
B 975	FREE
B 976	FREE
B 977	FREE
B 978	FREE
B 979	FREE
B 980	FREE
B 981	FREE
B 982	FREE
B 983	FREE
B 984	FREE
B 985	FREE
B 986	FREE
B 987	FREE

B 988	FREE
B 989	FREE
B 990	FREE
B 991	FREE
B 992	FREE
B 993	FREE
B 994	FREE
B 995	FREE
B 996	FREE
B 997	FREE
B 998	FREE
B 999	FREE
B 1000	FREE
B 1001	HOPPER #1 AUGER MOTOR RUN CONAIR BLENDER
B 1002	HOPPER #2 AUGER MOTOR RUN AFTER B1001
B 1003	HOPPER #3 AUGER MOTOR RUN
B 1004	HOPPER #4 AUGER MOTOR RUN
B 1005	HOPPER #5 AUGER MOTOR RUN
B 1006	FREE
B 1007	FREE
B 1008	FREE
B 1009	FREE
B 1010	FREE
B 1011	HOPPER #1 CALLING RESIN
B 1012	HOPPER #2 CALLING RESIN
B 1013	HOPPER #3 CALLING RESIN
B 1014	HOPPER #4 CALLING RESIN
B 1015	HOPPER #5 CALLING RESIN
B 1016	MIXING HOPPER FULL
B 1071	START SYSTEM FOR HOPPER #1
B 1072	START SYSTEM FOR HOPPER #2
B 1073	START SYSTEM FOR HOPPER #3
B 1074	START SYSTEM FOR HOPPER #4
B 1075	START SYSTEM FOR HOPPER #5
B 1100	START SYSTEM WHEN IS AUTO START
B 1101	AUTO START THE SYSTEM
B 1102	SYSTEM RUNNING MAX. SPEED
B 1103	SYSTEM RUNNING LINE SPEED
B 1104	SYSTEM RUNNING MIN. SPEED
B 1105	RUNNING LINE SPEED
B 1106	STOP SYSTEM
B 1111	HOPPER #1 IS FILLING
B 1112	HOPPER #2 IS FILLING
B 1113	HOPPER #3 IS FILLING
B 1114	HOPPER #4 IS FILLING
B 1115	HOPPER #5 IS FILLING
B 1121	HOPPER #1 IS CALLING RESIN WHILE OVER 100 LBS
B 1122	HOPPER #2 IS CALLING RESIN WHILE OVER 100 LBS
B 1123	HOPPER #3 IS CALLING RESIN WHILE OVER 100 LBS
B 1124	HOPPER #4 IS CALLING RESIN WHILE OVER 100 LBS
B 1125	HOPPER #5 IS CALLING RESIN WHILE OVER 100 LBS

B 1211	HOPPER #1 VACUUM VALVE OPEN
B 1212	HOPPER #1 DUMP VALVE OPEN
B 1213	HOPPER #2 VACUUM VALVE OPEN
B 1214	HOPPER #2 DUMP VALVE OPEN
B 1215	HOPPER #3 VACUUM VALVE OPEN
B 1216	HOPPER #3 DUMP VALVE OPEN
B 1217	HOPPER #4 VACUUM VALVE OPEN
B 1218	HOPPER #4 DUMP VALVE OPEN
B 1219	HOPPER #5 VACUUM VALVE OPEN
B 1220	HOPPER #5 DUMP VALVE OPEN
B 1400	HOPPER #1 IS CALLING RESIN
B 1401	HOPPER #2 IS CALLING RESIN
B 1402	HOPPER #3 IS CALLING RESIN
B 1403	HOPPER #4 IS CALLING RESIN
B 1404	HOPPER #5 IS CALLING RESIN
B 1410	HOPPER #1 IS CALLING RESIN
B 1411	HOPPER #2 IS CALLING RESIN
B 1412	HOPPER #3 IS CALLING RESIN
B 1413	HOPPER #4 IS CALLING RESIN
B 1414	HOPPER #5 IS CALLING RESIN
B 1415	TOP VIEW ALARM
B 1950	RUN SYSTEM
B 1990	CALIBRATION

TEMPERATURE CONTROL 16 BIT

B 2000	AUTO/MANU (MANU -> "1")
B 2001	LOCKED
B 2002	ALARM H+ OR L- (TEMPERATURE CONTROL OUT OF RANGE)
B 2003	ALARM H
B 2004	ALARM L
B 2005	DEFECT MEASURE
B 2006	BIT ALL ALARMS (B2004+B2003+B2002+B2005)--->B2006
B 2007	FAULT CONTROL LOOP
B 2008	FREE
B 2009	SAMPLE TIME SELECT (60 OR 1)
B 2010	START CONTROL LOOP
B 2011	REVERSE CONTROL LOOP
B 2012	FREE
B 2013	BIT OUTPUT 100;-100
B 2014	FREE
B 2015	TEMPERATURE NO DEFECT (OK)

B 2200	AUTHORIZATION TO START SCREW AND ROTATING ARM
B 2201	OUTPUT % OF R200 IS >70% OR <45%