

## F-13 MODULE LIST

### MAST

MAIN - CALL SUBROUTINES  
SR0 - CONFIGURATION SCM 2222  
SR1 - READ/WRITE DATA TO PC;PLC  
SR2 - CONFIGURATION AEM 413  
SR3 - CONFIGURATION AEM 811  
SR4 - CONFIGURATION ASR 403  
SR5 - ALL EQUIPMENTS - CONTACT ANSWER  
SR6 - MDO  
SR7 - CHILL ROLL  
SR8 - START ALL EQUIPMENTS - INTERNAL BIT  
SR9 - TDO (EXCEPT BLOWERS & BURNERS)  
SR10 - TDO BLOWERS  
SR11 - TDO BURNERS  
SR12 - PRS & AUX WINDER #3  
SR13 - COLD & WARM START INITIALIZATION  
SR14 - DC MOTOR INTERLOCK  
SR15 - MDO WARM DC MOTOR INTERLOCK  
SR16 - TEMPERATURE MEASURE  
SR17 - TEMPERATUER CONTROL OUTPUT 4-20MA  
SR18 - TEMPERATURE CONTROL - TRANSFER SET VALUE FROM PC -> PLC  
SR19 - TEMPERATURE CONTROL - TRANSFER ALARM FROM PLC -> PC  
SR20 - KLAXON OF F13  
SR21 - ROTATING LIGHT OF F13  
SR22 - RELEASE ALL DEFECT  
SR23 - INCREASE ALL SET POINT TDO  
SR24 - SCREEN TOP FAULT VIEWS

### AUX0

MAIN - CALL P.I.D CONTROL LOOPS  
SR0 - P.I.D CONTROL OUTPUT CALCULATION

### F13 I/O LIST

F13\INPUTBIT.DOC

| I/O<br>WORD | DESCRIPTION                             | SYMBOL        | PAGE #<br>(DRAW') |
|-------------|-----------------------------------------|---------------|-------------------|
| I80,0       | FAN FOR EXHAUST HOOD F23                | M1263-01      | 64                |
| I80,1       | AIR KNIFE BLOWER F23                    | M1310-01      | 64                |
| I80,2       | FILM WATER REMOVAL BLOWER #1 F23        | M1310-02      | 64                |
| I80,3       | FILM WATER REMOVAL BLOWER #2 F23        | M1310-03      | 64                |
| I80,4       | C. R. DRYING BLOWER F23                 | M1330-01      | 64                |
| I80,5       | C. R. BRAKE ELECTRON MAGNETIC BRAKE F23 | Y1302-01      | 64                |
| I80,6       | (FREE)                                  |               | 64                |
| I80,7       | AUX. WINDER #1 F23                      | M1360-01 & 02 | 64                |
| I80,8       | (FREE)                                  |               | 65                |
| I80,9       | (FREE)                                  |               | 65                |
| I80,A       | (FREE)                                  |               | 65                |
| I80,B       | (FREE)                                  |               | 65                |
| I80,C       | AUX. WINDER #2 (W506,A) F23             | M1450-01 & 02 | 65                |
| I80,D       | MDO PUMP, ROLL #1&2 (Z1) F23            | M1430-01      | 65                |
| I80,E       | MDO PUMP, ROLL #3&4 (Z2) F23            | M1430-02      | 65                |
| I80,F       | MDO PUMP, ROLL #5&6 (Z3) F23            | M1430-03      | 65                |
|             |                                         |               |                   |
| I81,0       | TDO CENT. EXHAUST AIR FAN F24           | M1525-01      | 68                |
| I81,1       | TDO CLIPS COOLING FAN (INLET) F24       | M1528-01      | 68                |
| I81,2       | TDO CLIPS COOLING FAN (MIDDLE) F24      | M1528-02      | 68                |
| I81,3       | TDO CLIPS COOLING FAN (INTERVAL) F24    | M1528-03      | 68                |
| I81,4       | TDO EXHAUST AIR FAN (OUTLET) F24        | M1530-01      | 68                |
| I81,5       | (FREE)                                  |               | 68                |
| I81,6       | (FREE)                                  |               | 68                |
| I81,7       | TDO FAN ZONE 1 (H.S) - E185 F24         | M1520-01      | 68                |
| I81,8       | TDO FAN ZONE 1 (L.S) - E185 F24         | M1520-01      | 69                |
| I81,9       | TDO FAN ZONE 2 (H.S) - E187 F24         | M1520-02      | 69                |
| I81,A       | TDO FAN ZONE 2 (L.S) - E187 F24         | M1520-02      | 69                |
| I81,B       | TDO FAN ZONE 3 (H.S) - E188 F24         | M1520-03      | 69                |
| I81,C       | TDO FAN ZONE 3 (L.S) - E188 F24         | M1520-03      | 69                |
| I81,D       | TDO FAN ZONE 4 (H.S) - E189 F24         | M1520-04      | 69                |
| I81,E       | TDO FAN ZONE 4 (L.S) - E189 F24         | M1520-04      | 69                |
| I81,F       | TDO FAN ZONE 5 (H.S) - E190 F24         | M1520-05      | 69                |
|             |                                         |               |                   |
| I82,0       | TDO FAN 2 ZONE 11 (L.S) - E198 F24      | M1520-13      | 72                |
| I82,1       | TDO FAN 1 ZONE 12 (H.S) - E199 F24      | M1520-14      | 72                |
| I82,2       | TDO FAN 1 ZONE 12 (L.S) - E199 F24      | M1520-14      | 72                |
| I82,3       | TDO FAN 2 ZONE 12 (H.S) - E200 F24      | M1520-15      | 72                |
| I82,4       | TDO FAN 2 ZONE 12 (L.S) - E200 F24      | M1520-15      | 72                |
| I82,5       | TDO FAN 1 ZONE 13 (H.S) - E201 F24      | M1520-16      | 72                |
| I82,6       | TDO FAN 1 ZONE 13 (L.S) - E201 F24      | M1520-16      | 72                |
| I82,7       | TDO FAN 2 ZONE 13 (H.S) - E202 F24      | M1520-17      | 72                |
| I82,8       | TDO FAN 2 ZONE 13 (L.S) - E202 F24      | M1520-17      | 73                |
| I82,9       | TDO FAN 1 ZONE 14 (H.S) - E203 F24      | M1520-18      | 73                |
| I82,A       | TDO FAN 1 ZONE 14 (L.S) - E203 F24      | M1520-18      | 73                |
| I82,B       | TDO FAN 2 ZONE 14 (H.S) - E204 F24      | M1520-19      | 73                |
| I82,C       | TDO FAN 2 ZONE 14 (L.S) - E204 F24      | M1520-19      | 73                |

|       |                                                                |      |            |    |
|-------|----------------------------------------------------------------|------|------------|----|
| I82,D | TDO FAN 1 ZONE 15 (H.S) - E205                                 | F24  | M1520-20   | 73 |
| I82,E | TDO FAN 1 ZONE 15 (L.S) - E205                                 | F24  | M1520-20   | 73 |
| I82,F | TDO FAN 2 ZONE 15 (H.S) - E206                                 | F24  | M1520-21   | 73 |
|       |                                                                |      |            |    |
| I83,0 | TDO FAN 2 ZONE 19 (L.S) - E214                                 | F24  | M1520-29   | 76 |
| I83,1 | TDO FAN 1 ZONE 20 (H.S) - E215                                 | F24  | M1520-30   | 76 |
| I83,2 | TDO FAN 1 ZONE 20 (L.S) - E215                                 | F24  | M1520-30   | 76 |
| I83,3 | TDO FAN 2 ZONE 20 (H.S) - E216                                 | F24  | M1520-31   | 76 |
| I83,4 | TDO FAN 2 ZONE 20 (L.S) - E216                                 | F24  | M1520-31   | 76 |
| I83,5 | TDO FAN 1 COOLING ZONE (H.S) - E217                            | F24  | M1520-32   | 76 |
| I83,6 | TDO FAN 1 COOLING ZONE (L.S) - E217                            | F24  | M1520-32   | 76 |
| I83,7 | TDO FAN 2 COOLING ZONE (H.S) - E218                            | F24  | M1520-33   | 76 |
| I83,8 | TDO FAN 2 COOLING ZONE (L.S) - E218                            | F24  | M1520-33   | 77 |
| I83,9 | TDO FAN 3 COOLING ZONE (H.S) - E219                            | F24  | M1520-34   | 77 |
| I83,A | TDO FAN 3 COOLING ZONE (L.S) - E219                            | F24  | M1520-34   | 77 |
| I83,B | TDO FAN 4 COOLING ZONE (H.S) - E220                            | F24  | M1520-35   | 77 |
| I83,C | TDO FAN 4 COOLING ZONE (L.S) - E220                            | F24  | M1520-35   | 77 |
| I83,D | (FREE)                                                         |      |            | 77 |
| I83,E | (FREE)                                                         |      |            | 77 |
| I83,F | FAN FOR VACUUM ROLL                                            | F24  | M1812-01   | 77 |
|       |                                                                |      |            |    |
| I84,0 | C. R. HAND CRANK                                               | C. R | ZS1301-03  | 80 |
| I84,1 | C. R. HOME POS.                                                | C. R | ZS1301-04  | 80 |
| I84,2 | C. R. HIGH/LOW SPEED                                           | C. R | ZS1301-05  | 80 |
| I84,3 | C. R. WORKING POS.                                             | C. R | ZS1301-06  | 80 |
| I84,4 | AIR KNIFE IN WORK POS. (DRIVING SIDE)                          | C. R | ZSH1310-05 | 80 |
| I84,5 | AIR KNIFE IN WORK POS. (OPERATING SIDE)                        | C. R | ZSH1310-06 | 80 |
| I84,6 | AIR KNIFE IN HOME POS. (DRIVING SIDE)                          | C. R | ZSH1310-07 | 80 |
| I84,7 | AIR KNIFE IN HOME POS. (OPERATING SIDE)                        | C. R | ZSH1310-08 | 80 |
| I84,8 | ROLL #1 LOW POS.                                               | MDO  | ZSL1402-04 | 81 |
| I84,9 | ROLL #1 MIDDLE POS.                                            | MDO  | ZSM1402-05 | 81 |
| I84,A | ROLL #1 INTER POS.                                             | MDO  | ZSI1402-06 | 81 |
| I84,B | ROLL #1 HIGH POS.                                              | MDO  | ZSH1402-07 | 81 |
| I84,C | ROLL #2 LOW POS.                                               | MDO  | ZSL1402-08 | 81 |
| I84,D | ROLL #2 MIDDLE POS.                                            | MDO  | ZSM1402-09 | 81 |
| I84,E | ROLL #2 INTER POS.                                             | MDO  | ZSI1402-10 | 81 |
| I84,F | ROLL #2 HIGH POS.                                              | MDO  | ZSH1402-11 | 81 |
|       |                                                                |      |            |    |
| I85,0 | COR. ELECTRODE 1 IN POS., R SIDE                               | PRS  | ZSH1820-08 | 84 |
| I85,1 | COR. ELECTRODE 1 PRESSURE<br>(INSTALLED, BUT DOESN'T WORK)     | PRS  | PSL1820-09 | 84 |
| I85,2 | COR. ELECTRODE 1 IN POS., L SIDE                               | PRS  | ZSH1820-10 | 84 |
| I85,3 | COR. ELECTRODE 3 IN POS., R SIDE                               | PRS  | ZSH1820-12 | 84 |
| I85,4 | COR. ELECTRODE 3 PRESSURE<br>(INSTALLED, BUT DOESN'T WORK)     | PRS  | PSL1820-14 | 84 |
| I85,5 | COR. ELECTRODE 3 IN POS., L SIDE<br>PRS WEB DETECTOR           | PRS  | ZSH1820-13 | 84 |
| I85,6 | COR. ELECTRODE 2 IN POS., R SIDE<br>PRS WEB DETECTOR           | PRS  | ZSL1820-17 | 84 |
| I85,7 | COR. ELECTRODE 2 IN POS., L SIDE                               | PRS  | ZSL1820-18 | 84 |
| I85,8 | COR. ELECTRODE 2 PRESSURE PRS<br>(INSTALLED, BUT DOESN'T WORK) |      | PSL1820-19 | 85 |

|       |                                 |     |            |    |
|-------|---------------------------------|-----|------------|----|
| I85,9 | EXTRAC. FLOW #1                 | PRS | FSL1831-06 | 85 |
| I85,A | EXTRAC. FLOW #3                 | PRS | FSL1831-07 | 85 |
| I85,B | AUX. WINDER 3, AIR PRESSURE LOW | PRS | PSL1860-   | 85 |
| I85,C | (FREE)                          |     |            | 85 |
| I85,D | WEB BREAK DETECTOR              | PRS | ZT1840-10  | 85 |
| I85,E | ANTENNA SENSOR O.S. - XE01      | PRS |            | 85 |
| I85,F | ANTENNA SENSOR D.S. - XE01      | PRS |            | 85 |
|       |                                 |     |            |    |
| I86,0 | EXHAUST HOOD - START            | F32 |            | 88 |
| I86,1 | EXHAUST HOOD - STOP             | F32 |            | 88 |
| I86,2 | EDGE PINNING - START            | F32 |            | 88 |
| I86,3 | EDGE PINNING - STOP             | F32 |            | 88 |
| I86,4 | C. R. FORWARD                   | F32 |            | 88 |
| I86,5 | C. R. BACKWARD                  | F32 |            | 88 |
| I86,6 | C. R. STOP                      | F32 |            | 88 |
| I86,7 | AIR KNIFE - ENGAGE              | F32 |            | 88 |
| I86,8 | AIR KNIFE - RETRACT             | F32 |            | 89 |
| I86,9 | AIR KNIFE BLOWER - START        | F32 |            | 89 |
| I86,A | AIR KNIFE BLOWER - STOP         | F32 |            | 89 |
| I86,B | FILM REMOVAL POS. ENGAGE        | F32 |            | 89 |
| I86,C | FILM REMOVAL POS. RETRACT       | F32 |            | 89 |
| I86,D | RUBBER ROLL - ENGAGE            | F32 |            | 89 |
| I86,E | RUBBER ROLL - RETRACT           | F32 |            | 89 |
| I86,F | CHROMED ROLL - ENGAGE           | F32 |            | 89 |
|       |                                 |     |            |    |
| I87,0 | MDO STOP                        | F40 |            | 92 |
| I87,1 | THREADING SYSTEM - START        | F40 |            | 92 |
| I87,2 | THREADING SYSTEM - STOP         | F40 |            | 92 |
| I87,3 | (FREE)                          |     |            | 92 |
| I87,4 | TREADING SYSTEM - STOP          | F41 |            | 92 |
| I87,5 | MDO STOP                        | F41 |            | 92 |
| I87,6 | PRESS ROLL INLET - ENGAGE       | F42 |            | 92 |
| I87,7 | PRESS ROLL INLET - RETRACT      | F42 |            | 92 |
| I87,8 | PRESS ROLL OUTLET - ENGAGE      | F42 |            | 93 |
| I87,9 | PRESS ROLL OUTLET - RETRACT     | F42 |            | 93 |
| I87,A | NIP ROLL 1 - ENGAGE             | F42 |            | 93 |
| I87,B | NIP ROLL 1 - RETRACT            | F42 |            | 93 |
| I87,C | NIP ROLL 2 - ENGAGE             | F42 |            | 93 |
| I87,D | NIP ROLL 2 - RETRACT            | F42 |            | 93 |
| I87,E | NIP ROLL 3 - ENGAGE             | F42 |            | 93 |
| I87,F | NIP ROLL 3 - RETRACT            | F42 |            | 93 |
|       |                                 |     |            |    |
| I90,0 | PUMP ROLL #7&8                  | F23 | M1430-04   | 66 |
| I90,1 | PUMP ROLL #9&10                 | F23 | M1430-05   | 66 |
| I90,2 | PUMP ROLL #11&12                | F23 | M1430-06   | 66 |
| I90,3 | PUMP ROLL #13&14                | F23 | M1430-07   | 66 |
| I90,4 | PUMP ROLL #15&16                | F23 | M1430-08   | 66 |
| I90,5 | PUMP ROLL #17&18                | F23 | M1430-09   | 66 |
| I90,6 | PUMP ROLL #19&20                | F23 | M1430-10   | 66 |
| I90,7 | PUMP ROLL #21&22                | F23 | M1430-11   | 66 |
| I90,8 | PUMP ROLL #23&24                | F23 | M1430-12   | 67 |
| I90,9 | (FREE)                          |     |            | 67 |

|       |                         |     |          |    |
|-------|-------------------------|-----|----------|----|
| I90,A | (FREE)                  |     |          | 67 |
| I90,B | (FREE)                  |     |          | 67 |
| I90,C | (FREE)                  |     |          | 67 |
| I90,D | (FREE)                  |     |          | 67 |
| I90,E | (FREE)                  |     |          | 67 |
| I90,F | (FREE)                  |     |          | 67 |
|       |                         |     |          |    |
| I91,0 | AIR FAN ZONE 5 (L.S)    | F24 | M1520-05 | 70 |
| I91,1 | AIR FAN ZONE 6 (H.S)    | F24 | M1520-06 | 70 |
| I91,2 | AIR FAN ZONE 6 (L.S)    | F24 | M1520-06 | 70 |
| I91,3 | AIR FAN ZONE 7 (H.S)    | F24 | M1520-07 | 70 |
| I91,4 | AIR FAN ZONE 7 (L.S)    | F24 | M1520-07 | 70 |
| I91,5 | AIR FAN ZONE 8 (H.S)    | F24 | M1520-08 | 70 |
| I91,6 | AIR FAN ZONE 8 (L.S)    | F24 | M1520-08 | 70 |
| I91,7 | AIR FAN ZONE 9 (H.S)    | F24 | M1520-09 | 70 |
| I91,8 | AIR FAN ZONE 9 (L.S)    | F24 | M1520-09 | 71 |
| I91,9 | AIR FAN 1 ZONE 10 (H.S) | F24 | M1520-10 | 71 |
| I91,A | AIR FAN 1 ZONE 10 (L.S) | F24 | M1520-10 | 71 |
| I91,B | AIR FAN 2 ZONE 10 (H.S) | F24 | M1520-11 | 71 |
| I91,C | AIR FAN 2 ZONE 10 (L.S) | F24 | M1520-11 | 71 |
| I91,D | AIR FAN 1 ZONE 11 (H.S) | F24 | M1520-12 | 71 |
| I91,E | AIR FAN 1 ZONE 11 (L.S) | F24 | M1520-12 | 71 |
| I91,F | AIR FAN 2 ZONE 11 (H.S) | F24 | M1520-13 | 71 |
|       |                         |     |          |    |
| I92,0 | AIR FAN 2 ZONE 15 (L.S) | F24 | M1520-21 | 74 |
| I92,1 | AIR FAN 1 ZONE 16 (H.S) | F24 | M1520-22 | 74 |
| I92,2 | AIR FAN 1 ZONE 16 (L.S) | F24 | M1520-22 | 74 |
| I92,3 | AIR FAN 2 ZONE 16 (H.S) | F24 | M1520-23 | 74 |
| I92,4 | AIR FAN 2 ZONE 16 (L.S) | F24 | M1520-23 | 74 |
| I92,5 | AIR FAN 1 ZONE 17 (H.S) | F24 | M1520-24 | 74 |
| I92,6 | AIR FAN 1 ZONE 17 (L.S) | F24 | M1520-24 | 74 |
| I92,7 | AIR FAN 2 ZONE 17 (H.S) | F24 | M1520-25 | 74 |
| I92,8 | AIR FAN 2 ZONE 17 (L.S) | F24 | M1520-25 | 75 |
| I92,9 | AIR FAN 1 ZONE 18 (H.S) | F24 | M1520-26 | 75 |
| I92,A | AIR FAN 1 ZONE 18 (L.S) | F24 | M1520-26 | 75 |
| I92,B | AIR FAN 2 ZONE 18 (H.S) | F24 | M1520-27 | 75 |
| I92,C | AIR FAN 2 ZONE 18 (L.S) | F24 | M1520-27 | 75 |
| I92,D | AIR FAN 1 ZONE 19 (H.S) | F24 | M1520-28 | 75 |
| I92,E | AIR FAN 1 ZONE 19 (L.S) | F24 | M1520-28 | 75 |
| I92,F | AIR FAN 2 ZONE 19 (H.S) | F24 | M1520-29 | 75 |
|       |                         |     |          |    |
| I93,0 | FAN FOR VACUUM ROLL     | F24 | M1825-01 | 78 |
| I93,1 | OZONE EXHAUST 1         | F24 | M1831-01 | 78 |
| I93,2 | OZONE EXHAUST 2         | F24 | M1831-02 | 78 |
| I93,3 | OZONE EXHAUST 3         | F24 | M1831-03 | 78 |
| I93,4 | OZONE TREATER FAN 1     | F24 |          | 78 |
| I93,5 | OZONE TREATER FAN 2     | F24 |          | 78 |
| I93,6 | OZONE TREATER FAN 3     | F24 |          | 78 |
| I93,7 | OZONE TREATER FAN 4     | F24 |          | 78 |
| I93,8 | (FREE)                  |     |          | 79 |
| I93,9 | (FREE)                  |     |          | 79 |
| I93,A | (FREE)                  |     |          | 79 |

|       |                                                             |      |            |    |
|-------|-------------------------------------------------------------|------|------------|----|
| I93,B | CHAIN TENSION - HYDRAULIC PUMP                              | F24  | M1515-01   | 79 |
| I93,C | (FREE)                                                      |      |            | 79 |
| I93,D | (FREE)                                                      |      |            | 79 |
| I93,E | (FREE)                                                      |      |            | 79 |
| I93,F | (FREE)                                                      |      |            | 79 |
|       |                                                             |      |            |    |
| I94,0 | STRETCHING ROLL #3 LOW POS.                                 | MDO  | ZSL1402-12 | 82 |
| I94,1 | STRETCHING ROLL #3 MIDDLE POS.                              | MDO  | ZSM1402-13 | 82 |
| I94,2 | STRETCHING ROLL #3 INTER. POS.                              | MDO  | ZSI1402-14 | 82 |
| I94,3 | STRETCHING ROLL #3 HIGH POS.                                | MDO  | ZSH1402-15 | 82 |
| I94,4 | MDO WEB BREAK OCT.                                          | MDO  | ZT1420-01  | 82 |
| I94,5 | MDO WEB BREAK OCT.                                          | MDO  | ZT1420-02  | 82 |
| I94,6 | TDO FAULT ALARM                                             | TDO  |            | 82 |
| I94,7 | TDO FAST STOP , CRITICAL ALARM                              | TDO  |            | 82 |
| I94,8 | CHAIN TENSION OIL PUMP LOW LEVEL                            | TDO  | LSL1515-02 | 83 |
| I94,9 | CHAIN TENSION PUMP PRESSURE LOW                             | TDO  | PSL1515-03 | 83 |
| I94,A | WEB BREAK FILM (F149) TDO EXIT                              | TDO  | ZT1531-01  | 83 |
| I94,B | WEB BREAK FILM (F148) COOLING ZONE                          | TDO  | ZT1531-02  | 83 |
| I94,C | DRIVE SIDE TENSION                                          |      | ZS1515-06  | 83 |
| I94,D | OPERATOR SIDE TENSION                                       |      | ZS1515-07  | 83 |
| I94,E | DRIVE SIDE COUNTER<br>(TDO OUTLET SPROCKET)                 | TDO  | ZS1550-01  | 83 |
| I94,F | OPERATOR SIDE COUNTER MDO WEB DET.<br>(TDO OUTLET SPROCKET) | MDO  | ZS1550-02  | 83 |
|       |                                                             |      |            |    |
| I95,0 | AUX. WINDER 1 THERMOSTAT                                    |      | TSH1360-03 | 86 |
| I95,1 | AUX. WINDER 2 THERMOSTAT                                    |      | TSH1450-03 | 86 |
| I95,2 | C. R. WATER BATH LEVEL SWITCH                               | C. R | LSL1350-03 | 86 |
| I95,3 | NIP ROLL 1 IN POS.                                          | MDO  | ZSH1404-06 | 86 |
| I95,4 | NIP ROLL 1 IN POS.                                          | MDO  | ZSH1404-07 | 86 |
| I95,5 | NIP ROLL 2 IN POS.                                          | MDO  | ZSH1404-08 | 86 |
| I95,6 | NIP ROLL 2 IN POS.                                          | MDO  | ZSH1404-09 | 86 |
| I95,7 | NIP ROLL 3 IN POS.                                          | MDO  | ZSH1404-10 | 86 |
| I95,8 | NIP ROLL 3 IN POS.                                          | MDO  | ZSH1404-11 | 87 |
| I95,9 | PRESS ROLL INLET IN POS.                                    | MDO  | ZSH1404-12 | 87 |
| I95,A | PRESS ROLL INLET IN POS.                                    | MDO  | ZSH1404-13 | 87 |
| I95,B | PRESS ROLL OUTLET IN POS.                                   | MDO  | ZSH1404-14 | 87 |
| I95,C | PRESS ROLL OUTLET IN POS.                                   | MDO  | ZSH1404-15 | 87 |
| I95,D | (FREE) PRS WEB BREAK PRS                                    |      |            | 87 |
| I95,E | (FREE)                                                      |      |            | 87 |
| I95,F | (FREE)                                                      |      |            | 87 |
|       |                                                             |      |            |    |
| I96,0 | CHROMED ROLL - RETRACT                                      | F32  |            | 90 |
| I96,1 | C. R. WATER REMOVAL - START                                 | F32  |            | 90 |
| I96,2 | C. R. WATER REMOVAL - STOP                                  | F32  |            | 90 |
| I96,3 | FILM WATER REMOVAL - START, 1                               | F32  |            | 90 |
| I96,4 | FILM WATER REMOVAL - STOP, 1                                | F32  |            | 90 |
| I96,5 | FILM WATER REMOVAL - START, 2                               | F32  |            | 90 |
| I96,6 | FILM WATER REMOVAL - STOP, 2                                | F32  |            | 90 |
| I96,7 | WATER BATH LEVEL - ON                                       | F32  | 90S32      | 90 |
| I96,8 | WATER BATH LEVEL - AUTO                                     | F32  | 90S32      | 91 |
| I96,9 | C. R. STOP                                                  | F32  |            | 91 |

|       |                                   |     |  |     |
|-------|-----------------------------------|-----|--|-----|
| I96,A | INST. AIR START (NO USE)          | F32 |  | 91  |
| I96,B | INST. AIR STOP (NO USE)           | F32 |  | 91  |
| I96,C | TEST LAMPS                        | F32 |  | 91  |
| I96,D | (FREE)                            |     |  | 91  |
| I96,E | (FREE)                            |     |  | 91  |
| I96,F | (FREE)                            |     |  | 91  |
|       |                                   |     |  |     |
| I97,0 | STRETCHING ROLL 1 - UP            |     |  | 94  |
| I97,1 | STRETCHING ROLL 1 - DOWN          |     |  | 94  |
| I97,2 | STRETCHING ROLL 2 - UP            | F42 |  | 94  |
| I97,3 | STRETCHING ROLL 2 - DOWN          | F42 |  | 94  |
| I97,4 | STRETCHING ROLL 3 - UP            | F42 |  | 94  |
| I97,5 | STRETCHING ROLL 3 - DOWN          | F42 |  | 94  |
| I97,6 | GENERAL STRETCHING ROLL - UP      | F42 |  | 94  |
| I97,7 | GENERAL STRETCHING ROLL - DOWN    | F42 |  | 94  |
| I97,8 | FILM <> 60 MICRO-M                | F42 |  | 95  |
| I97,9 | WEB BREAK DETECTOR MDO            | F42 |  | 95  |
| I97,A | MDO STOP                          | F42 |  | 95  |
| I97,B | (FREE)                            |     |  | 95  |
| I97,C | LAMPS TEST                        | F42 |  | 95  |
| I97,D | (FREE)                            |     |  | 95  |
| I97,E | (FREE)                            |     |  | 95  |
| I97,F | (FREE)                            |     |  | 95  |
|       |                                   |     |  |     |
| IA0,0 | AUX. WINDER 2 MOTOR - START       | F46 |  | 97  |
| IA0,1 | AUX. WINDER 2 MOTOR - STOP        | F46 |  | 97  |
| IA0,2 | AUX. WINDER 2 SPINDLE - ENGAGE    | F46 |  | 97  |
| IA0,3 | AUX. WINDER 2 SPINDLE - RETRACT   | F46 |  | 97  |
| IA0,4 | AUX. WINDER 2 FOOT SWITCH         | F46 |  | 97  |
| IA0,5 | AUX. WINDER 1 MOTOR - START       | F36 |  | 97  |
| IA0,6 | AUX. WINDER 1 MOTOR - STOP        | F36 |  | 97  |
| IA0,7 | AUX. WINDER 1 SPINDLE - ENGAGE    | F36 |  | 97  |
| IA0,8 | AUX. WINDER 1 SPINDLE - RETRACT   | F36 |  | 98  |
| IA0,9 | AUX. WINDER 1 FOOT SWITCH         | F36 |  | 98  |
| IA0,A | AUX. WINDER 3 WEB BREAK BYPASS    | F70 |  | 98  |
| IA0,B | TDO DEFECT TO F13 SHUT OFF BLOWER | F50 |  | 98  |
| IA0,C | CLIPS OPENING/CLOSING             | F50 |  | 98  |
| IA0,D | CHAIN TENSION START               | F50 |  | 98  |
| IA0,E | CHAIN TENSION STOP                | F50 |  | 98  |
| IA0,F | TDO STOP                          | F50 |  | 98  |
|       |                                   |     |  |     |
| IA1,0 | VACUUM ROLL 1 - START             | F55 |  | 101 |
| IA1,1 | VACUUM ROLL 1 - STOP              | F55 |  | 101 |
| IA1,2 | WEB BREAK PRS BYPASS / ON         | F55 |  | 101 |
| IA1,3 | OZONE EXHAUST FAN 1 - START       | F55 |  | 101 |
| IA1,4 | OZONE EXHAUST FAN 1 - STOP        | F55 |  | 101 |
| IA1,5 | OZONE EXHAUST FAN 2 - START       | F55 |  | 101 |
| IA1,6 | OZONE EXHAUST FAN 2 - STOP        | F55 |  | 101 |
| IA1,7 | OZONE EXHAUST FAN 3 - START       | F55 |  | 101 |
| IA1,8 | OZONE EXHAUST FAN 3 - STOP        | F55 |  | 102 |
| IA1,9 | VACUUM ROLL 2 - START             | F55 |  | 102 |
| IA1,A | VACUUM ROLL 2 - STOP              | F55 |  | 102 |

|       |                                                  |      |  |     |
|-------|--------------------------------------------------|------|--|-----|
| IA1,B | NIP ROLL FOR CORONA #1 - ENGAGE                  | F55  |  | 102 |
| IA1,C | NIP ROLL FOR CORONA #1 - RETRACT                 | F55  |  | 102 |
| IA1,D | COR. ELECTRODE 1 ENGAGE                          | F55  |  | 102 |
| IA1,E | COR. ELECTRODE 1 RETRACT                         | F55  |  | 102 |
| IA1,F | NIP ROLL FOR CORONA #3 - ENGAGE                  | F55  |  | 102 |
|       |                                                  |      |  |     |
| IA2,0 | NIP ROLL FOR CORONA #1 - ENGAGE                  | F56  |  | 105 |
| IA2,1 | NIP ROLL FOR CORONA #1 - RETRACT                 | F56  |  | 105 |
| IA2,2 | NIP ROLL FOR CORONA #3 - ENGAGE                  | F56  |  | 105 |
| IA2,3 | NIP ROLL FOR CORONA #3 - RETRACT                 | F56  |  | 105 |
| IA2,4 | SPREADER ROLL 2 ENGAGE                           | F56  |  | 105 |
| IA2,5 | SPREADER ROLL 2 RETRACT                          | F56  |  | 105 |
| IA2,6 | SPREADER ROLL 3 ENGAGE                           | F56  |  | 105 |
| IA2,7 | SPREADER ROLL 3 RETRACT                          | F56  |  | 105 |
| IA2,8 | OP. SPREADER ROLL 2 ENGAGE                       | F66  |  | 106 |
| IA2,9 | OP. SPREADER ROLL 2 RETRACT                      | F66  |  | 106 |
| IA2,A | DRIVE SPREADER ROLL 2 ENGAGE                     | F66  |  | 106 |
| IA2,B | DRIVE SPREADER ROLL 2 RETRACT                    | F66  |  | 106 |
| IA2,C | OP. SPREADER ROLL 3 ENGAGE                       | F68  |  | 106 |
| IA2,D | OP. SPREADER ROLL 3 RETRACT                      | F68  |  | 106 |
| IA2,E | DRIVE SPREADER ROLL 3 ENGAGE                     | F68  |  | 106 |
| IA2,F | DRIVE SPREADER ROLL 3 RETRACT                    | F68  |  | 106 |
|       |                                                  |      |  |     |
| IA3,0 | BURNER 1 ON                                      | F151 |  | 109 |
| IA3,1 | BURNER 1 DEFECT                                  | F151 |  | 109 |
| IA3,2 | BURNER 2 ON                                      | F152 |  | 109 |
| IA3,3 | BURNER 2 DEFECT                                  | F152 |  | 109 |
| IA3,4 | BURNER 3 ON                                      | F153 |  | 109 |
| IA3,5 | BURNER 3 DEFECT                                  | F153 |  | 109 |
| IA3,6 | BURNER 4 ON                                      | F154 |  | 109 |
| IA3,7 | BURNER 4 DEFECT                                  | F154 |  | 109 |
| IA3,8 | BURNER 5 ON                                      | F155 |  | 110 |
| IA3,9 | BURNER 5 DEFECT                                  | F155 |  | 110 |
| IA3,A | BURNER 6 ON                                      | F156 |  | 110 |
| IA3,B | BURNER 6 DEFECT                                  | F156 |  | 110 |
| IA3,C | BURNER 7 ON                                      | F157 |  | 110 |
| IA3,D | BURNER 7 DEFECT                                  | F157 |  | 110 |
| IA3,E | BURNER 8 ON                                      | F158 |  | 110 |
| IA3,F | BURNER 8 DEFECT                                  | F158 |  | 110 |
|       |                                                  |      |  |     |
| IA4,0 | BURNER 17 ON                                     | F167 |  | 113 |
| IA4,1 | BURNER 17 DEFECT                                 | F167 |  | 113 |
| IA4,2 | BURNER 18 ON                                     | F168 |  | 113 |
| IA4,3 | BURNER 18 DEFECT                                 | F168 |  | 113 |
| IA4,4 | BURNER 19 ON                                     | F169 |  | 113 |
| IA4,5 | BURNER 19 DEFECT                                 | F169 |  | 113 |
| IA4,6 | BURNER 20 ON                                     | F170 |  | 113 |
| IA4,7 | BURNER 20 DEFECT                                 | F170 |  | 113 |
| IA4,8 | RELEASE DEFECT                                   | F12  |  | 114 |
| IA4,9 | RELEASE KLAXON (ALARM)                           | F12  |  | 114 |
| IA4,A | UP TO SPEED FOR TREATERS FROM F16 (075,A) - XE02 |      |  | 114 |
| IA4,B | (FREE)                                           |      |  | 114 |



|       |                                                  |  |     |
|-------|--------------------------------------------------|--|-----|
| IA4,C | (FREE) INTRO STRETCH SIGNAL FOR PRS BARRIER      |  | 114 |
| IA4,D | (FREE) LOW STRETCH SIGNAL FOR PRS BARRIER        |  | 114 |
| IA4,E | (FREE)                                           |  | 114 |
| IA4,F | (FREE)                                           |  | 114 |
|       |                                                  |  |     |
| IA5,0 | UP TO SPEED FOR TREATERS FROM F16 (075,A) - XE01 |  | 117 |
| IA5,1 | (FREE)                                           |  | 117 |
| IA5,2 | (FREE)                                           |  | 117 |
| IA5,3 | (FREE)                                           |  | 117 |
| IA5,4 | (FREE)                                           |  | 117 |
| IA5,5 | (FREE)                                           |  | 117 |
| IA5,6 | (FREE)                                           |  | 117 |
| IA5,7 | (FREE)                                           |  | 117 |
| IA5,8 | (FREE)                                           |  | 118 |
| IA5,9 | (FREE)                                           |  | 118 |
| IA5,A | (FREE)                                           |  | 118 |
| IA5,B | (FREE)                                           |  | 118 |
| IA5,C | (FREE)                                           |  | 118 |
| IA5,D | (FREE)                                           |  | 118 |
| IA5,E | (FREE)                                           |  | 118 |
| IA5,F | (FREE)                                           |  | 118 |
|       |                                                  |  |     |
| IA7,0 | C. R. RUNNING F16                                |  | 125 |
| IA7,1 | MDO 1 RUNNING F16                                |  | 125 |
| IA7,2 | MDO 2 RUNNING F16                                |  | 125 |
| IA7,3 | MDO 3 RUNNING F16                                |  | 125 |
| IA7,4 | TDO RUNNING F16                                  |  | 125 |
| IA7,5 | PRS 1 RUNNING F16                                |  | 125 |
| IA7,6 | PRS 2 RUNNING F16                                |  | 125 |
| IA7,7 | AUX. 1 RUNNING F16                               |  | 125 |
| IA7,8 | AUX. 2 RUNNING F16                               |  | 126 |
| IA7,9 | AUX. WINDER RUNNING F16                          |  | 126 |
| IA7,A | PRODUCTION STRETCHING F16                        |  | 126 |
| IA7,B | C. R. ROTATION F16                               |  | 126 |
| IA7,C | MDO 1 ROTATION F16                               |  | 126 |
| IA7,D | MDO 2 ROTATION F16                               |  | 126 |
| IA7,E | MDO 3 ROTATION F16                               |  | 126 |
| IA7,F | TDO ROTATION F16                                 |  | 126 |
|       |                                                  |  |     |
| IB0,0 | AIR ON CLIPS - ON                                |  | 99  |
| IB0,1 | AIR ON CLIPS - AUTO                              |  | 99  |
| IB0,2 | TDO STOP F52                                     |  | 99  |
| IB0,3 | TDO STOP F53                                     |  | 99  |
| IB0,4 | OP. TRIM NIP ROLL ENGAGE F62                     |  | 99  |
| IB0,5 | OP. NIP ROLL RETRACT F62                         |  | 99  |
| IB0,6 | DRIVE NIP ROLL ENGAGE F62                        |  | 99  |
| IB0,7 | DRIVE NIP ROLL RETRACT F62                       |  | 99  |
| IB0,8 | OP. KNIFE - ENGAGE F62                           |  | 100 |
| IB0,9 | OP. KNIFE - RETRACT F62                          |  | 100 |
| IB0,A | DRIVE KNIFE - ENGAGE F62                         |  | 100 |
| IB0,B | DRIVE KNIFE - RETRACT F62                        |  | 100 |
| IB0,C | OP. SPREADER ROLL 1 ENGAGE F62                   |  | 100 |

|       |                                        |      |  |     |
|-------|----------------------------------------|------|--|-----|
| IB0,D | OP. SPREADER ROLL 1 RETRACT            | F62  |  | 100 |
| IB0,E | DRIVE SPREADER ROLL 1 ENGAGE           | F62  |  | 100 |
| IB0,F | DRIVE SPREADER ROLL 1 RETRACT          | F62  |  | 100 |
|       |                                        |      |  |     |
| IB1,0 | NIP ROLL FOR CORONA #3 - RETRACT       | F55  |  | 103 |
| IB1,1 | COR. ELECTRODE 3 ENGAGE                | F55  |  | 103 |
| IB1,2 | COR. ELECTRODE 3 RETRACT               | F55  |  | 103 |
| IB1,3 | COR. ELECTRODE 2 ENGAGE                | F55  |  | 103 |
| IB1,4 | COR. ELECTRODE 2 RETRACT               | F55  |  | 103 |
| IB1,5 | PRS STOP                               | F55  |  | 103 |
| IB1,6 | (FREE)                                 |      |  | 103 |
| IB1,7 | LAMPS TEST                             | F55  |  | 103 |
| IB1,8 | WEB BREAK TDO BYPASS / ON              | F55  |  | 104 |
| IB1,9 | INDEPENDENT MODE PRS - CORONA TREATERS |      |  | 104 |
| IB1,A | (FREE)                                 |      |  | 104 |
| IB1,B | (FREE)                                 |      |  | 104 |
| IB1,C | (FREE)                                 |      |  | 104 |
| IB1,D | (FREE)                                 |      |  | 104 |
| IB1,E | AUX. WINDER 1 WEB BREAK BYPASS         | F36  |  | 104 |
| IB1,F | AUX. WINDER 2 WEB BREAK BYPASS         | F46  |  | 104 |
|       |                                        |      |  |     |
| IB2,0 | NIP ROLL ENGAGE                        | F63  |  | 107 |
| IB2,1 | NIP ROLL RETRACT                       | F63  |  | 107 |
| IB2,2 | KNIFE ENGAGE                           | F63  |  | 107 |
| IB2,3 | KNIFE RETRACT                          | F63  |  | 107 |
| IB2,4 | SPREADER ROLL 1 ENGAGE                 | F63  |  | 107 |
| IB2,5 | SPREADER ROLL 1 RETRACT                | F63  |  | 107 |
| IB2,6 | PRS STOP E                             | F95  |  | 107 |
| IB2,7 | PRS STOP E                             | F63  |  | 107 |
| IB2,8 | (FREE)                                 |      |  | 108 |
| IB2,9 | AUX. WINDER 3 START                    | F70  |  | 108 |
| IB2,A | AUX. WINDER 3 STOP                     | F70  |  | 108 |
| IB2,B | AUX. WINDER 3 ENGAGE                   | F70  |  | 108 |
| IB2,C | AUX. WINDER 3 RETRACT                  | F70  |  | 108 |
| IB2,D | (FREE)                                 |      |  | 108 |
| IB2,E | C. R. COOLING STOP                     |      |  | 108 |
| IB2,F | WATER BATH COOLING STOP                |      |  | 108 |
|       |                                        |      |  |     |
| IB3,0 | BURNER 9 ON                            | F159 |  | 111 |
| IB3,1 | BURNER 9 DEFECT                        | F159 |  | 111 |
| IB3,2 | BURNER 10 ON                           | F160 |  | 111 |
| IB3,3 | BURNER 10 DEFECT                       | F160 |  | 111 |
| IB3,4 | BURNER 11 ON                           | F161 |  | 111 |
| IB3,5 | BURNER 11 DEFECT                       | F161 |  | 111 |
| IB3,6 | BURNER 12 ON                           | F162 |  | 111 |
| IB3,7 | BURNER 12 DEFECT                       | F162 |  | 111 |
| IB3,8 | BURNER 13 ON                           | F163 |  | 112 |
| IB3,9 | BURNER 13 DEFECT                       | F163 |  | 112 |
| IB3,A | BURNER 14 ON                           | F164 |  | 112 |
| IB3,B | BURNER 14 DEFECT                       | F164 |  | 112 |
| IB3,C | BURNER 15 ON                           | F165 |  | 112 |
| IB3,D | BURNER 15 DEFECT                       | F165 |  | 112 |

|       |                      |           |          |     |
|-------|----------------------|-----------|----------|-----|
| IB3,E | BURNER 16 ON         | F166      |          | 112 |
| IB3,F | BURNER 16 DEFECT     | F166      |          | 112 |
|       |                      |           |          |     |
| IB4,0 | (FREE)               |           |          | 115 |
| IB4,1 | (FREE)               |           |          | 115 |
| IB4,2 | (FREE)               |           |          | 115 |
| IB4,3 | (FREE)               |           |          | 115 |
| IB4,4 | (FREE)               |           |          | 115 |
| IB4,5 | (FREE)               |           |          | 115 |
| IB4,6 | (FREE)               |           |          | 115 |
| IB4,7 | (FREE)               |           |          | 115 |
| IB4,8 | CORE A DEFECT        | CANCELLED |          | 116 |
| IB4,9 | CORE A RUNNING       | CANCELLED |          | 116 |
| IB4,A | CORE B DEFECT        | CANCELLED |          | 116 |
| IB4,B | CORE B RUNNING       | CANCELLED |          | 116 |
| IB4,C | WEB BREAK -> B1211   | F201      |          | 116 |
| IB4,D | ROLL 2 DEFECT        | CANCELLED |          | 116 |
| IB4,E | ROLL 2 RUNNING       | CANCELLED |          | 116 |
| IB4,F | LIGHT BARRIER        | PRS       |          | 116 |
|       |                      |           |          |     |
| IB5,0 | (FREE)               |           |          | 119 |
| IB5,1 | (FREE)               |           |          | 119 |
| IB5,2 | (FREE)               |           |          | 119 |
| IB5,3 | (FREE)               |           |          | 119 |
| IB5,4 | (FREE)               |           |          | 119 |
| IB5,5 | (FREE)               |           |          | 119 |
| IB5,6 | (FREE)               |           |          | 119 |
| IB5,7 | (FREE)               |           |          | 119 |
| IB5,8 | (FREE)               |           |          | 119 |
| IB5,9 | (FREE)               |           |          | 119 |
| IB5,A | (FREE)               |           |          | 119 |
| IB5,B | (FREE)               |           |          | 119 |
| IB5,C | (FREE)               |           |          | 119 |
| IB5,D | (FREE)               |           |          | 119 |
| IB5,E | (FREE)               |           |          | 119 |
| IB5,F | (FREE)               |           |          | 119 |
|       |                      |           |          |     |
| IB7,0 | C. R. COOLING ON     | C1340     | C1340    | 127 |
| IB7,1 | C. R. COOLING DEFECT | C1340     | C1340    | 127 |
| IB7,2 | WATER BATH ON        | C1350     | C1350    | 127 |
| IB7,3 | WATER BATH DEFECT    | C1350     | C1350    | 127 |
| IB7,4 | MDO OIL SKID ON      | C1430     | C1430    | 127 |
| IB7,5 | MDO OIL SKID DEFECT  | C1430     | C1430    | 127 |
| IB7,6 | (FREE)               |           |          | 127 |
| IB7,7 | CORONA 1 ON          | F75       | G1820-01 | 127 |
| IB7,8 | CORONA 1 DEFECT      | F75       | G1820-01 | 128 |
| IB7,9 | CORONA 2 ON          | F76       | G1820-02 | 128 |
| IB7,A | CORONA 2 DEFECT      | F76       | G1820-02 | 128 |
| IB7,B | CORONA 3 ON          | F77       | G1820-03 | 128 |
| IB7,C | CORONA 3 DEFECT      | F77       | G1820-03 | 128 |
| IB7,D | CORONA 4 ON          | F78       | G1820-04 | 128 |
| IB7,E | CORONA 4 DEFECT      | F78       | G1820-04 | 128 |

|       |                |  |     |
|-------|----------------|--|-----|
| IB7,F | EMERGENCY STOP |  | 128 |
|       |                |  |     |

F13 TO LIST

F13\OUTPUTBIT.DOC

| I/O<br>WORD | DESCRIPTION                                      | SYMBOL        | PAGE #<br>(DRAW') |
|-------------|--------------------------------------------------|---------------|-------------------|
| OC4,0       | FAN FOR DIE EXHAUST HOOD F23                     | M1260-01      | 146               |
| OC4,1       | AIR KNIFE BLOWER F23                             | M1310-01      | 146               |
| OC4,2       | FILM WATER REMOVAL BLOWER #1 F23                 | M1310-02      | 146               |
| OC4,3       | FILM WATER REMOVAL BLOWER #2 F23                 | M1330-01      | 146               |
| OC4,4       | C. R. DRYING BLOWER F23                          | M1330-01      | 146               |
| OC4,5       | C. R. BRAKE F23                                  | Y1302-01      | 146               |
| OC4,6       | AUX. WINDER 1 BRAKE (NOT USED) F23               |               | 146               |
| OC4,7       | AUX. WINDER #1 F23                               | M1360-01 & 02 | 146               |
| OC4,8       | WYE DELTA FILM DRYING BLOWER                     |               | 147               |
| OC4,9       | (FREE)                                           |               | 147               |
| OC4,A       | THREAD UP MOTOR - FAST ROLLS MUST BE UP POSITION |               | 147               |
| OC4,B       | AUX. WINDER 2 BRAKE (NOT USED) F23               |               | 147               |
| OC4,C       | AUX. WINDER #2 F23                               | M1450-01 & 02 | 147               |
| OC4,D       | MDO PUMP PREHEATING ROLL #1 & 2 F23              | M1430-01      | 147               |
| OC4,E       | MDO PUMP STRETCHING ROLL #3 & 4 F23              | M1430-02      | 147               |
| OC4,F       | MDO PUMP STRETCHING ROLL #5 & 6 F23              | M1430-03      | 147               |
|             |                                                  |               |                   |
| OC5,0       | CENT. EXHAUST AIR FAN F24                        | M1525-01      | 150               |
| OC5,1       | CLIPS COOLING FAN - INLET F24                    | M1520-01      | 150               |
| OC5,2       | CLIPS COOLING FAN - MIDDLE F24                   | M1520-02      | 150               |
| OC5,3       | CLIPS COOLING FAN - INTERVAL F24                 | M1520-03      | 150               |
| OC5,4       | TDO EXHAUST FAN - OUTLET F24                     | M1530-01      | 150               |
| OC5,5       | (FREE)                                           |               | 150               |
| OC5,6       | (FREE)                                           |               | 150               |
| OC5,7       | TDO FAN ZONE 1 (H.S) - E185 F24                  | M1520-01      | 150               |
| OC5,8       | TDO FAN ZONE 1 (L.S) - E185 F24                  | M1520-01      | 151               |
| OC5,9       | TDO FAN ZONE 2 (H.S) - E187 F24                  | M1520-02      | 151               |
| OC5,A       | TDO FAN ZONE 2 (L.S) - E187 F24                  | M1520-02      | 151               |
| OC5,B       | TDO FAN ZONE 3 (H.S) - E188 F24                  | M1520-03      | 151               |
| OC5,C       | TDO FAN ZONE 3 (L.S) - E188 F24                  | M1520-03      | 151               |
| OC5,D       | TDO FAN ZONE 4 (H.S) - E189 F24                  | M1520-04      | 151               |
| OC5,E       | TDO FAN ZONE 4 (L.S) - E189 F24                  | M1520-04      | 151               |
| OC5,F       | TDO FAN ZONE 5 (H.S) - E190 F24                  | M1520-05      | 151               |
|             |                                                  |               |                   |
| OC6,0       | TDO FAN W. ZONE 11 (L.S) - E198 F24              | M1520-13      | 154               |
| OC6,1       | TDO FAN E. ZONE 12 (H.S) - E199 F24              | M1520-14      | 154               |
| OC6,2       | TDO FAN E. ZONE 12 (L.S) - E199 F24              | M1520-14      | 154               |
| OC6,3       | TDO FAN W. ZONE 12 (H.S) - E200 F24              | M1520-15      | 154               |
| OC6,4       | TDO FAN W. ZONE 12 (L.S) - E200 F24              | M1520-15      | 154               |
| OC6,5       | TDO FAN E. ZONE 13 (H.S) - E201 F24              | M1520-16      | 154               |
| OC6,6       | TDO FAN E. ZONE 13 (L.S) - E201 F24              | M1520-16      | 154               |
| OC6,7       | TDO FAN W. ZONE 13 (H.S) - E202 F24              | M1520-17      | 154               |
| OC6,8       | TDO FAN W. ZONE 13 (L.S) - E202 F24              | M1520-17      | 155               |
| OC6,9       | TDO FAN E. ZONE 14 (H.S) - E203 F24              | M1520-18      | 155               |
| OC6,A       | TDO FAN E. ZONE 14 (L.S) - E203 F24              | M1520-18      | 155               |
| OC6,B       | TDO FAN W. ZONE 14 (H.S) - E204 F24              | M1520-19      | 155               |
| OC6,C       | TDO FAN W. ZONE 14 (L.S) - E204 F24              | M1520-19      | 155               |

|       |                                      |     |          |     |
|-------|--------------------------------------|-----|----------|-----|
| OC6,D | TDO FAN E. ZONE 15 (H.S) - E205      | F24 | M1520-20 | 155 |
| OC6,E | TDO FAN E. ZONE 15 (L.S) - E205      | F24 | M1520-20 | 155 |
| OC6,F | TDO FAN W. ZONE 15 (H.S) - E206      | F24 | M1520-21 | 155 |
|       |                                      |     |          |     |
| OC7,0 | TDO FAN 2. ZONE 19 (L.S) - E214      | F24 | M1520-29 | 158 |
| OC7,1 | TDO FAN E. ZONE 20 (H.S) - E215      | F24 | M1520-30 | 158 |
| OC7,2 | TDO FAN E. ZONE 20 (L.S) - E215      | F24 | M1520-30 | 158 |
| OC7,3 | TDO FAN W. ZONE 20 (H.S) - E216      | F24 | M1520-31 | 158 |
| OC7,4 | TDO FAN W. ZONE 20 (L.S) - E216      | F24 | M1520-31 | 158 |
| OC7,5 | TDO FAN E. COOLING ZONE (H.S) - E217 | F24 | M1520-32 | 158 |
| OC7,6 | TDO FAN E. COOLING ZONE (L.S) - E217 | F24 | M1520-32 | 158 |
| OC7,7 | TDO FAN W. COOLING ZONE (H.S) - E218 | F24 | M1520-33 | 158 |
| OC7,8 | TDO FAN W. COOLING ZONE (L.S) - E218 | F24 | M1520-33 | 159 |
| OC7,9 | TDO FAN 3 COOLING ZONE (H.S) - E219  | F24 | M1520-34 | 159 |
| OC7,A | TDO FAN 3 COOLING ZONE (L.S) - E219  | F24 | M1520-34 | 159 |
| OC7,B | TDO FAN 4 COOLING ZONE (H.S) - E220  | F24 | M1520-35 | 159 |
| OC7,C | TDO FAN 4 COOLING ZONE (L.S) - E220  | F24 | M1520-35 | 159 |
| OC7,D | (FREE)                               |     |          | 159 |
| OC7,E | (FREE)                               |     |          | 159 |
| OC7,F | FAN FOR PRS1 VACUUM ROLL             | F23 | M1812-01 | 159 |
|       |                                      |     |          |     |
| OD4,0 | MDO PUMP ROLL #7 & 8                 | F23 | M1430-04 | 148 |
| OD4,1 | MDO PUMP ROLL #9 & 10                | F23 | M1430-05 | 148 |
| OD4,2 | MDO PUMP ROLL #11 & 12               | F23 | M1430-06 | 148 |
| OD4,3 | MDO PUMP ROLL #13 & 14               | F23 | M1430-07 | 148 |
| OD4,4 | MDO PUMP ROLL #15 & 16               | F23 | M1430-08 | 148 |
| OD4,5 | MDO PUMP ROLL #17 & 18               | F23 | M1430-09 | 148 |
| OD4,6 | MDO PUMP ROLL #19 & 20               | F23 | M1430-10 | 148 |
| OD4,7 | MDO PUMP ROLL #21 & 22               | F23 | M1430-11 | 148 |
| OD4,8 | MDO PUMP ROLL #23 & 24               | F23 | M1430-12 | 149 |
| OD4,9 | LI1 (AUX. WINDER 1)                  | F23 | M1360-01 | 149 |
| OD4,A | LI2 (AUX. WINDER 1)                  | F23 | M1360-01 | 149 |
| OD4,B | FW (AUX. WINDER 1)                   | F23 | M1360-01 | 149 |
| OD4,C | LI1 (AUX. WINDER 2)                  | F23 | M1450-01 | 149 |
| OD4,D | LI2 (AUX. WINDER 2)                  | F23 | M1450-01 | 149 |
| OD4,E | FW (AUX. WINDER 2)                   | F23 | M1450-01 | 149 |
| OD4,F | (FREE)                               |     |          | 149 |
|       |                                      |     |          |     |
| OD5,0 | TDO FAN ZONE 5 (L.S) - E190          | F24 | M1520-05 | 152 |
| OD5,1 | TDO FAN ZONE 6 (H.S) - E191          | F24 | M1520-06 | 152 |
| OD5,2 | TDO FAN ZONE 6 (L.S) - E191          | F24 | M1520-06 | 152 |
| OD5,3 | TDO FAN ZONE 7 (H.S) - E192          | F24 | M1520-07 | 152 |
| OD5,4 | TDO FAN ZONE 7 (L.S) - E192          | F24 | M1520-07 | 152 |
| OD5,5 | TDO FAN ZONE 8 (H.S) - E193          | F24 | M1520-08 | 152 |
| OD5,6 | TDO FAN ZONE 8 (L.S) - E193          | F24 | M1520-08 | 152 |
| OD5,7 | TDO FAN ZONE 9 (H.S) - E194          | F24 | M1520-09 | 152 |
| OD5,8 | TDO FAN ZONE 9 (L.S) - E194          | F24 | M1520-09 | 153 |
| OD5,9 | TDO FAN ZONE 10 (H.S) - E195         | F24 | M1520-10 | 153 |
| OD5,A | TDO FAN ZONE 10 (L.S) - E195         | F24 | M1520-10 | 153 |
| OD5,B | TDO FAN W. ZONE 10 (H.S) - E196      | F24 | M1520-11 | 153 |
| OD5,C | TDO FAN W. ZONE 10 (L.S) - E196      | F24 | M1520-11 | 153 |
| OD5,D | TDO FAN E. ZONE 11 (H.S) - E197      | F24 | M1520-12 | 153 |

|       |                                       |     |          |     |
|-------|---------------------------------------|-----|----------|-----|
| OD5,E | TDO FAN E. ZONE 11 (L.S) - E197       | F24 | M1520-12 | 153 |
| OD5,F | TDO FAN W. ZONE 11 (H.S) - E198       | F24 | M1520-13 | 153 |
|       |                                       |     |          |     |
| OD6,0 | TDO FAN W. ZONE 15 (L.S) - E206       | F24 | M1520-21 | 156 |
| OD6,1 | TDO FAN E. ZONE 16 (H.S) - E207       | F24 | M1520-22 | 156 |
| OD6,2 | TDO FAN E. ZONE 16 (L.S) - E207       | F24 | M1520-22 | 156 |
| OD6,3 | TDO FAN W. ZONE 16 (H.S) - E208       | F24 | M1520-23 | 156 |
| OD6,4 | TDO FAN W. ZONE 16 (L.S) - E208       | F24 | M1520-23 | 156 |
| OD6,5 | TDO FAN E. ZONE 17 (H.S) - E209       | F24 | M1520-24 | 156 |
| OD6,6 | TDO FAN E. ZONE 17 (L.S) - E209       | F24 | M1520-24 | 156 |
| OD6,7 | TDO FAN W. ZONE 17 (H.S) - E210       | F24 | M1520-25 | 156 |
| OD6,8 | TDO FAN W. ZONE 17 (L.S) - E210       | F24 | M1520-25 | 157 |
| OD6,9 | TDO FAN E. ZONE 18 (H.S) - E211       | F24 | M1520-26 | 157 |
| OD6,A | TDO FAN E. ZONE 18 (L.S) - E211       | F24 | M1520-26 | 157 |
| OD6,B | TDO FAN W. ZONE 18 (H.S) - E212       | F24 | M1520-27 | 157 |
| OD6,C | TDO FAN W. ZONE 18 (L.S) - E212       | F24 | M1520-27 | 157 |
| OD6,D | TDO FAN E. ZONE 19 (H.S) - E213       | F24 | M1520-28 | 157 |
| OD6,E | TDO FAN E. ZONE 19 (L.S) - E213       | F24 | M1520-28 | 157 |
| OD6,F | TDO FAN W. ZONE 19 (H.S) - E214       | F24 | M1520-29 | 157 |
|       |                                       |     |          |     |
| OD7,0 | FAN FOR PRS2 VACUUM ROLL              | F24 | M1825-01 | 160 |
| OD7,1 | OZONE EXHAUST 1 (NOT USED)            |     | M1831-01 | 160 |
| OD7,2 | OZONE EXHAUST 2 (NOT USED)            |     | M1831-02 | 160 |
| OD7,3 | OZONE EXHAUST 3 (NOT USED)            |     | M1831-03 | 160 |
| OD7,4 | OZONE TREATER 1                       | F24 |          | 160 |
| OD7,5 | OZONE TREATER 2                       | F24 |          | 160 |
| OD7,6 | OZONE TREATER 3                       | F24 |          | 160 |
| OD7,7 | OZONE TREATER 4                       | F24 |          | 160 |
| OD7,8 | RELEASE DEFECT                        |     |          | 161 |
| OD7,9 | TDO ROTATION                          |     |          | 161 |
| OD7,A | TDO CLIPS CLEANING AIR OFF CONDITIONS |     |          | 161 |
| OD7,B | CHAIN TENSION PUMP                    |     | M1515-01 | 161 |
| OD7,C | CLIP CLEANING AIR OUTPUT              |     |          | 161 |
| OD7,D | (FREE)                                |     |          | 161 |
| OD7,E | (FREE)                                |     |          | 161 |
| OD7,F | (FREE)                                |     |          | 161 |
|       |                                       |     |          |     |
| OE0,0 | C. R. BRAKE                           | F23 | Y1301-02 | 163 |
| OE0,1 | C. R. HOR. MOV. (BACKWARD)            | F23 | M1301-01 | 163 |
| OE0,2 | C. R. HOR. MOV. (FORWARD)             | F23 | M1301-01 | 163 |
| OE0,3 | C. R. HOR. MOV. (H.S)                 | F23 | M1301-01 | 163 |
| OE0,4 | C. R. HOR. MOV. (L.S)                 | F23 | M1301-01 | 163 |
| OE0,5 | STRETCHING ROLL #1 UP                 | F23 | M1402-01 | 163 |
| OE0,6 | STRETCHING ROLL #1 DOWN               | F23 | M1402-01 | 163 |
| OE0,7 | STRETCHING ROLL #2 UP                 | F23 | M1402-02 | 163 |
| OE0,8 | STRETCHING ROLL #2 DOWN               | F23 | M1402-02 | 164 |
| OE0,9 | STRETCHING ROLL #3 UP                 | F23 | M1402-03 | 164 |
| OE0,A | STRETCHING ROLL #3 DOWN               | F23 | M1402-03 | 164 |
| OE0,B | MDO THREADING CLUTCH                  | F23 | Y1410-01 | 164 |
| OE0,C | CHILL ROLL IN WORKING POSITION        |     |          | 164 |
| OE0,D | CHILL ROLL IN HOME POSITION           |     |          | 164 |
| OE0,E | (FREE)                                |     |          | 164 |

|       |                                      |     |           |     |
|-------|--------------------------------------|-----|-----------|-----|
| OE0,F | (FREE)                               |     |           | 164 |
|       |                                      |     |           |     |
| OE1,0 | AIR KNIFE POS. TO POSITION           | F23 | SV1310-09 | 167 |
| OE1,1 | ROLL POS. FOR WATER REMOVAL CARRIAGE | F23 | SV1310-11 | 167 |
| OE1,2 | CHROMEO ROLL TO POSITION             | F23 | SV1310-12 | 167 |
| OE1,3 | RUBBER ROLL TO POSITION              | F23 | SV1310-13 | 167 |
| OE1,4 | COOLING WATER VALVE FOR WATER BATH   | F23 | SV1350-03 | 167 |
| OE1,5 | AUX. WINDER #1 ENGAGE                | F23 | SV1360-04 | 167 |
| OE1,6 | AUX. WINDER #1 RETRACT               | F23 | SV1360-05 | 167 |
| OE1,7 | EDGE PINNING TO POSITION             | F23 | SV1310-10 | 167 |
| OE1,8 | INST. AIR OPEN (NOT USED)            |     | SV1310-14 | 168 |
| OE1,9 | MDO NIP ROLL 1 SOLENOID              | F23 | SV1404-01 | 168 |
| OE1,A | MDO NIP ROLL 2 SOLENOID              | F23 | SV1404-02 | 168 |
| OE1,B | MDO NIP ROLL 3 SOLENOID              | F23 | SV1404-03 | 168 |
| OE1,C | MDO PRESS ROLL INLET                 | F23 | SV1404-04 | 168 |
| OE1,D | MDO PRESS ROLL OUTLET                | F23 | SV1404-05 | 168 |
| OE1,E | AUX. WINDER 2 RETRACT                | F23 | SV1450-04 | 168 |
| OE1,F | AUX. WINDER 2 ENGAGE                 | F23 | SV1450-05 | 168 |
|       |                                      |     |           |     |
| OE2,0 | NIP ROLL FOR CORONA #3               | F23 | SV1820-15 | 171 |
| OE2,1 | SR12 L230+9                          |     |           | 171 |
| OE2,2 | OP. SPREADER ROLL 1                  | F23 | SV1840-01 | 171 |
| OE2,3 | DRIVE SPREADER ROLL 1                | F23 | SV1840-02 | 171 |
| OE2,4 | OP. SPREADER ROLL 2                  | F23 | SV1840-03 | 171 |
| OE2,5 | DRIVE SPREADER ROLL 2                | F23 | SV1840-04 | 171 |
| OE2,6 | OP. SPREADER ROLL 3                  | F23 | SV1840-05 | 171 |
| OE2,7 | DRIVE SPREADER ROLL 3                | F23 | SV1840-06 | 171 |
| OE2,8 | OP. NIP ROLL FOR EDGE TRIM           | F23 | SV1850-01 | 172 |
| OE2,9 | DRIVE NIP ROLL FOR EDGE TRIM         | F23 | SV1850-02 | 172 |
| OE2,A | OP. KNIFE FOR EDGE TRIM              | F23 | SV1850-03 | 172 |
| OE2,B | DRIVE KNIFE FOR EDGE TRIM            | F23 | SV1850-04 | 172 |
| OE2,C | AUX. WINDER 3 ENGAGE                 | F23 | SV1860-01 | 172 |
| OE2,D | AUX. WINDER 3 RETRACT                | F23 | SV1860-02 | 172 |
| OE2,E | AUX. WINDER 3 LOCKING                | F23 | SV1860-03 | 172 |
| OE2,F | TDO GAS SUPPLY OPEN/CLOSE            | F23 | SV1500-00 | 172 |
|       |                                      |     |           |     |
| OE3,0 | WEB BREAK MDO LAMP                   | F42 |           | 175 |
| OE3,1 | WEB BREAK MDO LAMP                   | F42 |           | 175 |
| OE3,2 | FILM BREAK BYPASS ON                 | F42 |           | 175 |
| OE3,3 | CHAIN TENSION LAMP                   | F50 |           | 175 |
| OE3,4 | (FREE)                               |     |           | 175 |
| OE3,5 | WEB BREAK TDO LAMP                   | F55 |           | 175 |
| OE3,6 | WEB BREAK PRS LAMP                   | F55 |           | 175 |
| OE3,7 | NIP ROLL FOR CORONA #1               | F55 |           | 175 |
| OE3,8 | COR. ELECTRODE 1 ENGAGED - LAMP      | F55 |           | 176 |
| OE3,9 | COR. ELECTRODE 2 ENGAGED - LAMP      | F55 |           | 176 |
| OE3,A | NIP ROLL FOR CORONA #3               | F55 |           | 176 |
| OE3,B | COR. ELECTRODE 3 ENGAGED - LAMP      | F55 |           | 176 |
| OE3,C | VACUUM ROLL 1 ON - LAMP              | F55 |           | 176 |
| OE3,D | VACUUM ROLL 2 ON - LAMP              | F55 |           | 176 |
| OE3,E | OZONE EXHAUST FAN 1                  | F55 |           | 176 |
| OE3,F | OZONE EXHAUST FAN 2                  | F55 |           | 176 |



|       |                                      |      |     |
|-------|--------------------------------------|------|-----|
| OE4,0 | TDO BURNER 1 INTER.                  | F151 | 179 |
| OE4,1 | TDO BURNER 1 START/STOP              | F151 | 179 |
| OE4,2 | TDO BURNER 2 INTER.                  | F152 | 179 |
| OE4,3 | TDO BURNER 2 START/STOP              | F152 | 179 |
| OE4,4 | TDO BURNER 3 INTER.                  | F153 | 179 |
| OE4,5 | TDO BURNER 3 START/STOP              | F153 | 179 |
| OE4,6 | TDO BURNER 4 INTER.                  | F154 | 179 |
| OE4,7 | TDO BURNER 4 START/STOP              | F154 | 179 |
| OE4,8 | TDO BURNER 5 INTER.                  | F155 | 180 |
| OE4,9 | TDO BURNER 5 START/STOP              | F155 | 180 |
| OE4,A | TDO BURNER 6 INTER.                  | F156 | 180 |
| OE4,B | TDO BURNER 6 START/STOP              | F156 | 180 |
| OE4,C | TDO BURNER 7 INTER.                  | F157 | 180 |
| OE4,D | TDO BURNER 7 START/STOP              | F157 | 180 |
| OE4,E | TDO BURNER 8 INTER.                  | F158 | 180 |
| OE4,F | TDO BURNER 8 START/STOP              | F158 | 180 |
| OE5,0 | TDO BURNER 17 INTER.                 | F167 | 183 |
| OE5,1 | TDO BURNER 17 START/STOP             | F167 | 183 |
| OE5,2 | TDO BURNER 18 INTER.                 | F168 | 183 |
| OE5,3 | TDO BURNER 18 START/STOP             | F168 | 183 |
| OE5,4 | TDO BURNER 19 INTER.                 | F169 | 183 |
| OE5,5 | TDO BURNER 19 START/STOP             | F169 | 183 |
| OE5,6 | TDO BURNER 20 INTER.                 | F170 | 183 |
| OE5,7 | TDO BURNER 20 START/STOP             | F170 | 183 |
| OE5,8 | CLOSE TOP KNIFE GATE TO WEIGH HOPPER |      | 184 |
| OE5,9 | OPEN TOP KNIFE GATE TO WEIGH HOPPER  |      | 184 |
| OE5,A | (FREE)                               |      | 184 |
| OE5,B | (FREE)                               |      | 184 |
| OE5,C | (FREE)                               |      | 184 |
| OE5,D | (FREE)                               |      | 184 |
| OE5,E | (FREE)                               |      | 184 |
| OE5,F | (FREE)                               |      | 184 |
| OE6,0 | C. R. INTERLOCK                      | F16  | 187 |
| OE6,1 | MDO 1 INTERLOCK                      | F16  | 187 |
| OE6,2 | MDO 2 INTERLOCK                      | F16  | 187 |
| OE6,3 | MDO 3 INTERLOCK                      | F16  | 187 |
| OE6,4 | TDO INTERLOCK                        | F16  | 187 |
| OE6,5 | PRS 1 INTERLOCK                      | F16  | 187 |
| OE6,6 | PRS 2 INTERLOCK                      | F16  | 187 |
| OE6,7 | AUX. 1 INTERLOCK                     | F16  | 187 |
| OE6,8 | AUX. 2 INTERLOCK                     | F16  | 188 |
| OE6,9 | AUX. WINDER INTERLOCK                | F16  | 188 |
| OE6,A | WEB BREAK MDO                        | F16  | 188 |
| OE6,B | WEB BREAK TDO                        | F16  | 188 |
| OE6,C | WEB BREAK PRS                        | F16  | 188 |
| OE6,D | MDO WARM ROLLS                       | F16  | 188 |
| OE6,E | TDO WARM                             | F16  | 188 |
| OE6,F | AUX. WINDER START/STOP               | F16  | 188 |

|       |                                            |      |           |
|-------|--------------------------------------------|------|-----------|
| OF0,0 | RAISE CLIP CLOSER WHILE INDEPENDENT MODE   |      | 165       |
| OF0,1 | WEST CLIP CLOSER RAISE WHILE SEQUENCE MODE |      | 165       |
| OF0,2 | MDO ZONE 9, HEATING                        | MDO  | SV1435-13 |
| OF0,3 | MDO ZONE 10, HEATING                       | MDO  | SV1435-14 |
| OF0,4 | MDO ZONE 1                                 | MDO  | SV1435-01 |
| OF0,5 | MDO ZONE 2                                 | MDO  | SV1435-02 |
| OF0,6 | MDO ZONE 3                                 | MDO  | SV1435-03 |
| OF0,7 | MDO ZONE 4                                 | MDO  | SV1435-04 |
| OF0,8 | MDO ZONE 5                                 | MDO  | SV1435-05 |
| OF0,9 | MDO ZONE 6                                 | MDO  | SV1435-06 |
| OF0,A | MDO ZONE 7                                 | MDO  | SV1435-07 |
| OF0,B | MDO ZONE 8                                 | MDO  | SV1435-08 |
| OF0,C | MDO ZONE 9, COOLING                        | MDO  | SV1435-09 |
| OF0,D | MDO ZONE 10, COOLING                       | MDO  | SV1435-10 |
| OF0,E | MDO ZONE 11, COOLING                       | MDO  | SV1435-11 |
| OF0,F | MDO ZONE 12, COOLING                       | MDO  | SV1435-12 |
| OF1,0 | LUMP CAMERA                                |      | 169       |
| OF1,1 | TABLE RAISE CYLINDER                       | F140 | SV1511-02 |
| OF1,2 | CHAIN TENSION CYLINDER                     | TDO  | SV1515-08 |
| OF1,3 | CHAIN TRACK LUBRIF. EAST SIDE              | F143 | SV1518-01 |
| OF1,4 | CLIPS LUBRIF. EAST SIDE - PUMP ENGAGE      | F143 | SV1518-03 |
| OF1,5 | CLIPS LUBRIF. EAST SIDE - PUMP RETRACT     | F143 | SV1518-04 |
| OF1,6 | CHAIN TRACK LUBRIF. WEST SIDE              | F142 | SV1518-02 |
| OF1,7 | CLIPS LUBRIF. WEST SIDE - PUMP ENGAGE      | F142 | SV1518-05 |
| OF1,8 | CLIPS LUBRIF. WEST SIDE - PUMP RETRACT     | F142 | SV1518-06 |
| OF1,9 | AIR ON CLIPS VALVE                         | F142 | SV1511-03 |
| OF1,A | MDO ZONE 11, HEATING                       | MDO  | SV1435-15 |
| OF1,B | MDO ZONE 12, HEATING                       | MDO  | SV1435-16 |
| OF1,C | COR. ELECTRODE 1 CYLINDER                  | PRS  | SV1820-07 |
| OF1,D | NIP ROLL FOR CORONA #1                     | PRS  | SV1820-19 |
| OF1,E | COR. ELECTRODE 2 CYLINDER                  | PRS  | SV1820-16 |
| OF1,F | COR. ELECTRODE 3 CYLINDER                  | PRS  | SV1820-11 |
| OF2,0 | DIE EXHAUST HOOD ON - LAMP                 | F32  | 173       |
| OF2,1 | EDGE PINNING ON - LAMP                     | F32  | 173       |
| OF2,2 | AIR KNIFE POS. - LAMP                      | F32  | 173       |
| OF2,3 | AIR KNIFE BLOWER ON - LAMP                 | F32  | 173       |
| OF2,4 | C. R. WATER REMOVAL FAN ON - LAMP          | F32  | 173       |
| OF2,5 | FILM WATER REMOVAL 1 ON - LAMP             | F32  | 173       |
| OF2,6 | FILM WATER REMOVAL 2 ON - LAMP             | F32  | 173       |
| OF2,7 | INSTRUMENT AIR (NOT USED)                  |      | 173       |
| OF2,8 | (FREE)                                     |      | 174       |
| OF2,9 | KLAXON FOR F13                             | F32  | 174H14    |
| OF2,A | MDO NIP ROLL 1 ON - LAMP                   | F32  | 174       |
| OF2,B | MDO NIP ROLL 2 ON - LAMP                   | F32  | 174       |
| OF2,C | MDO NIP ROLL 3 ON - LAMP                   | F32  | 174       |
| OF2,D | PRESS ROLL INLET ON - LAMP                 | F32  | 174       |
| OF2,E | PRESS ROLL OUTLET ON - LAMP                | F32  | 174       |
| OF2,F | > 60M MICRO m - LAMP                       | F32  | 174       |
| OF3,0 | OZONE EXHAUST FAN 3                        | F55  | 177       |

|       |                                                                          |      |  |     |
|-------|--------------------------------------------------------------------------|------|--|-----|
| OF3,1 | WEB BREAKER DETECTOR TDO - LAMP                                          | F55  |  | 177 |
| OF3,2 | WEB BREAKER DETECTOR 1 - LAMP                                            | F55  |  | 177 |
| OF3,3 | WEB BREAKER DETECTOR 2 - LAMP                                            | F55  |  | 177 |
| OF3,4 | OP. NIP ROLL FOR EDGE TRIM ON - LAMP                                     | F62  |  | 177 |
| OF3,5 | OP. KNIFE FOR EDGE TRIM ON - LAMP                                        | F62  |  | 177 |
| OF3,6 | DRIVE NIP ROLL FOR EDGE TRIM ON - LAMP                                   | F62  |  | 177 |
| OF3,7 | DRIVE KNIFE FOR EDGE TRIM ON - LAMP                                      | F62  |  | 177 |
| OF3,8 | DRIVE NIP ROLL FOR EDGE TRIM ON - LAMP                                   | F63  |  | 178 |
| OF3,9 | DRIVE KNIFE FOR EDGE TRIM ON - LAMP                                      | F63  |  | 178 |
| OF3,A | NIP ROLL FOR CORONA #1, FOR EDGE TRIM ON - LAMP                          | F56  |  | 178 |
| OF3,B | NIP ROLL FOR CORONA #3, FOR EDGE TRIM ON - LAMP                          | F56  |  | 178 |
| OF3,C | (FREE)                                                                   |      |  | 178 |
| OF3,D | AUX. WINDER 3 WEB BREAK BYPASS ON - LAMP                                 | F70  |  | 178 |
| OF3,E | AUX. WINDER 1 WEB BREAK BYPASS ON - LAMP                                 | F36  |  | 178 |
| OF3,F | AUX. WINDER 2 WEB BREAK BYPASS ON - LAMP                                 | F46  |  | 178 |
|       |                                                                          |      |  |     |
| OF4,0 | TDO BURNER 9 INTER.                                                      | F159 |  | 181 |
| OF4,1 | TDO BURNER 9 START/STOP                                                  | F159 |  | 181 |
| OF4,2 | TDO BURNER 10 INTER.                                                     | F160 |  | 181 |
| OF4,3 | TDO BURNER 10 START/STOP                                                 | F160 |  | 181 |
| OF4,4 | TDO BURNER 11 INTER.                                                     | F161 |  | 181 |
| OF4,5 | TDO BURNER 11 START/STOP                                                 | F161 |  | 181 |
| OF4,6 | TDO BURNER 12 INTER.                                                     | F162 |  | 181 |
| OF4,7 | TDO BURNER 12 START/STOP                                                 | F162 |  | 181 |
| OF4,8 | TDO BURNER 13 INTER.                                                     | F163 |  | 181 |
| OF4,9 | TDO BURNER 13 START/STOP                                                 | F163 |  | 181 |
| OF4,A | TDO BURNER 14 INTER.                                                     | F164 |  | 181 |
| OF4,B | TDO BURNER 14 START/STOP                                                 | F164 |  | 181 |
| OF4,C | TDO BURNER 15 INTER.                                                     | F165 |  | 181 |
| OF4,D | TDO BURNER 15 START/STOP                                                 | F165 |  | 181 |
| OF4,E | TDO BURNER 16 INTER.                                                     | F166 |  | 181 |
| OF4,F | TDO BURNER 16 START/STOP                                                 | F166 |  | 181 |
|       |                                                                          |      |  |     |
| OF5,0 | TDO AND PRS WEB BREAK -> WINDER SR12 L250 + 15                           |      |  | 185 |
| OF5,1 | FLAME TREATER WEB BREAK / PROCESS STOP ACTION &<br>PRS VACUUM ROLL #2 ON |      |  | 185 |
| OF5,2 | FLAME TREATER WEB BREAK / PROCESS STOP ACTION &<br>PRS VACUUM ROLL #2 ON |      |  | 185 |
| OF5,3 | FLAME TREATER WEB BREAK / PROCESS STOP ACTION &<br>PRS VACUUM ROLL #2 ON |      |  | 185 |
| OF5,4 | CHILL ROLL SPEED CONTROLLED BY THE GAUGE                                 |      |  | 185 |
| OF5,5 | KLAXON FM F12 I96,E TO INPUT OF F12 FOR KLAXON ALARM                     |      |  | 185 |
| OF5,6 | (FREE) SOFTAL TREATER C.D ENGAGE ELECTRODES                              |      |  | 185 |
| OF5,7 | (FREE) SOFTAL TREATER C.D RETRACT ELECTRODES                             |      |  | 185 |
| OF5,8 | (FREE) UP TO SPEED FOR SOFTAL TREATER C                                  |      |  | 186 |
| OF5,9 | (FREE) UP TO SPEED FOR SOFTAL TREATER D                                  |      |  | 186 |
| OF5,A | (FREE) SOFTAL TREATER A,B ENGAGED ELECTRODES                             |      |  | 186 |
| OF5,B | (FREE) SOFTAL TREATER A,B RETRACT ELECTRODES                             |      |  | 186 |
| OF5,C | (FREE)                                                                   |      |  | 186 |
| OF5,D | (FREE)                                                                   |      |  | 186 |
| OF5,E | (FREE)                                                                   |      |  | 186 |

|       |                                          |          |          |     |
|-------|------------------------------------------|----------|----------|-----|
| OF5,F | (FREE)                                   |          |          | 186 |
|       |                                          |          |          |     |
| OF6,0 | C. R. COOLING SKID INTER.                | C.R      |          | 189 |
| OF6,1 | C. R. COOLING SKID START/STOP            | C.R      |          | 189 |
| OF6,2 | WATER BATH SKID INTER.                   | C.R      |          | 189 |
| OF6,3 | WATER BATH SKID START/STOP               | C.R      |          | 189 |
| OF6,4 | MDO BOILER SKID START/STOP               | MDO      |          | 189 |
| OF6,5 | MDO SR5 L834+10                          |          |          | 189 |
| OF6,6 | WATER BATH LEVEL                         | C.R      |          | 189 |
| OF6,7 | FILM BREAK TO MEASUREX                   | MEASUREX |          | 189 |
| OF6,8 | MDO BOILER SKID INTERLOCK                |          | C1430    | 190 |
| OF6,9 | KLAXON FOR F13                           | F13      | 17H3     | 190 |
| OF6,A | ROTATING LIGHT FOR F13                   | F13      | 17H7     | 190 |
| OF6,B | COR. 1 INTERLOCK UP TO SPEED SOFTAL A    | F75      | G1820-01 | 190 |
| OF6,C | COR. 2 INTERLOCK UP TO SPEED SOFTAL B    | F76      | G1820-02 | 190 |
| OF6,D | COR. 3 INTERLOCK                         | F77      | G1820-03 | 190 |
| OF6,E | COR. 4 INTERLOCK                         | F78      | G1820-04 | 190 |
| OF6,F | ISO DAC GAUGE CONTROL ON/OFF TO MEASUREX | MEASUREX |          | 190 |

**F13 I/O LIST**

F13\INPUTWD.DOC

| I/O<br>WORD | DESCRIPTION                        | SYMBOL    | PAGE #<br>(DRAW') |
|-------------|------------------------------------|-----------|-------------------|
| IW01,3      | C. R. TEMPERATURE MEASUREMENT      | TE1340-02 | 32                |
| IW01,4      | WATER BATH TEMPERATUER MEASUREMENT | TE1350-02 | 32                |
| IW01,5      | (FREE)                             |           | 32                |
| IW01,6      | (FREE)                             |           | 32                |
|             |                                    |           |                   |
| IW02,3      | MDO ZONE 1, TEMP. MEASUREMENT      | TE1435-01 | 33                |
| IW02,4      | MDO ZONE 2, TEMP. MEASUREMENT      | TE1435-02 | 33                |
| IW02,5      | MDO ZONE 3, TEMP. MEASUREMENT      | TE1435-03 | 33                |
| IW02,6      | MDO ZONE 4, TEMP. MEASUREMENT      | TE1435-04 | 33                |
|             |                                    |           |                   |
| IW03,3      | MDO ZONE 5, TEMP. MEASUREMENT      | TE1435-05 | 34                |
| IW03,4      | MDO ZONE 6, TEMP. MEASUREMENT      | TE1435-06 | 34                |
| IW03,5      | MDO ZONE 7, TEMP. MEASUREMENT      | TE1435-07 | 34                |
| IW03,6      | MDO ZONE 8, TEMP. MEASUREMENT      | TE1435-08 | 34                |
|             |                                    |           |                   |
| IW04,3      | MDO ZONE 9, TEMP. MEASUREMENT      | TE1435-09 | 35                |
| IW04,4      | MDO ZONE 10, TEMP. MEASUREMENT     | TE1435-10 | 35                |
| IW04,5      | MDO ZONE 11, TEMP. MEASUREMENT     | TE1435-11 | 35                |
| IW04,6      | MDO ZONE 12, TEMP. MEASUREMENT     | TE1435-12 | 35                |
|             |                                    |           |                   |
| IW05,3      | TDO ZONE 1, TEMP. MEASUREMENT      | TE1545-01 | 36                |
| IW05,4      | TDO ZONE 2, TEMP. MEASUREMENT      | TE1545-02 | 36                |
| IW05,5      | TDO ZONE 3, TEMP. MEASUREMENT      | TE1545-03 | 36                |
| IW05,6      | TDO ZONE 4, TEMP. MEASUREMENT      | TE1545-04 | 36                |
|             |                                    |           |                   |
| IW06,3      | TDO ZONE 5, TEMP. MEASUREMENT      | TE1545-05 | 37                |
| IW06,4      | TDO ZONE 6, TEMP. MEASUREMENT      | TE1545-06 | 37                |
| IW06,5      | TDO ZONE 7, TEMP. MEASUREMENT      | TE1545-07 | 37                |
| IW06,6      | TDO ZONE 8, TEMP. MEASUREMENT      | TE1545-08 | 37                |
|             |                                    |           |                   |
| IW07,3      | TDO ZONE 9, TEMP. MEASUREMENT      | TE1545-09 | 38                |
| IW07,4      | TDO ZONE 10, TEMP. MEASUREMENT     | TE1545-10 | 38                |
| IW07,5      | TDO ZONE 11, TEMP. MEASUREMENT     | TE1545-11 | 38                |
| IW07,6      | TDO ZONE 12, TEMP. MEASUREMENT     | TE1545-12 | 38                |
|             |                                    |           |                   |
| IW40,3      | TDO ZONE 13, TEMP. MEASUREMENT     | TE1545-13 | 40                |
| IW40,4      | TDO ZONE 14, TEMP. MEASUREMENT     | TE1545-14 | 40                |
| IW40,5      | TDO ZONE 15, TEMP. MEASUREMENT     | TE1545-15 | 40                |
| IW40,6      | TDO ZONE 16, TEMP. MEASUREMENT     | TE1545-16 | 40                |
|             |                                    |           |                   |
| IW41,3      | TDO ZONE 17, TEMP. MEASUREMENT     | TE1545-17 | 41                |
| IW41,4      | TDO ZONE 18, TEMP. MEASUREMENT     | TE1545-18 | 41                |
| IW41,5      | TDO ZONE 19, TEMP. MEASUREMENT     | TE1545-19 | 41                |
| IW41,6      | TDO ZONE 20, TEMP. MEASUREMENT     | TE1545-20 | 41                |
|             |                                    |           |                   |
| IW42,3      | (FREE)                             |           | 42                |
| IW42,4      | (FREE)                             |           | 42                |
| IW42,5      | (FREE)                             |           | 42                |
| IW42,6      | (FREE)                             |           | 42                |
|             |                                    |           |                   |
| IW43,3      | AUX. WINDER 1 CURRENT              |           | 43                |
| IW43,3      | (FREE)                             |           | 44                |
| IW43,4      | AUX. WINDER 2 CURRENT              |           | 43                |

|        |                    |           |    |
|--------|--------------------|-----------|----|
| IW43,4 | (FREE)             |           | 44 |
| IW43,5 | F. P. C. FLOWMETER | FT1310-15 | 43 |
| IW43,5 | (FREE)             |           | 44 |
| IW43,6 | LINE SPEED         |           | 43 |
| IW43,6 | (FREE)             |           | 44 |

**F13 I/O LIST**

F13\OUTPUTWD.DOC

| I/O<br>WORD | DESCRIPTION                      | SYMBOL    | PAGE #<br>(DRAW') |
|-------------|----------------------------------|-----------|-------------------|
| OW44,3      | (FREE)                           |           | 47                |
| OW44,4      | (FREE)                           |           | 47                |
| OW44,5      | C. R. BRAKE                      | Y1302-01  | 47                |
| OW44,6      | (FREE)                           |           | 47                |
|             |                                  |           |                   |
| OW45,3      | MDO ZONE 1, CONTROL VALVE        | TV1435-01 | 48                |
| OW45,4      | MDO ZONE 2, CONTROL VALVE        | TV1435-02 | 48                |
| OW45,5      | MDO ZONE 3, CONTROL VALVE        | TV1435-03 | 48                |
| OW45,6      | MDO ZONE 4, CONTROL VALVE        | TV1435-04 | 48                |
|             |                                  |           |                   |
| OW46,3      | MDO ZONE 5, CONTROL VALVE        | TV1435-05 | 49                |
| OW46,4      | MDO ZONE 6, CONTROL VALVE        | TV1435-06 | 49                |
| OW46,5      | MDO ZONE 7, CONTROL VALVE        | TV1435-07 | 49                |
| OW46,6      | MDO ZONE 8, CONTROL VALVE        | TV1435-08 | 49                |
|             |                                  |           |                   |
| OW47,3      | MDO ZONE 9, CONTROL VALVE        | TV1435-09 | 50                |
| OW47,4      | MDO ZONE 10, CONTROL VALVE       | TV1435-10 | 50                |
| OW47,5      | MDO ZONE 11, CONTROL VALVE       | TV1435-11 | 50                |
| OW47,6      | MDO ZONE 12, CONTROL VALVE       | TV1435-12 | 50                |
|             |                                  |           |                   |
| OW60,3      | TDO ZONE 1                       | BURNER 1  | 52                |
| OW60,4      | TDO ZONE 2                       | BURNER 2  | 52                |
| OW60,5      | TDO ZONE 3                       | BURNER 3  | 52                |
| OW60,6      | TDO ZONE 4                       | BURNER 4  | 52                |
|             |                                  |           |                   |
| OW61,3      | TDO ZONE 5                       | BURNER 5  | 53                |
| OW61,4      | TDO ZONE 6                       | BURNER 6  | 53                |
| OW61,5      | TDO ZONE 7                       | BURNER 7  | 53                |
| OW61,6      | TDO ZONE 8                       | BURNER 8  | 53                |
|             |                                  |           |                   |
| OW62,3      | TDO ZONE 9                       | BURNER 9  | 54                |
| OW62,4      | TDO ZONE 10                      | BURNER 10 | 54                |
| OW62,5      | TDO ZONE 11                      | BURNER 11 | 54                |
| OW62,6      | TDO ZONE 12                      | BURNER 12 | 54                |
|             |                                  |           |                   |
| OW63,3      | TDO ZONE 13                      | BURNER 13 | 55                |
| OW63,4      | TDO ZONE 14                      | BURNER 14 | 55                |
| OW63,5      | TDO ZONE 15                      | BURNER 15 | 55                |
| OW63,6      | TDO ZONE 16                      | BURNER 16 | 55                |
|             |                                  |           |                   |
| OW64,3      | TDO ZONE 17                      | BURNER 17 | 56                |
| OW64,4      | TDO ZONE 18                      | BURNER 18 | 56                |
| OW64,5      | TDO ZONE 19                      | BURNER 19 | 56                |
| OW64,6      | TDO ZONE 20                      | BURNER 20 | 56                |
|             |                                  |           |                   |
| OW65,3      | SMOOT #1                         |           | 57                |
| OW65,4      | (FREE)                           |           | 57                |
| OW65,5      | (FREE)                           |           | 57                |
| OW65,6      | (FREE)                           |           | 57                |
|             |                                  |           |                   |
| OW66,3      | MDO ZONE 9, CTRL. VAL., HEATING  | TV1435-13 | 58                |
| OW66,4      | MDO ZONE 10, CTRL. VAL., HEATING | TV1435-14 | 58                |
| OW66,5      | MDO ZONE 11, CTRL. VAL., HEATING | TV1435-15 | 58                |

|        |                                  |           |    |
|--------|----------------------------------|-----------|----|
| OW66,6 | MDO ZONE 12, CTRL. VAL., HEATING | TV1435-16 | 58 |
|--------|----------------------------------|-----------|----|



|      |                                           |
|------|-------------------------------------------|
| B 0  |                                           |
| B 1  | 1 SEC PULSE                               |
| B 2  | 1 SEC SYSTEM BIT                          |
| B 3  | 100 MS PULSE                              |
| B 4  | 100 MS SYSTEM BIT                         |
| B 5  |                                           |
| B 6  |                                           |
| B 7  |                                           |
| B 8  |                                           |
| B 9  |                                           |
| B 10 | CONFIGURATION CARD AEM 413 RACK 0-1 TXT0  |
| B 11 | CONFIGURATION CARD AEM 413 RACK 0-2 TXT1  |
| B 12 | CONFIGURATION CARD AEM 413 RACK 0-3 TXT2  |
| B 13 | CONFIGURATION CARD AEM 413 RACK 0-4 TXT3  |
| B 14 | CONFIGURATION CARD AEM 413 RACK 0-5 TXT4  |
| B 15 | CONFIGURATION CARD AEM 413 RACK 0-6 TXT5  |
| B 16 | CONFIGURATION CARD AEM 413 RACK 0-7 TXT6  |
| B 17 |                                           |
| B 18 |                                           |
| B 19 |                                           |
| B 20 | CONFIGURATION CARD AEM 413 RACK 4-0 TXT7  |
| B 21 | CONFIGURATION CARD AEM 413 RACK 4-1 TXT8  |
| B 22 | CONFIGURATION CARD AEM 413 RACK 4-2 TXT9  |
| B 23 |                                           |
| B 24 |                                           |
| B 25 |                                           |
| B 26 |                                           |
| B 27 |                                           |
| B 28 |                                           |
| B 29 |                                           |
| B 30 |                                           |
| B 31 |                                           |
| B 32 | CONFIGURATION CARD AEM 811 RACK 4-3 TXT17 |
| B 33 | CONFIGURATION CARD AEM 811 RACK 4-2 TXT17 |
| B 34 |                                           |
| B 35 |                                           |
| B 36 |                                           |
| B 37 |                                           |
| B 38 |                                           |
| B 39 |                                           |
| B 40 |                                           |
| B 41 |                                           |
| B 42 | MODULE SCM 2222 CONFIGURED; CHANNEL OK    |
| B 43 | COLD RESTART OR WARM RESTART              |
| B 44 | CHANNEL CONFIGURED                        |
| B 45 | MODULE IN "EXCHANGE VALUES" MODE          |
| B 46 |                                           |
| B 47 | BLOCK TEXT EXCHANGE OVER WITHOUT DEFECT   |
| B 48 | SCM2222 IN FAULT OR NOT PRESENT           |
| B 49 | RECEIVING IN PROGRESS                     |
| B 50 | IN USE                                    |
| B 51 | IN USE                                    |
| B 52 | IN USE                                    |
| B 53 | IN USE                                    |
| B 54 | IN USE                                    |
| B 55 | IN USE                                    |
| B 56 | IN USE                                    |

|       |                                              |
|-------|----------------------------------------------|
| B 57  | IN USE                                       |
| B 58  | IN USE                                       |
| B 59  | IN USE                                       |
| B 60  | IN USE                                       |
| B 61  | IN USE                                       |
| B 62  | IN USE                                       |
| B 63  | IN USE                                       |
| B 64  | DRIVING SIDE COUNTER - TDO OUTLET SPROCKET   |
| B 65  | OPERATING SIDE COUNTER - TDO OUTLET SPROCKET |
| B 66  |                                              |
| B 67  |                                              |
| B 68  |                                              |
| B 69  |                                              |
| B 70  |                                              |
| B 71  |                                              |
| B 72  |                                              |
| B 73  |                                              |
| B 74  |                                              |
| B 75  |                                              |
| B 76  |                                              |
| B 77  |                                              |
| B 78  |                                              |
| B 79  |                                              |
| B 80  | BIT RELEASE DEFECT                           |
| B 81  |                                              |
| B 82  |                                              |
| B 83  |                                              |
| B 84  |                                              |
| B 85  |                                              |
| B 86  |                                              |
| B 87  |                                              |
| B 88  |                                              |
| B 89  |                                              |
| B 90  |                                              |
| B 91  |                                              |
| B 92  |                                              |
| B 93  |                                              |
| B 94  |                                              |
| B 95  |                                              |
| B 96  |                                              |
| B 97  |                                              |
| B 98  |                                              |
| B 99  |                                              |
| B 100 | STEP 0 E170 MDO START PUMP                   |
| B 101 | STEP 1 E170 MDO START PUMP                   |
| B 102 | STEP 2 E170 MDO START PUMP                   |
| B 103 | STEP 0 E171 MDO START PUMP                   |
| B 104 | STEP 1 E171 MDO START PUMP                   |
| B 105 | STEP 2 E171 MDO START PUMP                   |
| B 106 | STEP 0 E172 MDO START PUMP                   |
| B 107 | STEP 1 E172 MDO START PUMP                   |
| B 108 | STEP 2 E172 MDO START PUMP                   |
| B 109 | STEP 0 E173 MDO START PUMP                   |
| B 110 | STEP 1 E173 MDO START PUMP                   |
| B 111 | STEP 2 E173 MDO START PUMP                   |
| B 112 | STEP 0 E174 MDO START PUMP                   |
| B 113 | STEP 1 E174 MDO START PUMP                   |
| B 114 | STEP 2 E174 MDO START PUMP                   |

|       |                                           |
|-------|-------------------------------------------|
| B 115 | STEP 0 E175 MDO START PUMP                |
| B 116 | STEP 1 E175 MDO START PUMP                |
| B 117 | STEP 2 E175 MDO START PUMP                |
| B 118 | STEP 0 E176 MDO START PUMP                |
| B 119 | STEP 1 E176 MDO START PUMP                |
| B 120 | STEP 2 E176 MDO START PUMP                |
| B 121 | STEP 0 E177 MDO START PUMP                |
| B 122 | STEP 1 E177 MDO START PUMP                |
| B 123 | STEP 2 E177 MDO START PUMP                |
| B 124 | STEP 0 E178 MDO START PUMP                |
| B 125 | STEP 1 E178 MDO START PUMP                |
| B 126 | STEP 2 E178 MDO START PUMP                |
| B 127 | STEP 0 E179 MDO START PUMP                |
| B 128 | STEP 1 E179 MDO START PUMP                |
| B 129 | STEP 2 E179 MDO START PUMP                |
| B 130 | STEP 0 E180 MDO START PUMP                |
| B 131 | STEP 1 E180 MDO START PUMP                |
| B 132 | STEP 2 E180 MDO START PUMP                |
| B 133 | STEP 0 E181 MDO START PUMP                |
| B 134 | STEP 1 E181 MDO START PUMP                |
| B 135 | STEP 2 E181 MDO START PUMP                |
| B 136 |                                           |
| B 137 |                                           |
| B 138 |                                           |
| B 139 |                                           |
| B 140 |                                           |
| B 141 |                                           |
| B 142 |                                           |
| B 143 |                                           |
| B 144 |                                           |
| B 145 |                                           |
| B 146 |                                           |
| B 147 |                                           |
| B 148 |                                           |
| B 149 |                                           |
| B 150 | INTERLOCK OF CHILL ROLL SKID E160         |
| B 151 | INTERLOCK OF WATER BATH COOLING SKID E161 |
| B 152 |                                           |
| B 153 |                                           |
| B 154 | AUXILIARY WINDER #1 DEFECT                |
| B 155 | AUXILIARY WINDER #2 DEFECT                |
| B 156 |                                           |
| B 157 |                                           |
| B 158 |                                           |
| B 159 |                                           |
| B 160 |                                           |
| B 161 |                                           |
| B 162 |                                           |
| B 163 |                                           |
| B 164 |                                           |
| B 165 |                                           |
| B 166 |                                           |
| B 167 |                                           |
| B 168 |                                           |
| B 169 |                                           |
| B 170 |                                           |
| B 171 |                                           |
| B 172 |                                           |

|       |                                                          |
|-------|----------------------------------------------------------|
| B 173 |                                                          |
| B 174 |                                                          |
| B 175 |                                                          |
| B 176 |                                                          |
| B 177 |                                                          |
| B 178 |                                                          |
| B 179 |                                                          |
| B 180 |                                                          |
| B 181 |                                                          |
| B 182 |                                                          |
| B 183 |                                                          |
| B 184 |                                                          |
| B 185 |                                                          |
| B 186 |                                                          |
| B 187 |                                                          |
| B 188 |                                                          |
| B 189 |                                                          |
| B 190 |                                                          |
| B 191 |                                                          |
| B 192 |                                                          |
| B 193 |                                                          |
| B 194 |                                                          |
| B 195 |                                                          |
| B 196 |                                                          |
| B 197 |                                                          |
| B 198 |                                                          |
| B 199 |                                                          |
| B 200 | CHILL ROLL FORWARD MOVEMENT STEP 0                       |
| B 201 | CHILL ROLL FORWARD MOVEMENT STEP 1                       |
| B 202 | CHILL ROLL FORWARD MOVEMENT STEP 2                       |
| B 203 | CHILL ROLL FORWARD MOVEMENT STEP 3                       |
| B 204 | CHILL ROLL FORWARD MOVEMENT STEP 4                       |
| B 205 | CHILL ROLL FORWARD MOVEMENT STEP 5                       |
| B 206 | CHILL ROLL BACKWARD MOVEMENT STEP 0                      |
| B 207 | CHILL ROLL BACKWARD MOVEMENT STEP 1                      |
| B 208 | CHILL ROLL BACKWARD MOVEMENT STEP 2                      |
| B 209 | CHILL ROLL BACKWARD MOVEMENT STEP 3                      |
| B 210 | CHILL ROLL BACKWARD MOVEMENT STEP 4                      |
| B 211 |                                                          |
| B 212 |                                                          |
| B 213 | EXHAUST HOOD BLOWER STEP 0, M1263.01                     |
| B 214 | EXHAUST HOOD BLOWER STEP 1, M1263.01                     |
| B 215 | AIR KNIFE BLOWER STEP 0, M1310.01                        |
| B 216 | AIR KNIFE BLOWER STEP 1, M1310.01                        |
| B 217 | FILM WATER REMOVAL BLOWER M1310,02 STEP 0                |
| B 218 | FILM WATER REMOVAL BLOWER M1310,02 STEP 1                |
| B 219 | FILM WATER REMOVAL BLOWER M1310,03 STEP 0                |
| B 220 | FILM WATER REMOVAL BLOWER M1310,03 STEP 1                |
| B 221 | CHILL ROLL WATER REMOVAL BLOWER M1330,01 STEP 0          |
| B 222 | CHILL ROLL WATER REMOVAL BLOWER M1330,01 STEP 1          |
| B 223 | RUBBER ROLL WATER REMOVAL POSITION SV1310.03, STEP 0     |
| B 224 | RUBBER ROLL WATER REMOVAL POSITION SV1310.03, STEP 1     |
| B 225 | CHROMED ROLL POSITION SV1310.12 STEP 0                   |
| B 226 | CHROMED ROLL POSITION SV1310.12 STEP 1                   |
| B 227 | ROLL FOR CARRIAGE FILM REMOVAL POSITION SV1310.11 STEP 0 |
| B 228 | ROLL FOR CARRIAGE FILM REMOVAL POSITION SV1310.11 STEP 1 |
| B 229 | EDGE PINNING STEP 0                                      |
| B 230 | EDGE PINNING STEP 1                                      |

|       |                                                               |
|-------|---------------------------------------------------------------|
| B 231 | AIR KNIFE POSITION SV1310.09 STEP 0                           |
| B 232 | AIR KNIFE POSITION SV1310.09 STEP 1                           |
| B 233 | AUXILIARY WINDER 1 TEMPERATURE HIGH, TAH1360.03 STEP 0        |
| B 234 | AUXILIARY WINDER 1 TEMPERATURE HIGH, TAH1360.03 STEP 1        |
| B 235 | AUXILIARY WINDER 1 TEMPERATURE HIGH, TAH1360.03 STEP 2        |
| B 236 | AUXILIARY WINDER 1 MOTOR M1360.01, STEP 0                     |
| B 237 | AUXILIARY WINDER 1 MOTOR M1360.01, STEP 1                     |
| B 238 | AUXILIARY WINDER 1 CHUCK SV1360.04/SV1360.05, RETRACT         |
| B 239 | AUXILIARY WINDER 1 CHUCK SV1360.04/SV1360.05, ENGAGE          |
| B 240 | WATER BATH WATER FILLING SV1350.03, STEP 0                    |
| B 241 | WATER BATH WATER FILLING SV1350.03, STEP 1                    |
| B 242 | WATER BATH WATER FILLING SV1350.03, STEP 2                    |
| B 243 | WATER BATH WATER FILLING SV1350.03, STEP 3                    |
| B 244 | CHILL ROLL ELECTROMAGNETIC BRAKE (E162) Y1301.02, STEP 0      |
| B 245 | CHILL ROLL ELECTROMAGNETIC BRAKE (E162) Y1301.02, STEP 1      |
| B 246 | CHILL ROLL INTERLOCK NOT OK                                   |
| B 247 | CHILL ROLL INTERLOCK OK                                       |
| B 248 |                                                               |
| B 249 |                                                               |
| B 250 | MDO THREADING CHAIN CLUTCH Y1410.01 => OFF                    |
| B 251 | MDO THREADING CHAIN CLUTCH Y1410.01 => ON                     |
| B 252 | MDO WEB BREAK BYPASS                                          |
| B 253 | MDO NO WEB BREAK AND NO BYPASS                                |
| B 254 | MDO WEB BREAK AND NO BYPASS                                   |
| B 255 | MDP WEB BREAK AND BYPASS                                      |
| B 256 | MDO NIP ROLL 1 SV1404.01 RETRACTED                            |
| B 257 | MDO NIP ROLL 1 SV1404.01 ENGAGED                              |
| B 258 | MDO NIP ROLL 2 SV1404.02 RETRACTED                            |
| B 259 | MDO NIP ROLL 2 SV1404.02 ENGAGED                              |
| B 260 | MDO NIP ROLL 3 SV1404.03 RETRACTED                            |
| B 261 | MDO NIP ROLL 3 SV1404.03 ENGAGED                              |
| B 262 | STRETCHING ROLL 1 UP                                          |
| B 263 | STRETCHING ROLL 1 UP                                          |
| B 264 | STRETCHING ROLL 2 UP                                          |
| B 265 | STRETCHING ROLL 2 UP                                          |
| B 266 | STRETCHING ROLL 3 UP                                          |
| B 267 | STRETCHING ROLL 3 UP                                          |
| B 268 | STRETCHING ROLL 1 DOWN                                        |
| B 269 | STRETCHING ROLL 1 DOWN                                        |
| B 270 | STRETCHING ROLL 2 DOWN                                        |
| B 271 | STRETCHING ROLL 2 DOWN                                        |
| B 272 | STRETCHING ROLL 3 DOWN                                        |
| B 273 | STRETCHING ROLL 3 DOWN                                        |
| B 274 | MDO OUTLET PRESSURE ROLL SV1404.05 RETRACTED                  |
| B 275 | MDO OUTLET PRESSURE ROLL SV1404.05 ENGAGED                    |
| B 276 |                                                               |
| B 277 | WEB BREAK MDO & BYPASS STEP 0                                 |
| B 278 | WEB BREAK MDO & BYPASS STEP 1                                 |
| B 279 | WEB BREAK MDO & BYPASS STEP 2                                 |
| B 280 | MDO PROCESS STOP                                              |
| B 281 |                                                               |
| B 282 |                                                               |
| B 283 | TAH 1450,03 AUXILIARY WINDER 2 HIGH TEMP. => RELEASE DEFECT   |
| B 284 | TAH 1450,03 MDO AUXILIARY WINDER 2 => HIGH TEMP.              |
| B 285 | TAH 1450,03 MDO AUXILIARY WINDER 2 HIGH TEMP. => END OF TIMER |
| B 286 | AUXILIARY WINDER 2 M1450,02, STOP                             |
| B 287 | AUXILIARY WINDER 2 M1450,02, START                            |
| B 288 | AUXILIARY WINDER 2 CHUCK RETRACT                              |

|       |                                                              |
|-------|--------------------------------------------------------------|
| B 289 | AUXILIARY WINDER 2 CHUCK ENGAGE                              |
| B 290 | MDO1 MDO2 MDO3 => INTERLOCK NOT OK                           |
| B 291 | MDO1 MDO2 MDO3 => INTERLOCK OK                               |
| B 292 |                                                              |
| B 293 |                                                              |
| B 294 |                                                              |
| B 295 |                                                              |
| B 296 |                                                              |
| B 297 |                                                              |
| B 298 |                                                              |
| B 299 |                                                              |
| B 300 | TDO CHAIN TENSION SYSTEM => LOW LEVEL (LSL1515.02)           |
| B 301 | TDO CHAIN TENSION LOW LEVEL ALARM => RELEASE DEFECT          |
| B 302 | TDO CHAIN TENSION SYSTEM LOW LEVEL => END OF TIMER           |
| B 303 | PSL1515.03 CHAIN TENSION SYSTEM => PRESSURE LOW              |
| B 304 | PSL CHAIN TENSION SYSTEM => RELEASE DEFECT                   |
| B 305 | PSL CHAIN TENSION SYSTEM => END OF TIMER                     |
| B 306 | CHAIN TENSION SYSTEM MOTOR (M1515,01) => STOP                |
| B 307 | CHAIN TENSION SYSTEM MOTOR (M1515,01) => START               |
| B 308 | CHAIN TENSION SYSTEM MOTOR (M1515,01) => DEFECT              |
| B 309 | CHAIN TENSION SYSTEM MOTOR CYLINDER (SV1515.08) => RETRACTED |
| B 310 | CHAIN TENSION SYSTEM MOTOR CYLINDER (SV1515.08) => ENGAGED   |
| B 311 | TDO WEB BREAK DETECTOR (ZT1531.01 ZT1531.02)                 |
| B 312 | TDO WEB BREAK DETECTOR                                       |
| B 313 | TDO WEB BREAK DETECTOR                                       |
| B 314 | TDO INLET CLIPS OPENING/CLOSING => CLOSE                     |
| B 315 | TDO SWITCH CLIPS OPENING/CLOSING => OPEN                     |
| B 316 | TDO AIR ON CLIPS (SV1511.03) => OFF                          |
| B 317 | TDO AIR ON CLIPS (SV1511.04) => ON                           |
| B 318 | TDO TABLE RAISE (SV1511.08) => OFF                           |
| B 319 | TDO TABLE RAISE (SV1511.08) => ON                            |
| B 320 | TDO LUBRICATION CLIPS                                        |
| B 321 | TDO LUBRICATION CLIPS                                        |
| B 322 | TDO LUBRICATION CLIPS                                        |
| B 323 | TDO LUBRICATION TRACKS                                       |
| B 324 | TDO LUBRICATION TRACKS                                       |
| B 325 | TDO LUBRICATION TRACKS                                       |
| B 326 | IMPULSE ZS 1550.01                                           |
| B 327 | IMPULSE ZS 1550.01                                           |
| B 328 | IMPULSE ZS 1550.02                                           |
| B 329 | IMPULSE ZS 1550.02                                           |
| B 330 |                                                              |
| B 331 | TDO INTERLOCK                                                |
| B 332 | TDO MAIN GAS VALVE (SV 1500,00) => STOP                      |
| B 333 | TDO MAIN GAS VALVE (SV 1500,00) => START                     |
| B 334 |                                                              |
| B 335 |                                                              |
| B 336 | MDO INLET PRESSURE ROLL SV1404.05 RETRACTED                  |
| B 337 | MDO INLET PRESSURE ROLL SV1404.05 ENGAGED                    |
| B 338 |                                                              |
| B 339 |                                                              |
| B 340 | TIMER FOR TDO WEB BREAK                                      |
| B 341 | TIMER FOR PRS WEB BREAK                                      |
| B 342 |                                                              |
| B 343 |                                                              |
| B 344 |                                                              |
| B 345 |                                                              |
| B 346 | INSTRUMENT AIR (NOT USED)                                    |

|       |                                                                      |
|-------|----------------------------------------------------------------------|
| B 347 | INSTRUMENT AIR (NOT USED)                                            |
| B 348 |                                                                      |
| B 349 |                                                                      |
| B 350 | SPREADER ROLL #1, RETRACT - DRIVING SIDE                             |
| B 351 | SPREADER ROLL #1, ENGAGE - DRIVING SIDE                              |
| B 352 | SPREADER ROLL #2, RETRACT - DRIVING SIDE                             |
| B 353 | SPREADER ROLL #2, ENGAGE - DRIVING SIDE                              |
| B 354 | SPREADER ROLL #3, RETRACT - DRIVING SIDE                             |
| B 355 | SPREADER ROLL #3, ENGAGE - DRIVING SIDE                              |
| B 356 | OPERATING SIDE NIP ROLL (SV1850.01) => RETRACT                       |
| B 357 | OPERATING SIDE NIP ROLL (SV1850.01) => ENGAGE                        |
| B 358 | DRIVING SIDE NIP ROLL (SV1850.02) => RETRACT                         |
| B 359 | DRIVING SIDE NIP ROLL (SV1850.02) => ENGAGE                          |
| B 360 | OPERATING SIDE KNIFE (SV1850.03) => RETRACT                          |
| B 361 | OPERATING SIDE KNIFE (SV1850.03) => ENGAGE                           |
| B 362 | DRIVING SIDE KNIFE (SV1850.04) => RETRACT                            |
| B 363 | DRIVING SIDE KNIFE (SV1850.04) => ENGAGE                             |
| B 364 | PRS OZONE BLOWER #1 - LOW FLOW ALARM (FSL1831.06) RELEASE DEFECT     |
| B 365 | PRS OZONE BLOWER #1 - LOW FLOW ALARM (FSL1831.06)                    |
| B 366 | PRS OZONE BLOWER #1 - LOW FLOW ALARM (FSL1831.06) END OF TIMER       |
| B 367 | PRS OZONE BLOWER #2 - LOW FLOW ALARM (FSL1831.07) RELEASE DEFECT     |
| B 368 | PRS OZONE BLOWER #2 - LOW FLOW ALARM (FSL1831.07)                    |
| B 369 | PRS OZONE BLOWER #2 - LOW FLOW ALARM (FSL1831.07) END OF TIMER       |
| B 370 | CORONA ELECTRODE #1, PAL1820.09                                      |
| B 371 | CORONA ELECTRODE #1, PAL1820.09                                      |
| B 372 | CORONA ELECTRODE #1, PAL1820.09                                      |
| B 373 | CORONA ELECTRODE #2, PAL1820.19                                      |
| B 374 | CORONA ELECTRODE #2, PAL1820.19                                      |
| B 375 | CORONA ELECTRODE #2, PAL1820.19                                      |
| B 376 | CORONA ELECTRODE #3, PAL1820.14                                      |
| B 377 | CORONA ELECTRODE #3, PAL1820.14                                      |
| B 378 | CORONA ELECTRODE #3, PAL1820.14                                      |
| B 379 | BLOWER PRS ROLL 2 (M1812.01) => STOP                                 |
| B 380 | BLOWER PRS ROLL 2 (M1812.01) => START                                |
| B 381 | CORONA ELECTRODE #1 - OZONE EXHAUST BLOWER => STOP (CELLIER SUPPLY)  |
| B 382 | CORONA ELECTRODE #1 - OZONE EXHAUST BLOWER => START (CELLIER SUPPLY) |
| B 383 | CORONA ELECTRODE #2 - OZONE EXHAUST BLOWER => STOP (CELLIER SUPPLY)  |
| B 384 | CORONA ELECTRODE #2 - OZONE EXHAUST BLOWER => START (CELLIER SUPPLY) |
| B 385 | VACUUM ROLL 2 BLOWER - STOP                                          |
| B 386 | VACUUM ROLL 2 BLOWER - START                                         |
| B 387 | CORONA #1 NIP ROLL RETRACT (SV1820.19)                               |
| B 388 | CORONA #1 NIP ROLL ENGAGE (SV1820.19)                                |
| B 389 | CORONA #3 NIP ROLL RETRACT (SV1820.15)                               |
| B 390 | CORONA #3 NIP ROLL ENGAGE (SV1820.15)                                |
| B 391 | CORONA ELECTRODE #1 => RETRACT                                       |
| B 392 | CORONA ELECTRODE #1 => ENGAGE                                        |
| B 393 | CORONA ELECTRODE #2 => RETRACT                                       |
| B 394 | CORONA ELECTRODE #2 => ENGAGE                                        |
| B 395 | CORONA ELECTRODE #3 => RETRACT                                       |
| B 396 | CORONA ELECTRODE #3 => ENGAGE                                        |
| B 397 | WEB BREAK PRS (ZT1840.10) OR WINDER                                  |
| B 398 | WEB BREAK PRS (ZT1840.10) OR WINDER                                  |
| B 399 | WEB BREAK PRS (ZT1840.10) OR WINDER                                  |
| B 400 | INTERLOCK GENERATOR 1 & 2                                            |
| B 401 | INTERLOCK GENERATOR 1 & 2                                            |
| B 402 | INTERLOCK GENERATOR 3 & 4                                            |
| B 403 | INTERLOCK GENERATOR 3 & 4                                            |
| B 404 | CORONA ELECTRODE #2 - OZONE EXHAUST BLOWER => STOP (CELLIER SUPPLY)  |

|       |                                                                      |
|-------|----------------------------------------------------------------------|
| B 405 | CORONA ELECTRODE #2 - OZONE EXHAUST BLOWER => START (CELLIER SUPPLY) |
| B 406 |                                                                      |
| B 407 |                                                                      |
| B 408 | PRS OZONE BLOWER #3 - LOW FLOW ALARM (FSL1831.07) RELEASE DEFECT     |
| B 409 | PRS OZONE BLOWER #3 - LOW FLOW ALARM (FSL1831.07)                    |
| B 410 | PRS OZONE BLOWER #3 - LOW FLOW ALARM (FSL1831.07) END OF TIMER       |
| B 411 | PRS SPREADER ROLL #1 RETRACT - OPERATING SIDE                        |
| B 412 | PRS SPREADER ROLL #1 ENGAGE - OPERATING SIDE                         |
| B 413 | PRS SPREADER ROLL #2 RETRACT - OPERATING SIDE                        |
| B 414 | PRS SPREADER ROLL #2 ENGAGE - OPERATING SIDE                         |
| B 415 | PRS SPREADER ROLL #3 RETRACT - OPERATING SIDE                        |
| B 416 | PRS SPREADER ROLL #3 ENGAGE - OPERATING SIDE                         |
| B 417 | AUXILIARY WINDER #3 CHUCK - RETRACT, END OF TIMER                    |
| B 418 | AUXILIARY WINDER #3 CHUCK - ENGAGE                                   |
| B 419 | AUXILIARY WINDER #3 CHUCK - ENGAGE, END OF TIMER                     |
| B 420 | AUXILIARY WINDER #3 CHUCK - RETRACT                                  |
| B 421 | OZONE TREATER #1 BLOWER => STOP (FPC SUPPLY)                         |
| B 422 | OZONE TREATER #1 BLOWER => START (FPC SUPPLY)                        |
| B 423 | OZONE TREATER #2 BLOWER => STOP (FPC SUPPLY)                         |
| B 424 | OZONE TREATER #2 BLOWER => START (FPC SUPPLY)                        |
| B 425 | OZONE TREATER #3 BLOWER => STOP (FPC SUPPLY)                         |
| B 426 | OZONE TREATER #3 BLOWER => START (FPC SUPPLY)                        |
| B 427 | OZONE TREATER #4 BLOWER => STOP (FPC SUPPLY)                         |
| B 428 | OZONE TREATER #4 BLOWER => START (FPC SUPPLY)                        |
| B 429 |                                                                      |
| B 430 | PRS1 & PRS2 INTERLOCK NOT OK                                         |
| B 431 | PRS1 & PRS2 INTERLOCK OK                                             |
| B 432 |                                                                      |
| B 433 |                                                                      |
| B 434 |                                                                      |
| B 435 |                                                                      |
| B 436 |                                                                      |
| B 437 |                                                                      |
| B 438 |                                                                      |
| B 439 |                                                                      |
| B 440 |                                                                      |
| B 441 |                                                                      |
| B 442 |                                                                      |
| B 443 |                                                                      |
| B 444 |                                                                      |
| B 445 |                                                                      |
| B 446 |                                                                      |
| B 447 |                                                                      |
| B 448 |                                                                      |
| B 449 |                                                                      |
| B 450 |                                                                      |
| B 451 |                                                                      |
| B 452 |                                                                      |
| B 453 |                                                                      |
| B 454 |                                                                      |
| B 455 |                                                                      |
| B 456 |                                                                      |
| B 457 |                                                                      |
| B 458 |                                                                      |
| B 459 |                                                                      |
| B 460 |                                                                      |
| B 461 |                                                                      |
| B 462 |                                                                      |



|       |                                                       |
|-------|-------------------------------------------------------|
| B 463 |                                                       |
| B 464 |                                                       |
| B 465 |                                                       |
| B 466 |                                                       |
| B 467 |                                                       |
| B 468 |                                                       |
| B 469 |                                                       |
| B 470 |                                                       |
| B 471 |                                                       |
| B 472 |                                                       |
| B 473 |                                                       |
| B 474 |                                                       |
| B 475 |                                                       |
| B 476 |                                                       |
| B 477 |                                                       |
| B 478 |                                                       |
| B 479 |                                                       |
| B 480 |                                                       |
| B 481 |                                                       |
| B 482 |                                                       |
| B 483 |                                                       |
| B 484 |                                                       |
| B 485 |                                                       |
| B 486 |                                                       |
| B 487 |                                                       |
| B 488 |                                                       |
| B 489 |                                                       |
| B 490 |                                                       |
| B 491 |                                                       |
| B 492 |                                                       |
| B 493 |                                                       |
| B 494 |                                                       |
| B 495 |                                                       |
| B 496 |                                                       |
| B 497 |                                                       |
| B 498 |                                                       |
| B 499 |                                                       |
| B 500 | BIT MDO ZONE 1                      TEMP > 60 CW 800  |
| B 501 | BIT MDO ZONE 2                      TEMP > 60 CW 800  |
| B 502 | BIT MDO ZONE 3                      TEMP > 60 CW 800  |
| B 503 | BIT MDO ZONE 4                      TEMP > 60 CW 800  |
| B 504 | BIT MDO ZONE 5                      TEMP > 60 CW 800  |
| B 505 | BIT MDO ZONE 6                      TEMP > 60 CW 800  |
| B 506 | BIT MDO ZONE 7                      TEMP > 60 CW 800  |
| B 507 | BIT MDO ZONE 8                      TEMP > 60 CW 800  |
| B 508 | BIT MDO ZONE 9                      TEMP > 60 CW 800  |
| B 509 | BIT MDO ZONE 10                      TEMP > 60 CW 800 |
| B 510 | BIT MDO ZONE 11                      TEMP > 60 CW 800 |
| B 511 | BIT MDO ZONE 12                      TEMP > 60 CW 800 |
| B 512 |                                                       |
| B 513 |                                                       |
| B 514 |                                                       |
| B 515 |                                                       |
| B 516 |                                                       |
| B 517 |                                                       |
| B 518 |                                                       |
| B 519 |                                                       |
| B 520 |                                                       |

|       |                                  |
|-------|----------------------------------|
| B 521 |                                  |
| B 522 |                                  |
| B 523 |                                  |
| B 524 |                                  |
| B 525 |                                  |
| B 526 |                                  |
| B 527 |                                  |
| B 528 |                                  |
| B 529 |                                  |
| B 530 |                                  |
| B 531 |                                  |
| B 532 |                                  |
| B 533 |                                  |
| B 534 |                                  |
| B 535 |                                  |
| B 536 |                                  |
| B 537 |                                  |
| B 538 |                                  |
| B 539 |                                  |
| B 540 | BIT TDO ZONE 1 TEMP > 60 CW 801  |
| B 541 | BIT TDO ZONE 2 TEMP > 60 CW 801  |
| B 542 | BIT TDO ZONE 3 TEMP > 60 CW 801  |
| B 543 | BIT TDO ZONE 4 TEMP > 60 CW 801  |
| B 544 | BIT TDO ZONE 5 TEMP > 60 CW 801  |
| B 545 | BIT TDO ZONE 6 TEMP > 60 CW 801  |
| B 546 | BIT TDO ZONE 7 TEMP > 60 CW 801  |
| B 547 | BIT TDO ZONE 8 TEMP > 60 CW 801  |
| B 548 | BIT TDO ZONE 9 TEMP > 60 CW 801  |
| B 549 | BIT TDO ZONE 10 TEMP > 60 CW 801 |
| B 550 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 551 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 552 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 553 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 554 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 555 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 556 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 557 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 558 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 559 | BIT TDO ZONE 11 TEMP > 60 CW 801 |
| B 560 |                                  |
| B 561 |                                  |
| B 562 |                                  |
| B 563 |                                  |
| B 564 |                                  |
| B 565 |                                  |
| B 566 |                                  |
| B 567 |                                  |
| B 568 |                                  |
| B 569 |                                  |
| B 570 |                                  |
| B 571 |                                  |
| B 572 |                                  |
| B 573 |                                  |
| B 574 |                                  |
| B 575 |                                  |
| B 576 |                                  |
| B 577 |                                  |
| B 578 |                                  |

|       |                          |
|-------|--------------------------|
| B 579 |                          |
| B 580 |                          |
| B 581 |                          |
| B 582 |                          |
| B 583 |                          |
| B 584 |                          |
| B 585 |                          |
| B 586 |                          |
| B 587 |                          |
| B 588 |                          |
| B 589 |                          |
| B 590 |                          |
| B 591 |                          |
| B 592 |                          |
| B 593 |                          |
| B 594 |                          |
| B 595 |                          |
| B 596 |                          |
| B 597 |                          |
| B 598 |                          |
| B 599 |                          |
| B 600 | TDO BLOWER E186          |
| B 601 | TDO BLOWER E186          |
| B 602 | TDO BLOWER E221          |
| B 603 | TDO BLOWER E221          |
| B 604 | TDO BLOWER E185      OFF |
| B 605 | TDO BLOWER E185      ON  |
| B 606 | TDO BLOWER E187          |
| B 607 | TDO BLOWER E187          |
| B 608 | TDO BLOWER E188          |
| B 609 | TDO BLOWER E188          |
| B 610 | TDO BLOWER E189          |
| B 611 | TDO BLOWER E189          |
| B 612 | TDO BLOWER E190          |
| B 613 | TDO BLOWER E190          |
| B 614 | TDO BLOWER E191          |
| B 615 | TDO BLOWER E191          |
| B 616 | TDO BLOWER E192          |
| B 617 | TDO BLOWER E192          |
| B 618 | TDO BLOWER E193          |
| B 619 | TDO BLOWER E193          |
| B 620 | TDO BLOWER E194          |
| B 621 | TDO BLOWER E194          |
| B 622 | TDO BLOWER E195          |
| B 623 | TDO BLOWER E195          |
| B 624 | TDO BLOWER E196          |
| B 625 | TDO BLOWER E196          |
| B 626 | TDO BLOWER E197          |
| B 627 | TDO BLOWER E197          |
| B 628 | TDO BLOWER E198          |
| B 629 | TDO BLOWER E198          |
| B 630 | TDO BLOWER E199          |
| B 631 | TDO BLOWER E199          |
| B 632 | TDO BLOWER E200          |
| B 633 | TDO BLOWER E200          |
| B 634 | TDO BLOWER E201          |
| B 635 | TDO BLOWER E201          |
| B 636 | TDO BLOWER E202          |

|       |                               |
|-------|-------------------------------|
| B 637 | TDO BLOWER E202               |
| B 638 | TDO BLOWER E203               |
| B 639 | TDO BLOWER E203               |
| B 640 | TDO BLOWER E204               |
| B 641 | TDO BLOWER E204               |
| B 642 | TDO BLOWER E205               |
| B 643 | TDO BLOWER E205               |
| B 644 | TDO BLOWER E206               |
| B 645 | TDO BLOWER E206               |
| B 646 | TDO BLOWER E207               |
| B 647 | TDO BLOWER E207               |
| B 648 | TDO BLOWER E208               |
| B 649 | TDO BLOWER E208               |
| B 650 | TDO BLOWER E209               |
| B 651 | TDO BLOWER E209               |
| B 652 | TDO BLOWER E210               |
| B 653 | TDO BLOWER E210               |
| B 654 | TDO BLOWER E211               |
| B 655 | TDO BLOWER E211               |
| B 656 | TDO BLOWER E212               |
| B 657 | TDO BLOWER E212               |
| B 658 | TDO BLOWER E213               |
| B 659 | TDO BLOWER E213               |
| B 660 | TDO BLOWER E214               |
| B 661 | TDO BLOWER E214               |
| B 662 | TDO BLOWER E215               |
| B 663 | TDO BLOWER E215               |
| B 664 | TDO BLOWER E216               |
| B 665 | TDO BLOWER E216               |
| B 666 | TDO BLOWER E217               |
| B 667 | TDO BLOWER E217               |
| B 668 | TDO BLOWER E218               |
| B 669 | TDO BLOWER E218               |
| B 670 | TDO BLOWER E219               |
| B 671 | TDO BLOWER E219               |
| B 672 | TDO BLOWER E220               |
| B 673 | TDO BLOWER E220               |
| B 674 | TDO BLOWER E222               |
| B 675 | TDO BLOWER E222               |
| B 676 | TDO BLOWER E223               |
| B 677 | TDO BLOWER E223               |
| B 678 | TDO BLOWER E224               |
| B 679 | TDO BLOWER E224               |
| B 680 |                               |
| B 681 |                               |
| B 682 |                               |
| B 683 |                               |
| B 684 |                               |
| B 685 |                               |
| B 686 |                               |
| B 687 |                               |
| B 688 |                               |
| B 689 |                               |
| B 690 | CHILL ROLL MEMORIZATION ORDER |
| B 691 | MDO MEMORIZATION ORDER        |
| B 692 | TDO MEMORIZATION ORDER        |
| B 693 |                               |
| B 694 |                               |

|       |  |
|-------|--|
| B 695 |  |
| B 696 |  |
| B 697 |  |
| B 698 |  |
| B 699 |  |
| B 700 |  |
| B 701 |  |
| B 702 |  |
| B 703 |  |
| B 704 |  |
| B 705 |  |
| B 706 |  |
| B 707 |  |
| B 708 |  |
| B 709 |  |
| B 710 |  |
| B 711 |  |
| B 712 |  |
| B 713 |  |
| B 714 |  |
| B 715 |  |
| B 716 |  |
| B 717 |  |
| B 718 |  |
| B 719 |  |
| B 720 |  |
| B 721 |  |
| B 722 |  |
| B 723 |  |
| B 724 |  |
| B 725 |  |
| B 726 |  |
| B 727 |  |
| B 728 |  |
| B 729 |  |
| B 730 |  |
| B 731 |  |
| B 732 |  |
| B 733 |  |
| B 734 |  |
| B 735 |  |
| B 736 |  |
| B 737 |  |
| B 738 |  |
| B 739 |  |
| B 740 |  |
| B 741 |  |
| B 742 |  |
| B 743 |  |
| B 744 |  |
| B 745 |  |
| B 746 |  |
| B 747 |  |
| B 748 |  |
| B 749 |  |
| B 750 |  |
| B 751 |  |
| B 752 |  |

|       |                                                   |
|-------|---------------------------------------------------|
| B 753 |                                                   |
| B 754 |                                                   |
| B 755 |                                                   |
| B 756 |                                                   |
| B 757 |                                                   |
| B 758 |                                                   |
| B 759 |                                                   |
| B 760 |                                                   |
| B 761 |                                                   |
| B 762 |                                                   |
| B 763 |                                                   |
| B 764 |                                                   |
| B 765 |                                                   |
| B 766 |                                                   |
| B 767 |                                                   |
| B 768 |                                                   |
| B 769 |                                                   |
| B 770 |                                                   |
| B 771 |                                                   |
| B 772 |                                                   |
| B 773 |                                                   |
| B 774 |                                                   |
| B 775 |                                                   |
| B 776 |                                                   |
| B 777 |                                                   |
| B 778 |                                                   |
| B 779 |                                                   |
| B 780 |                                                   |
| B 781 |                                                   |
| B 782 |                                                   |
| B 783 |                                                   |
| B 784 |                                                   |
| B 785 |                                                   |
| B 786 |                                                   |
| B 787 |                                                   |
| B 788 |                                                   |
| B 789 |                                                   |
| B 790 |                                                   |
| B 791 | START TIMER T50 FOR STARTING MDO EQUIPMENT        |
| B 792 | END OF STARTING MDO EQUIPMENT                     |
| B 793 | START TIMER T51 FOR STARTING CHILL ROLL EQUIPMENT |
| B 794 | END OF STARTING CHILL ROLL EQUIPMENT              |
| B 795 | START TIMER T52 FOR STARTING TDO EQUIPMENT        |
| B 796 | END OF STARTING TDO EQUIPMENT                     |
| B 797 |                                                   |
| B 798 |                                                   |
| B 799 |                                                   |
| B 800 | BIT START E169                                    |
| B 801 | BIT START E170                                    |
| B 802 | BIT START E171                                    |
| B 803 | BIT START E172                                    |
| B 804 | BIT START E173                                    |
| B 805 | BIT START E174                                    |
| B 806 | BIT START E175                                    |
| B 807 | BIT START E176                                    |
| B 808 | BIT START E177                                    |
| B 809 | BIT START E178                                    |
| B 810 | BIT START E179                                    |

|       |           |      |
|-------|-----------|------|
| B 811 | BIT START | E180 |
| B 812 | BIT START | E181 |
| B 813 |           |      |
| B 814 | BIT START | E160 |
| B 815 | BIT START | E161 |
| B 816 | BIT START | E162 |
| B 817 |           |      |
| B 818 | BIT START | E122 |
| B 819 | BIT START | E223 |
| B 820 | BIT START | E224 |
| B 821 | BIT START | E456 |
| B 822 | BIT START | E221 |
| B 823 |           |      |
| B 824 | BIT START | E186 |
| B 825 | BIT START | E187 |
| B 826 | BIT START | E188 |
| B 827 | BIT START | E189 |
| B 828 | BIT START | E190 |
| B 829 | BIT START | E191 |
| B 830 | BIT START | E192 |
| B 831 | BIT START | E193 |
| B 832 | BIT START | E194 |
| B 833 | BIT START | E195 |
| B 834 | BIT START | E196 |
| B 835 | BIT START | E197 |
| B 836 | BIT START | E198 |
| B 837 | BIT START | E199 |
| B 838 | BIT START | E200 |
| B 839 | BIT START | E201 |
| B 840 | BIT START | E202 |
| B 841 | BIT START | E203 |
| B 842 | BIT START | E204 |
| B 843 | BIT START | E205 |
| B 844 | BIT START | E206 |
| B 845 | BIT START | E207 |
| B 846 | BIT START | E208 |
| B 847 | BIT START | E209 |
| B 848 | BIT START | E210 |
| B 849 | BIT START | E211 |
| B 850 | BIT START | E212 |
| B 851 | BIT START | E213 |
| B 852 | BIT START | E214 |
| B 853 | BIT START | E215 |
| B 854 | BIT START | E216 |
| B 855 | BIT START | E217 |
| B 856 | BIT START | E218 |
| B 857 | BIT START | E219 |
| B 858 | BIT START | E220 |
| B 859 |           |      |
| B 860 |           |      |
| B 861 |           |      |
| B 862 |           |      |
| B 863 |           |      |
| B 864 |           |      |
| B 865 |           |      |
| B 866 |           |      |
| B 867 |           |      |
| B 868 |           |      |

|       |                            |
|-------|----------------------------|
| B 869 |                            |
| B 870 | ALARM "STOEXT" IN TOP VIW  |
| B 871 | ALARM "STOSAT1" IN TOP VIW |
| B 872 | ALARM "STOSAT2" IN TOP VIW |
| B 873 | ALARM PCC MAIN LOADING     |
| B 874 |                            |
| B 875 |                            |
| B 876 |                            |
| B 877 |                            |
| B 878 |                            |
| B 879 |                            |
| B 880 |                            |
| B 881 |                            |
| B 882 |                            |
| B 883 |                            |
| B 884 |                            |
| B 885 |                            |
| B 886 |                            |
| B 887 |                            |
| B 888 |                            |
| B 889 |                            |
| B 890 |                            |

|        |                              |
|--------|------------------------------|
| B 2000 | AUTO/MANUAL (MANUAL -> 1)    |
| B 2001 | CONTROL LOCKED               |
| B 2002 | ALARM H+/L-                  |
| B 2003 | ALARM H                      |
| B 2004 | ALARM L                      |
| B 2005 | DEFECT MEASURE               |
| B 2006 |                              |
| B 2007 | CONTROL LOOP FAULT           |
| B 2008 |                              |
| B 2009 | SAMPLE TIME SELECT (60 OR 1) |
| B 2010 | START CONTROL LOOP           |
| B 2011 | REVERSE CONTROL LOOP         |
| B 2012 |                              |
| B 2013 | BIT OUTPUT 100; -100         |
| B 2014 |                              |
| B 2015 | TEMPERATURE NO DEFECT (OK)   |

|        |                   |
|--------|-------------------|
| B 2300 | FOR SMOOTH SYSTEM |
|--------|-------------------|



|     |                          |
|-----|--------------------------|
| W0  | CONFIGURATION OF SCM2222 |
| W1  | CONFIGURATION OF SCM2222 |
| W2  | CONFIGURATION OF SCM2222 |
| W3  | CONFIGURATION OF SCM2222 |
| W4  | CONFIGURATION OF SCM2222 |
| W5  | CONFIGURATION OF SCM2222 |
| W6  | CONFIGURATION OF SCM2222 |
| W7  | CONFIGURATION OF SCM2222 |
| W8  | CONFIGURATION OF SCM2222 |
| W9  | CONFIGURATION OF SCM2222 |
| W10 | CONFIGURATION OF SCM2222 |
| W11 | CONFIGURATION OF SCM2222 |
| W12 | CONFIGURATION OF SCM2222 |
| W13 | CONFIGURATION OF SCM2222 |
| W14 | CONFIGURATION OF SCM2222 |
| W15 | CONFIGURATION OF SCM2222 |
| W16 | CONFIGURATION OF SCM2222 |
| W17 | CONFIGURATION OF SCM2222 |
| W18 | CONFIGURATION OF SCM2222 |
| W19 | CONFIGURATION OF SCM2222 |
| W20 | CONFIGURATION OF SCM2222 |
| W21 | CONFIGURATION OF SCM2222 |
| W22 | CONFIGURATION OF SCM2222 |
| W23 | CONFIGURATION OF SCM2222 |
| W24 | CONFIGURATION OF SCM2222 |
| W25 | CONFIGURATION OF SCM2222 |
| W26 | CONFIGURATION OF SCM2222 |
| W27 | CONFIGURATION OF SCM2222 |
| W28 | CONFIGURATION OF SCM2222 |
| W29 |                          |
| W30 |                          |
| W31 |                          |
| W32 |                          |
| W33 |                          |
| W34 |                          |
| W35 |                          |
| W36 |                          |
| W37 |                          |
| W38 |                          |
| W39 |                          |
| W40 |                          |
| W41 |                          |
| W42 |                          |
| W43 |                          |
| W44 |                          |
| W45 |                          |
| W46 |                          |
| W47 |                          |
| W48 |                          |
| W49 |                          |
| W50 |                          |
| W51 |                          |

|      |                                                  |
|------|--------------------------------------------------|
| W52  |                                                  |
| W53  |                                                  |
| W54  |                                                  |
| W55  |                                                  |
| W56  |                                                  |
| W57  |                                                  |
| W58  |                                                  |
| W59  |                                                  |
| W60  |                                                  |
| W61  |                                                  |
| W62  |                                                  |
| W63  |                                                  |
| W64  |                                                  |
| W65  |                                                  |
| W66  |                                                  |
| W67  |                                                  |
| W68  |                                                  |
| W69  |                                                  |
| W70  |                                                  |
| W71  |                                                  |
| W72  |                                                  |
| W73  |                                                  |
| W74  |                                                  |
| W75  |                                                  |
| W76  |                                                  |
| W77  |                                                  |
| W78  |                                                  |
| W79  |                                                  |
| W80  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W81  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W82  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W83  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W84  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W85  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W86  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W87  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W88  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W89  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W90  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W91  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W92  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W93  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W94  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W95  | CONFIGURATION OF SCM2222 CARD MODBUS SR0         |
| W96  |                                                  |
| W97  |                                                  |
| W98  |                                                  |
| W99  |                                                  |
| W100 | TRANSFER RECEIVE CODE FOR READ CODE FROM SCM2222 |
| W101 |                                                  |
| W102 |                                                  |
| W103 |                                                  |

|      |                            |
|------|----------------------------|
| W104 |                            |
| W105 |                            |
| W106 |                            |
| W107 | INDEX FOR MODBUS IN SR0    |
| W108 |                            |
| W109 |                            |
| W110 | WORD FOR RECEIVE READ CODE |
| W111 | WORD FOR RECEIVE READ CODE |
| W112 | WORD FOR RECEIVE READ CODE |
| W113 | WORD FOR RECEIVE READ CODE |
| W114 | WORD FOR RECEIVE READ CODE |
| W115 | WORD FOR RECEIVE READ CODE |
| W116 | WORD FOR RECEIVE READ CODE |
| W117 | WORD FOR RECEIVE READ CODE |
| W118 | WORD FOR RECEIVE READ CODE |
| W119 | WORD FOR RECEIVE READ CODE |
| W120 | WORD FOR RECEIVE READ CODE |
| W121 | WORD FOR RECEIVE READ CODE |
| W122 | WORD FOR RECEIVE READ CODE |
| W123 | WORD FOR RECEIVE READ CODE |
| W124 | WORD FOR RECEIVE READ CODE |
| W125 | WORD FOR RECEIVE READ CODE |
| W126 | WORD FOR RECEIVE READ CODE |
| W127 | WORD FOR RECEIVE READ CODE |
| W128 | WORD FOR RECEIVE READ CODE |
| W129 | WORD FOR RECEIVE READ CODE |
| W130 | WORD FOR RECEIVE READ CODE |
| W131 | WORD FOR RECEIVE READ CODE |
| W132 | WORD FOR RECEIVE READ CODE |
| W133 | WORD FOR RECEIVE READ CODE |
| W134 | WORD FOR RECEIVE READ CODE |
| W135 | WORD FOR RECEIVE READ CODE |
| W136 | WORD FOR RECEIVE READ CODE |
| W137 | WORD FOR RECEIVE READ CODE |
| W138 | WORD FOR RECEIVE READ CODE |
| W139 | WORD FOR RECEIVE READ CODE |
| W140 | WORD FOR RECEIVE READ CODE |
| W141 | WORD FOR RECEIVE READ CODE |
| W142 | WORD FOR RECEIVE READ CODE |
| W143 | WORD FOR RECEIVE READ CODE |
| W144 | WORD FOR RECEIVE READ CODE |
| W145 | WORD FOR RECEIVE READ CODE |
| W146 | WORD FOR RECEIVE READ CODE |
| W147 | WORD FOR RECEIVE READ CODE |
| W148 | WORD FOR RECEIVE READ CODE |
| W149 | WORD FOR RECEIVE READ CODE |
| W150 | WORD FOR RECEIVE READ CODE |
| W151 | WORD FOR RECEIVE READ CODE |
| W152 | WORD FOR RECEIVE READ CODE |
| W153 | WORD FOR RECEIVE READ CODE |
| W154 | WORD FOR RECEIVE READ CODE |
| W155 | WORD FOR RECEIVE READ CODE |

|      |                            |
|------|----------------------------|
| W156 | WORD FOR RECEIVE READ CODE |
| W157 | WORD FOR RECEIVE READ CODE |
| W158 | WORD FOR RECEIVE READ CODE |
| W159 | WORD FOR RECEIVE READ CODE |
| W160 | WORD FOR RECEIVE READ CODE |
| W161 | WORD FOR RECEIVE READ CODE |
| W162 | WORD FOR RECEIVE READ CODE |
| W163 | WORD FOR RECEIVE READ CODE |
| W164 | WORD FOR RECEIVE READ CODE |
| W165 | WORD FOR RECEIVE READ CODE |
| W166 | WORD FOR RECEIVE READ CODE |
| W167 | WORD FOR RECEIVE READ CODE |
| W168 | WORD FOR RECEIVE READ CODE |
| W169 | WORD FOR RECEIVE READ CODE |
| W170 | WORD FOR RECEIVE READ CODE |
| W171 | WORD FOR RECEIVE READ CODE |
| W172 | WORD FOR RECEIVE READ CODE |
| W173 | WORD FOR RECEIVE READ CODE |
| W174 | WORD FOR RECEIVE READ CODE |
| W175 | WORD FOR RECEIVE READ CODE |
| W176 | WORD FOR RECEIVE READ CODE |
| W177 | WORD FOR RECEIVE READ CODE |
| W178 | WORD FOR RECEIVE READ CODE |
| W179 | WORD FOR RECEIVE READ CODE |
| W180 | WORD FOR RECEIVE READ CODE |
| W181 | WORD FOR RECEIVE READ CODE |
| W182 | WORD FOR RECEIVE READ CODE |
| W183 | WORD FOR RECEIVE READ CODE |
| W184 | WORD FOR RECEIVE READ CODE |
| W185 | WORD FOR RECEIVE READ CODE |
| W186 | WORD FOR RECEIVE READ CODE |
| W187 | WORD FOR RECEIVE READ CODE |
| W188 | WORD FOR RECEIVE READ CODE |
| W189 | WORD FOR RECEIVE READ CODE |
| W190 | WORD FOR RECEIVE READ CODE |
| W191 | WORD FOR RECEIVE READ CODE |
| W192 | WORD FOR RECEIVE READ CODE |
| W193 | WORD FOR RECEIVE READ CODE |
| W194 | WORD FOR RECEIVE READ CODE |
| W195 | WORD FOR RECEIVE READ CODE |
| W196 | WORD FOR RECEIVE READ CODE |
| W197 | WORD FOR RECEIVE READ CODE |
| W198 | WORD FOR RECEIVE READ CODE |
| W199 | WORD FOR RECEIVE READ CODE |
| W200 | WORD FOR RECEIVE READ CODE |
| W201 | WORD FOR RECEIVE READ CODE |
| W202 | WORD FOR RECEIVE READ CODE |
| W203 | WORD FOR RECEIVE READ CODE |
| W204 | WORD FOR RECEIVE READ CODE |
| W205 | WORD FOR RECEIVE READ CODE |
| W206 | WORD FOR RECEIVE READ CODE |
| W207 | WORD FOR RECEIVE READ CODE |

|      |                            |
|------|----------------------------|
| W208 | WORD FOR RECEIVE READ CODE |
| W209 | WORD FOR RECEIVE READ CODE |
| W210 | WORD FOR RECEIVE READ CODE |
| W211 | WORD FOR RECEIVE READ CODE |
| W212 | WORD FOR RECEIVE READ CODE |
| W213 | WORD FOR RECEIVE READ CODE |
| W214 | WORD FOR RECEIVE READ CODE |
| W215 | WORD FOR RECEIVE READ CODE |
| W216 | WORD FOR RECEIVE READ CODE |
| W217 | WORD FOR RECEIVE READ CODE |
| W218 | WORD FOR RECEIVE READ CODE |
| W219 | WORD FOR RECEIVE READ CODE |
| W220 | WORD FOR RECEIVE READ CODE |
| W221 | WORD FOR RECEIVE READ CODE |
| W222 | WORD FOR RECEIVE READ CODE |
| W223 | WORD FOR RECEIVE READ CODE |
| W224 | WORD FOR RECEIVE READ CODE |
| W225 | WORD FOR RECEIVE READ CODE |
| W226 | WORD FOR RECEIVE READ CODE |
| W227 | WORD FOR RECEIVE READ CODE |
| W228 | WORD FOR RECEIVE READ CODE |
| W229 | WORD FOR RECEIVE READ CODE |
| W230 | WORD FOR RECEIVE READ CODE |
| W231 | WORD FOR RECEIVE READ CODE |
| W232 | WORD FOR RECEIVE READ CODE |
| W233 | WORD FOR RECEIVE READ CODE |
| W234 | WORD FOR RECEIVE READ CODE |
| W235 | WORD FOR RECEIVE READ CODE |
| W236 | WORD FOR RECEIVE READ CODE |
| W237 | WORD FOR RECEIVE READ CODE |
| W238 | WORD FOR RECEIVE READ CODE |
| W239 | WORD FOR RECEIVE READ CODE |
| W240 | WORD FOR RECEIVE READ CODE |
| W241 | WORD FOR RECEIVE READ CODE |
| W242 | WORD FOR RECEIVE READ CODE |
| W243 | WORD FOR RECEIVE READ CODE |
| W244 | WORD FOR RECEIVE READ CODE |
| W245 | WORD FOR RECEIVE READ CODE |
| W246 | WORD FOR RECEIVE READ CODE |
| W247 | WORD FOR RECEIVE READ CODE |
| W248 | WORD FOR RECEIVE READ CODE |
| W249 | WORD FOR RECEIVE READ CODE |
| W250 | WORD FOR RECEIVE READ CODE |
| W251 | WORD FOR RECEIVE READ CODE |
| W252 | WORD FOR RECEIVE READ CODE |
| W253 | WORD FOR RECEIVE READ CODE |
| W254 | WORD FOR RECEIVE READ CODE |
| W255 | WORD FOR RECEIVE READ CODE |
| W256 | WORD FOR RECEIVE READ CODE |
| W257 | WORD FOR RECEIVE READ CODE |
| W258 | WORD FOR RECEIVE READ CODE |
| W259 | WORD FOR RECEIVE READ CODE |

|      |                            |
|------|----------------------------|
| W260 | WORD FOR RECEIVE READ CODE |
| W261 | WORD FOR RECEIVE READ CODE |
| W262 | WORD FOR RECEIVE READ CODE |
| W263 | WORD FOR RECEIVE READ CODE |
| W264 | WORD FOR RECEIVE READ CODE |
| W265 | WORD FOR RECEIVE READ CODE |
| W266 | WORD FOR RECEIVE READ CODE |
| W267 | WORD FOR RECEIVE READ CODE |
| W268 | WORD FOR RECEIVE READ CODE |
| W269 | WORD FOR RECEIVE READ CODE |
| W270 | WORD FOR RECEIVE READ CODE |
| W271 | WORD FOR RECEIVE READ CODE |
| W272 | WORD FOR RECEIVE READ CODE |
| W273 | WORD FOR RECEIVE READ CODE |
| W274 | WORD FOR RECEIVE READ CODE |
| W275 | WORD FOR RECEIVE READ CODE |
| W276 | WORD FOR RECEIVE READ CODE |
| W277 | WORD FOR RECEIVE READ CODE |
| W278 | WORD FOR RECEIVE READ CODE |
| W279 | WORD FOR RECEIVE READ CODE |
| W280 | WORD FOR RECEIVE READ CODE |
| W281 | WORD FOR RECEIVE READ CODE |
| W282 | WORD FOR RECEIVE READ CODE |
| W283 | WORD FOR RECEIVE READ CODE |
| W284 | WORD FOR RECEIVE READ CODE |
| W285 | WORD FOR RECEIVE READ CODE |
| W286 | WORD FOR RECEIVE READ CODE |
| W287 | WORD FOR RECEIVE READ CODE |
| W288 | WORD FOR RECEIVE READ CODE |
| W289 | WORD FOR RECEIVE READ CODE |
| W290 | WORD FOR RECEIVE READ CODE |
| W291 | WORD FOR RECEIVE READ CODE |
| W292 | WORD FOR RECEIVE READ CODE |
| W293 | WORD FOR RECEIVE READ CODE |
| W294 | WORD FOR RECEIVE READ CODE |
| W295 | WORD FOR RECEIVE READ CODE |
| W296 | WORD FOR RECEIVE READ CODE |
| W297 | WORD FOR RECEIVE READ CODE |
| W298 | WORD FOR RECEIVE READ CODE |
| W299 | WORD FOR RECEIVE READ CODE |
| W300 | WORD FOR RECEIVE READ CODE |
| W301 | WORD FOR RECEIVE READ CODE |
| W302 | WORD FOR RECEIVE READ CODE |
| W303 | WORD FOR RECEIVE READ CODE |
| W304 | WORD FOR RECEIVE READ CODE |
| W305 | WORD FOR RECEIVE READ CODE |
| W306 | WORD FOR RECEIVE READ CODE |
| W307 | WORD FOR RECEIVE READ CODE |
| W308 | WORD FOR RECEIVE READ CODE |
| W309 | WORD FOR RECEIVE READ CODE |
| W310 | WORD FOR RECEIVE READ CODE |
| W311 | FREE                       |

|      |      |
|------|------|
| W312 | FREE |
| W313 | FREE |
| W314 | FREE |
| W315 | FREE |
| W316 | FREE |
| W317 | FREE |
| W318 | FREE |
| W319 | FREE |
| W320 | FREE |
| W321 | FREE |
| W322 | FREE |
| W323 | FREE |
| W324 | FREE |
| W325 | FREE |
| W326 | FREE |
| W327 | FREE |
| W328 | FREE |
| W329 | FREE |
| W330 | FREE |
| W331 | FREE |
| W332 | FREE |
| W333 | FREE |
| W334 | FREE |
| W335 | FREE |
| W336 | FREE |
| W337 | FREE |
| W338 | FREE |
| W339 | FREE |
| W340 | FREE |
| W341 | FREE |
| W342 | FREE |
| W343 | FREE |
| W344 | FREE |
| W345 | FREE |
| W346 | FREE |
| W347 | FREE |
| W348 | FREE |
| W349 | FREE |
| W350 | FREE |
| W351 | FREE |
| W352 | FREE |
| W353 | FREE |
| W354 | FREE |
| W355 | FREE |
| W356 | FREE |
| W357 | FREE |
| W358 | FREE |
| W359 | FREE |
| W360 | FREE |
| W361 | FREE |
| W362 | FREE |
| W363 | FREE |

|      |                                                      |
|------|------------------------------------------------------|
| W364 | FREE                                                 |
| W365 | FREE                                                 |
| W366 | FREE                                                 |
| W367 | FREE                                                 |
| W368 | FREE                                                 |
| W369 | FREE                                                 |
| W370 | FREE                                                 |
| W371 | FREE                                                 |
| W372 | FREE                                                 |
| W373 | FREE                                                 |
| W374 | FREE                                                 |
| W375 | FREE                                                 |
| W376 | FREE                                                 |
| W377 | FREE                                                 |
| W378 | FREE                                                 |
| W379 | FREE                                                 |
| W380 | FREE                                                 |
| W381 | FREE                                                 |
| W382 | FREE                                                 |
| W383 | FREE                                                 |
| W384 | FREE                                                 |
| W385 | FREE                                                 |
| W386 | FREE                                                 |
| W387 | FREE                                                 |
| W388 | FREE                                                 |
| W389 | FREE                                                 |
| W390 | FREE                                                 |
| W391 | FREE                                                 |
| W392 | FREE                                                 |
| W393 | FREE                                                 |
| W394 | FREE                                                 |
| W395 | FREE                                                 |
| W396 | FREE                                                 |
| W397 | FREE                                                 |
| W398 | FREE                                                 |
| W399 | FREE                                                 |
| W400 | WORD FOR COUNTER FOR ALL CONTROL LOOP INDEX AUX0, S0 |
| W401 | WORD FOR COUNTER FOR ALL CONTROL LOOP INDEX AUX1, S0 |
| W402 | COUNTER FOR MODBUS                                   |
| W403 | FREE                                                 |
| W404 | FREE                                                 |
| W405 | FREE                                                 |
| W406 | FREE                                                 |
| W407 | FREE                                                 |
| W408 | FREE                                                 |
| W409 | FREE                                                 |
| W410 | FREE                                                 |
| W411 | FREE                                                 |
| W412 | FREE                                                 |
| W413 | FREE                                                 |
| W414 | FREE                                                 |
| W415 | FREE                                                 |



|      |                            |
|------|----------------------------|
| W416 | FREE                       |
| W417 | FREE                       |
| W418 | FREE                       |
| W419 | FREE                       |
| W420 | FREE                       |
| W421 | FREE                       |
| W422 | FREE                       |
| W423 | FREE                       |
| W424 | FREE                       |
| W425 | FREE                       |
| W426 | FREE                       |
| W427 | FREE                       |
| W428 | FREE                       |
| W429 | FREE                       |
| W430 | FREE                       |
| W431 | FREE                       |
| W432 | FREE                       |
| W433 | FREE                       |
| W434 | FREE                       |
| W435 | FREE                       |
| W436 | FREE                       |
| W437 | FREE                       |
| W438 | FREE                       |
| W439 | FREE                       |
| W440 | FREE                       |
| W441 | FREE                       |
| W442 | FREE                       |
| W443 | FREE                       |
| W444 | FREE                       |
| W445 | FREE                       |
| W446 | FREE                       |
| W447 | FREE                       |
| W448 | FREE                       |
| W449 | FREE                       |
| W450 | 0000 0000 1111 1111 MASK   |
| W451 |                            |
| W452 |                            |
| W453 |                            |
| W454 | SEE " WORD BIT "           |
| W455 | SEE " WORD BIT "           |
| W456 | SEE " WORD BIT "           |
| W457 |                            |
| W458 |                            |
| W459 |                            |
| W460 | CONTROL LOOPS [R365, R366] |
| W461 |                            |
| W462 | CONTROL LOOPS [R370, R371] |
| W463 |                            |
| W464 | CONTROL LOOPS [R372, R373] |
| W465 |                            |
| W466 | CONTROL LOOPS [R374, R375] |
| W467 |                            |

|      |                            |
|------|----------------------------|
| W468 | CONTROL LOOPS [R376, R377] |
| W469 |                            |
| W470 | CONTROL LOOPS [R378, R379] |
| W471 |                            |
| W472 | CONTROL LOOPS [R380, R381] |
| W473 |                            |
| W474 | CONTROL LOOPS [R386, R387] |
| W475 |                            |
| W476 | CONTROL LOOPS [R388, R389] |
| W477 |                            |
| W478 | CONTROL LOOPS [R390, R391] |
| W479 |                            |
| W480 | CONTROL LOOPS [R392, R393] |
| W481 |                            |
| W482 | CONTROL LOOPS [R394, R395] |
| W483 |                            |
| W484 | CONTROL LOOP [R396, R397]  |
| W485 |                            |
| W486 | CONTROL LOOP [R398, R399]  |
| W487 |                            |
| W488 | CONTROL LOOP [R400, R401]  |
| W489 |                            |
| W490 | CONTROL LOOP [R402, R403]  |
| W491 |                            |
| W492 |                            |
| W493 |                            |
| W494 |                            |
| W495 |                            |
| W496 |                            |
| W497 |                            |
| W498 |                            |
| W499 |                            |
| W500 | SEE " WORD BIT "           |
| W501 | SEE " WORD BIT "           |
| W502 | SEE " WORD BIT "           |
| W503 | SEE " WORD BIT "           |
| W504 | SEE " WORD BIT "           |
| W505 | SEE " WORD BIT "           |
| W506 | SEE " WORD BIT "           |
| W507 | SEE " WORD BIT "           |
| W508 | SEE " WORD BIT "           |
| W509 | SEE " WORD BIT "           |
| W510 | SEE " WORD BIT "           |
| W511 | SEE " WORD BIT "           |
| W512 | SEE " WORD BIT "           |
| W513 | SEE " WORD BIT "           |
| W514 | SEE " WORD BIT "           |
| W515 | SEE " WORD BIT "           |
| W516 | SEE " WORD BIT "           |
| W517 | SEE " WORD BIT "           |
| W518 | SEE " WORD BIT "           |
| W519 | SEE " WORD BIT "           |

|      |                                        |
|------|----------------------------------------|
| W520 | SEE " WORD BIT "                       |
| W521 | SEE " WORD BIT "                       |
| W522 | SEE " WORD BIT "                       |
| W523 | SEE " WORD BIT "                       |
| W524 | SEE " WORD BIT "                       |
| W525 | SEE " WORD BIT "                       |
| W526 | SEE " WORD BIT "                       |
| W527 | SEE " WORD BIT "                       |
| W528 | SEE " WORD BIT "                       |
| W529 | SEE " WORD BIT "                       |
| W530 | SEE " WORD BIT "                       |
| W531 | SEE " WORD BIT "                       |
| W532 | SEE " WORD BIT "                       |
| W533 | SEE " WORD BIT "                       |
| W534 | SEE " WORD BIT "                       |
| W535 | SEE " WORD BIT "                       |
| W536 | SEE " WORD BIT "                       |
| W537 | SEE " WORD BIT "                       |
| W538 | SEE " WORD BIT "                       |
| W539 | SEE " WORD BIT "                       |
| W540 |                                        |
| W541 |                                        |
| W542 |                                        |
| W543 |                                        |
| W544 |                                        |
| W545 |                                        |
| W546 |                                        |
| W547 |                                        |
| W548 |                                        |
| W549 |                                        |
| W550 | COUNTER FOR ELECTROMAGNETIC BRAKE E162 |
| W551 | COUNTER FOR E170                       |
| W552 | COUNTER FOR E171                       |
| W553 | COUNTER FOR E172                       |
| W554 | COUNTER FOR E173                       |
| W555 | COUNTER FOR E174                       |
| W556 | COUNTER FOR E175                       |
| W557 | COUNTER FOR E176                       |
| W558 | COUNTER FOR E177                       |
| W559 | COUNTER FOR E178                       |
| W560 | COUNTER FOR E179                       |
| W561 | COUNTER FOR E180                       |
| W562 | COUNTER FOR E181                       |
| W563 | COUNTER FOR FLOWER E185                |
| W564 | COUNTER FOR FLOWER E186                |
| W565 | COUNTER FOR FLOWER E187                |
| W566 | COUNTER FOR FLOWER E188                |
| W567 | COUNTER FOR FLOWER E189                |
| W568 | COUNTER FOR FLOWER E190                |
| W569 | COUNTER FOR FLOWER E191                |
| W570 | COUNTER FOR FLOWER E192                |
| W571 | COUNTER FOR FLOWER E193                |

|      |                                                           |
|------|-----------------------------------------------------------|
| W572 | COUNTER FOR FLOWER E194                                   |
| W573 | COUNTER FOR FLOWER E195                                   |
| W574 | COUNTER FOR FLOWER E196                                   |
| W575 | COUNTER FOR FLOWER E197                                   |
| W576 | COUNTER FOR FLOWER E198                                   |
| W577 | COUNTER FOR FLOWER E199                                   |
| W578 | COUNTER FOR FLOWER E200                                   |
| W579 | COUNTER FOR FLOWER E201                                   |
| W580 | COUNTER FOR FLOWER E202                                   |
| W581 | COUNTER FOR FLOWER E203                                   |
| W582 | COUNTER FOR FLOWER E204                                   |
| W583 | COUNTER FOR FLOWER E205                                   |
| W584 | COUNTER FOR FLOWER E206                                   |
| W585 | COUNTER FOR FLOWER E207                                   |
| W586 | COUNTER FOR FLOWER E208                                   |
| W587 | COUNTER FOR FLOWER E209                                   |
| W588 | COUNTER FOR FLOWER E210                                   |
| W589 | COUNTER FOR FLOWER E211                                   |
| W590 | COUNTER FOR FLOWER E212                                   |
| W591 | COUNTER FOR FLOWER E213                                   |
| W592 | COUNTER FOR FLOWER E214                                   |
| W593 | COUNTER FOR FLOWER E215                                   |
| W594 | COUNTER FOR FLOWER E216                                   |
| W595 | COUNTER FOR FLOWER E217                                   |
| W596 | COUNTER FOR FLOWER E218                                   |
| W597 | COUNTER FOR FLOWER E219                                   |
| W598 | COUNTER FOR FLOWER E220                                   |
| W599 | COUNTER FOR FLOWER E221                                   |
| W600 | COUNTER FOR FLOWER E222                                   |
| W601 | COUNTER FOR FLOWER E223                                   |
| W602 | COUNTER FOR FLOWER E224                                   |
| W603 |                                                           |
| W604 |                                                           |
| W605 |                                                           |
| W606 |                                                           |
| W607 |                                                           |
| W608 |                                                           |
| W609 |                                                           |
| W610 | COUNTER CHILL ROLL EXHAUST HOOD                           |
| W611 | COUNTER CHILL ROLL WATR REMOVAL                           |
| W612 | COUNTER CHILL ROLL WATR REMOVAL                           |
| W613 | COUNTER CHILL ROLL WATR REMOVAL                           |
| W614 | COUNTER CHILL ROLL WATR REMOVAL                           |
| W615 | COUNTER CHILL ROLL HORIZONTAL MOVEMENT                    |
| W616 | COUNTER CHILL ROLL HORIZONTAL MOVEMENT                    |
| W617 | COUNTER CHILL ROLL AUXILARY WINDER1                       |
| W618 | COUNTER MDO AUXILARY WINDER2                              |
| W619 | COUNTER TDO CHAIN TENSION SYSTEM                          |
| W620 | COUNTER PRS FAN ROLL #2                                   |
| W621 | COUNTER PRS FAN ROLL #1                                   |
| W622 | COUNTER PRS OZONE EXHAUST BLOWER#1 BLOWER, MOTOR M1831.01 |
| W623 | COUNTER PRS OZONE EXHAUST BLOWER#2 BLOWER, MOTOR M1831.02 |

|      |                                                           |
|------|-----------------------------------------------------------|
| W624 | COUNTER PRS OZONE EXHAUST BLOWER#3 BLOWER, MOTOR M1831.03 |
| W625 |                                                           |
| W626 |                                                           |
| W627 | COUNTER FOR OZONE TREATER#1 BLOWER, CORONA#1              |
| W628 | COUNTER FOR OZONE TREATER#2 BLOWER, CORONA#1              |
| W629 | COUNTER FOR OZONE TREATER#3 BLOWER, CORONA#2&#3           |
| W630 | COUNTER FOR OZONE TREATER#4 BLOWER, CORONA#2&#3           |
| W631 |                                                           |
| W632 | SETPOINT WITHOUT LUBRICTION OF TRACK                      |
| W633 | SETPOINT WITHOUT LUBRICTION OF TRACK                      |
| W634 | SETPOINT WITHOUT LUBRICTION OF CHAIN                      |
| W635 | SETPOINT WITHOUT LUBRICTION OF CHAIN                      |
| W636 |                                                           |
| W637 |                                                           |
| W638 | COUNTER WITHOUT LUBRICATION OF TRACK                      |
| W639 | COUNTER WITHOUT LUBRICATION OF TRACK                      |
| W640 | COUNTER WITH LUBRICATION OF TRACK                         |
| W641 | COUNTER WITH LUBRICATION OF TRACK                         |
| W642 | COUNTER WITHOUT LUBRICATION OF CHAIN                      |
| W643 | COUNTER WITHOUT LUBRICATION OF CHAIN                      |
| W644 | COUNTER WITH LUBRICATION OF CHAIN                         |
| W645 | COUNTER WITH LUBRICATION OF CHAIN                         |
| W646 |                                                           |
| W647 |                                                           |
| W648 |                                                           |
| W649 |                                                           |
| W650 |                                                           |

| NO.   | TAGNAME  | DESCRIPTION                  |
|-------|----------|------------------------------|
| W4000 |          |                              |
| W4001 |          |                              |
| W4002 | AOSPR365 | SETPOINT R365                |
| W4003 | AOOUR365 | OUTPUT                       |
| W4004 | AOPR365  | PROPORTIONAL VALUE           |
| W4005 | AOINR365 | INTEGRAL                     |
| W4006 | AODER365 | DERIVATIVE                   |
| W4007 | AOAH+0   | HIGH ALARM                   |
| W4008 | AOAH+1   | H+/L- (CONTROL OUT OF RANGE) |
| W4009 | AOAH+2   | LOW ALARM                    |
| W4010 |          |                              |
| W4011 | AOSPR366 | SETPOINT R365                |
| W4012 | AOOUR366 | OUTPUT                       |
| W4013 | AOPR366  | PROPORTIONAL VALUE           |
| W4014 | AOINR366 | INTEGRAL                     |
| W4015 | AODER366 | DERIVATIVE                   |
| W4016 | AOAH+9   | HIGH ALARM                   |
| W4017 | AOAH+10  | H+/L- (CONTROL OUT OF RANGE) |
| W4018 | AOAH+12  | LOW ALARM                    |
| W4019 |          |                              |
| W4020 |          |                              |
| W4021 |          |                              |
| W4022 |          |                              |
| W4023 |          |                              |
| W4024 |          |                              |
| W4025 |          |                              |
| W4026 |          |                              |
| W4027 |          |                              |
| W4028 |          |                              |
| W4029 |          |                              |
| W4030 |          |                              |
| W4031 |          |                              |
| W4032 |          |                              |
| W4033 |          |                              |
| W4034 |          |                              |
| W4035 |          |                              |
| W4036 |          |                              |
| W4037 |          |                              |
| W4038 |          |                              |
| W4039 |          |                              |
| W4040 |          |                              |
| W4041 |          |                              |
| W4042 |          |                              |
| W4043 |          |                              |
| W4044 |          |                              |
| W4045 |          |                              |
| W4046 |          |                              |
| W4047 | AOSPR370 | SETPOINT R370                |
| W4048 | AOOUR370 | OUTPUT                       |
| W4049 | AOPR370  | PROPORTIONAL VALUE           |
| W4050 | AOINR370 | INTEGRAL                     |

|       |          |                              |
|-------|----------|------------------------------|
| W4051 | AODER370 | DERIVATIVE                   |
| W4052 | AOAH+45  | HIGH ALARM                   |
| W4053 | AOAH+46  | H+/L- (CONTROL OUT OF RANGE) |
| W4054 | AOAH+47  | LOW ALARM                    |
| W4055 |          |                              |
| W4056 | AOSPR371 | SETPOINT R371                |
| W4057 | AOOUR371 | OUTPUT                       |
| W4058 | AOPR371  | PROPORTIONAL VALUE           |
| W4059 | AOINR371 | INTEGRAL                     |
| W4060 | AODER371 | DERIVATIVE                   |
| W4061 | AOAH+54  | HIGH ALARM                   |
| W4062 | AOAH+55  | H+/L- (CONTROL OUT OF RANGE) |
| W4063 | AOAH+56  | LOW ALARM                    |
| W4064 |          |                              |
| W4065 | AOSPR372 | SETPOINT R372                |
| W4066 | AOOUR372 | OUTPUT                       |
| W4067 | AOPR372  | PROPORTIONAL VALUE           |
| W4068 | AOINR372 | INTEGRAL                     |
| W4069 | AODER372 | DERIVATIVE                   |
| W4070 | AOAH+63  | HIGH ALARM                   |
| W4071 | AOAH+64  | H+/L- (CONTROL OUT OF RANGE) |
| W4072 | AOAH+65  | LOW ALARM                    |
| W4073 |          |                              |
| W4074 | AOSPR373 | SETPOINT R373                |
| W4075 | AOOUR373 | OUTPUT                       |
| W4076 | AOPR373  | PROPORTIONAL VALUE           |
| W4077 | AOINR373 | INTEGRAL                     |
| W4078 | AODER373 | DERIVATIVE                   |
| W4079 | AOAH+72  | HIGH ALARM                   |
| W4080 | AOAH+73  | H+/L- (CONTROL OUT OF RANGE) |
| W4081 | AOAH+74  | LOW ALARM                    |
| W4082 |          |                              |
| W4083 | AOSPR374 | SETPOINT R374                |
| W4084 | AOOUR374 | OUTPUT                       |
| W4085 | AOPR374  | PROPORTIONAL VALUE           |
| W4086 | AOINR374 | INTEGRAL                     |
| W4087 | AODER374 | DERIVATIVE                   |
| W4088 | AOAH+81  | HIGH ALARM                   |
| W4089 | AOAH+82  | H+/L- (CONTROL OUT OF RANGE) |
| W4090 | AOAH+83  | LOW ALARM                    |
| W4091 |          |                              |
| W4092 | AOSPR375 | SETPOINT R375                |
| W4093 | AOOUR375 | OUTPUT                       |
| W4094 | AOPR375  | PROPORTIONAL VALUE           |
| W4095 | AOINR375 | INTEGRAL                     |
| W4096 | AODER375 | DERIVATIVE                   |
| W4097 | AOAH+81  | HIGH ALARM                   |
| W4098 | AOAH+82  | H+/L- (CONTROL OUT OF RANGE) |
| W4099 | AOAH+83  | LOW ALARM                    |
| W4100 |          |                              |
| W4101 | AOSPR376 | SETPOINT R376                |
| W4102 | AOOUR376 | OUTPUT                       |

|       |          |                              |
|-------|----------|------------------------------|
| W4103 | AOPR376  | PROPORTIONAL VALUE           |
| W4104 | AOINR376 | INTEGRAL                     |
| W4105 | AODER376 | DERIVATIVE                   |
| W4106 | AOAH+81  | HIGH ALARM                   |
| W4107 | AOAH+82  | H+/L- (CONTROL OUT OF RANGE) |
| W4108 | AOAH+83  | LOW ALARM                    |
| W4109 |          |                              |
| W4110 | AOSPR377 | SETPOINT R377                |
| W4111 | AOOUR377 | OUTPUT                       |
| W4112 | AOPR377  | PROPORTIONAL VALUE           |
| W4113 | AOINR377 | INTEGRAL                     |
| W4114 | AODER377 | DERIVATIVE                   |
| W4115 | AOAH+81  | HIGH ALARM                   |
| W4116 | AOAH+82  | H+/L- (CONTROL OUT OF RANGE) |
| W4117 | AOAH+83  | LOW ALARM                    |
| W4118 |          |                              |
| W4119 | AOSPR378 | SETPOINT R378                |
| W4120 | AOOUR378 | OUTPUT                       |
| W4121 | AOPR378  | PROPORTIONAL VALUE           |
| W4122 | AOINR378 | INTEGRAL                     |
| W4123 | AODER378 | DERIVATIVE                   |
| W4124 | AOAH+81  | HIGH ALARM                   |
| W4125 | AOAH+82  | H+/L- (CONTROL OUT OF RANGE) |
| W4126 | AOAH+83  | LOW ALARM                    |
| W4127 |          |                              |
| W4128 | AOSPR379 | SETPOINT R379                |
| W4129 | AOOUR379 | OUTPUT                       |
| W4130 | AOPR379  | PROPORTIONAL VALUE           |
| W4131 | AOINR379 | INTEGRAL                     |
| W4132 | AODER379 | DERIVATIVE                   |
| W4133 | AOAH+81  | HIGH ALARM                   |
| W4134 | AOAH+82  | H+/L- (CONTROL OUT OF RANGE) |
| W4135 | AOAH+83  | LOW ALARM                    |
| W4136 |          |                              |
| W4137 | AOSPR380 | SETPOINT R380                |
| W4138 | AOOUR380 | OUTPUT                       |
| W4139 | AOPR380  | PROPORTIONAL VALUE           |
| W4140 | AOINR380 | INTEGRAL                     |
| W4141 | AODER380 | DERIVATIVE                   |
| W4142 | AOAH+81  | HIGH ALARM                   |
| W4143 | AOAH+82  | H+/L- (CONTROL OUT OF RANGE) |
| W4144 | AOAH+83  | LOW ALARM                    |
| W4145 |          |                              |
| W4146 | AOSPR381 | SETPOINT R381                |
| W4147 | AOOUR381 | OUTPUT                       |
| W4148 | AOPR381  | PROPORTIONAL VALUE           |
| W4149 | AOINR381 | INTEGRAL                     |
| W4150 | AODER381 | DERIVATIVE                   |
| W4151 | AOAH+18  | HIGH ALARM                   |
| W4152 | AOAH+19  | H+/L- (CONTROL OUT OF RANGE) |
| W4153 | AOAH+20  | LOW ALARM                    |
| W4154 |          |                              |



|       |          |                              |
|-------|----------|------------------------------|
| W4155 |          |                              |
| W4156 |          |                              |
| W4157 |          |                              |
| W4158 |          |                              |
| W4159 |          |                              |
| W4160 |          |                              |
| W4161 |          |                              |
| W4162 |          |                              |
| W4163 |          |                              |
| W4164 |          |                              |
| W4165 |          |                              |
| W4166 |          |                              |
| W4167 |          |                              |
| W4168 |          |                              |
| W4169 |          |                              |
| W4170 |          |                              |
| W4171 |          |                              |
| W4172 |          |                              |
| W4173 |          |                              |
| W4174 |          |                              |
| W4175 |          |                              |
| W4176 |          |                              |
| W4177 |          |                              |
| W4178 |          |                              |
| W4179 |          |                              |
| W4180 |          |                              |
| W4181 |          |                              |
| W4182 | AOSPR385 | SETPOINT R385                |
| W4183 | AOOUR385 | OUTPUT                       |
| W4184 | AOPR385  | PROPORTIONAL VALUE           |
| W4185 | AOINR385 | INTEGRAL                     |
| W4186 | AODER385 | DERIVATIVE                   |
| W4187 | AOAH+54  | HIGH ALARM                   |
| W4188 | AOAH+55  | H+/L- (CONTROL OUT OF RANGE) |
| W4189 | AOAH+56  | LOW ALARM                    |
| W4190 |          |                              |
| W4191 | AOSPR386 | SETPOINT R386                |
| W4192 | AOOUR386 | OUTPUT                       |
| W4193 | AOPR386  | PROPORTIONAL VALUE           |
| W4194 | AOINR386 | INTEGRAL                     |
| W4195 | AODER386 | DERIVATIVE                   |
| W4196 | AOAH+63  | HIGH ALARM                   |
| W4197 | AOAH+64  | H+/L- (CONTROL OUT OF RANGE) |
| W4198 | AOAH+65  | LOW ALARM                    |
| W4199 |          |                              |
| W4200 | AOSPR387 | SETPOINT R387                |
| W4201 | AOOUR387 | OUTPUT                       |
| W4202 | AOPR387  | PROPORTIONAL VALUE           |
| W4203 | AOINR387 | INTEGRAL                     |
| W4204 | AODER387 | DERIVATIVE                   |
| W4205 | AOAH+72  | HIGH ALARM                   |
| W4206 | AOAH+73  | H+/L- (CONTROL OUT OF RANGE) |

|       |          |                              |
|-------|----------|------------------------------|
| W4207 | AOAH+74  | LOW ALARM                    |
| W4208 |          |                              |
| W4209 | AOSPR388 | SETPOINT R388                |
| W4210 | AOOUR388 | OUTPUT                       |
| W4211 | AOPR388  | PROPORTIONAL VALUE           |
| W4212 | AOINR388 | INTEGRAL                     |
| W4213 | AODER388 | DERIVATIVE                   |
| W4214 | AOAH+81  | HIGH ALARM                   |
| W4215 | AOAH+82  | H+/L- (CONTROL OUT OF RANGE) |
| W4216 | AOAH+83  | LOW ALARM                    |
| W4217 |          |                              |
| W4218 | AOSPR389 | SETPOINT R389                |
| W4219 | AOOUR389 | OUTPUT                       |
| W4220 | AOPR389  | PROPORTIONAL VALUE           |
| W4221 | AOINR389 | INTEGRAL                     |
| W4222 | AODER389 | DERIVATIVE                   |
| W4223 | AOAH+90  | HIGH ALARM                   |
| W4224 | AOAH+91  | H+/L- (CONTROL OUT OF RANGE) |
| W4225 | AOAH+92  | LOW ALARM                    |
| W4226 |          |                              |
| W4227 | AOSPR390 | SETPOINT R390                |
| W4228 | AOOUR390 | OUTPUT                       |
| W4229 | AOPR390  | PROPORTIONAL VALUE           |
| W4230 | AOINR390 | INTEGRAL                     |
| W4231 | AODER390 | DERIVATIVE                   |
| W4232 | AOAH+99  | HIGH ALARM                   |
| W4233 | AOAH+100 | H+/L- (CONTROL OUT OF RANGE) |
| W4234 | AOAH+101 | LOW ALARM                    |
| W4235 |          |                              |
| W4236 | AOSPR391 | SETPOINT R391                |
| W4237 | AOOUR391 | OUTPUT                       |
| W4238 | AOPR391  | PROPORTIONAL VALUE           |
| W4239 | AOINR391 | INTEGRAL                     |
| W4240 | AODER391 | DERIVATIVE                   |
| W4241 | AOAH+108 | HIGH ALARM                   |
| W4242 | AOAH+109 | H+/L- (CONTROL OUT OF RANGE) |
| W4243 | AOAH+110 | LOW ALARM                    |
| W4244 |          |                              |
| W4245 | AOSPR392 | SETPOINT R392                |
| W4246 | AOOUR392 | OUTPUT                       |
| W4247 | AOPR392  | PROPORTIONAL VALUE           |
| W4248 | AOINR392 | INTEGRAL                     |
| W4249 | AODER392 | DERIVATIVE                   |
| W4250 | AOAH+117 | HIGH ALARM                   |
| W4251 | AOAH+118 | H+/L- (CONTROL OUT OF RANGE) |
| W4252 | AOAH+119 | LOW ALARM                    |
| W4253 |          |                              |
| W4254 | AOSPR393 | SETPOINT R393                |
| W4255 | AOOUR393 | OUTPUT                       |
| W4256 | AOPR393  | PROPORTIONAL VALUE           |
| W4257 | AOINR393 | INTEGRAL                     |
| W4258 | AODER393 | DERIVATIVE                   |

|       |          |                              |
|-------|----------|------------------------------|
| W4259 | AOAH+0   | HIGH ALARM                   |
| W4260 | AOAH+1   | H+/L- (CONTROL OUT OF RANGE) |
| W4261 | AOAH+2   | LOW ALARM                    |
| W4262 |          |                              |
| W4263 | AOSPR394 | SETPOINT R394                |
| W4264 | AOOUR394 | OUTPUT                       |
| W4265 | AOPR394  | PROPORTIONAL VALUE           |
| W4266 | AOINR394 | INTEGRAL                     |
| W4267 | AODER394 | DERIVATIVE                   |
| W4268 | AOAH+9   | HIGH ALARM                   |
| W4269 | AOAH+10  | H+/L- (CONTROL OUT OF RANGE) |
| W4270 | AOAH+11  | LOW ALARM                    |
| W4271 |          |                              |
| W4272 | AOSPR395 | SETPOINT R395                |
| W4273 | AOOUR395 | OUTPUT                       |
| W4274 | AOPR395  | PROPORTIONAL VALUE           |
| W4275 | AOINR395 | INTEGRAL                     |
| W4276 | AODER395 | DERIVATIVE                   |
| W4277 | AOAH+18  | HIGH ALARM                   |
| W4278 | AOAH+19  | H+/L- (CONTROL OUT OF RANGE) |
| W4279 | AOAH+20  | LOW ALARM                    |
| W4280 |          |                              |
| W4281 | AOSPR396 | SETPOINT R396                |
| W4282 | AOOUR396 | OUTPUT                       |
| W4283 | AOPR396  | PROPORTIONAL VALUE           |
| W4284 | AOINR396 | INTEGRAL                     |
| W4285 | AODER396 | DERIVATIVE                   |
| W4286 | AOAH+27  | HIGH ALARM                   |
| W4287 | AOAH+28  | H+/L- (CONTROL OUT OF RANGE) |
| W4288 | AOAH+29  | LOW ALARM                    |
| W4289 |          |                              |
| W4290 | AOSPR397 | SETPOINT R397                |
| W4291 | AOOUR397 | OUTPUT                       |
| W4292 | AOPR397  | PROPORTIONAL VALUE           |
| W4293 | AOINR397 | INTEGRAL                     |
| W4294 | AODER397 | DERIVATIVE                   |
| W4295 | AOAH+36  | HIGH ALARM                   |
| W4296 | AOAH+37  | H+/L- (CONTROL OUT OF RANGE) |
| W4297 | AOAH+38  | LOW ALARM                    |
| W4298 |          |                              |
| W4299 | AOSPR398 | SETPOINT R398                |
| W4300 | AOOUR398 | OUTPUT                       |
| W4301 | AOPR398  | PROPORTIONAL VALUE           |
| W4302 | AOINR398 | INTEGRAL                     |
| W4303 | AODER398 | DERIVATIVE                   |
| W4304 | AOAH+45  | HIGH ALARM                   |
| W4305 | AOAH+46  | H+/L- (CONTROL OUT OF RANGE) |
| W4306 | AOAH+47  | LOW ALARM                    |
| W4307 |          |                              |
| W4308 | AOSPR399 | SETPOINT R399                |
| W4309 | AOOUR399 | OUTPUT                       |
| W4310 | AOPR399  | PROPORTIONAL VALUE           |

|       |          |                              |
|-------|----------|------------------------------|
| W4311 | AOINR399 | INTEGRAL                     |
| W4312 | AODER398 | DERIVATIVE                   |
| W4313 | AOAH+54  | HIGH ALARM                   |
| W4314 | AOAH+55  | H+/L- (CONTROL OUT OF RANGE) |
| W4315 | AOAH+56  | LOW ALARM                    |
| W4316 |          |                              |
| W4317 | AOSPR400 | SETPOINT R400                |
| W4318 | AOOUR400 | OUTPUT                       |
| W4319 | AOPR400  | PROPORTIONAL VALUE           |
| W4320 | AOINR400 | INTEGRAL                     |
| W4321 | AODER400 | DERIVATIVE                   |
| W4322 | AOAH+63  | HIGH ALARM                   |
| W4323 | AOAH+64  | H+/L- (CONTROL OUT OF RANGE) |
| W4324 | AOAH+65  | LOW ALARM                    |
| W4325 |          |                              |
| W4326 | AOSPR401 | SETPOINT R401                |
| W4327 | AOOUR401 | OUTPUT                       |
| W4328 | AOPR401  | PROPORTIONAL VALUE           |
| W4329 | AOINR401 | INTEGRAL                     |
| W4330 | AODER401 | DERIVATIVE                   |
| W4331 | AOAH+72  | HIGH ALARM                   |
| W4332 | AOAH+73  | H+/L- (CONTROL OUT OF RANGE) |
| W4333 | AOAH+74  | LOW ALARM                    |
| W4334 |          |                              |
| W4335 | AOSPR402 | SETPOINT R402                |
| W4336 | AOOUR402 | OUTPUT                       |
| W4337 | AOPR402  | PROPORTIONAL VALUE           |
| W4338 | AOINR402 | INTEGRAL                     |
| W4339 | AODER402 | DERIVATIVE                   |
| W4340 | AOAH+81  | HIGH ALARM                   |
| W4341 | AOAH+82  | H+/L- (CONTROL OUT OF RANGE) |
| W4342 | AOAH+83  | LOW ALARM                    |
| W4343 |          |                              |
| W4344 | AOSPR403 | SETPOINT R403                |
| W4345 | AOOUR403 | OUTPUT                       |
| W4346 | AOPR403  | PROPORTIONAL VALUE           |
| W4347 | AOINR403 | INTEGRAL                     |
| W4348 | AODER403 | DERIVATIVE                   |
| W4349 | AOAH+90  | HIGH ALARM                   |
| W4350 | AOAH+91  | H+/L- (CONTROL OUT OF RANGE) |
| W4351 | AOAH+92  | LOW ALARM                    |
| W4352 |          |                              |
| W4353 | AOSPR404 | SETPOINT R404                |
| W4354 | AOOUR404 | OUTPUT                       |
| W4355 | AOPR404  | PROPORTIONAL VALUE           |
| W4356 | AOINR404 | INTEGRAL                     |
| W4357 | AODER404 | DERIVATIVE                   |
| W4358 | AOAH+99  | HIGH ALARM                   |
| W4359 | AOAH+100 | H+/L- (CONTROL OUT OF RANGE) |
| W4360 | AOAH+101 | LOW ALARM                    |
| W4361 |          |                              |
| W4362 |          |                              |

|       |            |                                                   |
|-------|------------|---------------------------------------------------|
| W4363 |            |                                                   |
| W4364 |            |                                                   |
| W4365 |            |                                                   |
| W4366 |            |                                                   |
| W4367 |            |                                                   |
| W4368 |            |                                                   |
| W4369 |            |                                                   |
| W4370 |            |                                                   |
| W4371 |            |                                                   |
| W4372 |            |                                                   |
| W4373 |            |                                                   |
| W4374 |            |                                                   |
| W4375 |            |                                                   |
| W4376 |            |                                                   |
| W4377 |            |                                                   |
| W4378 |            |                                                   |
| W4379 |            |                                                   |
| W4380 | AOSPCRBRA  | ELECTROMAGNETIC BRAKE SETPOINT FOR CHILL ROLL     |
| W4381 |            |                                                   |
| W4382 |            |                                                   |
| W4383 | AOLUBCLIP2 | SETPOINT FOR " CHAIN WITHOUT LUBIRCATION"         |
| W4384 |            |                                                   |
| W4385 | AOLUBCLIP1 | SETPOINT FOR " CHAIN WITH LUBIRCATION"            |
| W4386 |            |                                                   |
| W4387 | AOLUBTRAK1 | SETPOINT FOR " TRACK WITH LUBRICATION"            |
| W4388 |            |                                                   |
| W4389 |            |                                                   |
| W4390 |            | SETPOINT OF TDO CURRENT TO CONTINUOUS LUBRICATION |
| W4391 |            | TDO CURRENT MEASURE                               |
| W4392 |            |                                                   |
| W4393 | AOLUBTRAK2 | SETPOINT FOR " TRACK WITHOUT LUBRICATION"         |
| W4394 |            |                                                   |
| W4395 |            |                                                   |
| W4396 |            |                                                   |
| W4397 |            |                                                   |
| W4398 |            |                                                   |
| W4399 |            |                                                   |

| NO    | TAG      | DESCRIPTION  |
|-------|----------|--------------|
| W4600 | AIMER365 | MEASURE R365 |
| W4601 | AIOUR365 | OUTPUT       |
| W4602 | AISPR365 | SETPOINT     |
| W4603 | AIMER366 | MEASURE      |
| W4604 | AIOUR366 | OUTPUT       |
| W4605 | AISPR366 | SETPOINT     |
| W4606 |          |              |
| W4607 |          |              |
| W4608 |          |              |
| W4609 |          |              |
| W4610 |          |              |
| W4611 |          |              |
| W4612 |          |              |
| W4613 |          |              |
| W4614 |          |              |
| W4615 | AIMER370 | MEASURE R370 |
| W4616 | AIOUR370 | OUTPUT       |
| W4617 | AISPR370 | SETPOINT     |
| W4618 | AIMER371 | MEASURE R371 |
| W4619 | AIOUR371 | OUTPUT       |
| W4620 | AISPR371 | SETPOINT     |
| W4621 | AIMER372 | MEASURE R372 |
| W4622 | AIOUR372 | OUTPUT       |
| W4623 | AISPR372 | SETPOINT     |
| W4624 | AIMER373 | MEASURE R373 |
| W4625 | AIOUR373 | OUTPUT       |
| W4626 | AISPR373 | SETPOINT     |
| W4627 | AIMER374 | MEASURE R374 |
| W4628 | AIOUR374 | OUTPUT       |
| W4629 | AISPR374 | SETPOINT     |
| W4630 | AIMER375 | MEASURE R375 |
| W4631 | AIOUR375 | OUTPUT       |
| W4632 | AISPR375 | SETPOINT     |
| W4633 | AIMER376 | MEASURE R376 |
| W4634 | AIOUR376 | OUTPUT       |
| W4635 | AISPR376 | SETPOINT     |
| W4636 | AIMER377 | MEASURE R378 |
| W4637 | AIOUR377 | OUTPUT       |
| W4638 | AISPR377 | SETPOINT     |
| W4639 | AIMER378 | MEASURE R379 |
| W4640 | AIOUR378 | OUTPUT       |
| W4641 | AISPR378 | SETPOINT     |
| W4642 | AIMER379 | MEASURE R380 |
| W4643 | AIOUR379 | OUTPUT       |
| W4644 | AISPR379 | SETPOINT     |
| W4645 | AIMER380 | MEASURE R381 |
| W4646 | AIOUR380 | OUTPUT       |
| W4647 | AISPR380 | SETPOINT     |
| W4648 | AIMER381 | MEASURE R382 |
| W4649 | AIOUR381 | OUTPUT       |
| W4650 | AISPR381 | SETPOINT     |

|       |          |              |
|-------|----------|--------------|
| W4651 |          |              |
| W4652 |          |              |
| W4653 |          |              |
| W4654 |          |              |
| W4655 |          |              |
| W4656 |          |              |
| W4657 |          |              |
| W4658 |          |              |
| W4659 |          |              |
| W4660 | AIMER385 | MEASURE R385 |
| W4661 | AIOUR385 | OUTPUT       |
| W4662 | AISPR385 | SETPOINT     |
| W4663 | AIMER386 | MEASURE R386 |
| W4664 | AIOUR386 | OUTPUT       |
| W4665 | AISPR386 | SETPOINT     |
| W4666 | AIMER387 | MEASURE R387 |
| W4667 | AIOUR387 | OUTPUT       |
| W4668 | AISPR387 | SETPOINT     |
| W4669 | AIMER388 | MEASURE R388 |
| W4670 | AIOUR388 | OUTPUT       |
| W4671 | AISPR388 | SETPOINT     |
| W4672 | AIMER389 | MEASURE R389 |
| W4673 | AIOUR389 | OUTPUT       |
| W4674 | AISPR389 | SETPOINT     |
| W4675 | AIMER390 | MEASURE R390 |
| W4676 | AIOUR390 | OUTPUT       |
| W4677 | AISPR390 | SETPOINT     |
| W4678 | AIMER391 | MEASURE R391 |
| W4679 | AIOUR391 | OUTPUT       |
| W4680 | AISPR391 | SETPOINT     |
| W4681 | AIMER392 | MEASURE R392 |
| W4682 | AIOUR392 | OUTPUT       |
| W4683 | AISPR392 | SETPOINT     |
| W4684 | AIMER393 | MEASURE R393 |
| W4685 | AIOUR393 | OUTPUT       |
| W4686 | AISPR393 | SETPOINT     |
| W4687 | AIMER394 | MEASURE R394 |
| W4688 | AIOUR394 | OUTPUT       |
| W4689 | AISPR394 | SETPOINT     |
| W4690 | AIMER395 | MEASURE R395 |
| W4691 | AIOUR395 | OUTPUT       |
| W4692 | AISPR395 | SETPOINT     |
| W4693 | AIMER396 | MEASURE R396 |
| W4694 | AIOUR396 | OUTPUT       |
| W4695 | AISPR396 | SETPOINT     |
| W4696 | AIMER397 | MEASURE R397 |
| W4697 | AIOUR397 | OUTPUT       |
| W4698 | AISPR397 | SETPOINT     |
| W4699 | AIMER398 | MEASURE R398 |
| W4700 | AIOUR398 | OUTPUT       |
| W4701 | AISPR398 | SETPOINT     |
| W4702 | AIMER399 | MEASURE R399 |

|       |            |                                      |
|-------|------------|--------------------------------------|
| W4703 | AIOUR399   | OUTPUT                               |
| W4704 | AISPR399   | SETPOINT                             |
| W4705 | AIMER400   | MEASURE R400                         |
| W4706 | AIOUR400   | OUTPUT                               |
| W4707 | AISPR400   | SETPOINT                             |
| W4708 | AIMER401   | MEASURE R401                         |
| W4709 | AIOUR401   | OUTPUT                               |
| W4710 | AISPR401   | SETPOINT                             |
| W4711 | AIMER402   | MEASURE R402                         |
| W4712 | AIOUR402   | OUTPUT                               |
| W4713 | AISPR402   | SETPOINT                             |
| W4714 | AIMER403   | MEASURE R403                         |
| W4715 | AIOUR403   | OUTPUT                               |
| W4716 | AISPR403   | SETPOINT                             |
| W4717 | AIMER404   | MEASURE R404                         |
| W4718 | AIOUR404   | OUTPUT                               |
| W4719 | AISPR404   | SETPOINT                             |
| W4720 |            |                                      |
| W4721 |            |                                      |
| W4722 |            |                                      |
| W4723 |            |                                      |
| W4724 |            |                                      |
| W4725 |            |                                      |
| W4726 |            |                                      |
| W4727 |            |                                      |
| W4728 |            |                                      |
| W4729 | AILUBCLIP1 | 1COUNTER MEASURE FOR CLIPS W/ LUB    |
| W4730 | AILUBCLIP2 | 2COUNTER MEASURE FOR CLIP W/OUT LUB  |
| W4731 | AILUBTRAK1 | 1COUNTER MEASURE FOR TRACK W/ LUB    |
| W4732 | AILUBTRAK2 | 2COUNTER MEASURE FOR TRACK W/OUT LUB |
| W4733 |            |                                      |
| W4734 |            |                                      |
| W4735 |            | AUXILIARY 1 CURRENT (NOT USED)       |
| W4736 |            | AUXILIARY 2 CURRENT (NOT USED)       |
| W4737 |            | FPC FLOWMETER (NOT USED)             |
| W4738 |            | LINE SPEED                           |
| W4739 |            |                                      |
| W4740 |            |                                      |
| W4741 |            |                                      |
| W4742 |            |                                      |
| W4743 |            |                                      |
| W4744 |            |                                      |
| W4745 |            |                                      |
| W4746 |            |                                      |
| W4747 |            |                                      |
| W4748 |            |                                      |
| W4749 |            |                                      |
| W4750 |            | SEE "WORD BIT"                       |
| W4751 |            | SEE "WORD BIT"                       |
| W4752 |            | SEE "WORD BIT"                       |
| W4753 |            | SEE "WORD BIT"                       |
| W4754 |            | SEE "WORD BIT"                       |



|       |  |                |
|-------|--|----------------|
| W4755 |  | SEE "WORD BIT" |
| W4756 |  | SEE "WORD BIT" |
| W4757 |  | SEE "WORD BIT" |
| W4758 |  | SEE "WORD BIT" |
| W4759 |  | SEE "WORD BIT" |
| W4760 |  | SEE "WORD BIT" |
| W4761 |  | SEE "WORD BIT" |
| W4762 |  | SEE "WORD BIT" |
| W4763 |  | SEE "WORD BIT" |
| W4764 |  | SEE "WORD BIT" |
| W4765 |  | SEE "WORD BIT" |
| W4766 |  | SEE "WORD BIT" |
| W4767 |  | SEE "WORD BIT" |
| W4768 |  | SEE "WORD BIT" |
| W4769 |  | SEE "WORD BIT" |
| W4770 |  | SEE "WORD BIT" |
| W4771 |  | SEE "WORD BIT" |
| W4772 |  | SEE "WORD BIT" |
| W4773 |  | SEE "WORD BIT" |
| W4774 |  | SEE "WORD BIT" |
| W4775 |  | SEE "WORD BIT" |
| W4776 |  | SEE "WORD BIT" |
| W4777 |  | SEE "WORD BIT" |
| W4778 |  | SEE "WORD BIT" |
| W4779 |  | SEE "WORD BIT" |
| W4780 |  | SEE "WORD BIT" |
| W4781 |  | SEE "WORD BIT" |
| W4782 |  | SEE "WORD BIT" |
| W4783 |  | SEE "WORD BIT" |
| W4784 |  | SEE "WORD BIT" |
| W4785 |  | SEE "WORD BIT" |
| W4786 |  | SEE "WORD BIT" |
| W4787 |  | SEE "WORD BIT" |
| W4788 |  | SEE "WORD BIT" |
| W4789 |  | SEE "WORD BIT" |
| W4790 |  | SEE "WORD BIT" |
| W4791 |  | SEE "WORD BIT" |
| W4792 |  | SEE "WORD BIT" |
| W4793 |  | SEE "WORD BIT" |
| W4794 |  | SEE "WORD BIT" |
| W4795 |  | SEE "WORD BIT" |
| W4796 |  | SEE "WORD BIT" |
| W4797 |  | SEE "WORD BIT" |
| W4798 |  | SEE "WORD BIT" |
| W4799 |  | SEE "WORD BIT" |
| W4800 |  | SEE "WORD BIT" |
| W4801 |  | SEE "WORD BIT" |
| W4802 |  | SEE "WORD BIT" |
| W4803 |  | SEE "WORD BIT" |
| W4804 |  | SEE "WORD BIT" |
| W4805 |  | SEE "WORD BIT" |
| W4806 |  | SEE "WORD BIT" |

|       |  |      |
|-------|--|------|
| W4807 |  | FREE |
| W4808 |  | FREE |
| W4809 |  | FREE |
| W4810 |  | FREE |
| W4811 |  | FREE |
| W4812 |  | FREE |
| W4813 |  | FREE |
| W4814 |  | FREE |
| W4815 |  | FREE |
| W4816 |  | FREE |
| W4817 |  | FREE |
| W4818 |  | FREE |
| W4819 |  | FREE |
| W4820 |  | FREE |
| W4821 |  | FREE |
| W4822 |  | FREE |
| W4823 |  | FREE |
| W4824 |  | FREE |
| W4825 |  | FREE |
| W4826 |  | FREE |
| W4827 |  | FREE |
| W4828 |  | FREE |
| W4829 |  | FREE |
| W4830 |  | FREE |
| W4831 |  | FREE |
| W4832 |  | FREE |
| W4833 |  | FREE |
| W4834 |  | FREE |
| W4835 |  | FREE |
| W4836 |  | FREE |
| W4837 |  | FREE |
| W4838 |  | FREE |
| W4839 |  | FREE |
| W4840 |  | FREE |
| W4841 |  | FREE |
| W4842 |  | FREE |
| W4843 |  | FREE |
| W4844 |  | FREE |
| W4845 |  | FREE |
| W4846 |  | FREE |
| W4847 |  | FREE |
| W4848 |  | FREE |
| W4849 |  | FREE |
| W4850 |  | FREE |
| W4851 |  | FREE |
| W4852 |  | FREE |
| W4853 |  | FREE |
| W4854 |  | FREE |
| W4855 |  | FREE |
| W4856 |  | FREE |
| W4857 |  | FREE |
| W4858 |  | FREE |

|       |  |      |
|-------|--|------|
| W4859 |  | FREE |
| W4860 |  | FREE |
| W4861 |  | FREE |
| W4862 |  | FREE |
| W4863 |  | FREE |
| W4864 |  | FREE |
| W4865 |  | FREE |
| W4866 |  | FREE |
| W4867 |  | FREE |
| W4868 |  | FREE |
| W4869 |  | FREE |
| W4870 |  | FREE |
| W4871 |  | FREE |
| W4872 |  | FREE |
| W4873 |  | FREE |
| W4874 |  | FREE |
| W4875 |  | FREE |
| W4876 |  | FREE |
| W4877 |  | FREE |
| W4878 |  | FREE |
| W4879 |  | FREE |
| W4880 |  | FREE |
| W4881 |  | FREE |
| W4882 |  | FREE |
| W4883 |  | FREE |
| W4884 |  | FREE |
| W4885 |  | FREE |
| W4886 |  | FREE |
| W4887 |  | FREE |
| W4888 |  | FREE |
| W4889 |  | FREE |
| W4890 |  | FREE |
| W4891 |  | FREE |
| W4892 |  | FREE |
| W4893 |  | FREE |
| W4894 |  | FREE |
| W4895 |  | FREE |
| W4896 |  | FREE |
| W4897 |  | FREE |
| W4898 |  | FREE |
| W4899 |  | FREE |
| W4900 |  | FREE |
| W4901 |  | FREE |
| W4902 |  | FREE |
| W4903 |  | FREE |
| W4904 |  | FREE |
| W4905 |  | FREE |
| W4906 |  | FREE |
| W4907 |  | FREE |
| W4908 |  | FREE |
| W4909 |  | FREE |
| W4910 |  | FREE |

|       |  |      |
|-------|--|------|
| W4911 |  | FREE |
| W4912 |  | FREE |
| W4913 |  | FREE |
| W4914 |  | FREE |
| W4915 |  | FREE |
| W4916 |  | FREE |
| W4917 |  | FREE |
| W4918 |  | FREE |
| W4919 |  | FREE |
| W4920 |  | FREE |
| W4921 |  | FREE |
| W4922 |  | FREE |
| W4923 |  | FREE |
| W4924 |  | FREE |
| W4925 |  | FREE |
| W4926 |  | FREE |
| W4927 |  | FREE |
| W4928 |  | FREE |
| W4929 |  | FREE |
| W4930 |  | FREE |
| W4931 |  | FREE |
| W4932 |  | FREE |
| W4933 |  | FREE |
| W4934 |  | FREE |
| W4935 |  | FREE |
| W4936 |  | FREE |
| W4937 |  | FREE |
| W4938 |  | FREE |
| W4939 |  | FREE |
| W4940 |  | FREE |
| W4941 |  | FREE |
| W4942 |  | FREE |
| W4943 |  | FREE |
| W4944 |  | FREE |
| W4945 |  | FREE |
| W4946 |  | FREE |
| W4947 |  | FREE |
| W4948 |  | FREE |
| W4949 |  | FREE |
| W4950 |  | FREE |
| W4951 |  | FREE |
| W4952 |  | FREE |
| W4953 |  | FREE |
| W4954 |  | FREE |
| W4955 |  | FREE |
| W4956 |  | FREE |
| W4957 |  | FREE |
| W4958 |  | FREE |
| W4959 |  | FREE |
| W4960 |  | FREE |
| W4961 |  | FREE |
| W4962 |  | FREE |

|       |  |      |
|-------|--|------|
| W4963 |  | FREE |
| W4964 |  | FREE |
| W4965 |  | FREE |
| W4966 |  | FREE |
| W4967 |  | FREE |
| W4968 |  | FREE |
| W4969 |  | FREE |
| W4970 |  | FREE |
| W4971 |  | FREE |
| W4972 |  | FREE |
| W4973 |  | FREE |
| W4974 |  | FREE |
| W4975 |  | FREE |
| W4976 |  | FREE |
| W4977 |  | FREE |
| W4978 |  | FREE |
| W4979 |  | FREE |
| W4980 |  | FREE |
| W4981 |  | FREE |
| W4982 |  | FREE |
| W4983 |  | FREE |
| W4984 |  | FREE |
| W4985 |  | FREE |
| W4986 |  | FREE |
| W4987 |  | FREE |
| W4988 |  | FREE |
| W4989 |  | FREE |
| W4990 |  | FREE |
| W4991 |  | FREE |
| W4992 |  | FREE |
| W4993 |  | FREE |
| W4994 |  | FREE |
| W4995 |  | FREE |
| W4996 |  | FREE |
| W4997 |  | FREE |
| W4998 |  | FREE |
| W4999 |  | FREE |
| W5000 |  | FREE |
| W5001 |  | FREE |
| W5002 |  | FREE |
| W5003 |  | FREE |
| W5004 |  | FREE |
| W5005 |  | FREE |
| W5006 |  | FREE |
| W5007 |  | FREE |
| W5008 |  | FREE |
| W5009 |  | FREE |
| W5010 |  | FREE |
| W5011 |  | FREE |
| W5012 |  | FREE |
| W5013 |  | FREE |
| W5014 |  | FREE |

|       |  |                 |
|-------|--|-----------------|
| W5015 |  | FREE            |
| W5016 |  | FREE            |
| W5017 |  | FREE            |
| W5018 |  | FREE            |
| W5019 |  | FREE            |
| W5020 |  | FREE            |
| W5021 |  | FREE            |
| W5022 |  | FREE            |
| W5023 |  | FREE            |
| W5024 |  | FREE            |
| W5025 |  | FREE            |
| W5026 |  | FREE            |
| W5027 |  | FREE            |
| W5028 |  | FREE            |
| W5029 |  | FREE            |
| W5030 |  | FREE            |
| W5031 |  | FREE            |
| W5032 |  | FREE            |
| W5033 |  | FREE            |
| W5034 |  | FREE            |
| W5035 |  | FREE            |
| W5036 |  | FREE            |
| W5037 |  | FREE            |
| W5038 |  | FREE            |
| W5039 |  | FREE            |
| W5040 |  | FREE            |
| W5041 |  | FREE            |
| W5042 |  | FREE            |
| W5043 |  | FREE            |
| W5044 |  | FREE            |
| W5045 |  | FREE            |
| W5046 |  | FREE            |
| W5047 |  | FREE            |
| W5048 |  | FREE            |
| W5049 |  | FREE            |
| W5050 |  | COPY FROM W4603 |
| W5051 |  | FREE            |

|              |      |                         |
|--------------|------|-------------------------|
| W6000 [50]   | R365 | CHILL ROLL COOLING SKID |
| W6050 [50]   | R366 | WATER-BATH SKID         |
| W6100 [50]   | R370 | MDO ZONE #1             |
| W6150 [50]   | R371 | MDO ZONE #2             |
| W6200 [50]   | R372 | MDO ZONE #3             |
| W6250 [50]   | R373 | MDO ZONE #4             |
| W6300 [50]   | R374 | MDO ZONE #5             |
| W6350 [50]   | R375 | MDO ZONE #6             |
| W6400 [50]   | R376 | MDO ZONE #7             |
| W6450 [50]   | R377 | MDO ZONE #8             |
| W6500 [50]   | R378 | MDO ZONE #9             |
| W6550 [50]   | R379 | MDO ZONE #10            |
| W6600 [50]   | R380 | MDO ZONE #11            |
| W6650 [50]   | R381 | MDO ZONE #12            |
| W6700 [50]   | R385 | TDO ZONE #1             |
| W6750 [50]   | R386 | TDO ZONE #2             |
| W6800 [50]   | R387 | TDO ZONE #3             |
| W6850 [50]   | R388 | TDO ZONE #4             |
| W6900 [50]   | R389 | TDO ZONE #5             |
| W6950 [50]   | R390 | TDO ZONE #6             |
| W7000 [50]   | R391 | TDO ZONE #7             |
| W7050 [50]   | R392 | TDO ZONE #8             |
| W7100 [50]   | R393 | TDO ZONE #9             |
| W7150 [50]   | R394 | TDO ZONE #10            |
| W7200 [50]   | R395 | TDO ZONE #11            |
| W7250 [50]   | R396 | TDO ZONE #12            |
| W7300 [50]   | R397 | TDO ZONE #13            |
| W7350 [50]   | R398 | TDO ZONE #14            |
| W7400 [50]   | R399 | TDO ZONE #15            |
| W7450 [50]   | R400 | TDO ZONE #16            |
| W7500 [50]   | R401 | TDO ZONE #17            |
| W7550 [50]   | R402 | TDO ZONE #18            |
| W7600 [50]   | R403 | TDO ZONE #19            |
| W7650 [50]   | R404 | TDO ZONE #20            |
| W7700 ~ 8999 |      | FREE                    |

|      |   |                      |  |
|------|---|----------------------|--|
| W454 | 0 | DEFECT MEASURE, R365 |  |
| W454 | 1 | DEFECT MEASURE, R366 |  |
| W454 | 2 |                      |  |
| W454 | 3 |                      |  |
| W454 | 4 |                      |  |
| W454 | 5 | DEFECT MEASURE, R370 |  |
| W454 | 6 | DEFECT MEASURE, R371 |  |
| W454 | 7 | DEFECT MEASURE, R372 |  |
| W454 | 8 | DEFECT MEASURE, R373 |  |
| W454 | 9 | DEFECT MEASURE, R374 |  |
| W454 | A | DEFECT MEASURE, R375 |  |
| W454 | B | DEFECT MEASURE, R376 |  |
| W454 | C | DEFECT MEASURE, R377 |  |
| W454 | D | DEFECT MEASURE, R378 |  |
| W454 | E | DEFECT MEASURE, R379 |  |
| W454 | F | DEFECT MEASURE, R380 |  |
|      |   |                      |  |
| W455 | 0 | DEFECT MEASURE, R381 |  |
| W455 | 1 |                      |  |
| W455 | 2 |                      |  |
| W455 | 3 |                      |  |
| W455 | 4 | DEFECT MEASURE, R385 |  |
| W455 | 5 | DEFECT MEASURE, R386 |  |
| W455 | 6 | DEFECT MEASURE, R387 |  |
| W455 | 7 | DEFECT MEASURE, R388 |  |
| W455 | 8 | DEFECT MEASURE, R389 |  |
| W455 | 9 | DEFECT MEASURE, R390 |  |
| W455 | A | DEFECT MEASURE, R391 |  |
| W455 | B | DEFECT MEASURE, R392 |  |
| W455 | C | DEFECT MEASURE, R393 |  |
| W455 | D | DEFECT MEASURE, R394 |  |
| W455 | E | DEFECT MEASURE, R395 |  |
| W455 | F | DEFECT MEASURE, R396 |  |
|      |   |                      |  |
| W456 | 0 | DEFECT MEASURE, R397 |  |
| W456 | 1 | DEFECT MEASURE, R398 |  |
| W456 | 2 | DEFECT MEASURE, R399 |  |
| W456 | 3 | DEFECT MEASURE, R400 |  |
| W456 | 4 | DEFECT MEASURE, R401 |  |
| W456 | 5 | DEFECT MEASURE, R402 |  |
| W456 | 6 | DEFECT MEASURE, R403 |  |
| W456 | 7 | DEFECT MEASURE, R404 |  |
| W456 | 8 |                      |  |
| W456 | 9 |                      |  |
| W456 | A |                      |  |
| W456 | B |                      |  |
| W456 | C |                      |  |
| W456 | D |                      |  |
| W456 | E |                      |  |
| W456 | F |                      |  |
|      |   |                      |  |
| W464 | 5 | COPY FROM W454, 7    |  |



|      |   |                                                   |        |
|------|---|---------------------------------------------------|--------|
| W465 | D | COPY FROM W454, 8                                 |        |
|      |   |                                                   |        |
| W500 | 0 | CONTACTOR ANSWER OF CHILL ROLL COOLING SKID, E160 | IB7, 0 |
| W500 | 1 | CONTACTOR ANSWER OF WATER BATH COOLING SKID, E161 | IB7, 2 |
| W500 | 2 | CONTACTOR ANSWER OF ELECTROMAGNETIC BRAKE, E162   | I80, 5 |
| W500 | 3 |                                                   |        |
| W500 | 4 |                                                   |        |
| W500 | 5 |                                                   |        |
| W500 | 6 |                                                   |        |
| W500 | 7 |                                                   |        |
| W500 | 8 |                                                   |        |
| W500 | 9 | CONTACTOR ANSWER OF MDO OIL SKID ON, E169         | IB7, 4 |
| W500 | A | CONTACTOR ANSWER OF MDO PUMP M1430.01, E170       | I80, D |
| W500 | B | CONTACTOR ANSWER OF MDO PUMP M1430.02, E171       | I80, E |
| W500 | C | CONTACTOR ANSWER OF MDO PUMP M1430.03, E172       | I80, F |
| W500 | D | CONTACTOR ANSWER OF MDO PUMP M1430.04, E173       | I90, 0 |
| W500 | E | CONTACTOR ANSWER OF MDO PUMP M1430.05, E174       | I90, 1 |
| W500 | F | CONTACTOR ANSWER OF MDO PUMP M1430.06, E175       | I90, 2 |
|      |   |                                                   |        |
| W501 | 0 | CONTACTOR ANSWER OF MDO PUMP M1430.07, E170       | I90, 3 |
| W501 | 1 | CONTACTOR ANSWER OF MDO PUMP M1430.08, E171       | I90, 4 |
| W501 | 2 | CONTACTOR ANSWER OF MDO PUMP M1430.09, E172       | I90, 5 |
| W501 | 3 | CONTACTOR ANSWER OF MDO PUMP M1430.10, E173       | I90, 6 |
| W501 | 4 | CONTACTOR ANSWER OF MDO PUMP M1430.11, E174       | I90, 7 |
| W501 | 5 | CONTACTOR ANSWER OF MDO PUMP M1430.12, E175       | I90, 8 |
| W501 | 6 |                                                   |        |
| W501 | 7 |                                                   |        |
| W501 | 8 |                                                   |        |
| W501 | 9 | CONTACTOR OF TDO BLOWER M1520.01, E185            | I81, 7 |
| W501 | A | CONTACTOR OF TDO BLOWER M1528.01, E186            | I81, 1 |
| W501 | B | CONTACTOR OF TDO BLOWER M1520.02, E187            |        |
| W501 | C | CONTACTOR OF TDO BLOWER M1520.03, E188            |        |
| W501 | D | CONTACTOR OF TDO BLOWER M1520.04, E189            |        |
| W501 | E | CONTACTOR OF TDO BLOWER M1520.05, E190            |        |
| W501 | F | CONTACTOR OF TDO BLOWER M1520.06, E191            |        |
|      |   |                                                   |        |
| W502 | 0 | CONTACTOR OF TDO BLOWER M1520.07, E192            |        |
| W502 | 1 | CONTACTOR OF TDO BLOWER M1520.08, E193            |        |
| W502 | 2 | CONTACTOR OF TDO BLOWER M1520.09, E194            |        |
| W502 | 3 | CONTACTOR OF TDO BLOWER M1520.10, E195            |        |
| W502 | 4 | CONTACTOR OF TDO BLOWER M1520.11, E196            |        |
| W502 | 5 | CONTACTOR OF TDO BLOWER M1520.12, E197            |        |
| W502 | 6 | CONTACTOR OF TDO BLOWER M1520.13, E198            |        |
| W502 | 7 | CONTACTOR OF TDO BLOWER M1520.14, E199            |        |
| W502 | 8 | CONTACTOR OF TDO BLOWER M1520.15, E200            |        |
| W502 | 9 | CONTACTOR OF TDO BLOWER M1520.16, E201            |        |
| W502 | A | CONTACTOR OF TDO BLOWER M1520.17, E202            |        |
| W502 | B | CONTACTOR OF TDO BLOWER M1520.18, E203            |        |
| W502 | C | CONTACTOR OF TDO BLOWER M1520.19, E204            |        |
| W502 | D | CONTACTOR OF TDO BLOWER M1520.20, E205            |        |
| W502 | E | CONTACTOR OF TDO BLOWER M1520.21, E206            |        |
| W502 | F | CONTACTOR OF TDO BLOWER M1520.22, E207            |        |

|      |   |                                        |
|------|---|----------------------------------------|
|      |   |                                        |
| W503 | 0 | CONTACTOR OF TDO BLOWER M1520.01, E208 |
| W503 | 1 | CONTACTOR OF TDO BLOWER M1520.01, E209 |
| W503 | 2 | CONTACTOR OF TDO BLOWER M1520.01, E210 |
| W503 | 3 | CONTACTOR OF TDO BLOWER M1520.01, E211 |
| W503 | 4 | CONTACTOR OF TDO BLOWER M1520.01, E212 |
| W503 | 5 | CONTACTOR OF TDO BLOWER M1520.01, E213 |
| W503 | 6 | CONTACTOR OF TDO BLOWER M1520.01, E214 |
| W503 | 7 | CONTACTOR OF TDO BLOWER M1520.01, E215 |
| W503 | 8 | CONTACTOR OF TDO BLOWER M1520.01, E216 |
| W503 | 9 | CONTACTOR OF TDO BLOWER M1520.01, E217 |
| W503 | A | CONTACTOR OF TDO BLOWER M1520.01, E218 |
| W503 | B | CONTACTOR OF TDO BLOWER M1520.01, E219 |
| W503 | C | CONTACTOR OF TDO BLOWER M1520.01, E220 |
| W503 | D | CONTACTOR OF TDO BLOWER M1528.02, E221 |
| W503 | E | CONTACTOR OF TDO BLOWER M1528.03, E222 |
| W503 | F | CONTACTOR OF TDO BLOWER M1525.01, E223 |
|      |   |                                        |
| W504 | 0 | CONTACTOR OF TDO BLOWER M1530.01, E224 |
| W504 | 1 |                                        |
| W504 | 2 |                                        |
| W504 | 3 |                                        |
| W504 | 4 |                                        |
| W504 | 5 |                                        |
| W504 | 6 |                                        |
| W504 | 7 |                                        |
| W504 | 8 |                                        |
| W504 | 9 |                                        |
| W504 | A |                                        |
| W504 | B |                                        |
| W504 | C |                                        |
| W504 | D |                                        |
| W504 | E |                                        |
| W504 | F |                                        |
|      |   |                                        |
| W505 | 0 |                                        |
| W505 | 1 |                                        |
| W505 | 2 |                                        |
| W505 | 3 |                                        |
| W505 | 4 |                                        |
| W505 | 5 |                                        |
| W505 | 6 |                                        |
| W505 | 7 |                                        |
| W505 | 8 |                                        |
| W505 | 9 |                                        |
| W505 | A |                                        |
| W505 | B |                                        |
| W505 | C |                                        |
| W505 | D |                                        |
| W505 | E |                                        |
| W505 | F |                                        |
|      |   |                                        |

|      |   |                                                |          |  |
|------|---|------------------------------------------------|----------|--|
| W506 | 0 | CONTACTOR ANSWER OF CHILL ROLL EXHAUST HOOD    | M1263.01 |  |
| W506 | 1 | CONTACTOR ANSWER OF CHILL ROLL WATER REMOVAL   | M1330.01 |  |
| W506 | 2 | CONTACTOR ANSWER OF CHILL ROLL AIR KNIFE       | M1330.02 |  |
| W506 | 3 | CONTACTOR ANSWER OF CHILL ROLL WATER REMOVAL   | M1330.03 |  |
| W506 | 4 | CONTACTOR ANSWER OF CHILL ROLL WATER REMOVAL   | M1310.03 |  |
| W506 | 5 | CONTACTOR ANSWER OF CHILL ROLL WATER REMOVAL   | M1301.01 |  |
| W506 | 6 | CONTACTOR ANSWER OF CHILL ROLL BRAKE           | Y1301.02 |  |
| W506 | 7 | CONTACTOR ANSWER OF AUXILIARY #1               | M1360.01 |  |
| W506 | 8 |                                                |          |  |
| W506 | 9 |                                                |          |  |
| W506 | A | CONTACTOR ANSWER OF AUXILIARY #2               | M1450.01 |  |
| W506 | B |                                                |          |  |
| W506 | C |                                                |          |  |
| W506 | D |                                                |          |  |
| W506 | E | CONTACTOR ANSWER OF TDO CHAIN TENSION SYSTEM   | M1515.01 |  |
| W506 | F |                                                |          |  |
|      |   |                                                |          |  |
| W507 | 0 | CONTACTOR ANSWER OF VACUUM ROLL NO. 1 BLOWER   | M1812.01 |  |
| W507 | 1 | CONTACTOR ANSWER OF VACUUM ROLL NO. 2 BLOWER   | M1825.01 |  |
| W507 | 2 | CONTACTOR ANSWER OF OZONE EXHAUST NO. 1 BLOWER | M1831.01 |  |
| W507 | 3 | CONTACTOR ANSWER OF OZONE EXHAUST NO. 2 BLOWER | M1831.02 |  |
| W507 | 4 | CONTACTOR ANSWER OF AUXILIARY WINDER #3        |          |  |
| W507 | 5 | CONTACTOR ANSWER OF OZONE EXHAUST NO. 3 BLOWER | M1831.03 |  |
| W507 | 6 |                                                |          |  |
| W507 | 7 |                                                |          |  |
| W507 | 8 |                                                |          |  |
| W507 | 9 |                                                |          |  |
| W507 | A |                                                |          |  |
| W507 | B |                                                |          |  |
| W507 | C |                                                |          |  |
| W507 | D |                                                |          |  |
| W507 | E |                                                |          |  |
| W507 | F |                                                |          |  |
|      |   |                                                |          |  |
| W508 | 0 | CONTACTOR ANSWER OF OZONE TREATER #1 BLOWER    |          |  |
| W508 | 1 | CONTACTOR ANSWER OF OZONE TREATER #2 BLOWER    |          |  |
| W508 | 2 | CONTACTOR ANSWER OF OZONE TREATER #3 BLOWER    |          |  |
| W508 | 3 | CONTACTOR ANSWER OF OZONE TREATER #4 BLOWER    |          |  |
| W508 | 4 |                                                |          |  |
| W508 | 5 |                                                |          |  |
| W508 | 6 |                                                |          |  |
| W508 | 7 |                                                |          |  |
| W508 | 8 |                                                |          |  |
| W508 | 9 |                                                |          |  |
| W508 | A |                                                |          |  |
| W508 | B |                                                |          |  |
| W508 | C |                                                |          |  |
| W508 | D |                                                |          |  |
| W508 | E |                                                |          |  |
| W508 | F |                                                |          |  |
|      |   |                                                |          |  |
| W509 | 0 |                                                |          |  |

|      |   |                                         |  |
|------|---|-----------------------------------------|--|
| W509 | 1 |                                         |  |
| W509 | 2 |                                         |  |
| W509 | 3 |                                         |  |
| W509 | 4 |                                         |  |
| W509 | 5 |                                         |  |
| W509 | 6 |                                         |  |
| W509 | 7 |                                         |  |
| W509 | 8 |                                         |  |
| W509 | 9 |                                         |  |
| W509 | A |                                         |  |
| W509 | B |                                         |  |
| W509 | C |                                         |  |
| W509 | D |                                         |  |
| W509 | E |                                         |  |
| W509 | F |                                         |  |
|      |   |                                         |  |
| W510 | 0 | OUTPUT OF CHILL ROLL COOLING SKID, E160 |  |
| W510 | 1 | OUTPUT OF WATER BATH COOLING SKID, E161 |  |
| W510 | 2 | OUTPUT OF ELECTROMAGNETIC BRAKE, E162   |  |
| W510 | 3 |                                         |  |
| W510 | 4 |                                         |  |
| W510 | 5 |                                         |  |
| W510 | 6 |                                         |  |
| W510 | 7 |                                         |  |
| W510 | 8 |                                         |  |
| W510 | 9 |                                         |  |
| W510 | A | OUTPUT OF MDO PUMP M1430.01, E170       |  |
| W510 | B | OUTPUT OF MDO PUMP M1430.02, E171       |  |
| W510 | C | OUTPUT OF MDO PUMP M1430.03, E172       |  |
| W510 | D | OUTPUT OF MDO PUMP M1430.04, E173       |  |
| W510 | E | OUTPUT OF MDO PUMP M1430.05, E174       |  |
| W510 | F | OUTPUT OF MDO PUMP M1430.06, E175       |  |
|      |   |                                         |  |
| W511 | 0 | OUTPUT OF MDO PUMP M1430.07, E176       |  |
| W511 | 1 | OUTPUT OF MDO PUMP M1430.08, E177       |  |
| W511 | 2 | OUTPUT OF MDO PUMP M1430.09, E178       |  |
| W511 | 3 | OUTPUT OF MDO PUMP M1430.10, E179       |  |
| W511 | 4 | OUTPUT OF MDO PUMP M1430.11, E180       |  |
| W511 | 5 | OUTPUT OF MDO PUMP M1430.12, E181       |  |
| W511 | 6 |                                         |  |
| W511 | 7 |                                         |  |
| W511 | 8 |                                         |  |
| W511 | 9 | OUTPUT OF MDO PUMP M1520.01, E185       |  |
| W511 | A | OUTPUT OF MDO PUMP M1528.01, E186       |  |
| W511 | B | OUTPUT OF MDO PUMP M1520.02, E187       |  |
| W511 | C | OUTPUT OF MDO PUMP M1430.03, E188       |  |
| W511 | D | OUTPUT OF MDO PUMP M1430.04, E189       |  |
| W511 | E | OUTPUT OF MDO PUMP M1430.05, E190       |  |
| W511 | F | OUTPUT OF MDO PUMP M1520.06, E191       |  |
|      |   |                                         |  |
| W512 | 0 | OUTPUT OF MDO PUMP M1520.07, E192       |  |
| W512 | 1 | OUTPUT OF MDO PUMP M1520.08, E193       |  |

|      |   |                                   |  |
|------|---|-----------------------------------|--|
| W512 | 2 | OUTPUT OF MDO PUMP M1520.09, E194 |  |
| W512 | 3 | OUTPUT OF MDO PUMP M1520.10, E195 |  |
| W512 | 4 | OUTPUT OF MDO PUMP M1520.11, E196 |  |
| W512 | 5 | OUTPUT OF MDO PUMP M1520.12, E197 |  |
| W512 | 6 | OUTPUT OF MDO PUMP M1520.13, E198 |  |
| W512 | 7 | OUTPUT OF MDO PUMP M1520.14, E199 |  |
| W512 | 8 | OUTPUT OF MDO PUMP M1520.15, E200 |  |
| W512 | 9 | OUTPUT OF MDO PUMP M1520.16, E201 |  |
| W512 | A | OUTPUT OF MDO PUMP M1520.17, E202 |  |
| W512 | B | OUTPUT OF MDO PUMP M1520.18, E203 |  |
| W512 | C | OUTPUT OF MDO PUMP M1520.19, E204 |  |
| W512 | D | OUTPUT OF MDO PUMP M1520.20, E205 |  |
| W512 | E | OUTPUT OF MDO PUMP M1520.21, E206 |  |
| W512 | F | OUTPUT OF MDO PUMP M1520.22, E207 |  |
|      |   |                                   |  |
| W513 | 0 | OUTPUT OF MDO PUMP M1520.23, E208 |  |
| W513 | 1 | OUTPUT OF MDO PUMP M1520.24, E209 |  |
| W513 | 2 | OUTPUT OF MDO PUMP M1520.25, E210 |  |
| W513 | 3 | OUTPUT OF MDO PUMP M1520.26, E211 |  |
| W513 | 4 | OUTPUT OF MDO PUMP M1520.27, E212 |  |
| W513 | 5 | OUTPUT OF MDO PUMP M1520.28, E213 |  |
| W513 | 6 | OUTPUT OF MDO PUMP M1520.29, E214 |  |
| W513 | 7 | OUTPUT OF MDO PUMP M1520.30, E215 |  |
| W513 | 8 | OUTPUT OF MDO PUMP M1520.31, E216 |  |
| W513 | 9 | OUTPUT OF MDO PUMP M1520.32, E217 |  |
| W513 | A | OUTPUT OF MDO PUMP M1520.33, E218 |  |
| W513 | B | OUTPUT OF MDO PUMP M1520.34, E219 |  |
| W513 | C | OUTPUT OF MDO PUMP M1520.35, E220 |  |
| W513 | D | OUTPUT OF MDO PUMP M1520.36, E221 |  |
| W513 | E | OUTPUT OF MDO PUMP M1528.03, E222 |  |
| W513 | F | OUTPUT OF MDO PUMP M1525.01, E223 |  |
|      |   |                                   |  |
| W514 | 0 | OUTPUT OF MDO PUMP M1530.01, E224 |  |
| W514 | 1 |                                   |  |
| W514 | 2 |                                   |  |
| W514 | 3 |                                   |  |
| W514 | 4 |                                   |  |
| W514 | 5 |                                   |  |
| W514 | 6 |                                   |  |
| W514 | 7 |                                   |  |
| W514 | 8 |                                   |  |
| W514 | 9 |                                   |  |
| W514 | A |                                   |  |
| W514 | B |                                   |  |
| W514 | C |                                   |  |
| W514 | D |                                   |  |
| W514 | E |                                   |  |
| W514 | F |                                   |  |
|      |   |                                   |  |
| W515 | 0 |                                   |  |
| W515 | 1 |                                   |  |
| W515 | 2 |                                   |  |

|      |   |                                                   |        |
|------|---|---------------------------------------------------|--------|
| W515 | 3 |                                                   |        |
| W515 | 4 |                                                   |        |
| W515 | 5 |                                                   |        |
| W515 | 6 |                                                   |        |
| W515 | 7 |                                                   |        |
| W515 | 8 |                                                   |        |
| W515 | 9 |                                                   |        |
| W515 | A |                                                   |        |
| W515 | B |                                                   |        |
| W515 | C |                                                   |        |
| W515 | D |                                                   |        |
| W515 | E |                                                   |        |
| W515 | F |                                                   |        |
|      |   |                                                   |        |
| W516 | 0 | OUTPUT OF CHILL ROLL EXHAUST HOOD M1263.01        | OC4, 0 |
| W516 | 1 | OUTPUT OF CHILL ROLL WATER REMOVAL 1330.01        | OC4, 4 |
| W516 | 2 | OUTPUT OF CHILL ROLL WATER REMOVAL 1330.02        | OC4, 1 |
| W516 | 3 | OUTPUT OF CHILL ROLL WATER REMOVAL 1330.03        | OC4, 2 |
| W516 | 4 | OUTPUT OF CHILL ROLL WATER REMOVAL 1310.03        | OC4, 3 |
| W516 | 5 | OUTPUT OF CHILL ROLL HORIZONTAL MOVEMENT M1301.01 |        |
| W516 | 6 | OUTPUT OF CHILL ROLL BRAKE Y1301.02               |        |
| W516 | 7 | OUTPUT OF AUXILIARY WINDER #1 M1360.01            |        |
| W516 | 8 |                                                   |        |
| W516 | 9 |                                                   |        |
| W516 | A | OUTPUT OF AUXILIARY WINDER #2 M1450.01            |        |
| W516 | B |                                                   |        |
| W516 | C |                                                   |        |
| W516 | D |                                                   |        |
| W516 | E | OUTPUT OF TDO CHAIN TENSION SYSTEM M1515.01       |        |
| W516 | F |                                                   |        |
|      |   |                                                   |        |
| W517 | 0 | OUTPUT OF VACUUM ROLL #1 BLOWER M1812.01          |        |
| W517 | 1 | OUTPUT OF VACUUM ROLL #2 BLOWER M1825.01          |        |
| W517 | 2 | OUTPUT OF OZONE EXHAUST BLOWER #1 M1831.01        |        |
| W517 | 3 | OUTPUT OF OZONE EXHAUST BLOWER #2 M1831.02        |        |
| W517 | 4 | OUTPUT OF AUXILIARY WINDER #3                     |        |
| W517 | 5 | OUTPUT OF OZONE EXHAUST BLOWER #3 M1831.03        |        |
| W517 | 6 |                                                   |        |
| W517 | 7 |                                                   |        |
| W517 | 8 |                                                   |        |
| W517 | 9 |                                                   |        |
| W517 | A |                                                   |        |
| W517 | B |                                                   |        |
| W517 | C |                                                   |        |
| W517 | D |                                                   |        |
| W517 | E |                                                   |        |
| W517 | F |                                                   |        |
|      |   |                                                   |        |
| W518 | 0 | OUTPUT OF OZONE TREATER BLOWER #1                 |        |
| W518 | 1 | OUTPUT OF OZONE TREATER BLOWER #2                 |        |
| W518 | 2 | OUTPUT OF OZONE TREATER BLOWER #3                 |        |
| W518 | 3 | OUTPUT OF OZONE TREATER BLOWER #4                 |        |

|      |   |                                             |  |
|------|---|---------------------------------------------|--|
| W518 | 4 |                                             |  |
| W518 | 5 |                                             |  |
| W518 | 6 |                                             |  |
| W518 | 7 |                                             |  |
| W518 | 8 |                                             |  |
| W518 | 9 |                                             |  |
| W518 | A |                                             |  |
| W518 | B |                                             |  |
| W518 | C |                                             |  |
| W518 | D |                                             |  |
| W518 | E |                                             |  |
| W518 | F |                                             |  |
|      |   |                                             |  |
| W519 | 0 |                                             |  |
| W519 | 1 |                                             |  |
| W519 | 2 |                                             |  |
| W519 | 3 |                                             |  |
| W519 | 4 |                                             |  |
| W519 | 5 |                                             |  |
| W519 | 6 |                                             |  |
| W519 | 7 |                                             |  |
| W519 | 8 |                                             |  |
| W519 | 9 |                                             |  |
| W519 | A |                                             |  |
| W519 | B |                                             |  |
| W519 | C |                                             |  |
| W519 | D |                                             |  |
| W519 | E |                                             |  |
| W519 | F |                                             |  |
|      |   |                                             |  |
| W520 | 0 | IN XOR OUT OF CHILL ROLL COOLING SKID, E160 |  |
| W520 | 1 | IN XOR OUT OF WATER BATH COOLING SKID, E161 |  |
| W520 | 2 | IN XOR OUT OF ELECTROMAGNETIC BRAKE, E162   |  |
| W520 | 3 |                                             |  |
| W520 | 4 |                                             |  |
| W520 | 5 |                                             |  |
| W520 | 6 |                                             |  |
| W520 | 7 |                                             |  |
| W520 | 8 |                                             |  |
| W520 | 9 |                                             |  |
| W520 | A | IN XOR OUT OF MDO PUMP M1430.01, E170       |  |
| W520 | B | IN XOR OUT OF MDO PUMP M1430.02, E171       |  |
| W520 | C | IN XOR OUT OF MDO PUMP M1430.03, E172       |  |
| W520 | D | IN XOR OUT OF MDO PUMP M1430.04, E173       |  |
| W520 | E | IN XOR OUT OF MDO PUMP M1430.05, E174       |  |
| W520 | F | IN XOR OUT OF MDO PUMP M1430.06, E175       |  |
|      |   |                                             |  |
| W521 | 0 | IN XOR OUT OF MDO PUMP M1430.07, E176       |  |
| W521 | 1 | IN XOR OUT OF MDO PUMP M1430.08, E177       |  |
| W521 | 2 | IN XOR OUT OF MDO PUMP M1430.09, E178       |  |
| W521 | 3 | IN XOR OUT OF MDO PUMP M1430.10, E179       |  |
| W521 | 4 | IN XOR OUT OF MDO PUMP M1430.11, E180       |  |

|      |   |                                         |  |
|------|---|-----------------------------------------|--|
| W521 | 5 | IN XOR OUT OF MDO PUMP M1430.12, E181   |  |
| W521 | 6 |                                         |  |
| W521 | 7 |                                         |  |
| W521 | 8 |                                         |  |
| W521 | 9 | IN XOR OUT OF TDO BLOWER M1520.01, E185 |  |
| W521 | A | IN XOR OUT OF TDO BLOWER M1528.01, E186 |  |
| W521 | B | IN XOR OUT OF TDO BLOWER M1520.02, E187 |  |
| W521 | C | IN XOR OUT OF TDO BLOWER M1520.03, E188 |  |
| W521 | D | IN XOR OUT OF TDO BLOWER M1520.04, E189 |  |
| W521 | E | IN XOR OUT OF TDO BLOWER M1520.05, E190 |  |
| W521 | F | IN XOR OUT OF TDO BLOWER M1520.06, E191 |  |
|      |   |                                         |  |
| W522 | 0 | IN XOR OUT OF TDO BLOWER M1520.07, E192 |  |
| W522 | 1 | IN XOR OUT OF TDO BLOWER M1520.08, E193 |  |
| W522 | 2 | IN XOR OUT OF TDO BLOWER M1520.09, E194 |  |
| W522 | 3 | IN XOR OUT OF TDO BLOWER M1520.10, E195 |  |
| W522 | 4 | IN XOR OUT OF TDO BLOWER M1520.11, E196 |  |
| W522 | 5 | IN XOR OUT OF TDO BLOWER M1520.12, E197 |  |
| W522 | 6 | IN XOR OUT OF TDO BLOWER M1520.13, E198 |  |
| W522 | 7 | IN XOR OUT OF TDO BLOWER M1520.14, E199 |  |
| W522 | 8 | IN XOR OUT OF TDO BLOWER M1520.15, E200 |  |
| W522 | 9 | IN XOR OUT OF TDO BLOWER M1520.16, E201 |  |
| W522 | A | IN XOR OUT OF TDO BLOWER M1520.17, E202 |  |
| W522 | B | IN XOR OUT OF TDO BLOWER M1520.18, E203 |  |
| W522 | C | IN XOR OUT OF TDO BLOWER M1520.19, E204 |  |
| W522 | D | IN XOR OUT OF TDO BLOWER M1520.20, E205 |  |
| W522 | E | IN XOR OUT OF TDO BLOWER M1520.21, E206 |  |
| W522 | F | IN XOR OUT OF TDO BLOWER M1520.22, E207 |  |
|      |   |                                         |  |
| W523 | 0 | IN XOR OUT OF TDO BLOWER M1520.23, E208 |  |
| W523 | 1 | IN XOR OUT OF TDO BLOWER M1520.24, E209 |  |
| W523 | 2 | IN XOR OUT OF TDO BLOWER M1520.25, E210 |  |
| W523 | 3 | IN XOR OUT OF TDO BLOWER M1520.26, E211 |  |
| W523 | 4 | IN XOR OUT OF TDO BLOWER M1520.27, E212 |  |
| W523 | 5 | IN XOR OUT OF TDO BLOWER M1520.28, E213 |  |
| W523 | 6 | IN XOR OUT OF TDO BLOWER M1520.29, E214 |  |
| W523 | 7 | IN XOR OUT OF TDO BLOWER M1520.30, E215 |  |
| W523 | 8 | IN XOR OUT OF TDO BLOWER M1520.31, E216 |  |
| W523 | 9 | IN XOR OUT OF TDO BLOWER M1520.32, E217 |  |
| W523 | A | IN XOR OUT OF TDO BLOWER M1520.33, E218 |  |
| W523 | B | IN XOR OUT OF TDO BLOWER M1520.34, E219 |  |
| W523 | C | IN XOR OUT OF TDO BLOWER M1520.35, E220 |  |
| W523 | D | IN XOR OUT OF TDO BLOWER M1520.36, E221 |  |
| W523 | E | IN XOR OUT OF TDO BLOWER M1528.03, E222 |  |
| W523 | F | IN XOR OUT OF TDO BLOWER M1525.01, E223 |  |
|      |   |                                         |  |
| W524 | 0 | IN XOR OUT OF TDO BLOWER M1530.01, E224 |  |
| W524 | 1 |                                         |  |
| W524 | 2 |                                         |  |
| W524 | 3 |                                         |  |
| W524 | 4 |                                         |  |
| W524 | 5 |                                         |  |



|      |   |                                                       |  |
|------|---|-------------------------------------------------------|--|
| W524 | 6 |                                                       |  |
| W524 | 7 |                                                       |  |
| W524 | 8 |                                                       |  |
| W524 | 9 |                                                       |  |
| W524 | A |                                                       |  |
| W524 | B |                                                       |  |
| W524 | C |                                                       |  |
| W524 | D |                                                       |  |
| W524 | E |                                                       |  |
| W524 | F |                                                       |  |
|      |   |                                                       |  |
| W525 | 0 |                                                       |  |
| W525 | 1 |                                                       |  |
| W525 | 2 |                                                       |  |
| W525 | 3 |                                                       |  |
| W525 | 4 |                                                       |  |
| W525 | 5 |                                                       |  |
| W525 | 6 |                                                       |  |
| W525 | 7 |                                                       |  |
| W525 | 8 |                                                       |  |
| W525 | 9 |                                                       |  |
| W525 | A |                                                       |  |
| W525 | B |                                                       |  |
| W525 | C |                                                       |  |
| W525 | D |                                                       |  |
| W525 | E |                                                       |  |
| W525 | F |                                                       |  |
|      |   |                                                       |  |
| W526 | 0 | IN XOR OUT OF CHILL ROLL EXHAUST HOOD M1263.01        |  |
| W526 | 1 | IN XOR OUT OF CHILL ROLL WATER REMOVAL M1330.01       |  |
| W526 | 2 | IN XOR OUT OF CHILL ROLL WATER REMOVAL M1330.02       |  |
| W526 | 3 | IN XOR OUT OF CHILL ROLL WATER REMOVAL M1330.03       |  |
| W526 | 4 | IN XOR OUT OF CHILL ROLL WATER REMOVAL M1310.03       |  |
| W526 | 5 | IN XOR OUT OF CHILL ROLL HORIZONTAL MOVEMENT M1301.01 |  |
| W526 | 6 | IN XOR OUT OF CHILL ROLL BRAKE Y1301.02               |  |
| W526 | 7 | IN XOR OUT OF AUXILIARY WINDER #1 M1360.01            |  |
| W526 | 8 |                                                       |  |
| W526 | 9 |                                                       |  |
| W526 | A | IN XOR OUT OF AUXILIARY WINDER #2 M1450.01            |  |
| W526 | B |                                                       |  |
| W526 | C |                                                       |  |
| W526 | D |                                                       |  |
| W526 | E | IN XOR OUT OF TDO CHAIN TENSION SYSTEM M1515.01       |  |
| W526 | F |                                                       |  |
|      |   |                                                       |  |
| W527 | 0 | IN XOR OUT OF VACUUM ROLL #1 BLOWER M1812.01          |  |
| W527 | 1 | IN XOR OUT OF VACUUM ROLL #2 BLOWER M1825.01          |  |
| W527 | 2 | IN XOR OUT OF OZONE EXHAUST BLOWER #1 M1831.01        |  |
| W527 | 3 | IN XOR OUT OF OZONE EXHAUST BLOWER #2 M1831.02        |  |
| W527 | 4 | IN XOR OUT OF AUXILIARY WINDER #3                     |  |
| W527 | 5 | IN XOR OUT OF OZONE EXHAUST BLOWER #3 M1831.03        |  |
| W527 | 6 |                                                       |  |

|      |   |                                         |  |
|------|---|-----------------------------------------|--|
| W527 | 7 |                                         |  |
| W527 | 8 |                                         |  |
| W527 | 9 |                                         |  |
| W527 | A |                                         |  |
| W527 | B |                                         |  |
| W527 | C |                                         |  |
| W527 | D |                                         |  |
| W527 | E |                                         |  |
| W527 | F |                                         |  |
|      |   |                                         |  |
| W528 | 0 | IN XOR OUT OF OZONE TREATER #1 BLOWER   |  |
| W528 | 1 | IN XOR OUT OF OZONE TREATER #2 BLOWER   |  |
| W528 | 2 | IN XOR OUT OF OZONE TREATER #3 BLOWER   |  |
| W528 | 3 | IN XOR OUT OF OZONE TREATER #4 BLOWER   |  |
| W528 | 4 |                                         |  |
| W528 | 5 |                                         |  |
| W528 | 6 |                                         |  |
| W528 | 7 |                                         |  |
| W528 | 8 |                                         |  |
| W528 | 9 |                                         |  |
| W528 | A |                                         |  |
| W528 | B |                                         |  |
| W528 | C |                                         |  |
| W528 | D |                                         |  |
| W528 | E |                                         |  |
| W528 | F |                                         |  |
|      |   |                                         |  |
| W529 | 0 |                                         |  |
| W529 | 1 |                                         |  |
| W529 | 2 |                                         |  |
| W529 | 3 |                                         |  |
| W529 | 4 |                                         |  |
| W529 | 5 |                                         |  |
| W529 | 6 |                                         |  |
| W529 | 7 |                                         |  |
| W529 | 8 |                                         |  |
| W529 | 9 |                                         |  |
| W529 | A |                                         |  |
| W529 | B |                                         |  |
| W529 | C |                                         |  |
| W529 | D |                                         |  |
| W529 | E |                                         |  |
| W529 | F |                                         |  |
|      |   |                                         |  |
| W530 | 0 | DEFECT OF CHILL ROLL COOLING SKID, E160 |  |
| W530 | 1 | DEFECT OF WATER BATH COOLING SKID, E161 |  |
| W530 | 2 | DEFECT OF CHILL ROLL BRAKE, E162        |  |
| W530 | 3 |                                         |  |
| W530 | 4 |                                         |  |
| W530 | 5 |                                         |  |
| W530 | 6 |                                         |  |
| W530 | 7 |                                         |  |

|      |   |                               |      |
|------|---|-------------------------------|------|
| W530 | 8 |                               |      |
| W530 | 9 |                               |      |
| W530 | A | DEFECT OF MDO PUMP M1430.01,  | E170 |
| W530 | B | DEFECT OF MDO PUMP M1430.02,  | E171 |
| W530 | C | DEFECT OF MDO PUMP M1430.03,  | E172 |
| W530 | D | DEFECT OF MDO PUMP M1430.04,  | E173 |
| W530 | E | DEFECT OF MDO PUMP M1430.05,  | E174 |
| W530 | F | DEFECT OF MDO PUMP M1430.06,  | E175 |
|      |   |                               |      |
| W531 | 0 | DEFECT OF MDO PUMP M1430.07,  | E176 |
| W531 | 1 | DEFECT OF MDO PUMP M1430.08,  | E177 |
| W531 | 2 | DEFECT OF MDO PUMP M1430.09,  | E178 |
| W531 | 3 | DEFECT OF MDO PUMP M1430.10,  | E179 |
| W531 | 4 | DEFECT OF MDO PUMP M1430.11,  | E180 |
| W531 | 5 | DEFECT OF MDO PUMP M1430.12,  | E181 |
| W531 | 6 |                               |      |
| W531 | 7 |                               |      |
| W531 | 8 |                               |      |
| W531 | 9 | DEFECT OF TDO BLOWER M1520.01 | E185 |
| W531 | A | DEFECT OF TDO BLOWER M1528.01 | E186 |
| W531 | B | DEFECT OF TDO BLOWER M1520.02 | E187 |
| W531 | C | DEFECT OF TDO BLOWER M1520.03 | E188 |
| W531 | D | DEFECT OF TDO BLOWER M1520.04 | E189 |
| W531 | E | DEFECT OF TDO BLOWER M1520.05 | E190 |
| W531 | F | DEFECT OF TDO BLOWER M1520.06 | E191 |
|      |   |                               |      |
| W532 | 0 | DEFECT OF TDO BLOWER M1520.07 | E192 |
| W532 | 1 | DEFECT OF TDO BLOWER M1520.08 | E193 |
| W532 | 2 | DEFECT OF TDO BLOWER M1520.09 | E194 |
| W532 | 3 | DEFECT OF TDO BLOWER M1520.10 | E195 |
| W532 | 4 | DEFECT OF TDO BLOWER M1520.11 | E196 |
| W532 | 5 | DEFECT OF TDO BLOWER M1520.12 | E197 |
| W532 | 6 | DEFECT OF TDO BLOWER M1520.13 | E198 |
| W532 | 7 | DEFECT OF TDO BLOWER M1520.14 | E199 |
| W532 | 8 | DEFECT OF TDO BLOWER M1520.15 | E200 |
| W532 | 9 | DEFECT OF TDO BLOWER M1520.16 | E201 |
| W532 | A | DEFECT OF TDO BLOWER M1520.17 | E202 |
| W532 | B | DEFECT OF TDO BLOWER M1520.18 | E203 |
| W532 | C | DEFECT OF TDO BLOWER M1520.19 | E204 |
| W532 | D | DEFECT OF TDO BLOWER M1520.20 | E205 |
| W532 | E | DEFECT OF TDO BLOWER M1520.21 | E206 |
| W532 | F | DEFECT OF TDO BLOWER M1520.22 | E207 |
|      |   |                               |      |
| W533 | 0 | DEFECT OF TDO BLOWER M1520.23 | E208 |
| W533 | 1 | DEFECT OF TDO BLOWER M1520.24 | E209 |
| W533 | 2 | DEFECT OF TDO BLOWER M1520.25 | E210 |
| W533 | 3 | DEFECT OF TDO BLOWER M1520.26 | E211 |
| W533 | 4 | DEFECT OF TDO BLOWER M1520.27 | E212 |
| W533 | 5 | DEFECT OF TDO BLOWER M1520.28 | E213 |
| W533 | 6 | DEFECT OF TDO BLOWER M1520.29 | E214 |
| W533 | 7 | DEFECT OF TDO BLOWER M1520.30 | E215 |
| W533 | 8 | DEFECT OF TDO BLOWER M1520.31 | E216 |

|      |   |                                          |          |  |
|------|---|------------------------------------------|----------|--|
| W533 | 9 | DEFECT OF TDO BLOWER M1520.32            | E217     |  |
| W533 | A | DEFECT OF TDO BLOWER M1520.33            | E218     |  |
| W533 | B | DEFECT OF TDO BLOWER M1520.34            | E219     |  |
| W533 | C | DEFECT OF TDO BLOWER M1520.35            | E220     |  |
| W533 | D | DEFECT OF TDO BLOWER M1520.36            | E221     |  |
| W533 | E | DEFECT OF TDO BLOWER M1528.03            | E222     |  |
| W533 | F | DEFECT OF TDO BLOWER M1525.01            | E223     |  |
|      |   |                                          |          |  |
| W534 | 0 | DEFECT OF TDO BLOWER M1530.01            | E224     |  |
| W534 | 1 |                                          |          |  |
| W534 | 2 |                                          |          |  |
| W534 | 3 |                                          |          |  |
| W534 | 4 |                                          |          |  |
| W534 | 5 |                                          |          |  |
| W534 | 6 |                                          |          |  |
| W534 | 7 |                                          |          |  |
| W534 | 8 |                                          |          |  |
| W534 | 9 |                                          |          |  |
| W534 | A |                                          |          |  |
| W534 | B |                                          |          |  |
| W534 | C |                                          |          |  |
| W534 | D |                                          |          |  |
| W534 | E |                                          |          |  |
| W534 | F |                                          |          |  |
|      |   |                                          |          |  |
| W535 | 0 |                                          |          |  |
| W535 | 1 |                                          |          |  |
| W535 | 2 |                                          |          |  |
| W535 | 3 |                                          |          |  |
| W535 | 4 |                                          |          |  |
| W535 | 5 |                                          |          |  |
| W535 | 6 |                                          |          |  |
| W535 | 7 |                                          |          |  |
| W535 | 8 |                                          |          |  |
| W535 | 9 |                                          |          |  |
| W535 | A |                                          |          |  |
| W535 | B |                                          |          |  |
| W535 | C |                                          |          |  |
| W535 | D |                                          |          |  |
| W535 | E |                                          |          |  |
| W535 | F |                                          |          |  |
|      |   |                                          |          |  |
| W536 | 0 | DEFECT OF EXHAUST HOOD M1263.01          |          |  |
| W536 | 1 | DEFECT OF CHILL ROLL WATER REMOVAL       | M1330.01 |  |
| W536 | 2 | DEFECT OF CHILL ROLL AIR KNIFE BLOWER    | M1330.02 |  |
| W536 | 3 | DEFECT OF CHILL ROLL WATER REMOVAL       | M1330.03 |  |
| W536 | 4 | DEFECT OF CHILL ROLL WATER REMOVAL       | M1310.03 |  |
| W536 | 5 | DEFECT OF CHILL ROLL HORIZONTAL MOVEMENT | M1301.01 |  |
| W536 | 6 | DEFECT OF CHILL ROLL BRAKE               | Y1301.02 |  |
| W536 | 7 | DEFECT OF AUXILIARY WINDER #1 MOTOR      | M1360.01 |  |
| W536 | 8 |                                          |          |  |
| W536 | 9 |                                          |          |  |

|      |   |                                     |          |  |
|------|---|-------------------------------------|----------|--|
| W536 | A | DEFECT OF AUXILIARY WINDER #2 MOTOR | M1450.01 |  |
| W536 | B |                                     |          |  |
| W536 | C |                                     |          |  |
| W536 | D |                                     |          |  |
| W536 | E | DEFECT OF CHAIN TENSION SYSTEM      | M1515.01 |  |
| W536 | F |                                     |          |  |
|      |   |                                     |          |  |
| W537 | 0 | DEFECT OF VACUUM ROLL #1            | M1812.01 |  |
| W537 | 1 | DEFECT OF VACUUM ROLL #2            | M1825.01 |  |
| W537 | 2 | DEFECT OF OZONE EXHAUST BLOWER #1   | M1831.01 |  |
| W537 | 3 | DEFECT OF OZONE EXHAUST BLOWER #2   | M1831.02 |  |
| W537 | 4 | DEFECT OF AUXILIARY WINDER #3       |          |  |
| W537 | 5 | DEFECT OF OZONE EXHAUST BLOWER #3   | M1831.03 |  |
| W537 | 6 |                                     |          |  |
| W537 | 7 |                                     |          |  |
| W537 | 8 |                                     |          |  |
| W537 | 9 |                                     |          |  |
| W537 | A |                                     |          |  |
| W537 | B |                                     |          |  |
| W537 | C |                                     |          |  |
| W537 | D |                                     |          |  |
| W537 | E |                                     |          |  |
| W537 | F |                                     |          |  |
|      |   |                                     |          |  |
| W538 | 0 | DEFECT OF OZONE TREATER #1 BLOWER   |          |  |
| W538 | 1 | DEFECT OF OZONE TREATER #2 BLOWER   |          |  |
| W538 | 2 | DEFECT OF OZONE TREATER #3 BLOWER   |          |  |
| W538 | 3 | DEFECT OF OZONE TREATER #4 BLOWER   |          |  |
| W538 | 4 |                                     |          |  |
| W538 | 5 |                                     |          |  |
| W538 | 6 |                                     |          |  |
| W538 | 7 |                                     |          |  |
| W538 | 8 |                                     |          |  |
| W538 | 9 |                                     |          |  |
| W538 | A |                                     |          |  |
| W538 | B |                                     |          |  |
| W538 | C |                                     |          |  |
| W538 | D |                                     |          |  |
| W538 | E |                                     |          |  |
| W538 | F |                                     |          |  |

|       |   |           |                                      |
|-------|---|-----------|--------------------------------------|
| W4400 | 0 | DOSTE 160 | START/STOP GAZ HEATER CR C1340       |
| W4400 | 1 | DOSTE 161 | START/STOP GAZ HEATER CR C1350       |
| W4400 | 2 | DOSTE 162 | START/STOP ELEC. BRAKE Y1301.02      |
| W4400 | 3 |           |                                      |
| W4400 | 4 |           |                                      |
| W4400 | 5 |           |                                      |
| W4400 | 6 |           |                                      |
| W4400 | 7 |           |                                      |
| W4400 | 8 |           |                                      |
| W4400 | 9 | DOSTE 169 | START/STOP GAZ HEATER C1340.13, E169 |
| W4400 | A | DOSTE 170 | START/STOP MDO PUMP E170             |
| W4400 | B | DOSTE 171 | START/STOP MDO PUMP E171             |
| W4400 | C | DOSTE 172 | START/STOP MDO PUMP E172             |
| W4400 | D | DOSTE 173 | START/STOP MDO PUMP E173             |
| W4400 | E | DOSTE 174 | START/STOP MDO PUMP E174             |
| W4400 | F | DOSTE 175 | START/STOP MDO PUMP E175             |
|       |   |           |                                      |
| W4401 | 0 | DOSTE 176 | START/STOP MDO PUMP E176             |
| W4401 | 1 | DOSTE 177 | START/STOP MDO PUMP E177             |
| W4401 | 2 | DOSTE 178 | START/STOP MDO PUMP E178             |
| W4401 | 3 | DOSTE 179 | START/STOP MDO PUMP E179             |
| W4401 | 4 | DOSTE 180 | START/STOP MDO PUMP E180             |
| W4401 | 5 | DOSTE 181 | START/STOP MDO PUMP E176             |
| W4401 | 6 |           |                                      |
| W4401 | 7 |           |                                      |
| W4401 | 8 |           |                                      |
| W4401 | 9 | DOSTE 185 | START/STOP TDO BLOWER E185           |
| W4401 | A | DOSTE 186 | START/STOP TDO BLOWER E186           |
| W4401 | B | DOSTE 187 | START/STOP TDO BLOWER E187           |
| W4401 | C | DOSTE 188 | START/STOP TDO BLOWER E188           |
| W4401 | D | DOSTE 189 | START/STOP TDO BLOWER E189           |
| W4401 | E | DOSTE 190 | START/STOP TDO BLOWER E190           |
| W4401 | F | DOSTE 191 | START/STOP TDO BLOWER E191           |
|       |   |           |                                      |
| W4402 | 0 | DOSTE 192 | START/STOP TDO BLOWER E192           |
| W4402 | 1 | DOSTE 193 | START/STOP TDO BLOWER E193           |
| W4402 | 2 | DOSTE 194 | START/STOP TDO BLOWER E194           |
| W4402 | 3 | DOSTE 195 | START/STOP TDO BLOWER E195           |
| W4402 | 4 | DOSTE 196 | START/STOP TDO BLOWER E196           |
| W4402 | 5 | DOSTE 197 | START/STOP TDO BLOWER E197           |
| W4402 | 6 | DOSTE 198 | START/STOP TDO BLOWER E198           |
| W4402 | 7 | DOSTE 199 | START/STOP TDO BLOWER E199           |
| W4402 | 8 | DOSTE 200 | START/STOP TDO BLOWER E200           |
| W4402 | 9 | DOSTE 201 | START/STOP TDO BLOWER E201           |
| W4402 | A | DOSTE 202 | START/STOP TDO BLOWER E202           |
| W4402 | B | DOSTE 203 | START/STOP TDO BLOWER E203           |
| W4402 | C | DOSTE 204 | START/STOP TDO BLOWER E204           |
| W4402 | D | DOSTE 205 | START/STOP TDO BLOWER E205           |
| W4402 | E | DOSTE 206 | START/STOP TDO BLOWER E206           |
| W4402 | F | DOSTE 207 | START/STOP TDO BLOWER E207           |
|       |   |           |                                      |
| W4403 | 0 | DOSTE 208 | START/STOP TDO BLOWER E208           |

|       |   |           |                                    |
|-------|---|-----------|------------------------------------|
| W4403 | 1 | DOSTE 209 | START/STOP TDO BLOWER E209         |
| W4403 | 2 | DOSTE 210 | START/STOP TDO BLOWER E210         |
| W4403 | 3 | DOSTE 211 | START/STOP TDO BLOWER E211         |
| W4403 | 4 | DOSTE 212 | START/STOP TDO BLOWER E212         |
| W4403 | 5 | DOSTE 213 | START/STOP TDO BLOWER E213         |
| W4403 | 6 | DOSTE 214 | START/STOP TDO BLOWER E214         |
| W4403 | 7 | DOSTE 215 | START/STOP TDO BLOWER E215         |
| W4403 | 8 | DOSTE 216 | START/STOP TDO BLOWER E216         |
| W4403 | 9 | DOSTE 217 | START/STOP TDO BLOWER E217         |
| W4403 | A | DOSTE 218 | START/STOP TDO BLOWER E218         |
| W4403 | B | DOSTE 219 | START/STOP TDO BLOWER E219         |
| W4403 | C | DOSTE 220 | START/STOP TDO BLOWER E220         |
| W4403 | D | DOSTE 221 | START/STOP INLET E221              |
| W4403 | E | DOSTE 222 | START/STOP TDO OUTLET E222         |
| W4403 | F | DOSTE 223 | START/STOP TDO OUTLET E223         |
|       |   |           |                                    |
| W4404 | 0 | DOSTE 224 | START/STOP TDO OUTLET E224         |
| W4404 | 1 | DOSTE 225 | START/STOP TDO BURNER E225 ZONE 1  |
| W4404 | 2 | DOSTE 226 | START/STOP TDO BURNER E226 ZONE 2  |
| W4404 | 3 | DOSTE 227 | START/STOP TDO BURNER E227 ZONE 3  |
| W4404 | 4 | DOSTE 228 | START/STOP TDO BURNER E228 ZONE 4  |
| W4404 | 5 | DOSTE 229 | START/STOP TDO BURNER E229 ZONE 5  |
| W4404 | 6 | DOSTE 230 | START/STOP TDO BURNER E230 ZONE 6  |
| W4404 | 7 | DOSTE 231 | START/STOP TDO BURNER E231 ZONE 7  |
| W4404 | 8 | DOSTE 232 | START/STOP TDO BURNER E232 ZONE 8  |
| W4404 | 9 | DOSTE 233 | START/STOP TDO BURNER E233 ZONE 9  |
| W4404 | A | DOSTE 234 | START/STOP TDO BURNER E234 ZONE 10 |
| W4404 | B | DOSTE 235 | START/STOP TDO BURNER E235 ZONE 11 |
| W4404 | C | DOSTE 236 | START/STOP TDO BURNER E236 ZONE 12 |
| W4404 | D | DOSTE 237 | START/STOP TDO BURNER E237 ZONE 13 |
| W4404 | E | DOSTE 238 | START/STOP TDO BURNER E238 ZONE 14 |
| W4404 | F | DOSTE 239 | START/STOP TDO BURNER E239 ZONE 15 |
|       |   |           |                                    |
| W4405 | 0 | DOSTE 240 | START/STOP TDO BURNER E240 ZONE 16 |
| W4405 | 1 | DOSTE 241 | START/STOP TDO BURNER E241         |
| W4405 | 2 | DOSTE 242 | START/STOP TDO BURNER E242         |
| W4405 | 3 | DOSTE 243 | START/STOP TDO BURNER E243         |
| W4405 | 4 | DOSTE 244 | START/STOP TDO BURNER E244         |
| W4405 | 5 |           | START/STOP GAS SUPPLY E245         |
| W4405 | 6 |           |                                    |
| W4405 | 7 |           |                                    |
| W4405 | 8 |           |                                    |
| W4405 | 9 |           |                                    |
| W4405 | A |           |                                    |
| W4405 | B |           |                                    |
| W4405 | C |           |                                    |
| W4405 | D |           |                                    |
| W4405 | E |           |                                    |
| W4405 | F |           |                                    |
|       |   |           |                                    |
| W4406 | 0 |           |                                    |
| W4406 | 1 |           |                                    |

|       |   |           |                                 |
|-------|---|-----------|---------------------------------|
| W4406 | 2 |           |                                 |
| W4406 | 3 |           |                                 |
| W4406 | 4 |           |                                 |
| W4406 | 5 |           |                                 |
| W4406 | 6 |           |                                 |
| W4406 | 7 |           |                                 |
| W4406 | 8 |           |                                 |
| W4406 | 9 | DOSTE 185 | BLOWER ZONE 1 HIGH SPEED E185   |
| W4406 | A |           |                                 |
| W4406 | B | DOSTE 187 | BLOWER ZONE 2 HIGH SPEED E187   |
| W4406 | C | DOSTE 188 | BLOWER ZONE 3 HIGH SPEED E188   |
| W4406 | D | DOSTE 189 | BLOWER ZONE 4 HIGH SPEED E189   |
| W4406 | E | DOSTE 190 | BLOWER ZONE 5 HIGH SPEED E190   |
| W4406 | F | DOSTE 191 | BLOWER ZONE 6 HIGH SPEED E191   |
|       |   |           |                                 |
| W4407 | 0 | DOSTE 192 | BLOWER ZONE 7 HIGH SPEED E192   |
| W4407 | 1 | DOSTE 193 | BLOWER ZONE 8 HIGH SPEED E193   |
| W4407 | 2 | DOSTE 194 | BLOWER ZONE 9 HIGH SPEED E194   |
| W4407 | 3 | DOSTE 195 | BLOWER ZONE 10L HIGH SPEED E195 |
| W4407 | 4 | DOSTE 196 | BLOWER ZONE 10R HIGH SPEED E196 |
| W4407 | 5 | DOSTE 197 | BLOWER ZONE 11L HIGH SPEED E197 |
| W4407 | 6 | DOSTE 198 | BLOWER ZONE 11R HIGH SPEED E198 |
| W4407 | 7 | DOSTE 199 | BLOWER ZONE 12L HIGH SPEED E199 |
| W4407 | 8 | DOSTE 200 | BLOWER ZONE 12R HIGH SPEED E200 |
| W4407 | 9 | DOSTE 201 | BLOWER ZONE 13L HIGH SPEED E201 |
| W4407 | A | DOSTE 202 | BLOWER ZONE 13R HIGH SPEED E202 |
| W4407 | B | DOSTE 203 | BLOWER ZONE 14L HIGH SPEED E203 |
| W4407 | C | DOSTE 204 | BLOWER ZONE 14R HIGH SPEED E204 |
| W4407 | D | DOSTE 205 | BLOWER ZONE 15L HIGH SPEED E205 |
| W4407 | E | DOSTE 206 | BLOWER ZONE 15R HIGH SPEED E206 |
| W4407 | F | DOSTE 207 | BLOWER ZONE 16L HIGH SPEED E207 |
|       |   |           |                                 |
| W4408 | 0 | DOSTE 208 | BLOWER ZONE 16R HIGH SPEED E208 |
| W4408 | 1 | DOSTE 209 | BLOWER ZONE 17L HIGH SPEED E209 |
| W4408 | 2 | DOSTE 210 | BLOWER ZONE 17R HIGH SPEED E210 |
| W4408 | 3 | DOSTE 211 | BLOWER ZONE 18L HIGH SPEED E211 |
| W4408 | 4 | DOSTE 212 | BLOWER ZONE 18R HIGH SPEED E212 |
| W4408 | 5 | DOSTE 213 | BLOWER ZONE 19L HIGH SPEED E213 |
| W4408 | 6 | DOSTE 214 | BLOWER ZONE 19R HIGH SPEED E214 |
| W4408 | 7 | DOSTE 215 | BLOWER ZONE 20L HIGH SPEED E215 |
| W4408 | 8 | DOSTE 216 | BLOWER ZONE 20R HIGH SPEED E216 |
| W4408 | 9 | DOSTE 217 | BLOWER ZONE 21L HIGH SPEED E217 |
| W4408 | A | DOSTE 218 | BLOWER ZONE 21R HIGH SPEED E218 |
| W4408 | B | DOSTE 219 | BLOWER ZONE 22L HIGH SPEED E219 |
| W4408 | C | DOSTE 220 | BLOWER ZONE 22R HIGH SPEED E220 |
| W4408 | D |           |                                 |
| W4408 | E |           |                                 |
| W4408 | F |           |                                 |
|       |   |           |                                 |
| W4409 | 0 |           |                                 |
| W4409 | 1 |           |                                 |
| W4409 | 2 |           |                                 |



|       |   |         |                |
|-------|---|---------|----------------|
| W4409 | 3 |         |                |
| W4409 | 4 |         |                |
| W4409 | 5 |         |                |
| W4409 | 6 |         |                |
| W4409 | 7 |         |                |
| W4409 | 8 |         |                |
| W4409 | 9 |         |                |
| W4409 | A |         |                |
| W4409 | B |         |                |
| W4409 | C |         |                |
| W4409 | D |         |                |
| W4409 | E |         |                |
| W4409 | F |         |                |
|       |   |         |                |
| W4410 | 0 | DOAM+0  | AUTO/MANU R365 |
| W4410 | 1 | DOAM+1  | AUTO/MANU R366 |
| W4410 | 2 | DOAM+2  |                |
| W4410 | 3 | DOAM+3  |                |
| W4410 | 4 | DOAM+4  |                |
| W4410 | 5 | DOAM+5  | AUTO/MANU R370 |
| W4410 | 6 | DOAM+6  | AUTO/MANU R371 |
| W4410 | 7 | DOAM+7  | AUTO/MANU R372 |
| W4410 | 8 | DOAM+8  | AUTO/MANU R373 |
| W4410 | 9 | DOAM+9  | AUTO/MANU R374 |
| W4410 | A | DOAM+10 | AUTO/MANU R375 |
| W4410 | B | DOAM+11 | AUTO/MANU R376 |
| W4410 | C | DOAM+12 | AUTO/MANU R377 |
| W4410 | D | DOAM+13 | AUTO/MANU R378 |
| W4410 | E | DOAM+14 | AUTO/MANU R379 |
| W4410 | F | DOAM+15 | AUTO/MANU R380 |
|       |   |         |                |
| W4411 | 0 | DOAM+16 | AUTO/MANU R381 |
| W4411 | 1 | DOAM+17 |                |
| W4411 | 2 | DOAM+18 |                |
| W4411 | 3 | DOAM+19 |                |
| W4411 | 4 | DOAM+20 | AUTO/MANU R385 |
| W4411 | 5 | DOAM+21 | AUTO/MANU R386 |
| W4411 | 6 | DOAM+22 | AUTO/MANU R387 |
| W4411 | 7 | DOAM+23 | AUTO/MANU R388 |
| W4411 | 8 | DOAM+24 | AUTO/MANU R389 |
| W4411 | 9 | DOAM+25 | AUTO/MANU R390 |
| W4411 | A | DOAM+26 | AUTO/MANU R391 |
| W4411 | B | DOAM+27 | AUTO/MANU R392 |
| W4411 | C | DOAM+28 | AUTO/MANU R393 |
| W4411 | D | DOAM+29 | AUTO/MANU R394 |
| W4411 | E | DOAM+30 | AUTO/MANU R395 |
| W4411 | F | DOAM+31 | AUTO/MANU R396 |
|       |   |         |                |
| W4412 | 0 | DOAM+32 | AUTO/MANU R397 |
| W4412 | 1 | DOAM+33 | AUTO/MANU R398 |
| W4412 | 2 | DOAM+34 | AUTO/MANU R399 |
| W4412 | 3 | DOAM+35 | AUTO/MANU R400 |

|       |   |           |                                              |
|-------|---|-----------|----------------------------------------------|
| W4412 | 4 | DOAM+36   | AUTO/MANU R401                               |
| W4412 | 5 | DOAM+37   | AUTO/MANU R402                               |
| W4412 | 6 | DOAM+38   | AUTO/MANU R403                               |
| W4412 | 7 | DOAM+39   | AUTO/MANU R404                               |
| W4412 | 8 |           |                                              |
| W4412 | 9 |           |                                              |
| W4412 | A |           |                                              |
| W4412 | B |           |                                              |
| W4412 | C |           |                                              |
| W4412 | D |           |                                              |
| W4412 | E |           |                                              |
| W4412 | F |           |                                              |
|       |   |           |                                              |
| W4413 | 0 |           |                                              |
| W4413 | 1 |           |                                              |
| W4413 | 2 |           |                                              |
| W4413 | 3 |           |                                              |
| W4413 | 4 |           |                                              |
| W4413 | 5 |           |                                              |
| W4413 | 6 |           |                                              |
| W4413 | 7 |           |                                              |
| W4413 | 8 |           |                                              |
| W4413 | 9 |           |                                              |
| W4413 | A |           |                                              |
| W4413 | B |           |                                              |
| W4413 | C |           |                                              |
| W4413 | D |           |                                              |
| W4413 | E |           |                                              |
| W4413 | F |           |                                              |
|       |   |           |                                              |
| W4414 | 0 |           |                                              |
| W4414 | 1 |           |                                              |
| W4414 | 2 |           |                                              |
| W4414 | 3 |           |                                              |
| W4414 | 4 |           |                                              |
| W4414 | 5 |           |                                              |
| W4414 | 6 |           |                                              |
| W4414 | 7 |           |                                              |
| W4414 | 8 |           |                                              |
| W4414 | 9 |           |                                              |
| W4414 | A |           |                                              |
| W4414 | B |           |                                              |
| W4414 | C |           |                                              |
| W4414 | D |           |                                              |
| W4414 | E |           |                                              |
| W4414 | F |           |                                              |
|       |   |           |                                              |
| W4415 | 0 | DOLUBCLIP | START/STOP CHAIN LUBRICATION                 |
| W4415 | 1 | DOLUBTRAK | START/STOP TRACK LUBRICATION                 |
| W4415 | 2 | DOGAUGE   | START/STOP GAUGE CONTROL OF CHILL ROLL SPEED |
| W4415 | 3 |           |                                              |
| W4415 | 4 |           |                                              |

|       |   |          |                                       |
|-------|---|----------|---------------------------------------|
| W4415 | 5 | BINCTDO  | TDO TEMPERATURE SETPOINT IN AUTOMATIC |
| W4415 | 6 |          |                                       |
| W4415 | 7 |          |                                       |
| W4415 | 8 |          |                                       |
| W4415 | 9 |          |                                       |
| W4415 | A |          |                                       |
| W4415 | B |          |                                       |
| W4415 | C |          |                                       |
| W4415 | D |          |                                       |
| W4415 | E |          |                                       |
| W4415 | F |          |                                       |
|       |   |          |                                       |
| W4416 | 0 | CRS      | START CHILL ROLL EQUIPMENT            |
| W4416 | 1 | MDOS     | START MDO EQUIPMENT                   |
| W4416 | 2 | TDOSBLO  | START TDO BLOWERS                     |
| W4416 | 3 | TDOSBUR  | START TDO BURNERS                     |
| W4416 | 4 |          |                                       |
| W4416 | 5 | CRSO     | STOP CHILL ROLL EQUIPMENT             |
| W4416 | 6 | MDOSO    | STOP MDO EQUIPMENT                    |
| W4416 | 7 | TDOSOBLO | STOP TDO BLOWERS                      |
| W4416 | 8 | TDOSBUR  | STOP TDO BURNERS                      |
| W4416 | 9 |          |                                       |
| W4416 | A |          |                                       |
| W4416 | B |          |                                       |
| W4416 | C |          |                                       |
| W4416 | D |          |                                       |
| W4416 | E |          |                                       |
| W4416 | F |          |                                       |
|       |   |          |                                       |
| W4417 | 0 |          |                                       |
| W4417 | 1 |          |                                       |
| W4417 | 2 |          |                                       |
| W4417 | 3 |          |                                       |
| W4417 | 4 |          |                                       |
| W4417 | 5 |          |                                       |
| W4417 | 6 |          |                                       |
| W4417 | 7 |          |                                       |
| W4417 | 8 |          |                                       |
| W4417 | 9 |          |                                       |
| W4417 | A |          |                                       |
| W4417 | B |          |                                       |
| W4417 | C |          |                                       |
| W4417 | D |          |                                       |
| W4417 | E |          |                                       |
| W4417 | F |          |                                       |
|       |   |          |                                       |
| W4418 | 0 |          |                                       |
| W4418 | 1 |          |                                       |
| W4418 | 2 |          |                                       |
| W4418 | 3 |          |                                       |
| W4418 | 4 |          |                                       |
| W4418 | 5 |          |                                       |

|       |   |       |                |
|-------|---|-------|----------------|
| W4418 | 6 |       |                |
| W4418 | 7 |       |                |
| W4418 | 8 |       |                |
| W4418 | 9 |       |                |
| W4418 | A |       |                |
| W4418 | B |       |                |
| W4418 | C |       |                |
| W4418 | D |       |                |
| W4418 | E |       |                |
| W4418 | F |       |                |
|       |   |       |                |
| W4419 | 0 |       |                |
| W4419 | 1 |       |                |
| W4419 | 2 |       |                |
| W4419 | 3 |       |                |
| W4419 | 4 |       |                |
| W4419 | 5 |       |                |
| W4419 | 6 |       |                |
| W4419 | 7 |       |                |
| W4419 | 8 |       |                |
| W4419 | 9 |       |                |
| W4419 | A |       |                |
| W4419 | B |       |                |
| W4419 | C |       |                |
| W4419 | D |       |                |
| W4419 | E |       |                |
| W4419 | F |       |                |
|       |   |       |                |
| W4420 | 0 | DORED | RELEASE DEFECT |
| W4420 | 1 | DOREL | RELEASE KLAXON |
| W4420 | 2 |       |                |
| W4420 | 3 |       |                |
| W4420 | 4 |       |                |
| W4420 | 5 |       |                |
| W4420 | 6 |       |                |
| W4420 | 7 |       |                |
| W4420 | 8 |       |                |
| W4420 | 9 |       |                |
| W4420 | A |       |                |
| W4420 | B |       |                |
| W4420 | C |       |                |
| W4420 | D |       |                |
| W4420 | E |       |                |
| W4420 | F |       |                |
|       |   |       |                |
| W4421 | 0 |       |                |
| W4421 | 1 |       |                |
| W4421 | 2 |       |                |
| W4421 | 3 |       |                |
| W4421 | 4 |       |                |
| W4421 | 5 |       |                |
| W4421 | 6 |       |                |

|       |   |  |  |
|-------|---|--|--|
| W4421 | 7 |  |  |
| W4421 | 8 |  |  |
| W4421 | 9 |  |  |
| W4421 | A |  |  |
| W4421 | B |  |  |
| W4421 | C |  |  |
| W4421 | D |  |  |
| W4421 | E |  |  |
| W4421 | F |  |  |
|       |   |  |  |
| W4422 | 0 |  |  |
| W4422 | 1 |  |  |
| W4422 | 2 |  |  |
| W4422 | 3 |  |  |
| W4422 | 4 |  |  |
| W4422 | 5 |  |  |
| W4422 | 6 |  |  |
| W4422 | 7 |  |  |
| W4422 | 8 |  |  |
| W4422 | 9 |  |  |
| W4422 | A |  |  |
| W4422 | B |  |  |
| W4422 | C |  |  |
| W4422 | D |  |  |
| W4422 | E |  |  |
| W4422 | F |  |  |

| BIT NO. | TAG NAME | DESCRIPTION                                    |
|---------|----------|------------------------------------------------|
| W4750 0 | RE+0     | CHILL ROLL GAZ HEATER C 1340 E160              |
| W4750 1 | RE+1     | CHILL ROLL GAZ HEATER C 1340 E161              |
| W4750 2 | RE+2     | CONTACTOR ANSWER OF CHILL ROLL BRAKE E162      |
| W4750 3 | RE+3     |                                                |
| W4750 4 | RE+4     |                                                |
| W4750 5 | RE+5     |                                                |
| W4750 6 | RE+6     |                                                |
| W4750 7 | RE+7     |                                                |
| W4750 8 | RE+8     |                                                |
| W4750 9 | RE+9     | MDO GAZ HEATER C 1430.13 E169                  |
| W4750 A | RE+10    | MDO PUMP ZONE 1 M 1430.01 E170                 |
| W4750 B | RE+11    | MDO PUMP ZONE 2 M 1430.02 E171                 |
| W4750 C | RE+12    | MDO PUMP ZONE 3 M 1430.03 E172                 |
| W4750 D | RE+13    | MDO PUMP ZONE 4 M 1430.04 E173                 |
| W4750 E | RE+14    | MDO PUMP ZONE 5 M 1430.05 E174                 |
| W4750 F | RE+15    | MDO PUMP ZONE 6 M 1430.06 E175                 |
|         |          |                                                |
| W4751 0 | RE+16    | MDO PUMP ZONE 7 M 1430.07 E176                 |
| W4751 1 | RE+17    | MDO PUMP ZONE 8 M 1430.08 E177                 |
| W4751 2 | RE+18    | MDO PUMP STRETCHING ZONE 1 M 1430.09 E178      |
| W4751 3 | RE+19    | MDO PUMP STRETCHING ZONE 2 M 1430.10 E179      |
| W4751 4 | RE+20    | MDO PUMP STRETCHING ZONE 3 M 1430.11 E180      |
| W4751 5 | RE+21    | MDO PUMP LAST ZONE 1430.12 E181                |
| W4751 6 | RE+22    |                                                |
| W4751 7 | RE+23    |                                                |
| W4751 8 | RE+24    |                                                |
| W4751 9 | RE+25    | TDO BLOWER M 1520.01 ZONE 1 E185 BLOWER STATUS |
| W4751 A | RE+26    | TDO INLET BLOWER M 1528.01 E186                |
| W4751 B | RE+27    | TDO BLOWER M 1520.02 ZONE 2 E187               |
| W4751 C | RE+28    | TDO BLOWER M 1520.03 ZONE 3 E188               |
| W4751 D | RE+29    | TDO BLOWER M 1520.04 ZONE 4 E189               |
| W4751 E | RE+30    | TDO BLOWER M 1520.05 ZONE 5 E190               |
| W4751 F | RE+31    | TDO BLOWER M 1520.06 ZONE 6 E191               |
|         |          |                                                |
| W4752 0 | RE+32    | TDO BLOWER M 1520.07 ZONE 7 E192               |
| W4752 1 | RE+33    | TDO BLOWER M 1520.08 ZONE 8 E193               |
| W4752 2 | RE+34    | TDO BLOWER M 1520.09 ZONE 9 E194               |
| W4752 3 | RE+35    | TDO BLOWER M 1520.10 ZONE 10 E195              |
| W4752 4 | RE+36    | TDO BLOWER M 1520.11 ZONE 10 E196              |
| W4752 5 | RE+37    | TDO BLOWER M 1520.12 ZONE 11 E197              |
| W4752 6 | RE+38    | TDO BLOWER M 1520.13 ZONE 11 E198              |
| W4752 7 | RE+39    | TDO BLOWER M 1520.14 ZONE 12 E199              |
| W4752 8 | RE+40    | TDO BLOWER M 1520.15 ZONE 12 E200              |
| W4752 9 | RE+41    | TDO BLOWER M 1520.16 ZONE 13 E201              |
| W4752 A | RE+42    | TDO BLOWER M 1520.17 ZONE 13 E202              |
| W4752 B | RE+43    | TDO BLOWER M 1520.18 ZONE 14 E203              |
| W4752 C | RE+44    | TDO BLOWER M 1520.19 ZONE 14 E204              |
| W4752 D | RE+45    | TDO BLOWER M 1520.20 ZONE 15 E205              |
| W4752 E | RE+46    | TDO BLOWER M 1520.21 ZONE 15 E206              |
| W4752 F | RE+47    | TDO BLOWER M 1520.22 ZONE 16 E207              |
|         |          |                                                |

|       |   |       |                                      |
|-------|---|-------|--------------------------------------|
| W4753 | 0 | RE+48 | TDO BLOWER M 1520.23 ZONE 16 E208    |
| W4753 | 1 | RE+49 | TDO BLOWER M 1520.24 ZONE 17 E209    |
| W4753 | 2 | RE+50 | TDO BLOWER M 1520.25 ZONE 17 E210    |
| W4753 | 3 | RE+51 | TDO BLOWER M 1520.26 ZONE 18 E211    |
| W4753 | 4 | RE+52 | TDO BLOWER M 1520.27 ZONE 18 E212    |
| W4753 | 5 | RE+53 | TDO BLOWER M 1520.28 ZONE 19 E213    |
| W4753 | 6 | RE+54 | TDO BLOWER M 1520.29 ZONE 19 E214    |
| W4753 | 7 | RE+55 | TDO BLOWER M 1520.30 ZONE 20 E215    |
| W4753 | 8 | RE+56 | TDO BLOWER M 1520.31 ZONE 20 E216    |
| W4753 | 9 | RE+57 | TDO BLOWER M 1520.32 ZONE 21 E217    |
| W4753 | A | RE+58 | TDO BLOWER M 1520.33 ZONE 21 E218    |
| W4753 | B | RE+59 | TDO BLOWER M 1520.34 ZONE 22 E219    |
| W4753 | C | RE+60 | TDO BLOWER M 1520.35 ZONE 22 E220    |
| W4753 | D | RE+61 | TDO INLET BLOWER M 1528.02 ZONE E221 |
| W4753 | E | RE+62 | TDO OUTLET BLOWER M 1528.03 E222     |
| W4753 | F | RE+63 | TDO OUTLET BLOWER M 1525.01 E223     |
|       |   |       |                                      |
| W4754 | 0 | RE+64 | TDO OUTLET BLOWER M 1530.01 E224     |
| W4754 | 1 | RE+65 | TDO BURNER ZONE 1 M 1540.01 E225     |
| W4754 | 2 | RE+66 | TDO BURNER ZONE 2 M 1540.02 E226     |
| W4754 | 3 | RE+67 | TDO BURNER ZONE 3 M 1540.03 E227     |
| W4754 | 4 | RE+68 | TDO BURNER ZONE 4 M 1540.04 E228     |
| W4754 | 5 | RE+69 | TDO BURNER ZONE 5 M 1540.05 E229     |
| W4754 | 6 | RE+70 | TDO BURNER ZONE 6 M 1540.06 E230     |
| W4754 | 7 | RE+71 | TDO BURNER ZONE 7 M 1540.07 E231     |
| W4754 | 8 | RE+72 | TDO BURNER ZONE 8 M 1540.08 E232     |
| W4754 | 9 | RE+73 | TDO BURNER ZONE 9 M 1540.09 E233     |
| W4754 | A | RE+74 | TDO BURNER ZONE 10 M 1540.10 E234    |
| W4754 | B | RE+75 | TDO BURNER ZONE 11 M 1540.11 E235    |
| W4754 | C | RE+76 | TDO BURNER ZONE 12 M 1540.12 E236    |
| W4754 | D | RE+77 | TDO BURNER ZONE 13 M 1540.13 E237    |
| W4754 | E | RE+78 | TDO BURNER ZONE 14 M 1540.14 E238    |
| W4754 | F | RE+79 | TDO BURNER ZONE 15 M 1540.15 E239    |
|       |   |       |                                      |
| W4755 | 0 | RE+80 | TDO BURNER ZONE 16 M 1540.16 E240    |
| W4755 | 1 | RE+81 | TDO BURNER ZONE 17 M 1540.17 E241    |
| W4755 | 2 | RE+82 | TDO BURNER ZONE 18 M 1540.18 E242    |
| W4755 | 3 | RE+83 | TDO BURNER ZONE 19 M 1540.19 E243    |
| W4755 | 4 | RE+84 | TDO BURNER ZONE 20 M 1540.20 E244    |
| W4755 | 5 | RE+85 |                                      |
| W4755 | 6 | RE+86 |                                      |
| W4755 | 7 | RE+87 |                                      |
| W4755 | 8 | RE+88 |                                      |
| W4755 | 9 | RE+89 |                                      |
| W4755 | A | RE+90 |                                      |
| W4755 | B | RE+91 |                                      |
| W4755 | C | RE+92 |                                      |
| W4755 | D | RE+93 |                                      |
| W4755 | E | RE+94 |                                      |
| W4755 | F | RE+95 |                                      |
|       |   |       |                                      |
| W4756 | 0 | RE+96 | CHILL ROLL EXHAUST HOOD M1263-01     |

|       |   |           |                                               |
|-------|---|-----------|-----------------------------------------------|
| W4756 | 1 | RE+97     | CHILL ROLL WATER REMOVAL M1330-01             |
| W4756 | 2 | RE+98     | CHILL ROLL WATER REMOVAL M1310-01             |
| W4756 | 3 | RE+99     | CHILL ROLL WATER REMOVAL M1310-02             |
| W4756 | 4 | RE+100    | CHILL ROLL WATER REMOVAL M1310-03             |
| W4756 | 5 | RE+101    | CHILL ROLL HORIZONTAL MOVEMENT M1301-01       |
| W4756 | 6 | RE+102    | CHILL ROLL BRAKE Y1301-02                     |
| W4756 | 7 | RE+103    | CHILL ROLL AUXILIARY WINDER 1 M1360-01        |
| W4756 | 8 | RE+104    |                                               |
| W4756 | 9 | RE+105    |                                               |
| W4756 | A | RE+106    | CHILL ROLL AUXILIARY WINDER M1450-01          |
| W4756 | B | RE+107    |                                               |
| W4756 | C | RE+108    |                                               |
| W4756 | D | RE+109    |                                               |
| W4756 | E | RE+110    | CONTACTOR ANSWER OF TDO CHAIN TENSION         |
| W4756 | F | RE+111    |                                               |
|       |   |           |                                               |
| W4757 | 0 | RE+112    | PRS FAN ROLL 2 M1812.01                       |
| W4757 | 1 | RE+113    | PRS FAN ROLL 11 M1812.01                      |
| W4757 | 2 | RE+114    | PRS FAN ROLL OZONE EXTRA M1831-01 COR. 1      |
| W4757 | 3 | RE+115    | PRS FAN ROLL OZONE EXTRA M1831-02 COR. 2      |
| W4757 | 4 | RE+116    | AUXILIARY WINDER 2 M1450.01                   |
| W4757 | 5 | RE+117    | PRS FAN ROLL OZONE EXTRA M1831-03 COR. 3      |
| W4757 | 6 | RE+118    |                                               |
| W4757 | 7 | RE+119    | RECLAIM MATERIAL GRINDER M2607-01             |
| W4757 | 8 | RE+120    | RECLAIM MATERIAL GRINDER TRANSPORTER M2508-01 |
| W4757 | 9 |           |                                               |
| W4757 | A |           |                                               |
| W4757 | B |           |                                               |
| W4757 | C |           |                                               |
| W4757 | D |           |                                               |
| W4757 | E |           |                                               |
| W4757 | F |           |                                               |
|       |   |           |                                               |
| W4758 | 0 |           |                                               |
| W4758 | 1 |           |                                               |
| W4758 | 2 |           |                                               |
| W4758 | 3 |           |                                               |
| W4758 | 4 |           |                                               |
| W4758 | 5 |           |                                               |
| W4758 | 6 |           |                                               |
| W4758 | 7 |           |                                               |
| W4758 | 8 |           |                                               |
| W4758 | 9 |           |                                               |
| W4758 | A |           |                                               |
| W4758 | B |           |                                               |
| W4758 | C |           |                                               |
| W4758 | D |           |                                               |
| W4758 | E |           |                                               |
| W4758 | F |           |                                               |
|       |   |           |                                               |
| W4760 | 0 | DIFAE 160 | FAULT CHILL ROLL GAZ HEATER C 1340 E160       |
| W4760 | 1 | DIFAE 161 | FAULT CHILL ROLL GAZ HEATER C 1350 E161       |



|       |   |           |                                     |      |
|-------|---|-----------|-------------------------------------|------|
| W4760 | 2 | DIFAE 162 | FAULT CHILL ROLL BRAKE Y 1301.02    | E162 |
| W4760 | 3 |           |                                     |      |
| W4760 | 4 |           |                                     |      |
| W4760 | 5 |           |                                     |      |
| W4760 | 6 |           |                                     |      |
| W4760 | 7 |           |                                     |      |
| W4760 | 8 |           |                                     |      |
| W4760 | 9 | DIFAE 169 | FAULT MDO PUMP GAZ HEATER C 1430.13 | E169 |
| W4760 | A | DIFAE 170 | FAULT MDO PUMP ZONE 1 M 1430.01     | E170 |
| W4760 | B | DIFAE 171 | FAULT MDO PUMP ZONE 2 M 1430.02     | E171 |
| W4760 | C | DIFAE 172 | FAULT MDO PUMP ZONE 3 M 1430.03     | E172 |
| W4760 | D | DIFAE 173 | FAULT MDO PUMP ZONE 4 M 1430.04     | E173 |
| W4760 | E | DIFAE 174 | FAULT MDO PUMP ZONE 5 M 1430.05     | E174 |
| W4760 | F | DIFAE 175 | FAULT MDO PUMP ZONE 6 M 1430.06     | E175 |
|       |   |           |                                     |      |
| W4761 | 0 | DIFAE 176 | FAULT MDO PUMP ZONE 7 M 1430.07     | E176 |
| W4761 | 1 | DIFAE 177 | FAULT MDO PUMP ZONE 8 M 1430.08     | E177 |
| W4761 | 2 | DIFAE 178 | FAULT MDO PUMP STRET. 1 M1430.09    | E178 |
| W4761 | 3 | DIFAE 179 | FAULT MDO PUMP STRET. 2 M1430.10    | E179 |
| W4761 | 4 | DIFAE 180 | FAULT MDO PUMP STRET. 3 M1430.11    | E180 |
| W4761 | 5 | DIFAE 181 | FAULT MDO PUMP ZONE 12 M1430.06     | E181 |
| W4761 | 6 | DIFAE 182 |                                     |      |
| W4761 | 7 | DIFAE 183 |                                     |      |
| W4761 | 8 | DIFAE 184 |                                     |      |
| W4761 | 9 | DIFAE 185 | FAULT TDO BLOWER ZONE 1 M1520.01    | E185 |
| W4761 | A | DIFAE 186 | FAULT INLET BLOWER M1520.01         | E186 |
| W4761 | B | DIFAE 187 | FAULT TDO BLOWER ZONE 2 M1520.02    | E187 |
| W4761 | C | DIFAE 188 | FAULT TDO BLOWER ZONE 3 M1520.03    | E188 |
| W4761 | D | DIFAE 189 | FAULT TDO BLOWER ZONE 4 M1520.04    | E189 |
| W4761 | E | DIFAE 190 | FAULT TDO BLOWER ZONE 5 M1520.05    | E190 |
| W4761 | F | DIFAE 191 | FAULT TDO BLOWER ZONE 6 M1520.06    | E191 |
|       |   |           |                                     |      |
| W4762 | 0 | DIFAE 192 | FAULT TDO BLOWER ZONE 7 M1520.07    | E192 |
| W4762 | 1 | DIFAE 193 | FAULT TDO BLOWER ZONE 8 M1520.08    | E193 |
| W4762 | 2 | DIFAE 194 | FAULT TDO BLOWER ZONE 9 M1520.09    | E194 |
| W4762 | 3 | DIFAE 195 | FAULT TDO BLOWER ZONE 10 M1520.10   | E195 |
| W4762 | 4 | DIFAE 196 | FAULT TDO BLOWER ZONE 10 M1520.11   | E196 |
| W4762 | 5 | DIFAE 197 | FAULT TDO BLOWER ZONE 11 M1520.12   | E197 |
| W4762 | 6 | DIFAE 198 | FAULT TDO BLOWER ZONE 11 M1520.13   | E198 |
| W4762 | 7 | DIFAE 199 | FAULT TDO BLOWER ZONE 12 M1520.14   | E199 |
| W4762 | 8 | DIFAE 200 | FAULT TDO BLOWER ZONE 12 M1520.15   | E200 |
| W4762 | 9 | DIFAE 201 | FAULT TDO BLOWER ZONE 13 M1520.16   | E201 |
| W4762 | A | DIFAE 202 | FAULT TDO BLOWER ZONE 13 M1520.17   | E202 |
| W4762 | B | DIFAE 203 | FAULT TDO BLOWER ZONE 14 M1520.18   | E203 |
| W4762 | C | DIFAE 204 | FAULT TDO BLOWER ZONE 14 M1520.19   | E204 |
| W4762 | D | DIFAE 205 | FAULT TDO BLOWER ZONE 15 M1520.20   | E205 |
| W4762 | E | DIFAE 206 | FAULT TDO BLOWER ZONE 15 M1520.21   | E206 |
| W4762 | F | DIFAE 207 | FAULT TDO BLOWER ZONE 16 M1520.22   | E207 |
|       |   |           |                                     |      |
| W4763 | 0 | DIFAE 208 | FAULT TDO BLOWER ZONE 16 M1520.23   | E208 |
| W4763 | 1 | DIFAE 209 | FAULT TDO BLOWER ZONE 17 M1520.24   | E209 |
| W4763 | 2 | DIFAE 210 | FAULT TDO BLOWER ZONE 17 M1520.25   | E210 |

|       |   |             |                                             |
|-------|---|-------------|---------------------------------------------|
| W4763 | 3 | DIFAE 211   | FAULT TDO BLOWER ZONE 18 M1520.26 E211      |
| W4763 | 4 | DIFAE 212   | FAULT TDO BLOWER ZONE 18 M1520.27 E212      |
| W4763 | 5 | DIFAE 213   | FAULT TDO BLOWER ZONE 19 M1520.28 E213      |
| W4763 | 6 | DIFAE 214   | FAULT TDO BLOWER ZONE 19 M1520.29 E214      |
| W4763 | 7 | DIFAE 215   | FAULT TDO BLOWER ZONE 20 M1520.30 E215      |
| W4763 | 8 | DIFAE 216   | FAULT TDO BLOWER ZONE 20 M1520.31 E216      |
| W4763 | 9 | DIFAE 217   | FAULT TDO BLOWER ZONE 21 M1520.32 E217      |
| W4763 | A | DIFAE 218   | FAULT TDO BLOWER ZONE 21 M1520.33 E218      |
| W4763 | B | DIFAE 219   | FAULT TDO BLOWER ZONE 22 M1520.34 E219      |
| W4763 | C | DIFAE 220   | FAULT TDO BLOWER ZONE 22 M1520.35 E220      |
| W4763 | D | DIFAE 221   | FAULT TDO INLET BLOWER M1528.02 E224        |
| W4763 | E | DIFAE 222   | FAULT TDO OUTLET BLOWER M1520.03 E222       |
| W4763 | F | DIFAE 223   | FAULT TDO OUTLET BLOWER M1520.22 E223       |
|       |   |             |                                             |
| W4764 | 0 | DIFAE 224   | FAULT TDO OUTLET BLOWER M1530.01 E224       |
| W4764 | 1 | DIFAE 225   | FAULT TDO ZONE 1 BURNER M1540.01 E225       |
| W4764 | 2 | DIFAE 226   | FAULT TDO ZONE 2 BURNER M1540.02 E226       |
| W4764 | 3 | DIFAE 227   | FAULT TDO ZONE 3 BURNER M1540.03 E227       |
| W4764 | 4 | DIFAE 228   | FAULT TDO ZONE 4 BURNER M1540.04 E228       |
| W4764 | 5 | DIFAE 229   | FAULT TDO ZONE 5 BURNER M1540.05 E229       |
| W4764 | 6 | DIFAE 230   | FAULT TDO ZONE 6 BURNER M1540.06 E230       |
| W4764 | 7 | DIFAE 231   | FAULT TDO ZONE 7 BURNER M1540.07 E231       |
| W4764 | 8 | DIFAE 232   | FAULT TDO ZONE 8 BURNER M1540.08 E232       |
| W4764 | 9 | DIFAE 233   | FAULT TDO ZONE 9 BURNER M1540.09 E233       |
| W4764 | A | DIFAE 234   | FAULT TDO ZONE 10 BURNER M1540.10 E234      |
| W4764 | B | DIFAE 235   | FAULT TDO ZONE 11 BURNER M1540.10 E235      |
| W4764 | C | DIFAE 236   | FAULT TDO ZONE 12 BURNER M1540.12 E236      |
| W4764 | D | DIFAE 237   | FAULT TDO ZONE 13 BURNER M1540.13 E237      |
| W4764 | E | DIFAE 238   | FAULT TDO ZONE 14 BURNER M1540.14 E238      |
| W4764 | F | DIFAE 239   | FAULT TDO ZONE 15 BURNER M1540.15 E239      |
|       |   |             |                                             |
| W4765 | 0 | DIFAE 240   | FAULT TDO ZONE 16 BURNER M1540.16 E240      |
| W4765 | 1 | DIFAE 241   | FAULT TDO ZONE 17 BURNER M1540.17 E241      |
| W4765 | 2 | DIFAE 242   | FAULT TDO ZONE 18 BURNER M1540.18 E242      |
| W4765 | 3 | DIFAE 243   | FAULT TDO ZONE 19 BURNER M1540.19 E243      |
| W4765 | 4 | DIFAE 244   | FAULT TDO ZONE 20 BURNER M1540.20 E244      |
| W4765 | 5 |             |                                             |
| W4765 | 6 |             |                                             |
| W4765 | 7 |             |                                             |
| W4765 | 8 |             |                                             |
| W4765 | 9 |             |                                             |
| W4765 | A |             |                                             |
| W4765 | B |             |                                             |
| W4765 | C |             |                                             |
| W4765 | D |             |                                             |
| W4765 | E |             |                                             |
| W4765 | F |             |                                             |
|       |   |             |                                             |
| W4766 | 0 | DIFM 126301 | DEFECT OF CHILL ROLL EXHAUST HOOD M1263.01  |
| W4766 | 1 | DIFM 133001 | DEFECT OF CHILL ROLL WATER REMOVAL M1330.01 |
| W4766 | 2 | DIFM 131001 | DEFECT OF CHILL ROLL WATER REMOVAL M1330.02 |
| W4766 | 3 | DIFM 131002 | DEFECT OF CHILL ROLL WATER REMOVAL M1330.03 |

|       |   |             |                                             |
|-------|---|-------------|---------------------------------------------|
| W4766 | 4 | DIFM 131003 | DEFECT OF CHILL ROLL WATER REMOVAL M1310.03 |
| W4766 | 5 | DIFM 130101 | DEFECT OF HORIZONTAL MOVEMENT M1301.01      |
| W4766 | 6 | DIFM 130102 | DEFECT OF CHILL ROLL BRAKE Y1301.02         |
| W4766 | 7 | DIFM 136001 | DEFECT OF AUXILIARY WINDER #1 M1360.01      |
| W4766 | 8 |             |                                             |
| W4766 | 9 |             |                                             |
| W4766 | A | DIFM 145001 | DEFECT OF AUXILIARY WINDER #2 M1450.01      |
| W4766 | B |             |                                             |
| W4766 | C |             |                                             |
| W4766 | D |             |                                             |
| W4766 | E | DIFM 151501 | DEFECT OF TDO CHAIN TENSION SYSTEM M1515.01 |
| W4766 | F |             |                                             |
|       |   |             |                                             |
| W4767 | 0 | DIFM 181201 | DEFECT OF VACUUM ROLL #1 M1812.01           |
| W4767 | 1 | DIFM 181501 | DEFECT OF VACUUM ROLL #2 M1825.01           |
| W4767 | 2 | DIFM 183101 | DEFECT OF OZONE EXHAUST BLOWER #1 M1831.01  |
| W4767 | 3 | DIFM 183102 | DEFECT OF OZONE EXHAUST BLOWER #2 M1831.02  |
| W4767 | 4 | DIFM 1860A1 | DEFECT OF AUXILIARY WINDER #3               |
| W4767 | 5 | DIFM 183103 | DEFECT OF OZONE EXHAUST BLOWER #3 M1831.03  |
| W4767 | 6 |             |                                             |
| W4767 | 7 |             |                                             |
| W4767 | 8 |             |                                             |
| W4767 | 9 |             |                                             |
| W4767 | A |             |                                             |
| W4767 | B |             |                                             |
| W4767 | C |             |                                             |
| W4767 | D |             |                                             |
| W4767 | E |             |                                             |
| W4767 | F |             |                                             |
|       |   |             |                                             |
| W4768 | 0 |             |                                             |
| W4768 | 1 |             |                                             |
| W4768 | 2 |             |                                             |
| W4768 | 3 |             |                                             |
| W4768 | 4 |             |                                             |
| W4768 | 5 |             |                                             |
| W4768 | 6 |             |                                             |
| W4768 | 7 |             |                                             |
| W4768 | 8 |             |                                             |
| W4768 | 9 |             |                                             |
| W4768 | A |             |                                             |
| W4768 | B |             |                                             |
| W4768 | C |             |                                             |
| W4768 | D |             |                                             |
| W4768 | E |             |                                             |
| W4768 | F |             |                                             |
|       |   |             |                                             |
| W4770 | 0 | ZS 130103   | CHILL ROLL HAND CRANK ENGAGE ZS 1301-03     |
| W4770 | 1 | SV 131011   | ROLL CARRIAGE FILM REMOVAL POSITION (ENG)   |
| W4770 | 2 | SV 131013   | RUBBER ROLL WATER REMOVAL POSITION (ENG)    |
| W4770 | 3 | SV 131012   | CHROMED ROLL WATER REMOVAL POSITION (ENG)   |
| W4770 | 4 | SV 131009   | CHILL ROLL AIR KNIFE ENGAGE SV 1310.09      |

|       |   |            |                                              |
|-------|---|------------|----------------------------------------------|
| W4770 | 5 | SV 131010  | CHILL ROLL EDGE PINNING ON SV 1310.09        |
| W4770 | 6 | ZS 130104  | CHILL ROLL ON HOME POSITION ZS 1301.04       |
| W4770 | 7 | ZS 130105  | CHILL ROLL HIGH LOW SPEED ZS 1301.05         |
| W4770 | 8 | ZS 130106  | CHILL ROLL IN WORKING POSITION ZS 1301.06    |
| W4770 | 9 | TSH 136003 | HIGH TEMP. ALARM AUX. WINDER 1 TSH 1360.03   |
| W4770 | A | LSL 135003 | CHILL ROLL MDO LOW LEVEL TANK LSL 1350.03    |
| W4770 | B | AUX1LENG   | CHILL ROLL AUX. WINDER 1 ENGAGE              |
| W4770 | C | WBON       | CHILL ROLL WATER BATH ON                     |
| W4770 | D | WBAUTO     | CHILL ROLL WATER BATH AUTO                   |
| W4770 | E | AUX1RET    | CHILL ROLL AUX. WINDER 1 RETRACT             |
| W4770 | F | PESCR      | PROCESS STOP CHILL                           |
|       |   |            |                                              |
| W4771 | 0 | ROLL1ENG   | MDO NIP ROLL 1 IN WORK POS. ZSH 1404.06.07   |
| W4771 | 1 | ROLL2ENG   | MDO NIP ROLL 2 IN WORK POS. ZSH 1404.08.09   |
| W4771 | 2 | ROLL3ENG   | MDO NIP ROLL 3 IN WORK POS. ZSH 1404.10.11   |
| W4771 | 3 | INLET      | MDO PRES. ROLL INLET IN POS. ZSE 1404.12.13  |
| W4771 | 4 | OUTLET     | MDO PRES. ROLL OUTLET IN POS. ZSE 1404.14.15 |
| W4771 | 5 | DR1HOME    | DRAW ROLL 1 IN HOME POSITION ZSH 1402.07     |
| W4771 | 6 | DR1WORK    | DRAW ROLL 1 IN WORKING POSITION              |
| W4771 | 7 | DR2HOME    | DRAW ROLL 2 IN HOME POSITION ZSH 1402.15     |
| W4771 | 8 | DR2WORK    | DRAW ROLL 2 IN WORKING POSITION              |
| W4771 | 9 | DR3HOME    | DRAW ROLL 3 IN HOME POSITION ZSH 1402.15     |
| W4771 | A | DR3WORK    | DRAW ROLL 3 IN WORKING POSITION              |
| W4771 | B |            |                                              |
| W4771 | C |            |                                              |
| W4771 | D | ZTMDO      | BREAK FILM MDO ZT 1420.01 ST 1420.02         |
| W4771 | E | BYPASSMDO  | BYPASS MDO                                   |
| W4771 | F | PESMDO     | PROCESS STOP MDO                             |
|       |   |            |                                              |
| W4772 | 0 | TSH 145003 | AUXILIARY WINDER 2 TSH 1450.03               |
| W4772 | 1 | AUX2ENG    | AUX WINDER 2 ENGAGE SV 1450.05               |
| W4772 | 2 | AUX2RET    | AUX WINDER 2 RETRACT SV 1450.04              |
| W4772 | 3 |            |                                              |
| W4772 | 4 |            |                                              |
| W4772 | 5 | DICLIPOFF  | TDO AIR ON CLIPS SZ 1511.03 OFF              |
| W4772 | 6 | DICLIPON   | AIR ON CLIPS SV 1511.03 ON                   |
| W4772 | 7 | DICLIPAUTO | O AIR ON CLIPS SV 1511.03 AUTO               |
| W4772 | 8 | ZT 153102  | WEB BREAK BEFORE COOLING ZONE ZT 1531.02     |
| W4772 | 9 | ZT 153101  | WEB BREAK AFTER STRET. ZONE ZT 1531.01       |
| W4772 | A | BYPASSAUTO | BYPASS TDO                                   |
| W4772 | B | ZS 151506  | SECURITY SWITCH ZS 1515.06 (RIGHT)           |
| W4772 | C | ZS 151507  | SECURITY SWITCH ZS 1515.07 (LEFT)            |
| W4772 | D | PSL 151503 | LOW PRES. CHAIN TENSION (B305) PSL 1515.03   |
| W4772 | E | LSL 151502 | LOW LEVEL CHAIN TENSION (B302) LSL 1515.02   |
| W4772 | F | PESTD0     | PROCESS STOP TDO                             |
|       |   |            |                                              |
| W4773 | 0 | FSL 183106 | CORONA #1 OZONE EXHAUST FLOW LOW FSL 1831.06 |
| W4773 | 1 | FSL 183107 | CORONA #2 OZONE EXHAUST FLOW LOW FSL 1831.07 |
| W4773 | 2 | SPL 182009 | CORONA ELECTRODE #1 LOW PRESSURE PSL 1820.09 |
| W4773 | 3 | PSL 182019 | CORONA ELECTRODE #2 LOW PRESSURE PSL 1820.19 |
| W4773 | 4 | PSL 182014 | CORONA ELECTRODE #3 LOW PRESSURE PSL 1820.14 |
| W4773 | 5 | CO1ENG     | CORONA ELECTRODE #1 ENGAGED                  |

|       |   |            |                                                   |
|-------|---|------------|---------------------------------------------------|
| W4773 | 6 | CO2ENG     | CORONA ELECTRODE #2 ENGAGED                       |
| W4773 | 7 | CO3ENG     | CORONA ELECTRODE #3 ENGAGED                       |
| W4773 | 8 |            |                                                   |
| W4773 | 9 |            |                                                   |
| W4773 | A | SPR1ENG    | SPREADER ROLL #1 ENGAGED, SV 1840.01              |
| W4773 | B | SPR2ENG    | SPREADER ROLL #2 ENGAGED, SV 1840.03              |
| W4773 | C | SPR3ENG    | SPREADER ROLL #3 ENGAGED, SV 1840.05              |
| W4773 | D | BYPASSPRS  | PRS BYPASS                                        |
| W4773 | E | ZTPRS      | PRS WEB BREAKER ZT 1840.10                        |
| W4773 | F | PESPRS     | PRS PROCESS STOP                                  |
|       |   |            |                                                   |
| W4774 | 0 | OPKNIENG   | PRS RIGHT KNIFE (ENGAGE) SV 1850.03               |
| W4774 | 1 | DRIKNIENG  | PRS LEFT KNIFE (ENGAGE) SV 1850.04                |
| W4774 | 2 | OPROLLENG  | LEFT NIP ROLL (ENGAGE) SV 1850.01                 |
| W4774 | 3 | DRIROLLENG | RIGHT NIP ROLL (ENGAGE) SV 1850.02                |
| W4774 | 4 | AUX3ENG    | PRS AUX. WINDER 3 (ENGAGE) SV 1860.01.02          |
| W4774 | 5 | GE1R       | PRS GENERATOR 1 (G1820.01) RUNNING                |
| W4774 | 6 | GE1F       | PRS GENERATOR 1 (G1820.01) FAULT                  |
| W4774 | 7 | GE2R       | PRS GENERATOR 2 (G1820.02) RUNNING                |
| W4774 | 8 | GE2F       | PRS GENERATOR 2 (G1820.02) FAULT                  |
| W4774 | 9 | GE3R       | PRS GENERATOR 3 (G1820.03) RUNNING                |
| W4774 | A | GE3F       | PRS GENERATOR 3 (G1820.03) FAULT                  |
| W4774 | B | GE4R       | PRS GENERATOR 4 (G1820.04) RUNNING                |
| W4774 | C | GE4F       | PRS GENERATOR 4 (G1820.04) FAULT                  |
| W4774 | D | FSL 183108 | CORONA #3 OZONE EXHAUST FLOW LOW FSL 1831.03      |
| W4774 | E | TSHAUX3    | PRS AUX WINDER 3 HIGH TEMP. ALARM                 |
| W4774 | F |            |                                                   |
|       |   |            |                                                   |
| W4775 | 0 | ROLL6CPENG | ROLL 6 (NIP #1) CORONA PROXIMITY (ENG) SV 1820.20 |
| W4775 | 1 | ROLL8CPENG | ROLL 8 (NIP #3) CORONA PROXIMITY (ENG) SV 1820.15 |
| W4775 | 2 |            |                                                   |
| W4775 | 3 | ROTCR      | CHILL ROLL ROTATION                               |
| W4775 | 4 | ROTMDO     | ROTATION MDO SLOW                                 |
| W4775 | 5 | ROTMDO     | ROTATION MDO FAST1                                |
| W4775 | 6 | ROTMDOF    | ROTATION MDO FAST2                                |
| W4775 | 7 | ROTTDO     | ROTATION TDO                                      |
| W4775 | 8 |            |                                                   |
| W4775 | 9 | BINCTDO    | TDO IN TEMPERATURE AUTOMATIC CONTROL              |
| W4775 | A | SPR2ENG    | SPREADER ROLL1 ENGAGED, SV 1840.02                |
| W4775 | B | SPR4ENG    | SPREADER ROLL2 ENGAGED, SV 1840.04                |
| W4775 | C | SPR6ENG    | SPREADER ROLL3 ENGAGED, SV 1840.06                |
| W4775 | D |            |                                                   |
| W4775 | E |            |                                                   |
| W4775 | F |            |                                                   |
|       |   |            |                                                   |
| W4776 | 0 | FACR       | FAULT VIEW CHILL ROLL                             |
| W4776 | 1 | FAMDO1     | FAULT VIEW MDO 1                                  |
| W4776 | 2 | FAMDO2     | FAULT VIEW MDO 2                                  |
| W4776 | 3 | FATDO1     | FAULT VIEW TDO 1                                  |
| W4776 | 4 | FATDO2     | FAULT VIEW TDO 2                                  |
| W4776 | 5 | FATDO3     | FAULT VIEW TDO 3                                  |
| W4776 | 6 | FATDO4     | FAULT VIEW TDO 4                                  |

|       |   |           |                                      |
|-------|---|-----------|--------------------------------------|
| W4776 | 7 | FAPRS     | FAULT VIEW PRS                       |
| W4776 | 8 |           |                                      |
| W4776 | 9 | GES       | GENERAL EMERGENCY STOP OF THE LINE   |
| W4776 | A | CRLEG     | ONE EQUIPMENT RUNNING ON CHILL ROLL  |
| W4776 | B | MDOLEQ    | ONE EQUIPMENT RUNNING ON MDO         |
| W4776 | C | TDOLEQ    | ONE EQUIPMENT RUNNING ON TDO         |
| W4776 | D | CRALEQ    | ALL EQUIPMENT RUNNING ON CHILL ROLL  |
| W4776 | E | MDOALLEQ  | ALL EQUIPMENT RUNNING ON MDO         |
| W4776 | F | TDOALLEQ  | ALL EQUIPMENT RUNNING ON TDO         |
|       |   |           |                                      |
| W4777 | 0 | CRT       | TEMPERATURE H+, L- CHILL ROLL        |
| W4777 | 1 | MDOT      | TEMPERATURE H+, L- MDO               |
| W4777 | 2 | TDOT      | TEMPERATURE H+, L- TDO               |
| W4777 | 3 |           |                                      |
| W4777 | 4 | TDO1BUR   | ONE BURNER "ON" ON TDO               |
| W4777 | 5 | TDOALLBUR | ALL BURNER "ON" ON TDO               |
| W4777 | 6 |           |                                      |
| W4777 | 7 |           | SELECT SWITCH "> 60 MICRO FOR SCREEN |
| W4777 | 8 |           |                                      |
| W4777 | 9 |           |                                      |
| W4777 | A |           |                                      |
| W4777 | B |           |                                      |
| W4777 | C |           |                                      |
| W4777 | D |           |                                      |
| W4777 | E |           |                                      |
| W4777 | F |           |                                      |
|       |   |           |                                      |
| W4778 | 0 | CRI       | INTERLOCK CHILL ROLL                 |
| W4778 | 1 | MDO1I     | INTERLOCK MDO 1                      |
| W4778 | 2 | MDO2I     | INTERLOCK MDO 2                      |
| W4778 | 3 | MDO3I     | INTERLOCK MDO 3                      |
| W4778 | 4 | TDOI      | INTERLOCK TDO                        |
| W4778 | 5 | PRS1I     | INTERLOCK PRS 1                      |
| W4778 | 6 | PRS2I     | INTERLOCK PRS 2                      |
| W4778 | 7 |           |                                      |
| W4778 | 8 |           |                                      |
| W4778 | 9 |           |                                      |
| W4778 | A |           |                                      |
| W4778 | B |           |                                      |
| W4778 | C |           |                                      |
| W4778 | D |           |                                      |
| W4778 | E |           |                                      |
| W4778 | F |           |                                      |
|       |   |           |                                      |
| W4779 | 0 |           |                                      |
| W4779 | 1 |           |                                      |
| W4779 | 2 |           |                                      |
| W4779 | 3 |           |                                      |
| W4779 | 4 |           |                                      |
| W4779 | 5 |           |                                      |
| W4779 | 6 |           |                                      |
| W4779 | 7 |           |                                      |

|       |   |          |                                              |
|-------|---|----------|----------------------------------------------|
| W4779 | 8 |          |                                              |
| W4779 | 9 |          |                                              |
| W4779 | A |          |                                              |
| W4779 | B |          |                                              |
| W4779 | C |          |                                              |
| W4779 | D |          |                                              |
| W4779 | E |          |                                              |
| W4779 | F |          |                                              |
|       |   |          |                                              |
| W4780 | 0 |          |                                              |
| W4780 | 1 | INTE225  | INTERLOCK BURNER 1 ZONE 1 M 1450.01 (E225)   |
| W4780 | 2 | INTE226  | INTERLOCK BURNER 2 ZONE 2 M 1450.02 (E226)   |
| W4780 | 3 | INTE227  | INTERLOCK BURNER 3 ZONE 3 M 1450.03 (E227)   |
| W4780 | 4 | INTE228  | INTERLOCK BURNER 4 ZONE 4 M 1450.04 (E228)   |
| W4780 | 5 | INTE229  | INTERLOCK BURNER 5 ZONE 5 M 1450.05 (E229)   |
| W4780 | 6 | INTE230  | INTERLOCK BURNER 6 ZONE 6 M 1450.06 (E230)   |
| W4780 | 7 | INTE231  | INTERLOCK BURNER 7 ZONE 7 M 1450.07 (E231)   |
| W4780 | 8 | INTE232  | INTERLOCK BURNER 8 ZONE 8 M 1450.08 (E232)   |
| W4780 | 9 | INTE233  | INTERLOCK BURNER 9 ZONE 9 M 1450.09 (E233)   |
| W4780 | A | INTE234  | INTERLOCK BURNER 10 ZONE 10 M 1450.10 (E234) |
| W4780 | B | INTE235  | INTERLOCK BURNER 11 ZONE 11 M 1450.11 (E235) |
| W4780 | C | INTE236  | INTERLOCK BURNER 12 ZONE 12 M 1450.12 (E236) |
| W4780 | D | INTE237  | INTERLOCK BURNER 13 ZONE 13 M 1450.13 (E237) |
| W4780 | E | INTE238  | INTERLOCK BURNER 14 ZONE 14 M 1450.14 (E238) |
| W4780 | F | INTE239  | INTERLOCK BURNER 15 ZONE 15 M 1450.15 (E239) |
|       |   |          |                                              |
| W4781 | 0 | INTE240  | INTERLOCK BURNER 16 ZONE 16 M 1450.16 (E240) |
| W4781 | 1 | INTE241  | INTERLOCK BURNER 17 ZONE 17 M 1450.17 (E241) |
| W4781 | 2 | INTE242  | INTERLOCK BURNER 18 ZONE 18 M 1450.18 (E242) |
| W4781 | 3 | INTE243  | INTERLOCK BURNER 19 ZONE 19 M 1450.19 (E243) |
| W4781 | 4 | INTE244  | INTERLOCK BURNER 20 ZONE 20 M 1450.20 (E244) |
| W4781 | 5 |          |                                              |
| W4781 | 6 |          |                                              |
| W4781 | 7 |          |                                              |
| W4781 | 8 |          |                                              |
| W4781 | 9 |          |                                              |
| W4781 | A |          |                                              |
| W4781 | B |          |                                              |
| W4781 | C |          |                                              |
| W4781 | D |          |                                              |
| W4781 | E |          |                                              |
| W4781 | F |          |                                              |
|       |   |          |                                              |
| W4785 | 0 | DIAM+0   | AUTO/MANU R365                               |
| W4785 | 1 | DILO+0   | LOCKED                                       |
| W4785 | 2 | DIAC+0   | ALARM H+, L-                                 |
| W4785 | 3 | DIAHR365 | ALARM H                                      |
| W4785 | 4 | DIAL+0   | ALARM L                                      |
| W4785 | 5 | DIDER365 | DEFECT MEASURE                               |
| W4785 | 6 | DIA+0    | ALL ALARM                                    |
| W4785 | 7 |          |                                              |
| W4785 | 8 | DIAM+8   | AUTO/MANU R366                               |

|       |   |          |                |
|-------|---|----------|----------------|
| W4785 | 9 | DILO+8   | LOCKED         |
| W4785 | A | DIAC+8   | ALARM H+, L-   |
| W4785 | B | DIAHR366 | ALARM H        |
| W4785 | C | DIAL+8   | ALARM L        |
| W4785 | D | DIDER366 | DEFECT MEASURE |
| W4785 | E | DIA+8    | ALL ALARM      |
| W4785 | F |          |                |
|       |   |          |                |
| W4786 | 0 |          |                |
| W4786 | 1 |          |                |
| W4786 | 2 |          |                |
| W4786 | 3 |          |                |
| W4786 | 4 |          |                |
| W4786 | 5 |          |                |
| W4786 | 6 |          |                |
| W4786 | 7 |          |                |
| W4786 | 8 |          |                |
| W4786 | 9 |          |                |
| W4786 | A |          |                |
| W4786 | B |          |                |
| W4786 | C |          |                |
| W4786 | D |          |                |
| W4786 | E |          |                |
| W4786 | F |          |                |
|       |   |          |                |
| W4787 | 0 |          |                |
| W4787 | 1 |          |                |
| W4787 | 2 |          |                |
| W4787 | 3 |          |                |
| W4787 | 4 |          |                |
| W4787 | 5 |          |                |
| W4787 | 6 |          |                |
| W4787 | 7 |          |                |
| W4787 | 8 |          |                |
| W4787 | 9 |          |                |
| W4787 | A |          |                |
| W4787 | B |          |                |
| W4787 | C |          |                |
| W4787 | D |          |                |
| W4787 | E |          |                |
| W4787 | F |          |                |
|       |   |          |                |
| W4788 | 0 |          |                |
| W4788 | 1 |          |                |
| W4788 | 2 |          |                |
| W4788 | 3 |          |                |
| W4788 | 4 |          |                |
| W4788 | 5 |          |                |
| W4788 | 6 |          |                |
| W4788 | 7 |          |                |
| W4788 | 8 |          |                |
| W4788 | 9 |          |                |



|       |   |          |                |
|-------|---|----------|----------------|
| W4788 | A |          |                |
| W4788 | B |          |                |
| W4788 | C |          |                |
| W4788 | D |          |                |
| W4788 | E |          |                |
| W4788 | F |          |                |
|       |   |          |                |
| W4789 | 0 | DIAM+64  | AUTO/MANU R370 |
| W4789 | 1 | DILO+64  | LOCKED         |
| W4789 | 2 | DIAC+64  | ALARM H+, L-   |
| W4789 | 3 | DIAHR370 | ALARM H        |
| W4789 | 4 | DIAL+64  | ALARM L        |
| W4789 | 5 | DIDER370 | DEFECT MEASURE |
| W4789 | 6 | DIA+72   | ALL ALARM      |
| W4789 | 7 |          |                |
| W4789 | 8 | DIAM+72  | AUTO/MANU R371 |
| W4789 | 9 | DILO+72  | LOCKED         |
| W4789 | A | DIAC+72  | ALARM H+, L-   |
| W4789 | B | DIAHR371 | ALARM H        |
| W4789 | C | DIAL+72  | ALARM L        |
| W4789 | D | DIDER371 | DEFECT MEASURE |
| W4789 | E | DIA+72   | ALL ALARM      |
| W4789 | F |          |                |
|       |   |          |                |
| W4790 | 0 | DIAM+80  | AUTO/MANU R372 |
| W4790 | 1 | DILO+80  | LOCKED         |
| W4790 | 2 | DIAC+80  | ALARM H+, L-   |
| W4790 | 3 | DIAHR372 | ALARM H        |
| W4790 | 4 | DIAL+80  | ALARM L        |
| W4790 | 5 | DIDER372 | DEFECT MEASURE |
| W4790 | 6 | DIA+80   | ALL ALARM      |
| W4790 | 7 |          |                |
| W4790 | 8 | DIAM+88  | AUTO/MANU R373 |
| W4790 | 9 | DILO+88  | LOCKED         |
| W4790 | A | DIAC+88  | ALARM H+, L-   |
| W4790 | B | DIAHR373 | ALARM H        |
| W4790 | C | DIAL+88  | ALARM L        |
| W4790 | D | DIDER373 | DEFECT MEASURE |
| W4790 | E | DIA+88   | ALL ALARM      |
| W4790 | F |          |                |
|       |   |          |                |
| W4791 | 0 | DIAM+96  | AUTO/MANU R374 |
| W4791 | 1 | DILO+96  | LOCKED         |
| W4791 | 2 | DIAC+96  | ALARM H+, L-   |
| W4791 | 3 | DIAHR374 | ALARM H        |
| W4791 | 4 | DIAL+96  | ALARM L        |
| W4791 | 5 | DIDER374 | DEFECT MEASURE |
| W4791 | 6 | DIA+96   | ALL ALARM      |
| W4791 | 7 |          |                |
| W4791 | 8 | DIAM+96  | AUTO/MANU R375 |
| W4791 | 9 | DILO+96  | LOCKED         |
| W4791 | A | DIAC+96  | ALARM H+, L-   |

|       |   |          |                |
|-------|---|----------|----------------|
| W4791 | B | DIAHR375 | ALARM H        |
| W4791 | C | DIAL+96  | ALARM L        |
| W4791 | D | DIDER375 | DEFECT MEASURE |
| W4791 | E | DIA+96   | ALL ALARM      |
| W4791 | F |          |                |
|       |   |          |                |
| W4792 | 0 | DIAM+104 | AUTO/MANU R376 |
| W4792 | 1 | DILO+104 | LOCKED         |
| W4792 | 2 | DIAC+104 | ALARM H+, L-   |
| W4792 | 3 | DIAHR376 | ALARM H        |
| W4792 | 4 | DIAL+104 | ALARM L        |
| W4792 | 5 | DIDER376 | DEFECT MEASURE |
| W4792 | 6 | DIA+104  | ALL ALARM      |
| W4792 | 7 |          |                |
| W4792 | 8 | DIAM+112 | AUTO/MANU R377 |
| W4792 | 9 | DILO+112 | LOCKED         |
| W4792 | A | DIAC+112 | ALARM H+, L-   |
| W4792 | B | DIAHR377 | ALARM H        |
| W4792 | C | DIAL+112 | ALARM L        |
| W4792 | D | DIDER377 | DEFECT MEASURE |
| W4792 | E | DIA+112  | ALL ALARM      |
| W4792 | F |          |                |
|       |   |          |                |
| W4793 | 0 | DIAM+128 | AUTO/MANU R378 |
| W4793 | 1 | DILO+128 | LOCKED         |
| W4793 | 2 | DIAC+128 | ALARM H+, L-   |
| W4793 | 3 | DIAHR378 | ALARM H        |
| W4793 | 4 | DIAL+128 | ALARM L        |
| W4793 | 5 | DIDER378 | DEFECT MEASURE |
| W4793 | 6 | DIA+128  | ALL ALARM      |
| W4793 | 7 |          |                |
| W4793 | 8 | DIAM+136 | AUTO/MANU R379 |
| W4793 | 9 | DILO+136 | LOCKED         |
| W4793 | A | DIAC+136 | ALARM H+, L-   |
| W4793 | B | DIAHR379 | ALARM H        |
| W4793 | C | DIAL+136 | ALARM L        |
| W4793 | D | DIDER379 | DEFECT MEASURE |
| W4793 | E | DIA+136  | ALL ALARM      |
| W4793 | F |          |                |
|       |   |          |                |
| W4794 | 0 | DIAM+144 | AUTO/MANU R380 |
| W4794 | 1 | DILO+144 | LOCKED         |
| W4794 | 2 | DIAC+144 | ALARM H+, L-   |
| W4794 | 3 | DIAHR380 | ALARM H        |
| W4794 | 4 | DIAL+144 | ALARM L        |
| W4794 | 5 | DIDER380 | DEFECT MEASURE |
| W4794 | 6 | DIA+144  | ALL ALARM      |
| W4794 | 7 |          |                |
| W4794 | 8 | DIAM+152 | AUTO/MANU R381 |
| W4794 | 9 | DILO+152 | LOCKED         |
| W4794 | A | DIAC+152 | ALARM H+, L-   |
| W4794 | B | DIAHR381 | ALARM H        |

|       |   |          |                |
|-------|---|----------|----------------|
| W4794 | C | DIAL+152 | ALARM L        |
| W4794 | D | DIDER381 | DEFECT MEASURE |
| W4794 | E | DIA+152  | ALL ALARM      |
| W4794 | F |          |                |
|       |   |          |                |
| W4795 | 0 |          |                |
| W4795 | 1 |          |                |
| W4795 | 2 |          |                |
| W4795 | 3 |          |                |
| W4795 | 4 |          |                |
| W4795 | 5 |          |                |
| W4795 | 6 |          |                |
| W4795 | 7 |          |                |
| W4795 | 8 |          |                |
| W4795 | 9 |          |                |
| W4795 | A |          |                |
| W4795 | B |          |                |
| W4795 | C |          |                |
| W4795 | D |          |                |
| W4795 | E |          |                |
| W4795 | F |          |                |
|       |   |          |                |
| W4796 | 0 |          |                |
| W4796 | 1 |          |                |
| W4796 | 2 |          |                |
| W4796 | 3 |          |                |
| W4796 | 4 |          |                |
| W4796 | 5 |          |                |
| W4796 | 6 |          |                |
| W4796 | 7 |          |                |
| W4796 | 8 | DIAM+184 | AUTO/MANU R385 |
| W4796 | 9 | DILO+184 | LOCKED         |
| W4796 | A | DIAC+184 | ALARM H+, L-   |
| W4796 | B | DIAHR385 | ALARM H        |
| W4796 | C | DIAL+184 | ALARM L        |
| W4796 | D | DIDER385 | DEFECT MEASURE |
| W4796 | E | DIA+184  | ALL ALARM      |
| W4796 | F |          |                |
|       |   |          |                |
| W4797 | 0 | DIAM+192 | AUTO/MANU R386 |
| W4797 | 1 | DILO+192 | LOCKED         |
| W4797 | 2 | DIAC+192 | ALARM H+, L-   |
| W4797 | 3 | DIAHR386 | ALARM H        |
| W4797 | 4 | DIAL+192 | ALARM L        |
| W4797 | 5 | DIDER386 | DEFECT MEASURE |
| W4797 | 6 | DIA+192  | ALL ALARM      |
| W4797 | 7 |          |                |
| W4797 | 8 | DIAM+200 | AUTO/MANU R387 |
| W4797 | 9 | DILO+200 | LOCKED         |
| W4797 | A | DIAC+200 | ALARM H+, L-   |
| W4797 | B | DIAHR387 | ALARM H        |
| W4797 | C | DIAL+200 | ALARM L        |

|       |   |          |                |
|-------|---|----------|----------------|
| W4797 | D | DIDER387 | DEFECT MEASURE |
| W4797 | E | DIA+200  | ALL ALARM      |
| W4797 | F |          |                |
|       |   |          |                |
| W4798 | 0 | DIAM+208 | AUTO/MANU R388 |
| W4798 | 1 | DILO+208 | LOCKED         |
| W4798 | 2 | DIAC+208 | ALARM H+, L-   |
| W4798 | 3 | DIAHR388 | ALARM H        |
| W4798 | 4 | DIAL+208 | ALARM L        |
| W4798 | 5 | DIDER388 | DEFECT MEASURE |
| W4798 | 6 | DIA+208  | ALL ALARM      |
| W4798 | 7 |          |                |
| W4798 | 8 | DIAM+216 | AUTO/MANU R389 |
| W4798 | 9 | DILO+216 | LOCKED         |
| W4798 | A | DIAC+216 | ALARM H+, L-   |
| W4798 | B | DIAHR389 | ALARM H        |
| W4798 | C | DIAL+216 | ALARM L        |
| W4798 | D | DIDER389 | DEFECT MEASURE |
| W4798 | E | DIA+216  | ALL ALARM      |
| W4798 | F |          |                |
|       |   |          |                |
| W4799 | 0 | DIAM+224 | AUTO/MANU R390 |
| W4799 | 1 | DILO+224 | LOCKED         |
| W4799 | 2 | DIAC+224 | ALARM H+, L-   |
| W4799 | 3 | DIAHR390 | ALARM H        |
| W4799 | 4 | DIAL+224 | ALARM L        |
| W4799 | 5 | DIDER390 | DEFECT MEASURE |
| W4799 | 6 | DIA+224  | ALL ALARM      |
| W4799 | 7 |          |                |
| W4799 | 8 | DIAM+232 | AUTO/MANU R391 |
| W4799 | 9 | DILO+232 | LOCKED         |
| W4799 | A | DIAC+232 | ALARM H+, L-   |
| W4799 | B | DIAHR391 | ALARM H        |
| W4799 | C | DIAL+232 | ALARM L        |
| W4799 | D | DIDER391 | DEFECT MEASURE |
| W4799 | E | DIA+232  | ALL ALARM      |
| W4799 | F |          |                |
|       |   |          |                |
| W4800 | 0 | DIAM+240 | AUTO/MANU R392 |
| W4800 | 1 | DILO+240 | LOCKED         |
| W4800 | 2 | DIAC+240 | ALARM H+, L-   |
| W4800 | 3 | DIAHR392 | ALARM H        |
| W4800 | 4 | DIAL+240 | ALARM L        |
| W4800 | 5 | DIDER392 | DEFECT MEASURE |
| W4800 | 6 | DIA+240  | ALL ALARM      |
| W4800 | 7 |          |                |
| W4800 | 8 | DIAM+248 | AUTO/MANU R393 |
| W4800 | 9 | DILO+248 | LOCKED         |
| W4800 | A | DIAC+248 | ALARM H+, L-   |
| W4800 | B | DIAHR393 | ALARM H        |
| W4800 | C | DIAL+248 | ALARM L        |
| W4800 | D | DIDER393 | DEFECT MEASURE |

|       |   |          |                |
|-------|---|----------|----------------|
| W4800 | E | DIA+248  | ALL ALARM      |
| W4800 | F |          |                |
|       |   |          |                |
| W4801 | 0 | DIAM+256 | AUTO/MANU R394 |
| W4801 | 1 | DILO+256 | LOCKED         |
| W4801 | 2 | DIAC+256 | ALARM H+, L-   |
| W4801 | 3 | DIAHR394 | ALARM H        |
| W4801 | 4 | DIAL+256 | ALARM L        |
| W4801 | 5 | DIDER394 | DEFECT MEASURE |
| W4801 | 6 | DIA+256  | ALL ALARM      |
| W4801 | 7 |          |                |
| W4801 | 8 | DIAM+264 | AUTO/MANU R395 |
| W4801 | 9 | DILO+264 | LOCKED         |
| W4801 | A | DIAC+264 | ALARM H+, L-   |
| W4801 | B | DIAHR395 | ALARM H        |
| W4801 | C | DIAL+264 | ALARM L        |
| W4801 | D | DIDER395 | DEFECT MEASURE |
| W4801 | E | DIA+264  | ALL ALARM      |
| W4801 | F |          |                |
|       |   |          |                |
| W4802 | 0 | DIAM+272 | AUTO/MANU R396 |
| W4802 | 1 | DILO+272 | LOCKED         |
| W4802 | 2 | DIAC+272 | ALARM H+, L-   |
| W4802 | 3 | DIAHR396 | ALARM H        |
| W4802 | 4 | DIAL+272 | ALARM L        |
| W4802 | 5 | DIDER396 | DEFECT MEASURE |
| W4802 | 6 | DIA+272  | ALL ALARM      |
| W4802 | 7 |          |                |
| W4802 | 8 | DIAM+280 | AUTO/MANU R397 |
| W4802 | 9 | DILO+280 | LOCKED         |
| W4802 | A | DIAC+280 | ALARM H+, L-   |
| W4802 | B | DIAHR397 | ALARM H        |
| W4802 | C | DIAL+280 | ALARM L        |
| W4802 | D | DIDER397 | DEFECT MEASURE |
| W4802 | E | DIA+280  | ALL ALARM      |
| W4802 | F |          |                |
|       |   |          |                |
| W4803 | 0 | DIAM+288 | AUTO/MANU R398 |
| W4803 | 1 | DILO+288 | LOCKED         |
| W4803 | 2 | DIAC+288 | ALARM H+, L-   |
| W4803 | 3 | DIAHR398 | ALARM H        |
| W4803 | 4 | DIAL+288 | ALARM L        |
| W4803 | 5 | DIDER398 | DEFECT MEASURE |
| W4803 | 6 | DIA+288  | ALL ALARM      |
| W4803 | 7 |          |                |
| W4803 | 8 | DIAM+296 | AUTO/MANU R399 |
| W4803 | 9 | DILO+296 | LOCKED         |
| W4803 | A | DIAC+296 | ALARM H+, L-   |
| W4803 | B | DIAHR399 | ALARM H        |
| W4803 | C | DIAL+296 | ALARM L        |
| W4803 | D | DIDER399 | DEFECT MEASURE |
| W4803 | E | DIA+296  | ALL ALARM      |

|       |   |          |                |
|-------|---|----------|----------------|
| W4803 | F |          |                |
|       |   |          |                |
| W4804 | 0 | DIAM+304 | AUTO/MANU R400 |
| W4804 | 1 | DILO+304 | LOCKED         |
| W4804 | 2 | DIAC+304 | ALARM H+, L-   |
| W4804 | 3 | DIAHR400 | ALARM H        |
| W4804 | 4 | DIAL+304 | ALARM L        |
| W4804 | 5 | DIDER400 | DEFECT MEASURE |
| W4804 | 6 | DIA+304  | ALL ALARM      |
| W4804 | 7 |          |                |
| W4804 | 8 | DIAM+312 | AUTO/MANU R401 |
| W4804 | 9 | DILO+312 | LOCKED         |
| W4804 | A | DIAC+312 | ALARM H+, L-   |
| W4804 | B | DIAHR401 | ALARM H        |
| W4804 | C | DIAL+312 | ALARM L        |
| W4804 | D | DIDER401 | DEFECT MEASURE |
| W4804 | E | DIA+312  | ALL ALARM      |
| W4804 | F |          |                |
|       |   |          |                |
| W4805 | 0 | DIAM+320 | AUTO/MANU R402 |
| W4805 | 1 | DILO+320 | LOCKED         |
| W4805 | 2 | DIAC+320 | ALARM H+, L-   |
| W4805 | 3 | DIAHR402 | ALARM H        |
| W4805 | 4 | DIAL+320 | ALARM L        |
| W4805 | 5 | DIDER402 | DEFECT MEASURE |
| W4805 | 6 | DIA+320  | ALL ALARM      |
| W4805 | 7 |          |                |
| W4805 | 8 | DIAM+328 | AUTO/MANU R403 |
| W4805 | 9 | DILO+328 | LOCKED         |
| W4805 | A | DIAC+328 | ALARM H+, L-   |
| W4805 | B | DIAHR403 | ALARM H        |
| W4805 | C | DIAL+328 | ALARM L        |
| W4805 | D | DIDER403 | DEFECT MEASURE |
| W4805 | E | DIA+328  | ALL ALARM      |
| W4805 | F |          |                |
|       |   |          |                |
| W4806 | 0 | DIAM+336 | AUTO/MANU R404 |
| W4806 | 1 | DILO+336 | LOCKED         |
| W4806 | 2 | DIAC+336 | ALARM H+, L-   |
| W4806 | 3 | DIAHR404 | ALARM H        |
| W4806 | 4 | DIAL+336 | ALARM L        |
| W4806 | 5 | DIDER404 | DEFECT MEASURE |
| W4806 | 6 | DIA+336  | ALL ALARM      |
| W4806 | 7 |          |                |
| W4806 | 8 |          |                |
| W4806 | 9 |          |                |
| W4806 | A |          |                |
| W4806 | B |          |                |
| W4806 | C |          |                |
| W4806 | D |          |                |
| W4806 | E |          |                |
| W4806 | F |          |                |

|         |  |  |
|---------|--|--|
|         |  |  |
| W4807 0 |  |  |
| W4807 1 |  |  |
| W4807 2 |  |  |
| W4807 3 |  |  |
| W4807 4 |  |  |
| W4807 5 |  |  |
| W4807 6 |  |  |
| W4807 7 |  |  |
| W4807 8 |  |  |
| W4807 9 |  |  |
| W4807 A |  |  |
| W4807 B |  |  |
| W4807 C |  |  |
| W4807 D |  |  |
| W4807 E |  |  |
| W4807 F |  |  |
|         |  |  |
| W4808 0 |  |  |
| W4808 1 |  |  |
| W4808 2 |  |  |
| W4808 3 |  |  |
| W4808 4 |  |  |
| W4808 5 |  |  |
| W4808 6 |  |  |
| W4808 7 |  |  |
| W4808 8 |  |  |
| W4808 9 |  |  |
| W4808 A |  |  |
| W4808 B |  |  |
| W4808 C |  |  |
| W4808 D |  |  |
| W4808 E |  |  |
| W4808 F |  |  |

|          |                                 |
|----------|---------------------------------|
| W9000    | COPY FROM W4760, SEE "WORD BIT" |
| W9001    | COPY FROM W4761, SEE "WORD BIT" |
| W9002    | COPY FROM W4762, SEE "WORD BIT" |
| W9003    | COPY FROM W4763, SEE "WORD BIT" |
| W9004    | COPY FROM W4764, SEE "WORD BIT" |
| W9005    | COPY FROM W4765, SEE "WORD BIT" |
| W9006    | COPY FROM W4766, SEE "WORD BIT" |
| W9007    | COPY FROM W4767, SEE "WORD BIT" |
| W9008, 0 | COPY FROM W4785, 3              |
| W9008, 1 | COPY FROM W4785, 5              |
| W9008, 2 | COPY FROM W4785, B              |
| W9008, 3 | COPY FROM W4785, D              |
| W9008, 4 | COPY FROM W4789, 3              |
| W9008, 5 | COPY FROM W4789, 5              |
| W9008, 6 | COPY FROM W4789, B              |
| W9008, 7 | COPY FROM W4789, D              |
| W9008, 8 | COPY FROM W4790, 3              |
| W9008, 9 | COPY FROM W4790, 5              |
| W9008, A | COPY FROM W4790, B              |
| W9008, B | COPY FROM W4790, D              |
| W9008, C | COPY FROM W4791, 3              |
| W9008, D | COPY FROM W4791, 5              |
| W9008, E | COPY FROM W4791, B              |
| W9008, F | COPY FROM W4791, D              |
| W9009, 0 | COPY FROM W4792, 3              |
| W9009, 1 | COPY FROM W4792, 5              |
| W9009, 2 | COPY FROM W4792, B              |
| W9009, 3 | COPY FROM W4792, D              |
| W9009, 4 | COPY FROM W4793, 3              |
| W9009, 5 | COPY FROM W4793, 5              |
| W9009, 6 | COPY FROM W4793, B              |
| W9009, 7 | COPY FROM W4793, D              |
| W9009, 8 | COPY FROM W4794, 3              |
| W9009, 9 | COPY FROM W4794, 5              |
| W9009, A | COPY FROM W4794, B              |
| W9009, B | COPY FROM W4794, D              |
| W9009, C |                                 |
| W9009, D |                                 |
| W9009, E | COPY FROM W4796, B              |
| W9009, F | COPY FROM W4796, D              |
| W9010, 0 | COPY FROM W4797, 3              |
| W9010, 1 | COPY FROM W4797, 5              |
| W9010, 2 | COPY FROM W4797, B              |
| W9010, 3 | COPY FROM W4797, D              |
| W9010, 4 | COPY FROM W4798, 3              |
| W9010, 5 | COPY FROM W4798, 5              |
| W9010, 6 | COPY FROM W4798, B              |
| W9010, 7 | COPY FROM W4798, D              |
| W9010, 8 | COPY FROM W4799, 3              |
| W9010, 9 | COPY FROM W4799, 5              |
| W9010, A | COPY FROM W4799, B              |
| W9010, B | COPY FROM W4799, D              |



|          |                    |
|----------|--------------------|
| W9010, C | COPY FROM W4800, 3 |
| W9010, D | COPY FROM W4800, 5 |
| W9010, E | COPY FROM W4800, B |
| W9010, F | COPY FROM W4800, D |
| W9011, 0 | COPY FROM W4801, 3 |
| W9011, 1 | COPY FROM W4801, 5 |
| W9011, 2 | COPY FROM W4801, B |
| W9011, 3 | COPY FROM W4801, D |
| W9011, 4 | COPY FROM W4802, 3 |
| W9011, 5 | COPY FROM W4802, 5 |
| W9011, 6 | COPY FROM W4802, B |
| W9011, 7 | COPY FROM W4802, D |
| W9011, 8 | COPY FROM W4803, 3 |
| W9011, 9 | COPY FROM W4803, 5 |
| W9011, A | COPY FROM W4803, B |
| W9011, B | COPY FROM W4803, D |
| W9011, C | COPY FROM W4804, 3 |
| W9011, D | COPY FROM W4804, 5 |
| W9011, E | COPY FROM W4804, B |
| W9011, F | COPY FROM W4804, D |
| W9012, 0 | COPY FROM W4805, 3 |
| W9012, 1 | COPY FROM W4805, 5 |
| W9012, 2 | COPY FROM W4805, B |
| W9012, 3 | COPY FROM W4805, C |
| W9012, 4 | COPY FROM W4806, 3 |
| W9012, 5 | COPY FROM W4806, 4 |
| W9012, 6 |                    |
| W9012, 7 |                    |
| W9012, 8 |                    |
| W9012, 9 |                    |
| W9012, A |                    |
| W9012, B |                    |
| W9012, C |                    |
| W9012, D |                    |
| W9012, E |                    |
| W9012, F |                    |
| W9013, 0 | COPY FROM B235     |
| W9013, 1 | COPY FROM W4770, A |
| W9013, 2 | COPY FROM W4771, D |
| W9013, 3 | COPY FROM B285     |
| W9013, 4 | COPY FROM W4772, 8 |
| W9013, 5 | COPY FROM W4772, 9 |
| W9013, 6 | COPY FROM W4772, B |
| W9013, 7 | COPY FROM W4772, C |
| W9013, 8 | COPY FROM B305     |
| W9013, 9 | COPY FROM B302     |
| W9013, A | COPY FROM B366     |
| W9013, B | COPY FROM B410     |
| W9013, C | COPY FROM B369     |
| W9013, D | COPY FROM B372     |
| W9013, E | COPY FROM B375     |
| W9013, F | COPY FROM B378     |

|          |                                       |
|----------|---------------------------------------|
| W9014, 0 | COPY FROM W4773, E                    |
| W9014, 1 | COPY FROM W4774, 6                    |
| W9014, 2 | COPY FROM W4774, 8                    |
| W9014, 3 | COPY FROM W4774, A                    |
| W9014, 4 | COPY FROM W4774, C                    |
| W9014, 5 | COPY FROM W4774, D                    |
| W9014, 6 | COPY FROM W4774, E                    |
| W9014, 7 |                                       |
| W9014, 8 |                                       |
| W9014, 9 |                                       |
| W9014, A |                                       |
| W9014, B |                                       |
| W9014, C |                                       |
| W9014, D |                                       |
| W9014, E |                                       |
| W9014, F |                                       |
| W9015, 0 | COPY FROM W4770, F                    |
| W9015, 1 | COPY FROM W4771, F                    |
| W9015, 2 | COPY FROM W4772, F                    |
| W9015, 3 | COPY FROM W4773, F                    |
| W9015, 4 |                                       |
| W9015, 5 |                                       |
| W9015, 6 |                                       |
| W9015, 7 |                                       |
| W9015, 8 |                                       |
| W9015, 9 |                                       |
| W9015, A |                                       |
| W9015, B |                                       |
| W9015, C |                                       |
| W9015, D |                                       |
| W9015, E |                                       |
| W9015, F |                                       |
| W9016    | COPY FROM W4421 (ALL DEFECT DC MOTOR) |
| W9017, 0 | COPY FROM B278                        |
| W9017, 1 | COPY FROM B312                        |
| W9017, 2 | COPY FROM B398                        |
| W9017, 3 |                                       |
| W9017, 4 |                                       |
| W9017, 5 |                                       |
| W9017, 6 |                                       |
| W9017, 7 |                                       |
| W9017, 8 |                                       |
| W9017, 9 |                                       |
| W9017, A |                                       |
| W9017, B |                                       |
| W9017, C |                                       |
| W9017, D |                                       |
| W9017, E |                                       |
| W9017, F |                                       |
| W9018    |                                       |
| W9019    |                                       |
| W9020    |                                       |

|              |                                         |
|--------------|-----------------------------------------|
| W9021        |                                         |
| W9022        |                                         |
| W9023        |                                         |
| W9024        |                                         |
| W9025        |                                         |
| W9026        |                                         |
| W9027        |                                         |
| W9028        |                                         |
| W9029        |                                         |
| W9030        |                                         |
| W9031        |                                         |
| W9032        |                                         |
| W9033        |                                         |
| W9034        |                                         |
| W9035        |                                         |
| W9036        |                                         |
| W9037        |                                         |
| W9038        |                                         |
| W9039        |                                         |
| W9040        |                                         |
| W9041        |                                         |
| W9042        |                                         |
| W9043        |                                         |
| W9044        |                                         |
| W9045        |                                         |
| W9046        |                                         |
| W9047        |                                         |
| W9048        |                                         |
| W9049        |                                         |
| W9050        | COPY FROM W9000                         |
| W9051        | COPY FROM W9001                         |
| W9052        | COPY FROM W9002                         |
| W9053        | COPY FROM W9003                         |
| W9054        | COPY FROM W9004                         |
| W9055        | COPY FROM W9005                         |
| W9056        | COPY FROM W9006                         |
| W9057        | COPY FROM W9007                         |
| W9058        | COPY FROM W9008                         |
| W9059        | COPY FROM W9009                         |
| W9060        | COPY FROM W9010                         |
| W9061        | COPY FROM W9011                         |
| W9062        | COPY FROM W9012                         |
| W9063        | COPY FROM W9013                         |
| W9064        | COPY FROM W9014                         |
| W9065        | COPY FROM W9015                         |
| W9066        | COPY FROM W9016                         |
| W9067        | COPY FROM W9017                         |
| W9068        |                                         |
| W9069        |                                         |
| W9070 ~ 9499 | FREE                                    |
| W9500        | OFFSET POINT TDO ZONE 1 R385 (NOT USED) |

|       |                                                            |
|-------|------------------------------------------------------------|
| W9501 | OFFSET POINT TDO ZONE 2 R386 (NOT USED)                    |
| W9502 | OFFSET POINT TDO ZONE 3 R387 (NOT USED)                    |
| W9503 | OFFSET POINT TDO ZONE 4 R388 (NOT USED)                    |
| W9504 | OFFSET POINT TDO ZONE 5 R389 (NOT USED)                    |
| W9505 | OFFSET POINT TDO ZONE 6 R390 (NOT USED)                    |
| W9506 | OFFSET POINT TDO ZONE 7 R391 (NOT USED)                    |
| W9507 | OFFSET POINT TDO ZONE 8 R392 (NOT USED)                    |
| W9508 | OFFSET POINT TDO ZONE 9 R393 (NOT USED)                    |
| W9509 |                                                            |
| W9510 |                                                            |
| W9511 |                                                            |
| W9512 |                                                            |
| W9513 |                                                            |
| W9514 |                                                            |
| W9515 |                                                            |
| W9516 |                                                            |
| W9517 |                                                            |
| W9518 |                                                            |
| W9519 |                                                            |
| W9520 |                                                            |
| W9521 |                                                            |
| W9522 |                                                            |
| W9523 |                                                            |
| W9524 |                                                            |
| W9525 |                                                            |
| W9526 |                                                            |
| W9527 |                                                            |
| W9528 |                                                            |
| W9529 |                                                            |
| W9530 |                                                            |
| W9531 |                                                            |
| W9532 |                                                            |
| W9533 |                                                            |
| W9534 |                                                            |
| W9535 |                                                            |
| W9536 |                                                            |
| W9537 |                                                            |
| W9538 |                                                            |
| W9539 |                                                            |
| W9540 |                                                            |
| W9541 |                                                            |
| W9542 |                                                            |
| W9543 |                                                            |
| W9544 |                                                            |
| W9545 |                                                            |
| W9546 |                                                            |
| W9547 |                                                            |
| W9548 |                                                            |
| W9549 |                                                            |
| W9550 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 120 < SPEED <= 130 |
| W9551 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9552 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |

|       |                                                            |
|-------|------------------------------------------------------------|
| W9553 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9554 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9555 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9556 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9557 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9558 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9559 |                                                            |
| W9560 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 130 < SPEED <= 140 |
| W9561 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9562 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9563 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9564 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9565 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9566 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9567 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9568 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9569 |                                                            |
| W9570 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 140 < SPEED <= 150 |
| W9571 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9572 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9573 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9574 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9575 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9576 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9577 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9578 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9579 |                                                            |
| W9580 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 150 < SPEED <= 160 |
| W9581 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9582 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9583 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9584 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9585 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9586 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9587 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9588 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9589 |                                                            |
| W9590 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 160 < SPEED <= 170 |
| W9591 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9592 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9593 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9594 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9595 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9596 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9597 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9598 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9599 |                                                            |
| W9600 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 170 < SPEED <= 180 |
| W9601 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9602 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9603 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9604 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |

|       |                                                            |
|-------|------------------------------------------------------------|
| W9605 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9606 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9607 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9608 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9609 |                                                            |
| W9610 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 180 < SPEED <= 190 |
| W9611 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9612 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9613 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9614 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9615 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9616 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9617 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9618 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9619 |                                                            |
| W9620 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 190 < SPEED <= 200 |
| W9621 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9622 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9623 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9624 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9625 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9626 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9627 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9628 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9629 |                                                            |
| W9630 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 200 < SPEED <= 210 |
| W9631 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9632 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9633 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9634 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9635 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9636 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9637 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9638 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9639 |                                                            |
| W9640 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 210 < SPEED <= 220 |
| W9641 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9642 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9643 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9644 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9645 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9646 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9647 | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9648 | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9649 |                                                            |
| W9650 | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 220 < SPEED <= 230 |
| W9651 | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9652 | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9653 | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9654 | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9655 | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9656 | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |

|              |                                                            |
|--------------|------------------------------------------------------------|
| W9657        | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9658        | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9659        |                                                            |
| W9660        | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 230 < SPEED <= 240 |
| W9661        | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9662        | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9663        | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9664        | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9665        | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9666        | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9667        | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9668        | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9669        |                                                            |
| W9670        | VALUE OFFSET, SETPOINT TDO ZONE 1 R385, 240 < SPEED <= 250 |
| W9671        | VALUE OFFSET, SETPOINT TDO ZONE 2 R386                     |
| W9672        | VALUE OFFSET, SETPOINT TDO ZONE 3 R387                     |
| W9673        | VALUE OFFSET, SETPOINT TDO ZONE 4 R388                     |
| W9674        | VALUE OFFSET, SETPOINT TDO ZONE 5 R389                     |
| W9675        | VALUE OFFSET, SETPOINT TDO ZONE 6 R390                     |
| W9676        | VALUE OFFSET, SETPOINT TDO ZONE 7 R391                     |
| W9677        | VALUE OFFSET, SETPOINT TDO ZONE 8 R392                     |
| W9678        | VALUE OFFSET, SETPOINT TDO ZONE 9 R393                     |
| W9679 ~ 9999 | FREE                                                       |

TEMPERATURE REGULATOR 50 WORD

F13\WORD6

|         |                                                      |
|---------|------------------------------------------------------|
|         | W100XX                                               |
| 00 [50] | ACTUAL VALUE (MEASURE)                               |
| 01 [51] | SETPOINT                                             |
| 02 [52] | FREE                                                 |
| 03 [53] | ALARM H                                              |
| 04 [54] | ALARM VALUE ABOVE SETPOINT (H+)                      |
| 05 [55] | ALARM VALUE ABOVE SETPOINT (L-)                      |
| 06 [56] | ALARM L                                              |
| 07 [57] | 10                                                   |
| 08 [58] | REAL OUTPUT                                          |
| 09 [59] | 7, GENERAL GAIN                                      |
| 10 [60] | I                                                    |
| 11 [61] | 800, THRESHOLD INHIBIT INTEGRAL                      |
| 12 [62] | D                                                    |
| 13 [63] | P                                                    |
| 14 [64] | 1, OUTPUT GAIN                                       |
| 15 [65] | 0                                                    |
| 16 [66] | 300, RAMP INCREMENT                                  |
| 17 [67] | MEASURE VALUE FOR LAST TIME (T-1)                    |
| 18 [68] | I VALUE, AFTER CALCULATION                           |
| 19 [69] | I VALUE, AFTER CALCULATION                           |
| 20 [70] | ANALOG OUTPUT                                        |
| 21 [71] | STATUS LOOP                                          |
| 22 [72] | OUTPUT (MANUAL)                                      |
| 23 [73] | OUTPUT COUNTER                                       |
| 24 [74] | OUTPUT +- 10,000 PTS                                 |
| 25 [75] | OUTPUT +- 10,000 PTS                                 |
| 26 [76] | RESERVE CONTROL LOOP                                 |
| 27 [77] | TIME SAMPLE FOR DERIVATIVE                           |
| 28 [78] | ERROR, THE DIFFERENCE BTWN SETPOINT AND ACTUAL VALUE |
| 29 [79] | ERROR, THE DIFFERENCE BTWN SETPOINT AND ACTUAL VALUE |
| 30 [80] | OUTPUT IN PERCENT (%)                                |
| 31 [81] | FREE                                                 |
| 32 [82] | D VALUE, AFTER CALCULATION                           |
| 33 [83] | D VALUE, AFTER CALCULATION                           |
| 34 [84] | P GAIN, AFTER CALCULATION                            |
| 35 [85] | P GAIN, AFTER CALCULATION                            |
| 36 [86] | PID ACTION                                           |
| 37 [87] | PID ACTION                                           |
| 38 [88] | FREE                                                 |
| 39 [89] | FREE                                                 |
| 40 [90] | FREE                                                 |
| 41 [91] | FREE                                                 |
| 42 [92] | FREE                                                 |
| 43 [93] | COOLING OUTPUT                                       |
| 44 [94] | HEATER OUTPUT                                        |
| 45 [95] | COUNTER COOLING                                      |
| 46 [96] | COUNTER HEATING                                      |
| 47 [97] | 30, GAIN COOLING                                     |



|         |                  |
|---------|------------------|
| 48 [98] | 30, GAIN HEATING |
| 49 [99] |                  |

| NO.  | COMMENT                                                   |
|------|-----------------------------------------------------------|
| T 0  | SCM 2222 CARD                                             |
| T 1  | TIMER FOR CHILL ROLL FORWARD STEP 1                       |
| T 2  | TIMER FOR CHILL ROLL FORWARD STEP 2                       |
| T 3  | TIMER FOR CHILL ROLL FORWARD STEP 3                       |
| T 4  | TIMER FOR CHILL ROLL BACKWARD STEP 0                      |
| T 5  | TIMER FOR CHILL ROLL BACKWARD STEP 1                      |
| T 6  | TIMER FOR CHILL ROLL BACKWARD STEP 4                      |
| T 7  |                                                           |
| T 8  |                                                           |
| T 9  |                                                           |
| T 10 | TIMER TAM 1360,03 AUXILIARY WINDER 1                      |
| T 11 | TIMER LSL 1360,05 WATER BATH                              |
| T 12 | TIMER TAH 1650,03 AUXILIARY WINDER 2                      |
| T 13 | TIMER LSL 1515,02 CHAIN TENSION SYSTEM                    |
| T 14 | TIMER OSL 1515,03 CHAIN TENSION SYSTEM                    |
| T 15 |                                                           |
| T 16 |                                                           |
| T 17 |                                                           |
| T 18 |                                                           |
| T 19 | TIMER LOW FLOW ALARM FSL 1831,08                          |
| T 20 | TIMER LOW FLOW ALARM FSL 1831,06                          |
| T 21 | TIMER LOW FLOW ALARM FSL 1831,07                          |
| T 22 | TIMER LOW PRESSURE ALARM PSL 1820,07                      |
| T 23 | TIMER LOW PRESSURE ALARM PSL 1820,13                      |
| T 24 | TIMER LOW PRESSURE ALARM PSL 1820,16                      |
| T 25 |                                                           |
| T 26 |                                                           |
| T 27 |                                                           |
| T 28 |                                                           |
| T 29 |                                                           |
| T 30 | TIMER FOR AEM 811 CONFIGURATION                           |
| T 31 |                                                           |
| T 32 |                                                           |
| T 33 |                                                           |
| T 34 |                                                           |
| T 35 | TIMER FOR CLOSING AUXILIARY WINDER 3 SECURITY FINGER      |
| T 36 | TIMER FOR OPENING AUXILIARY WINDER 3 SECURITY FINGER      |
| T 37 |                                                           |
| T 38 |                                                           |
| T 39 |                                                           |
| T 40 | TIMER FOR AIR KNIFE BLOWER TURN OFF DELAY DUE TO MDO BUNK |
| T 41 |                                                           |
| T 42 |                                                           |
| T 43 |                                                           |
| T 44 |                                                           |
| T 45 |                                                           |
| T 46 |                                                           |
| T 47 |                                                           |
| T 48 |                                                           |
| T 49 |                                                           |

|       |                                         |
|-------|-----------------------------------------|
| T 50  | TIMER FOR STARTING MDO EQUIPMENT        |
| T 51  | TIMER FOR STARTING CHILL ROLL EQUIPMENT |
| T 52  | TIMER FOR STARTING MDO EQUIPMENT        |
| T 53  |                                         |
| T 54  |                                         |
| T 55  |                                         |
| T 56  |                                         |
| T 57  |                                         |
| T 58  |                                         |
| T 59  |                                         |
| T 60  |                                         |
| T 61  |                                         |
| T 62  |                                         |
| T 63  |                                         |
| T 64  | FILTER OF WEB BREAK DETECTION           |
| T 65  | FILTER OF WEB BREAK DETECTION           |
| T 66  |                                         |
| T 67  |                                         |
| T 68  |                                         |
| T 69  |                                         |
| T 70  |                                         |
| T 71  |                                         |
| T 72  |                                         |
| T 73  |                                         |
| T 74  |                                         |
| T 75  |                                         |
| T 76  |                                         |
| T 77  |                                         |
| T 78  |                                         |
| T 79  |                                         |
| T 80  |                                         |
| T 81  |                                         |
| T 82  |                                         |
| T 83  |                                         |
| T 84  |                                         |
| T 85  |                                         |
| T 86  |                                         |
| T 87  |                                         |
| T 88  |                                         |
| T 89  |                                         |
| T 90  |                                         |
| T 91  |                                         |
| T 92  |                                         |
| T 93  |                                         |
| T 94  |                                         |
| T 95  |                                         |
| T 96  |                                         |
| T 97  |                                         |
| T 98  |                                         |
| T 99  |                                         |
| T 100 |                                         |
| T 101 |                                         |

|       |  |
|-------|--|
| T 102 |  |
| T 103 |  |
| T 104 |  |
| T 105 |  |
| T 106 |  |
| T 107 |  |
| T 108 |  |
| T 109 |  |
| T 110 |  |
| T 111 |  |
| T 112 |  |
| T 113 |  |
| T 114 |  |
| T 115 |  |
| T 116 |  |
| T 117 |  |
| T 118 |  |
| T 119 |  |
| T 120 |  |
| T 121 |  |
| T 122 |  |
| T 123 |  |
| T 124 |  |
| T 125 |  |
| T 126 |  |
| T 127 |  |
| T 128 |  |

**TEMPERATURE CONTROL 16BIT**

|                  |                                     |
|------------------|-------------------------------------|
| **21,0<br>**71,0 | AUTO/MANU (MANU -> "1")             |
| **21,1<br>**71,1 | TEMPERATURE CONTROL LOCKED          |
| **21,2<br>**71,2 | ALARM H+ OR L- (TEMP OUT OF RANGE)  |
| **21,3<br>**71,3 | ALARM H                             |
| **21,4<br>**71,4 | ALARM L                             |
| **21,5<br>**71,5 | DEFECT MEASURE                      |
| **21,6<br>**71,6 | ALL ALARM (**21, 2+**21, 4+**21, 5) |
| **21,7<br>**71,7 | FAULT CONTROL LOOP                  |
| **21,8<br>**71,8 | HEATING => ON                       |
| **21,9<br>**71,9 | SAMPLE TIME SELECT                  |
| **21,A<br>**71,A | START CONTROL LOOP                  |
| **21,B<br>**71,B | REVERSE CONTROL LOOP                |
| **21,C<br>**71,C | COOLING VALVE => ON                 |
| **21,D<br>**71,D | BIT OUTPUT 100; -100                |
| **21,E<br>**71,E |                                     |
| **21,F<br>**71,F | TEMPERATURE NOT DEFECT (O.K.)       |

TEMPERATURE CONTROL 50 WORDS

|       |      |      |                         |
|-------|------|------|-------------------------|
| W6000 | [50] | R365 | CHILL ROLL COOLING SKID |
| w6050 | [50] | R366 | WATER BATH SKID         |
| w6100 | [50] | R370 | MDO ZONE 1              |
| w6150 | [50] | R371 | MDO ZONE 2              |
| w6200 | [50] | R372 | MDO ZONE 3              |
| w6250 | [50] | R373 | MDO ZONE 4              |
| w6300 | [50] | R374 | MDO ZONE 5              |
| w6350 | [50] | R375 | MDO ZONE 6              |
| w6400 | [50] | R376 | MDO ZONE 7              |
| w6450 | [50] | R377 | MDO ZONE 8              |
| w6500 | [50] | R378 | MDO ZONE 9              |
| w6550 | [50] | R379 | MDO ZONE 10             |
| w6600 | [50] | R380 | MDO ZONE 11             |
| w6650 | [50] | R381 | MDO ZONE 12             |
| w6700 | [50] | R385 | TDO ZONE 1              |
| w6750 | [50] | R386 | TDO ZONE 2              |
| w6800 | [50] | R387 | TDO ZONE 3              |
| w6850 | [50] | R388 | TDO ZONE 4              |
| w6900 | [50] | R389 | TDO ZONE 5              |
| w6950 | [50] | R390 | TDO ZONE 6              |
| w7000 | [50] | R391 | TDO ZONE 7              |
| w7050 | [50] | R392 | TDO ZONE 8              |
| w7100 | [50] | R393 | TDO ZONE 9              |
| w7150 | [50] | R394 | TDO ZONE 10             |
| w7200 | [50] | R395 | TDO ZONE 11             |
| w7250 | [50] | R396 | TDO ZONE 12             |
| w7300 | [50] | R397 | TDO ZONE 13             |
| w7350 | [50] | R398 | TDO ZONE 14             |
| w7400 | [50] | R399 | TDO ZONE 15             |
| w7450 | [50] | R400 | TDO ZONE 16             |
| w7500 | [50] | R401 | TDO ZONE 17             |
| w7550 | [50] | R402 | TDO ZONE 18             |
| w7600 | [50] | R403 | TDO ZONE 19             |
| w7650 | [50] | R404 | TDO ZONE 20             |
| w7700 | [50] |      |                         |

TEMPERATURE CONTROL & DATA WORD

|       |      |      |                                    |
|-------|------|------|------------------------------------|
| W6000 | [50] | R307 | SAT. EXT 1 ADAPTER                 |
| W6050 | [50] | R308 | SAT. EXT 1 FILTER                  |
| W6100 | [50] | R309 | SAT. EXT 1 MELT LINE               |
| W6150 | [50] | R317 | SAT. EXT 2 ADAPTER                 |
| W6200 | [50] | R318 | SAT. EXT 2 FILTER                  |
| W6250 | [50] | R319 | SAT. EXT 2 MELT LINE               |
| W6300 | [50] | R324 | MAIN EXT 1 ADAPTER                 |
| W6350 | [50] | R325 | MAIN EXT 1 FILTER ZONE #1          |
| W6400 | [50] | R326 | MAIN EXT 1 FILTER ZONE #2          |
| W6450 | [50] | R327 | MAIN EXT 1 FILTER ZONE #3          |
| W6500 | [50] |      |                                    |
| W6550 | [50] |      |                                    |
| W6600 | [50] | R330 | MAIN EXT 1 MELT LINE #1            |
| W6650 | [50] | R331 | MAIN EXT 1 MELT LINE #2            |
| W6700 | [50] | R332 | MAIN EXT 1 MELT LINE #3            |
| W6750 | [50] | R333 | MAIN EXT 1 MELT LINE #4            |
| W6800 | [50] | R344 | MAIN EXT 2 ADAPTER                 |
| W6850 | [50] | R345 | MAIN EXT 2 FILTER ZONE #1          |
| W6900 | [50] | R346 | MAIN EXT 2 FILTER ZONE #2          |
| W6950 | [50] | R347 | MAIN EXT 2 FILTER ZONE #3          |
| W7000 | [50] | R348 | MAIN EXT 2 MELT LINE #1            |
| W7050 | [50] | R349 | MAIN EXT 2 MELT LINE #2            |
| W7100 | [50] | R350 | MAIN EXT 2 STATIC MIXER            |
| W7150 | [50] | R351 | MAIN EXT 2 STATIC MIXER CONNECTION |
| W7200 | [50] | R352 | MAIN EXT 2 CONNECTION BOX          |
| W7250 | [50] | R355 | DIE ZONE #1                        |
| W7300 | [50] | R356 | DIE ZONE #2                        |
| W7350 | [50] | R357 | DIE ZONE #3                        |
| W7400 | [50] | R358 | DIE ZONE #4                        |
| W7450 | [50] | R359 | DIE ZONE #5                        |
| W7500 | [50] | R360 | DIE ZONE #6                        |
| W7550 | [50] | R361 | DIE ZONE #7                        |
| W7600 | [50] | R200 | HOPPER WEIGH REGULATION            |
| W7650 | [50] |      |                                    |
| W7700 | [50] |      |                                    |
| W7750 | [50] |      |                                    |
| W7800 | [50] |      |                                    |
| W7850 | [50] |      |                                    |
| W7900 | [50] |      |                                    |
| W7950 | [50] |      |                                    |
| W8000 | [50] | R300 | SAT. EXT 1 ZONE #1                 |
| W8050 | [50] | R301 | SAT. EXT 1 ZONE #2                 |
| W8100 | [50] | R302 | SAT. EXT 1 ZONE #3                 |
| W8150 | [50] | R303 | SAT. EXT 1 ZONE #4                 |
| W8200 | [50] | R304 | SAT. EXT 1 ZONE #5                 |
| W8250 | [50] | R305 | SAT. EXT 1 ZONE #6                 |
| W8300 | [50] | R306 | SAT. EXT 1 ZONE #7                 |
| W8350 | [50] | R310 | SAT. EXT 2 ZONE #1                 |
| W8400 | [50] | R311 | SAT. EXT 2 ZONE #2                 |
| W8450 | [50] | R312 | SAT. EXT 2 ZONE #3                 |
| W8500 | [50] | R313 | SAT. EXT 2 ZONE #4                 |

|       |      |      |                     |
|-------|------|------|---------------------|
| W8550 | [50] | R314 | SAT. EXT 2 ZONE #5  |
| W8600 | [50] | R315 | SAT. EXT 2 ZONE #6  |
| W8650 | [50] | R316 | SAT. EXT 2 ZONE #7  |
| W8700 | [50] |      |                     |
| W8750 | [50] |      |                     |
| W8800 | [50] |      |                     |
| W8850 | [50] |      |                     |
| W8900 | [50] |      |                     |
| W8950 | [50] |      |                     |
| W9000 | [50] | R320 | MAIN EXT. 1 ZONE #1 |
| W9050 | [50] | R321 | MAIN EXT. 1 ZONE #2 |
| W9100 | [50] | R322 | MAIN EXT. 1 ZONE #3 |
| W9150 | [50] | R323 | MAIN EXT. 1 ZONE #4 |
| W9200 | [50] | R340 | MAIN EXT. 2 ZONE #1 |
| W9250 | [50] | R341 | MAIN EXT. 2 ZONE #2 |
| W9300 | [50] | R342 | MAIN EXT. 2 ZONE #3 |
| W9350 | [50] | R343 | MAIN EXT. 2 ZONE #4 |
| W9400 | [50] |      |                     |
| W9450 | [50] |      |                     |
| W9500 | [50] |      |                     |



TEMPERATURE REGULATOR 50 WORDS  
W100XX

|         |                                                             |  |
|---------|-------------------------------------------------------------|--|
| 00 (50) | ACTUAL VALUE (MEASURE)                                      |  |
| 01 (51) | SETPOINT                                                    |  |
| 02 (52) | FREE                                                        |  |
| 03 (53) | ALARM H                                                     |  |
| 04 (54) | ALARM VALUE ABOVE SETPOINT (H+)                             |  |
| 05 (55) | ALARM VALUE BELOW SETPOINT (L-)                             |  |
| 06 (56) | ALARM L                                                     |  |
| 07 (57) | 10                                                          |  |
| 08 (58) | REAL OUTPUT                                                 |  |
| 09 (59) | 7. GENERAL GAIN                                             |  |
| 10 (60) | I                                                           |  |
| 11 (61) | 800, THRESHOLD INHIBIT INTEGRAL                             |  |
| 12 (62) | D                                                           |  |
| 13 (63) | P                                                           |  |
| 14 (64) | 1. OUTPUT GAIN                                              |  |
| 15 (65) | O                                                           |  |
| 16 (66) | 300, RAMP INCREMENT                                         |  |
| 17 (67) | MEASURE VALUE FOR LAST TIME (T-1)                           |  |
| 18 (68) | I VALUE AFTER CALCULATION                                   |  |
| 19 (69) | I VALUE AFTER CALCULATION                                   |  |
| 20 (70) | ANALOG OUTPUT                                               |  |
| 21 (71) | BIT STATUS FOR CONTROL LOOP                                 |  |
| 22 (72) | OUTPUT (MANUAL)                                             |  |
| 23 (73) | OUTPUT COUNTER                                              |  |
| 24 (74) | OUTPUT +/- 10,000 PTS                                       |  |
| 25 (75) | OUTPUT +/- 10,000 PTS                                       |  |
| 26 (76) | RECEIVE CONTROL LOOP                                        |  |
| 27 (77) | TIME SAMPLE FOR DERIVATIVE                                  |  |
| 28 (78) | [ERROR] THE DIFFERENCE BETWEEN SETPOINT<br>AND ACTUAL VALUE |  |
| 29 (79) | [ERROR] THE DIFFERENCE BETWEEN SETPOINT<br>AND ACTUAL VALUE |  |
| 30 (80) | OUTPUT IN PERCENT (%) W10020/10                             |  |
| 31 (81) | FREE                                                        |  |
| 32 (82) | D VALUE AFTER CALCULATION                                   |  |
| 33 (83) | D VALUE AFTER CALCULATION                                   |  |
| 34 (84) | P GAIN AFTER CALCULATION                                    |  |
| 35 (85) | P GAIN AFTER CALCULATION                                    |  |
| 36 (86) | PID ACTION                                                  |  |
| 37 (87) | PID ACTION                                                  |  |
| 38 (88) | FREE                                                        |  |
| 39 (89) | FREE                                                        |  |
| 40 (90) | FREE                                                        |  |
| 41 (91) | FREE                                                        |  |
| 42 (92) | FREE                                                        |  |
| 43 (93) | COOLING OUTPUT                                              |  |
| 44 (94) | HEATER OUTPUT                                               |  |
| 45 (95) | COUNTER COOLING                                             |  |
| 46 (96) | COUNTER HEATING                                             |  |

|         |                                       |       |
|---------|---------------------------------------|-------|
| 47 (97) | 30, GAIN COOLING                      |       |
| 48 (98) | 30, GAIN HEATING                      |       |
| 49 (99) |                                       |       |
|         |                                       |       |
| xx21, 0 | AUTO/MANUAL (MANUAL -> 1)             | B2000 |
| xx21, 1 | TEMPERATURE CONTROL LOCKED            | B2001 |
| xx21, 2 | ALARM H+ OR L- (TEMP OUT OF RANGE)    |       |
| xx21, 3 | ALARM H                               |       |
| xx21, 4 | ALARM L                               |       |
| xx21, 5 | DEFECT MEASURE                        |       |
| xx21, 6 | ALL ALARM (21.2 + 21.3 + 21.4 + 21.5) |       |
| xx21, 7 | FAULT CONTROL LOOP                    |       |
| xx21, 8 |                                       |       |
| xx21, 9 | SAMPLE TIME SELECT (60 OR 1)          |       |
| xx21, A | START CONTROL LOOP                    |       |
| xx21, B | REVERSE CONTROL LOOP                  |       |
| xx21, C |                                       |       |
| xx21, D | BIT OUTPUT 100; -100                  |       |
| xx21, E |                                       |       |
| xx21, F | TEMPERATURE NOT DEFECT (OK)           | B2015 |