



3 BUS DUCT LOAD SCHEDULE



1. NOT USED
2. PRIOR TO CLOSING A SWITCH, THE OTHER SWITCH MUST BE OPENED USING A KIRK KEY INTERLOCK TO PREVENT CONNECTION OF MULTIPLE SOURCES. REFER TO SEQUENCE OF OPERATIONS BY MANUFACTURER IN EQUIPMENT SUBMITTAL.
3. ADD LUG SECTION FOR CABLE BUS CONNECTION WHEN REQUIRED BY MANUFACTURER.
4. SQUARE D/ SCHNEIDER ION 9000 WITH RS-485 COMMUNICATIONS.
5. ENGINEERED CABLE BUS ASSEMBLY, CONDUIT, OR CABLE TRAY TO BUS DUCT CABLE TAP BOX.

ELECTRICAL ONE LINE DIAGRAM

	DATE	REMARKS
	06/28/2024	TFL 2170 REVISIONS
	06/28/2024	PERMIT RESUBMISSION B23 1400
	10/16/2024	DC-074 1P CD PROGRESS SET (MEP ONLY)
	11/01/2024	DC-074 1P FULL CD PACKAGE
	12/17/2024	TFLDC-074 REVISIONS
	03/11/2025	TFL CD REVISIONS
	06/19/2025	TFL CD RESUBMIT

PA/PM:	WB
DRAWN BY.:	ETS/AO/IA/JG
JOB NO.:	PHX21-5038-00

SHEET

1F0-E602

PLOT DATE: 06/19/2025

06/19/2025

Registered Professional Engineer - Electrical
CERTIFICATE NO.
30536
WILLIAM J.
BETHURUM, IV
Date Signed
[Signature]
SEAL EXPIRES: 09/30/26

VOLTA
 1730 E. Northern Avenue., Ste. 120, Phoenix, AZ 85020
 Tel. (480) 659-0511, VoltaUS.com

PROJECT ALPHA
1F0 - MAIN MANUFACTURING BUILDING
EAST PECOS ROAD
QUEEN CREEK, ARIZONA 85140

WARE MALCOMB

2777 E. Camelback Rd, Suite #325
Phoenix, AZ, 85016
P 480.907.2288

ARCHITECTURE
PLANNING
INTERIORS
CIVIL ENGINEERING
BRANDING
BUILDING MEASUREMENT