

KEYNOTES

(1) NEW 6" TYPE 2 VERTICAL CURB PER PAG SD 209

(2) END VERTICAL CURB WITH 3' TERMINAL SECTION PER PAG SD 212

(3) RADIUS RETURN WITH 6"x12" CONCRETE HEADER PER PAG SD 213

4 6' WIDE MIN CONC SIDEWALK PER PAG SD 200. SEE PLAN FOR WIDTH

6 CURB ACCESS RAMP PER ADA STANDARDS WITH TRUNCATED DOMES PER SECTION 705 ICC/ANSI 117.1

⟨7⟩ R1-1 30" X 30" STOP SIGN

8 STANDARD 90° PARKING REGULAR PARKING SPACE, 9'x 18'
(15.5' W/2.5' OVERHANG)

9 STANDARD 90°, 9'x18' HANDICAP PARKING SPACE. SEE DETAIL $\frac{\Gamma}{31}$ SHORT TERM BICYCLE PARKING IN CONFORMANCE WITH COT UDC \underbrace{E}_{31}

11) LONG TERM BICYCLE PARKING IN CONFORMANCE WITH COT UDC $\frac{E}{31}$ SECTION 7.4.9.

12 12'x50' TRAILER PARKING

(13) TRASH ENCLOSURE IN CONFORMANCE WITH COT TSM SEC. 8.01 $\frac{K}{32}$

BUILDING STEM WALL PER ARCHITECTURAL AND STRUCTURAL DRAWINGS 9" MAX DEPRESSED LANDSCAPING AREAS FOR STORM WATER PARVESTING

EXIST J2 CABINET, DOWNGRADE OR POWER TO REMAIN AND PROTECTED IN PLACE

(17) RETAINING WALL W/BARRICADE RAILING PER STRUCTURAL PLANS (33)

(18) NEW MONUMENT SIGN BY SEPARATE PERMIT

MODIFIED TYPE 4 CATCH BASIN W/5EF-1 GRATES PER PAG SD 309, W/ CONC. APRON WHERE SHOWN

MODIFIED TYPE 4 CATCH BASIN W/7EF-1 GRATES PER SD PAG 309, W/ CONC. APRON WHERE SHOWN

(2) STORM DRAIN CLEANOUT PER (3)

2 STORM DRAIN INLET/OUTLET PIPE $\frac{L}{32}$

DEPRESSED CURB, SIZE PER PLANS W/TYPE "B" POST BARRICADES M
PER PAG SD 106 @ 5' O.C. NUMBER PER PLAN. SEE DETAIL 32

2 2' CURB OPENING. PROVIDE 3'X3' RIP RAP APRON D50=8". T=8" (25) CONCRETE GUTTER PER (33)

26 42" SECURITY BARRIER. SEE ARCHITECTURAL PLANS FOR DETAILS

CURB OPENING LENGTH PER PLAN, PROVIDE 5' WIDE BAND OF RIP RAP APRON D50=8", T=8". EXTEND THE RIP RAP 3' BEYOND BOTH ENDS OF THE OPENING

6" TYPE 1 SIDEWALK SCUPPER PER PAG SD 204. COORDINATE WITH MECHANIAL DRAWINGS AND CONNECT ROOF DRAIN TO SCUPPER

TYPE 2 SIDEWALK SCUPPERS PER PAG SD 205. SEE PLAN FOR NUMBER OF CELLS. PROVIDE 10'x5' RIP RAP APPROX D50=8", T=8" OVER 1 LAYER MIRAFI 180N FILTER FABRIC OR EQUIVALENT

 $\langle 3 \rangle$ 12' WIDE PATH, 2" ASPHALT OVER 12" COMPACTED SUBGRADE $\frac{N}{34}$

(3) CONRETE CHANNEL PER (3)

33 1' CURB OPENING FOR WATER HARVESTING. PROVIDE 2'X2' RIP RAP APRON.

NOTE: NOT ALL RIP RAP SHOWN FOR CLARITY

TYPICAL SLOPE TREATMENT

FINAL SLOPE TREATMENT (UNLESS OTHERWISE NOTED IN THE SOILS REPORT OR ON THIS PLAN) SHALL BE AS FOLLOWS:

RECOMMENDATION (UON)

STEEPER THAN 1:1 1:1 TO 1.99:1 OVER 2' IN HEIGHT

- GROUTED ROCK RIP RAP PER DETAIL (32)

3:1 OR FLATTER

- HAND PLACED ANGULAR ROCK RIP RAP D50=8"MIN, T=8"MIN (UON) OVER 1 LAYER MIRAFI 180N FILTER FABRIC OR EQUIVALENT - REVEGETATED PER LANDSCAPE ARCHITECT'S

> **CDRC Approved Development Package** IMonshi1 01/06/2023 PLANNING & DEVELOPMENT SERVICES

> > ☐ SCZ Site/Dev Plan ☐ ERZ □ Tentative Plat ✓ Grading ☐ HDZ ✓ SWPPP WASH Other ✓ FUP per letter in SIRE, Revision # __

HORIZ : 1'' = 20'VERT : N/A SHEET 20 OF 86

DP22-0122

C 15-22-01

\\cp.rickeng.com\projects\T_TUC_F\4329_Los_Reales_Alvernon_Property\Civil\PHASE 1\4329APH1dp20.dgn

13-DEC-2022

Contact Arizona 811 at least two full working days before you begin excav

Call 811 or click Arizona811.cor