

KAGRA

INSTRUMENTS SUMMARY

KAGRA photon calibrator

Author:

Yuki INOUE, Sadakazu Haino
on the behalf of Calibration sub-group

Institute of Physics
Academia Sinica

February 21, 2017

KAGRA

Abstract

Institute of physics
Academia Sinica

KAGRA photon calibrator

by Yuki INOUE, Sadakazu Haino
on the behalf of Calibration sub-group

The Thesis Abstract is written here (and usually kept to just this page). The page is kept centered vertically so can expand into the blank space above the title too...

Contents

Abstract	iii
1 Introduction	1
1.1 Calibration of KAGRA	1
1.2 Requirement of KAGRA	1
1.3 Schedule of KAGRA	1
2 Photon calibrator	3
2.1 Photon calibrator	3
2.2 Purpose of photon calibrator	3
2.2.1 Interferometer Calibration	3
2.2.2 Hardware injection test	3
2.2.3 Photon pressure actuator	3
2.3 Calibration line of KAGRA	3
3 Instruments overview	5
3.1 Layout of Photon calibrator	5
3.2 Transmitter (Tx) module	5
3.2.1 Fiber laser	7
3.2.2 Beam shutter	7
3.2.3 Half wave plate	9
3.2.4 Polarizer	9
3.2.5 Lens	9
3.2.6 Mirror	10
3.2.7 Optical mount with Pico-motor	10
3.2.8 Beam splitter	10
3.2.9 Optical follower servo	11
3.2.10 Photo detector	11
Cover	11
InGaAs detector	11
Electrical Circuit	11
3.2.11 Beam sampler	13
3.2.12 2 inch integrating sphere	13
3.2.13 Structure	14
3.3 Periscope	14
3.3.1 Geometric optics	14
3.3.2 View window	15
3.3.3 Mirrors	15
3.3.4 Structure	15
3.3.5 Alignment	15
3.4 Receiver module	15
3.4.1 6inch Integrating sphere	15
3.4.2 Mirror	17

3.4.3	QPD	17
3.4.4	Structure	17
3.5	Camera module	17
3.5.1	Camera	18
3.5.2	Telescope	18
3.5.3	Focuser	18
3.5.4	View window	18
3.5.5	Mirror	18
3.5.6	Illuminator	18
3.6	Summary	18
4	Elastic deformation	19
4.1	Free mass motion	19
4.2	Transfer function	19
4.3	Modal analysis	19
4.4	Elastic deformation	19
4.5	Summary	19
5	Absolute power calibration	21
5.1	Introduction	21
5.2	Theory of Operation	21
5.3	End-station	21
5.4	Gold standard	21
5.5	Working standard	21
6	Beam position monitor	23
7	Summary	25

Chapter 1

Introduction

1.1 Calibration of KAGRA

1.2 Requirement of KAGRA

(1) GW 信号の符号の確認フィードバック回路で、何重ものフィルターを介して反転を繰り返しているため、検出した重力波信号の符号が正しいと確信するのは意外に難しい。回路を一つでも見逃したり、極性を間違えると符号が反転するリスクがある。一方で、万が一符号を間違えると物理結果には甚大な影響を及ぼす。その点、Pcal は原理的に一方向しか押せないので、GW 信号の符号確認に適している。実際、LIGO/Virgo ではこのような議論が度々起きており、Pcal 導入の最初のモチベーションになっている

(2) 観測中でのキャリブレーション Pcal が無い場合は、Laser wavelength などを使ったキャリブレーションが必要だが、これは、観測状態では行えないので、キャリブレーションランから観測ランの間にキャリブレーションパラメータが変わってしまうリスクをどのように系統誤差に反映させるかが問題となる。一方で、Pcal があると、観測中及び、観測感度を達成した状態でのキャリブレーションランが可能

(3) インジェクションアクチュエータを使ったインジェクションでは、フィードバック回路のサーボの抑制により、高周波でのインジェクションが難しくなる。その点、Pcal はアクチュエータよりも効率よく高周波でのハードウェアインジェクションを可能にする

(4) キャリブレーション手法の独立性、干渉計の信頼性担保制御ループにキャリブレーション信号を注入する従来の方法では、いわば自分で自分を較正することになるので、あるレベル以上の系統誤差は詰められない。PCAL の結果をだすことで、主干渉計の信頼性はぐっと増す。従来の方法は、アクチュエータ効率の推定など、ループ内部にある誤差・不定性の分離や評価が難しい。PCAL はそれを可能にする。PCAL 自体にも誤差や不定性はあるが、制御ループと独立な手段で基準信号を注入できることは意味がある。手法が独立故に、系統誤差を減らす工夫が可能になるからだ。

(5) 國際化 KAGRA, LIGO, Virgo で絶対値で正しい（お互いのズレを評価できる）キャリブレーションが必要である。それがあると、方向推定の誤差など、あらゆる物理をずらす。このことは、例えば、宇宙線空気シャワー観測と X 線観測の議論の違いを見ると実感できる。標準エネルギーourcesがない宇宙線空気シャワー観測では常にそして長い間宇宙線のエネルギー推定の正しさを巡って常に苦労している。一方、放射線源で較正が可能な X 線観測では、検出した X 線自体のエネルギーの中央値についての疑義はほとんどない。放射性同位体が較正線源として利用できる。重力実験ではとくに「絶対較正」が難しく、しかしそれが実験の要だったりする。

1.3 Schedule of KAGRA

Chapter 2

Photon calibrator

2.1 Photon calibrator

One of the goals of the gravitational wave experiment is the accurate measurement of the gravitational waveform that is measured through the absolute displacement of the end test masses. A recent study that LIGO conducted in US showed that a displacement uncertainty could be controlled by the photon calibrator. The photon calibrator is one of the calibration tools to push the mirror surface using the photon pressure of the laser as shown in Fig XXX. The absolute displacement is described as

$$dx = \frac{P \cos \theta}{c} s(f) \left(1 + \frac{I}{M} \vec{a} \cdot \vec{b} \right), \quad (2.1)$$

where P is an absolute power of the laser, c is the speed of light, θ is an incident angle of the laser, I and M are moment of inertia and mass of test mass, \vec{a} and \vec{b} is position vector of photon calibrator lasers and interferometer laser. Then, $s(f)$ is transfer function of the test masses. We simulated the transfer function of test mass as shown in Fig. XXX. We assumed the masses, shapes and Young's modules of the each pendulum mass and fiber as shown in Fig.XXX. According to transfer function, we can regard the motion of high frequency as free mass due to higher than the natural frequency. Therefore, we are able to assume as follows:

$$s(f) = \frac{1}{M\omega^2}, \quad (2.2)$$

where ω is the angular frequency of test mass.

2.2 Purpose of photon calibrator

- 2.2.1 Interferometer Calibration
- 2.2.2 Hardware injection test
- 2.2.3 Photon pressure actuator

2.3 Calibration line of KAGRA

Chapter 3

Instruments overview

3.1 Layout of Photon calibrator

The KAGRA photon calibrator is placed around EXA/EYA chamber, which is installed 36 m away from the end test mass (ETM). We push the mirror surface with the modulated photon pressure directly. Figure 3.1 shows the layout of the KAGRA photon calibrator. The photon calibrator consists of transmitter module (Tx module), receiver module (Rx module), periscope, and telephoto camera module (TCam module). We place the 20 W laser in Tx module, whose frequency is 1047 nm. The 1064 nm laser is not used due to avoid the coupling with main beams. The power of the laser is modulated by the optical follower servo (OFS). We split the beams in Tx module for pushing the drum head node points of the ETM due to elastic deformation. We transfer the beams to the ETM though the periscope. All the periscope structures are placed into the EXA/EYA chamber. The beam is received by the Rx module. We place a 6 inches integrating sphere for the accurate measurement of the laser power and two quadrant photo detector (QPD) for the beam position monitor. We also measure the beam position on the ETM surface using the telephoto camera (TCam). The Tcam is consists of the astronomical telescope, focuser, and high resolution digital camera. Details of instruments are described following section.

3.2 Transmitter (Tx) module

The Tx module is placed at the side of the EXA/EYA chamber. Figure 3.2 shows the view of Transmitter module. All the optical components are mounted on the 900 mm × 900 mm breadboard (B9090L; Thorlabs). The bread board is placed on the support structure. The electrical module for the control and readout are also hosed in the support structure.

Figure 3.3 shows the optical layout of Tx module. All the optical components are listed in Table 3.1.

TABLE 3.1: .

#	Name	Type
1	Fiber laser	CYFL-TERA-20-LP-1047-AM1-RGO-OM1-T305-C1




FIGURE 3.1: KAGRA photon calibrator. The calibration system is placed around the EXA/EYA chamber. We mount the optical lever and optical baffle as well.




FIGURE 3.2: Transmitter module of KAGRA Pcal. We place the optical table on the triangle table. The readout and control device is housed into the legs of table.




FIGURE 3.3: Optical layout of KAGRA photon calibrator. The laser power is modulated and controlled by the acousto-optic modulator (AOM). This modulated laser is sent to a 50:50 beam splitter, where we monitor the modulated laser power by using the integrating sphere.




FIGURE 3.4: The fiber laser and drawing of isolator.

3.2.1 Fiber laser

We employ the CW fiber laser made by the LER photonics as shown in Fig. 3.4. The maximum power and frequency are 20 W and 1047 nm, respectively. The model number of the laser is CYFL-TERA-20-LP-1047-AM1-RGO-OM1-T305-C1. The maximum laser power of KAGRA Pcal is 10 times larger than that of LIGO. This is because that we need the high power laser for the injection test and photon pressure actuator technique. The typical beam width of the laser is 0.5 mm when we mount the isolator. We summarize the specification of the laser as shown in Table 3.2.

3.2.2 Beam shutter

We have to pay attention to safety for the operation of the high power laser. In order to dump the beam, we use the beam shutter made by lasermet company. The model number of the shutter is LS-10-12. The aperture size and Max laser power are 15 mm and 20 W. These number meet our requirement due to the laser spot size and

TABLE 3.2: Specification summary of CW fiber Laser.

Characteristic	Typical value	Unit	Note
Operating central wavelength	1047	nm	± 1 nm
CW output power	20	W	
Output signal line-width	0.5	nm	FWHM
Output power stability	± 1	%RMS	Output power: 20 W
Output power tunability	10-100	%	
Optical polarization	Linier		
Polarization extinction ratio	15	dB	
Output fiber	PLMAFUD3460		Nufurn company
Output fiber length	2	m	
Beam diameter	0.5	mm	with isolator
Beam quality	1.1	M^2	
Control mode	Active current control, Active power control		
Beam quality	1.1	M^2	
Supply voltage	84-264	V	AC 47 to 63 Hz
Power consumption	650	W	
Housing	448x451x132.5	mm	
Total weight	13	kg	
Cooling	Air cooled with fans		
Operating temperature	15-35		
Humidity	5-85	%	

TABLE 3.3: Specification of beam shutter.

Charactaristic	Typical value	Unit	Note
Max laser power	20	W	
Aperture size	15	mm	
Drive voltage	11-14	V DC	
Current consumption	150	mA	
Size	98 × 63.5 × 36	mm	

TABLE 3.4: Specification of HWP.

Charactaristic	Typical value	Unit	Note
Waveplate Type	Quartz Waveplates		
Wavelength Range	1047	nm	
Retardance	$\lambda/2$		
Clear Aperture	85	%	of diameter
Reflection	0.25	%	
Retardance Tolerance	$\lambda/200$ to $\lambda/500$		at 23Degree C
Material	Crystal Quartz		
Surface Quality	10-5	scratch-dig	
Waveplate Diameter	12.7	mm	

maximum power. We control the beam shutter on the GUI. The specification of the beam shutter is shown in Table 3.3.

3.2.3 Half wave plate

To control the polarization angle of incident beam, we employ the zero order half wave plate (HWP) made by the CVI laser optics. The model number of the HWP is QWPO-1047-05-2-R10 whose diameter are 12.7mm. The HWP is mounted on the rotation mount made by Thorlabs. The thick ness are optimized at 1047 nm. The specification of the HWP is listed in Table 3.4.

3.2.4 Polarizer

We place two polarizers to define the polarization angle accurately. This is because that the power of the laser is modulated by acousto-optic modulator (AOM) whose performance strongly depend on the incident polarization angle. One polarizer is placed behind HWP. Another one is placed after AOM. The Polarizer is made by Karl-Lamrecht. We purchased TFPC12-1047 that is optimized at 1047 nm.

3.2.5 Lens

We have dane a mode matching simulation using JamMt. We assumed laser beam to be gaussian distribution. We have to place the focus of the laser at the AOM. Thus, we decide the optimal position and focal length of the 1 inch lens (L1), where the assumed beam waist of the fiber laser and AOM are 0.5 mm and XXX mm, respectively. Furthermore, we place two lenses for placing the focus at the surface of the

TABLE 3.5: Specification of lenses.

Lens number	part number	Diameter [mm]	Focal length
L1		25.4	
L2		25.4	
L3		25.4	
L4		50.8	

ETM. We employ the combination of 1 inch negative lens and 2 inch positive lens. The Gaussian beam can describe the following relation:

$$w(z) = \omega_0 \sqrt{1 + \left(\frac{\lambda z}{\pi \omega_0^2} \right)^2}, \quad (3.1)$$

where λ is wavelength of the laser, w_0 is beam waist, z is direction from the focus. We estimate the minimum differential beam spot by changing beam waist because it make the alignment easier. The minimum beam spot is written by

$$\frac{dw(z)}{dw_0} \Big|_{z=36m} = 0. \quad (3.2)$$

The estimated beam waist and beam spot is 3.5 mm and 5.5 mm as shown in Fig. XXXX. We also place the lens at the front of the photo detector for the OFS. The parameters of the simulation results are listed in Table. 3.5. All lenses are made by CVI laser optics. The material of lenses are fused silica. The AR coating is placed at both surface.

3.2.6 Mirror

We employ nine 1 inch mirrors and four 2 inch mirrors. The 1 inch mirror is made by CVI laser optics. They place the HR coating on the surface of mirror. On the other hand, we use the HR coating on the fused silica disc of 2 inch in diameter. The coating and polishing the fused silica is made by Sigma-koki corporation. The reflectance of the mirror is shown in Fig. 3.3. The reflectance of HR coating depends on the incident angle and the polarization angle. We labeled mirrors as M-Tx1 to M-Tx-11, M-Tx-t-1, M-Tx-t-2, and M-Tx-b-1. The specification of mirrors are summarized in Table.3.6. All mirror is aligned with optical mirror mount made by Newport company.

3.2.7 Optical mount with Pico-motor

The uncertainty of the beam position on the ETM is one of the largest. To control the beam position, we employ the Pico-motor after flip mirrors for changing mirror angle. The pico-motor is made by New port, whose part number is 8822.

3.2.8 Beam splitter

To reduce the elastic deformation, we separate the beam with the beam splitter made by CVI laser optics for pushing the node points of mirror. The part number of beam

TABLE 3.6: Specification of Mirrors.

Mirror number	part number	Diameter [mm]	Incident angle	Polarization
M-Tx-1		25.4	45	
M-Tx-2		25.4	45	
M-Tx-3		25.4	45	
M-Tx-4		25.4	45	
M-Tx-5		25.4	45	
M-Tx-6		25.4	48	
M-Tx-7		25.4	42	
M-Tx-8		25.4	45	
M-Tx-9		25.4	45	
M-Tx-10		50.8	45	
M-Tx-t-1		50.8	45	
M-Tx-t-2		50.8	23.3	
M-Tx-b-1		50.8	45	
M-Tx-b-2		50.8	21.8	

splitter is BS1-1064-50-2025-45P. The diameter of the beam splitter is 2 inch. Table 3.7 shows the separation ratio of beam splitter.

3.2.9 Optical follower servo

In order to achieve low-noise and accurate modulation, an active controller (servo) can modulate the waveform by means of feedback control. This feedback loop used for the Pcal is called as the Optical Follower Servo. The Optical Follower Servo will be used in the KAGRA Photon Calibrator as a means to reduce the relative power noise (RPN) of the laser. We will achieve maximum sideband to carrier suppression of the modulated output waveform.

3.2.10 Photo detector

To detect the laser power, we use the photo detector. We place the photodetector at the working standard, Optical follower servo, Integrating sphere in Tx and Rx module. We developed the photo detector as shown in Fig. xxx. We employ the InGaAs photo diode for absolute power measurement. The InGaAs diode is placed on the circuit board. The beam is collimated for the power detection reasonably.

Cover

The design of the cover is done by LIGO Pcal group. We make the detector cover in Academia Sinica, Institute of Physics. Figure 3.5 shows the machined detector covers. We housed the circuit board into the cover coated by the black anodized aluminum.

InGaAs detector

We employ the C30665GH, large area InGaAs PIN photodiode with diameter of 3.0 mm with a flat glass window. The C30665GH provides high quantum efficiency

TABLE 3.7: Specification of beam splitter.

Characteristic	Typical value	Unit	Note
Beamsplitter Type	Laser Line Plate Beamsplitters		
Beamsplitter Shape	Round		
Wavelength Range	800	nm	
Bevel/Chamfer	0.35 mm × 45 Degree		
Wedge Angle Tolerance	5	arcmin	
Coating Material	Laser Line Dielectric		
Angle of Incidence	45	Degree	
Clear Aperture	85	%	
Substrate/Material	Fused Silica		
Surface Flatness	$\lambda /10$		
Surface Quality	10-5	scratch-dig	
Beamsplitter Diameter	50.8	mm	
Beamsplitter Thickness	6.35 mm		
Thickness Tolerance	± 0.25 mm		




FIGURE 3.5: .

TABLE 3.8: Specification of InGaAs detector.

Characteristic	Typical value	Unit	Note
Dark Current	25	nA	
Peak Wavelength	1550	nm	
Responsivity	0.95	A/W	
Breakdown Voltage	50	V	
Capacitance	200	pF	




FIGURE 3.6: .

from 800nm to 1700nm. This detector is fabricated by Excelitas. The specification of detector is shown in Table. 3.11.

ditector

Electrical Circuit

We newly improved the electrical circuit of the photon detector as shown in Fig. 3.6. The electrical circuit is housed in the aluminum cover. We place the photo detector at the the behind of the electrical circuit. The layers of the circuit consists of 4 layer. We change the differential gain by changing the register and capacitor of the circuit. The electrical circuit are shown in Fig. 3.7.

3.2.11 Beam sampler

3.2.12 2 inch integrating sphere

The 2 inches integrating sphere is used for absolute power measurement of the laser. We receive the separated laser beam at beam sampler. We mount the photo detector at the port of integrating sphere. The integrating sphere is made by the Lab sphere. The inner surface of the integrating sphere in mounted on the Spectralon.

3.2.13 Structure

The breadboard is placed on the support structure. The material of this structure is SUS 306. This structure can be housed electrical devices, such as driver of the fiber laser, electronics of optical follower servo, and driver of laser shutter. We simulated the resonance frequency using ANSYS. The estimated frequency is XXX Hz.




FIGURE 3.7: D1300210.

3.3 Periscope

The periscope is used for sending the beams to ETM. We place the periscopes in EXA/EYA chamber as shown in Fig. 3.8. They consist of four periscopes. The first periscope is mounted at the vacuum side of the window. The laser is send to second periscope on optical table. We share one first mirror and one second mirror for the two beams of the laser. We send the two laser to two third periscope. The third periscope is sent to fourth periscope, which is aligned to same hight of the injected beam to the ETM.

3.3.1 Geometric optics

We consider the beam separation and focus position of the optical system for the laser to be sent and received to the ETM. We fixed 80 mm separation of the mirror in transmitter module. Figure XXX shows the schematic view of optical layout, where D_{win} , D_{m2} , and D_{m3} are separation of beams, L_{win} , L_{m2} , and L_{m3} are distance of each components. We calculated the beam separation of the vacuum window, second mirror, and third mirrors by changing the focus point as shown in Fig. XXXX. X axis shows the distance from the window. We find a optimal point of minimum separation of the window because of clear aperture of window and second mirror. The optimal focus point is at XXXX mm from the window corresponding to XXXX separation of the mirror. We also find a incident angle of window with optimal focus point as 1.6 degree.




FIGURE 3.8: Periscope.

3.3.2 View window

One of the serious systematic errors are optical efficiency of the view port. Therefore, we have to reduce the reflectance of view port at least 0.1 %. We employ the fused silica optical window whose diameter and thickness are 100 mm and 0.5 inch. We place the AR coating on both surfaces of the window. Figure XXX shows the simulated transmittance of the view port. The effective diameter of the view port is about 3 inch. The incident angle of the beams are 1.6 degree. We mounted the first periscope at the vacuum side of the window because we should avoid optical lever path. We set the incident angle of periscope mirror as 50 degrees.

The flange type of the view port is ICF152. We remodeled the blank flange of ICF 152 made by Cosmotech. Figure 3.9 shows the drawing of the view port. We employ the G-85 o-ring for vacuum sealing.




FIGURE 3.9: .

TABLE 3.9: Specification of Mirrors in periscope.

Mirror number	part number	Diameter [mm]	Incident angle	Polarization
M-P-1		76.2	50deg	
M-P-2		76.2	50deg	
M-P-t-3		76.2	22.5deg	
M-P-t-4		76.2	45deg	
M-P-b-3		76.2	22.5deg	
M-P-b-4		76.2	45deg	
M-P-5		76.2	50deg	
M-P-6		76.2	50deg	




FIGURE 3.10

3.3.3 Mirrors

We employ eight 3 inch mirrors. We place the HR coating on the polished fused silica disc. The coating and polishing the fused silica is made by Sigma-koki corporation. The reflectance of the mirror is shown in Figure. XXXX. The reflectance of HR coating depends on the incident angle and the polarization angle. We labeled mirrors as M1, XXXX. The specification of mirrors are summarized in Table. 3.9. All mirror is aligned with optical mirror mount made by XXXXXX.

3.3.4 Structure

3.3.5 Alignment

3.4 Receiver module

3.4.1 6inch Integrating sphere

The 6 inches integrating sphere is used for absolute power measurement of the laser. We receive the laser beam from two paths. To receive the power perfectly, we need a sufficiently large diameter hole of integrating sphere. We use for the 2 inch hole

TABLE 3.10: Specification of Mirrors in Rx module.

Mirror number	part number	Diameter [mm]	Incident angle	Polarization
M-Rx-1		76.2	21.7deg	
M-Rx-2		76.2	23.3deg	
M-Rx-3		76.2	21.7deg	
M-Rx-4		76.2	23.3deg	

TABLE 3.11: Specification of QPD.

Charactaristic	Typical value	Unit	Note
Substrate	InGaAs		
Wavelength Range	1000 - 1700	nm	
Detector Bandwidth	150	kHz	
Recommended Spot Size	ϕ 0.2 - 0.5	mm	

integrating sphere. We mounted the photo detector at the top of port. Details of the photo detector is explained in XXXXX.

3.4.2 Mirror

We employ four 2 inch mirrors. We place the HR coating made by Siguma-koki as shown in Fig. XXXX. For two mirrors, we make the AR coating on the back surface to pick up the beams. The specification of the mirrors are listed in Table 3.10.

3.4.3 QPD

We will implement QPDs for beam position control, which made by Tholabs. They also help us to understand the alignment drifts of the beams. The part number of QPD is PDQ30C.

3.4.4 Structure

The breadboard is placed on the support structure. The material of this structure is SUS 306. We simulated the resonance frequency using ANSYS. The estimated frequency is XXX Hz.

3.5 Camera module

The beam position of the ETM surface corresponds to systematic error of the rotation and elastic deformation. To measure the beam position, we measure the mirror surface directly. However, the KAGRA EXA/EYA chambers are placed at 36m far from the ETM. Thus, we employ the combination of telescope and high resolution camera, we call telephoto camera (TCam). We are tuning with focus point of the mirror using focuser. We place the view port and mirror between the ETM and TCam. Figure XXX shows the drawing of TCam unit.




FIGURE 3.11: .

3.5.1 Camera

Purpose of using the high resolution camera, we have to measure the beam position within 1 mm accuracy. We solved this problem by D810 digital camera made by Nikon. The D810 reprises the 36-megapixel resolution with 35.9×24.0 mm CMOS sensor. We remove the IR filter because the commercial camera is not sensitive to laser wavelength (1047 nm).

3.5.2 Telescope

We employ the Maksutov-Cassegrain type telescope for observing the ETM surface. The diameter of the primary mirror is 127 mm and its focal length is 1500 mm ($f/12$). The telescope is manufactured by Sky-watcher company. The diameter of the telescope is limited by the that of the view window size.

3.5.3 Focuser

A focuser, which is made by Moonlight, is used for the automatic focus control. We connect focuser between telescope and camera. The model number is XXXXX.

3.5.4 View window

The flange type of the view port is ICF203. We remodeled the blank flange of ICF 203 made by Cosmotech. Figure 3.11 shows the drawing of the view port. We employ the G-135 o-ring for vacuum sealing.

3.5.5 Mirror

We place the mirror in the EXA/EYA chamber. The mirror size is 100×80 mm, which is mounted on the aluminum holder and optical mount. The mirror is made by Thorlab. The reflectance of the mirror is shown in Fig XXXX.

3.5.6 Illuminator

3.6 Summary

Chapter 4

Elastic deformation

The elastic deformation is one of the serious systematic error in Photon calibrator.

4.1 Free mass motion

4.2 Transfer function

4.3 Modal analysis

4.4 Elastic deformation

4.5 Summary

Chapter 5

Absolute power calibration

5.1 Introduction

This section describes the in-situ calibration procedure of Photon Calibrator at each End station of KAGRA.

5.2 Theory of Operation

The Working Standard referred as WS is an integrating sphere with InGaAs photo detector, which has been calibrated against Gold Standard (GS) in the lab at LHO. The Gold Standard is calibrated by NIST. We will use this working standard to calibrate the Transmitter Module Photo Detector (TxPD) and Receiver Module Photo detector (RxPD), which are inside the Transmitter module and Receiver module of Photon calibrator respectively.

The following formula is used to obtain the calibration factor that will give the response of photodiodes in Photon calibrator modules in Watts/Volts:

$$\text{TxPD} = \frac{\text{TX}}{\text{WS}} * \frac{\text{WS}}{\text{GS}} * \text{GS} \quad (5.1)$$

$$\text{RxPD} = \frac{\text{RX}}{\text{WS}} * \frac{\text{WS}}{\text{GS}} * \text{GS} \quad (5.2)$$

5.3 End-station

5.4 Gold standard

5.5 Working standard

Chapter 6

Beam position monitor

Chapter 7

Summary