

PKG-LINE-04 NETWORK SKETCH - HAND MARKUP - UNDATED

SLC 5/03 CH0 -> DH-485 -> PANELVIEW MODEL UNKNOWN

1747-SDN SLOT 8 -> DEVICENET TRUNK

- VFD-01 NODE ?
- VFD-02 NODE ?
- STARTER 01 NODE ?
- STARTER 02 NODE ?
- SCALE NODE ?
- REMOTE I/O NODE ?

NODE ADDRESSES AND BAUD RATE NOT RECORDED.
NO DEVICENET CONFIGURATION BACKUP AVAILABLE.