

Adroit Technologies

Protocol Driver

Name	Scan Ethernet TCP/IP Scanner
DLL	ScanEth



COPYRIGHT

Copyright © 2022 Advanced Worx 112 (Pty) Ltd. All rights reserved.

Information in this document is subject to change without notice. The software described in this document is furnished under a license agreement or nondisclosure agreement. The software may be used or copied only in accordance with the terms of those agreements. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or any means electronic or mechanical, including photocopying and recording for any purpose other than the purchaser's personal use without the written permission of Advanced Worx 112 (Pty) Ltd.

Advanced Worx 112 (Pty) Ltd
20 Waterford Office Park
189 Witkoppen Road (c/o Waterford Drive)
Fourways
South Africa

<https://adroittech.co.za/>

Contents

1. Overview	4
2. Wiring	5
3. Device Configuration	6
3.1. Device Configuration	6
3.1.1. Local Daemon Config	6
4. Supported Addresses	7
5. Protocol Definition and Considerations	8
5.1. Script	8
6. General Notes and Troubleshooting	10
6.1. Contact Details.....	10
6.2. Adroit Technologies Knowledge Base.....	10
7. Revisions.....	10
7.1. Document Revision.....	10
7.2. DLL Revision	10

1. Overview

Adroit supports communication with the following :

Any simple asynchronous TCP/IP listener that will receive Ascii text , this will be sent to “D0” string agent and then onto a script for more advanced decoding.


The system allows telemetry functionality for efficient communication to large highly distributed systems.

2. Wiring

Standard Ethernet connection.

3. Device Configuration

3.1. Device Configuration



3.1.1. Local Daemon Config

Station Address – 16bit WORD is used as to determine a receiving device (future not used as yet, the data string and script must determine the receiving data in the script itself)

TCP Port – A daemon will listen on this port.

4. Supported Addresses

Data address types supported by the Scan Ethernet string driver.

Area	Min Range	Max Range	PLC Data Type	Boolean	Integer	Real	String
D	0	0	WORD	-	-	-	D0

5. Protocol Definition and Considerations

5.1. Script

Example Script Agent "bas" File triggered on the incoming string.

```
REM -----
REM - This is a simple demo script that will take a lora string in the
REM - format : AAAAAA,BBBBBB,CCCCC<LF> and strip it out an update
REM - "AAAAAA_A0" <- BBBB as analogue register value
REM - "AAAAAA_A1" <- CCCCC as analogue register value
REM -
REM - IOT agent is xml could and should be prototyped in here and then
REM - make an official lora driver and matching IOT agent pair...
REM -
REM - The string scanned to scanEth address D0 , is used as the trigger
REM - Its value is consumed in here as above
REM -----
```

```
Sub Main()
```

```
Dim msg
Dim instring
Dim tagname
Dim AAAAAA
Dim BBBB
Dim CCCCC
Dim ch
msg = "The following tags triggered this script..." & Chr(13) & Chr(10)
For i = 1 To Adroit.TriggerCount()
    If Adroit.TriggerActive(i) Then
        msg = msg & Adroit.TriggerName(i) & " = "
        msg = msg & Adroit.TriggerValue(i) & Chr(13) & Chr(10)
        instring = Adroit.TriggerValue(i)
    End If
Next

If (Len(instring) = 21) Then
    ch = Mid(instring,7,1) REM prechecks
    If (ch <> "," ) then
        MsgBox "1"+ch
        exit sub
    End if

    ch = Mid(instring,14,1)
    If (ch <> "," ) then
        MsgBox "2"+ch
        exit sub
    End if

    ch = Mid(instring,21,1)
    If (ch <> Chr(10) ) then
        MsgBox "3"
        exit sub REM <LF>
    End if

    AAAAAA = Mid(instring,1,6)
```



```
BBBBBB = Mid(instring,8,6)  
CCCCCC = Mid(instring,15,6)
```

```
REM MsgBox AAAAAA + " " + BBBBBB + " " + CCCCCC
```

```
tagname = AAAAAA+"_A0.rawValue"  
Adroit.SetTag tagname, BBBBBB
```

```
tagname = AAAAAA+"_A1.rawValue"  
Adroit.SetTag tagname, CCCCCC
```

```
End if  
End Sub
```

6. General Notes and Troubleshooting

6.1. Contact Details

Email: support@adroit.co.za and drivers@adroit.co.za

Phone: +27 11 658-8100

Web: www.adroit.co.za

6.2. Adroit Technologies Knowledge Base

For additional information, please refer to our Knowledgebase website:

[Latest Drivers topics - Features, discussions, tips, tricks, questions, problems and feedback \(adroittechnologiesautomation.com\)](http://adroittechnologiesautomation.com)

7. Revisions

7.1. Document Revision

Rev.	Date	Author	Comment	Approval
1.0	14-Dec-2022	J. Duncan	New Format	D. Jordaan
1.1		K. Robinson	Changes to format, updated image resources.	D. Jordaan
2.0				
3.0				
4.0				
5.0				
6.0				

7.2. DLL Revision

Rev.	Date	Changes
1	19-Sep-2019	First official release...