

Checklist Annual Service

Power Solutions

Customer Name / Contact Name		Digiplex / Alexander Olsen											
Generator Set Location / Address		Selma Ellefsensvei 1 / 0581 Oslo											
Generator Set designation		EF 1 anlegg											
Generator Model / Serial No.		Stamford HCI634J1 / 0266956/001											
Engine Model / Serial no.		16V 2000G65 / 536 109 044											
Measuring points	Unit	Measured values											
	Year	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
Engine													
Start time	sec												
Running hours	h	228											
Engine RPM	RPM	1498											
Engine injection	%	NA											
P-Lube Oil	bar	7,2											
P-Fuel	bar	NA											
P-Charge Air	bar	1,40											
T-Lube Oil	°C	72											
T-Coolant	°C	69											
T-Fuel	°C	43											
T-Charge Air	°C	15											
T-Exhaust A	°C	NA											
T-Exhaust B	°C	NA											
Generator													
Power	kW	197											
Voltage L1	V	418											
Voltage L2	V	417											
Voltage L3	V	418											
Current L1	A	281,0											
Current L2	A	279,0											
Current L3	A	266,0											
Frequency	Hz	50,0											
Apparant power	kVA	199,0											
Reactive power	kVAr	-2,0											
cos phi		1,0											
T-Winding L1	°C	NA											
T-Winding L2	°C	NA											
T-Winding L3	°C	NA											
T-Bearing DE	°C	NA											
T-Bearing NDE	°C	NA											
Engine Pre Heater HT													
T-Coolant before start	°C	38,0											
Current L1	A	22,8											
Current L2	A	NA											
Current L3	A	NA											
Engine Pre Heater LT													
T-Coolant before start	°C	NA											
Current L1	A	NA											
Current L2	A	NA											
Current L3	A	NA											
Starting system													
U-Batt. at start max.	V	26,9											
U-Batt. at start min.	V	22,5											
U-Batt. Charger	V	26,9											
R-Startmotor to ground	MΩ	> 1											
U-Alternator (dynamo)	V	27,9											
Simillar load conditions are important to compare performance from year to year.													

Checklist Annual Service

Power Solutions

Customer Name / Contact Name	Digiplex	/	Alexander Olsen
Generator Set Location / Address	Selma Ellefsensvei 1	/	0581 Oslo
Generator Set designation	EF 1 anlegg		
Generator Model / Serial No.	Stamford HCI634J1	/	0266956/001
Engine Model / Serial no.	16V 2000G65	/	536 109 044
Measuring points	Unit	Measured values	
Values to be logged at the end of the test run.			