

Checklist Annual Service

Power Solutions

Customer Name / Contact Name	Digiplex	/ Alexander Olsen
Generator Set Location / Address	Selma Ellefsens vei 1	/ 0581 Oslo
Generator Set designation	B_Anlegg	
Generator Model / Serial No.	Leroy Somer/ LSA 52.3 S7-4P	/ 608991/2
Engine Model / Serial no.	16V 4000G61	/ 527 104 128
Generator Set Running Hours / Date	101 Hours	/ 09.03.2020
System Items	Check	Comments
General		
Visual inspection for general condition	OK	
Visual inspection for leaks	OK	
Check Governor/Connections	OK	
Export engine error logfile *	OK	
Test run at not below 1/3 load and at least until steady-state temperature is reached	OK	
Check for abnormal running noises, exhaust gas color and vibration	OK	
Logg engine operating data	OK	
Logg generator data	OK	
Logg auxilaty data	NA	
Control Panel / LOP		
Control Panel & Wiring, visuell inspection	OK	
Cleanness	OK	
Cable glands, check	OK	
Ground connections	OK	
Wear and tear	OK	
Traces of overheating	OK	
Loose connections	OK	
Emergency stop buttons, check function	OK	
Generator		
Stator	OK	
Visual inspection	OK	
Cleanness	OK	
Cable glands, check	OK	
Ground connections	OK	
Wear and tear	OK	
Traces of overheating	OK	
Loose connections	OK	
Armature	OK	
Visual inspection	OK	
Cleanness	OK	
Cable glands, check	OK	
Ground connections	OK	
Wear and tear	OK	
Traces of overheating	OK	
Loose connections	OK	
Check rotating diodes	OK	
Voltage regulator	OK	
Cleanness	OK	

Checklist Annual Service

Power Solutions

Customer Name / Contact Name	Digiplex	/ Alexander Olsen
Generator Set Location / Address	Selma Ellefsens vei 1	/ 0581 Oslo
Generator Set designation	B Anlegg	
Generator Model / Serial No.	Leroy Somer/ LSA 52.3 S7-4P	/ 608991/2
Engine Model / Serial no.	16V 4000G61	/ 527 104 128
Generator Set Running Hours / Date	101 Hours	/ 09.03.2020
System Items	Check	Comments
Traces of overheating	OK	
Loose connections	OK	
Wear and tear	OK	
Auxiliary equipment	OK	
Air intake, filter	NA	
Space heater	OK	
Bearing DE, lubricate	OK	
Bearing NDE, lubricate	OK	
Temperature sensors, verify function	OK	
Grounding straps	OK	
Rubber mounts, bolts	OK	
Starting System		
Batteries, visual inspection, cleanliness, cracks, signs of overheating	PF	Missing batteri cover
Batteries, check battery acid level	NA	
Battery Charger, check connections	OK	
Starting Motor, check connections	OK	
Starting Motor, insulation condition	OK	
Alternator (dynamo), connections	NA	
Solenoids/valves, visual inspection	NA	
Engine Wiring Harness/Sensors	OK	
Air Intake & Exhaust System		
Air Filters, vacuum indicator	OK	
Air Intake Assembly	OK	
Charge Air Cooler	OK	
Exhaust Assembly	OK	
Turbo Assembly	OK	
Silencer/Muffler	OK	
Intercooler	OK	
Hoses & Connections	OK	
Lubrication System		
Check oil level	OK	
Oil Sample for Analysis *	OK	
Oil Pressure	OK	
Crankcase Ventilation	OK	
Lube Oil System Gasket Seals	OK	
Hoses & Connections	OK	

Checklist Annual Service


Power Solutions

Customer Name / Contact Name	Digiplex	/ Alexander Olsen
Generator Set Location / Address	Selma Ellefsens vei 1	/ 0581 Oslo
Generator Set designation	B Anlegg	
Generator Model / Serial No.	Leroy Somer/ LSA 52.3 S7-4P	/ 608991/2
Engine Model / Serial no.	16V 4000G61	/ 527 104 128
Generator Set Running Hours / Date	101 Hours	/ 09.03.2020

System Items	Check	Comments
Fuel System		
Fuel Line Connections	OK	
Main Filters	OK	
Intermedeate Filters	NA	
Pre Filters	OK	
Check service indicator of fuel prefilter	NA	
Transfer system	OK	
Transfer system Filters	OK	
Setling Tank / Day Tank	OK	
Hoses & Connections	OK	
Coolant System		
Radiator	OK	
Heat Exchanger	NA	
Coolant Sample for Analysis *	OK	
Check relief bores of coolant pump(s)	OK	
Inspect intercooler drain system	OK	
Gaskets/Seals	OK	
Hoses & Connections	OK	
Pre Heater, general check	OK	
Fan Drive & Pulley Assembly	OK	
Inspect condition of drive belts. Adjust tension.	NA	
Maintenance		
Replaced engine oil		
Replaced oil filter(s)		
Crank case ventilation filter(s)		
Replaced fuel filter(s)		
Replaced air filter(s)		
Replaced battery(s)		
Replaced coolant filter(s)		
Replaced coolant		
Replaced hoses		
Replaced fan belts		
Notes, comments or recommended work to be quoted		

Checklist Annual Service

Power Solutions

Customer Name / Contact Name	Digiplex	/ Alexander Olsen
Generator Set Location / Address	Selma Ellefsens vei 1	/ 0581 Oslo
Generator Set designation	B Anlegg	
Generator Model / Serial No.	Leroy Somer/ LSA 52.3 S7-4P	/ 608991/2
Engine Model / Serial no.	16V 4000G61	/ 527 104 128
Generator Set Running Hours / Date	101 Hours	/ 09.03.2020
System Items	Check	Comments
OK: No action required. PF: Potential failure, should be rectified. CF: Critical failure, immediate repair required. NA: Not Applicable. * Feedback will be given when analysed.		
Note: The details appearing in the above record are based on a visual inspection conducted in accordance with recognized technical standards. No liability can be accepted in respect of deficiencies and faults on the components inspected which cannot be identified.		
	09.03.2020	
Service Technician	Date	Customer Representative