

# **Checklist Annual Service**

Power Solutions

	CKIISL P	Annual Service Power Solutions
Customer Name / Contact Name	Digiplex	
Generator Set Location / Address		Ellefsensvei 1 / 0581 Oslo
Generator Set designation / BOS Power project	EF 3 ar	
Generator Model / Serial No.		rd HCl643J1 / 0270162/002
Engine Model / Serial no.	16V 20	·
Generator Set Running Hours / Date	159	/ 25.03.20
System Items	Check	Comments
General		
Visual inspection for general condition	OK	
Visual inspection for leaks	OK	
Check Governor/Connections	OK	
Export engine error logfile *	OK	
Test run at not below 1/3 load and at least until	ОК	
steady-state temperature is reached	OIX	Test run was done at 1/4 load
Check for abnormal running noises, exhaust gas	ОК	
color and vibration		
Logg engine operating data	OK	
Logg generator data	OK	
Logg auxilaty data	NA	
	1	
Control Bonol / LCB		
Control Panel / LOP		
Control Panel & Wiring, visuell inspection	OK	
Cleanness	OK	
Cable glands, check	OK	
Ground connections	OK	
Wear and tear	OK	
Traces of overheating	OK	
Loose connections	OK	
Emergency stop buttons, check function	OK	
	<del>                                     </del>	
	1	
Generator		
Generator Stator	T	
Visuel inspection	OK	
Cleanness	OK	
Cable glands, check	OK	
Ground connections	OK	
Wear and tear	OK	
Traces of overheating	OK	
Loose connections	OK	
=======================================		
	†	
Armature	1	
Visuel inspection	OK	
Cleanness	OK	
Cable glands, check	OK	
Ground connections	OK	
Wear and tear	OK	
Traces of overheating	OK	
Loose connections	OK	
Check rotating diodes	OK	



# **Checklist Annual Service**

Power Solutions

•		diliuai Sei vice	Power Solutions				
Customer Name / Contact Name	Digiple		/ Alexander Olsen				
Generator Set Location / Address		Ellefsensvei 1	/ 0581 Oslo				
Generator Set designation / BOS Power project	EF 3 ar		/ 33091				
Generator Model / Serial No.		rd HCI643J1	/ 0270162/002				
Engine Model / Serial no.	16V 20	00G65	/ 536 110 785				
Generator Set Running Hours / Date	159		/ 25.03.20				
System Items	Check	Comments					
Voltage regulator							
Cleanness	OK						
Traces of overheating	OK						
Loose connections	OK						
Wear and tear	OK						
Auxilary equipment							
Air intake, filter	NA						
Space heater	NA NA						
Bearing DE, lubricate	NA NA						
Bearing NDE, lubricate  Bearing NDE, lubricate	NA NA						
Temperature sensors, verify function	NA NA						
Grounding straps	OK						
Rubber mounts, bolts	OK						
Rubber mounts, boits							
	1						
Starting System							
Batteries, visual inspection,cleaness, cracks,	ОК						
signs of overheating							
Batteries, check battery acid level	NA						
Battery Charger, check connections	OK						
Starting Motor, check connections	OK						
Starting Motor, insulation condition	OK						
Alternator (dynamo), connections	OK						
Solenoids/valves, visual inspection	OK						
Engine Wiring Harness/Sensors	OK						
	+						
Air Intake & Exhaust System	<u> </u>	•					
Air Filters, vacuum indicator	OK						
Air Intake Assembly	OK						
Charge Air Cooler	OK						
Exhaust Assembly	OK						
Turbo Assembly	OK	ļ					
Silencer/Muffler	OK						
Hoses & Connections	OK						
	+						
	+						
Lubrication System							
Check oil level	OK						
Oil Sample for Analysis *	OK						
Oil Pressure	OK						
Crankcase Ventilation	OK						
Lube Oil System Gasket Seals	OK						
Hoses & Connections	OK						
		<u> </u>					



# **Checklist Annual Service**

Power Solutions

Customer Name / Contact Name	Digiplex	x / Alexander Olsen
Generator Set Location / Address		Ellefsensvei 1 / 0581 Oslo
Generator Set designation / BOS Power project	EF 3 ar	
Generator Model / Serial No.		rd HCl643J1 / 0270162/002
Engine Model / Serial no.	16V 20	
Generator Set Running Hours / Date	159	/ 25.03.20
System Items	Спеск	Comments
Fuel System		
Fuel Line Connections	OK	
Main Filters	OK	
Intermedeate Filters	NA	
Pre Filters	OK	
Check service indicator of fuel prefilter	NA	
Transfer system	OK	
Transfer system Filters	OK	
Setling Tank / Day Tank	OK	
Hoses & Connections	OK	
Coolant System		
Radiator	OK	
Heat Exchanger	NA	
Coolant Sample for Analysis *	OK	
Check relief bores of coolant pump(s)	OK	
Inspect intercooler drain system	NA	
Gaskets/Seals	OK	
Hoses & Connections	OK	
Pre Heater, general check	OK	
Fan Drive & Pulley Assembly	OK	
Inspect condition of drive belts. Adjust tension.	OK	
,		
Maintenance		
Replaced engine oil		
Replaced oil filter(s)		
Crank case ventilation filter(s)		
Replaced fuel filter(s)		
Replaced air filter(s)		
Replaced battery(s)		
Replaced coolant filter(s)	1	
Replaced coolant	1	
Replaced hoses	1	
Replaced fan belts	1	
,	1	
	1	
	1	

## Bertel O. Steen Power Solutions AS



# **Checklist Annual Service**

_					~					
$\sim$	$\cap$	۸./	10	r	So	11	111	$\sim$	n	C
	v	V	<i>,</i> .	1	-		4 U	ıv		_

Customer Name / Contact Name	Digiplex						
Generator Set Location / Address		Ellefsensvei 1 / 0581 Oslo					
Generator Set designation / BOS Power project	EF 3 an	00					
Generator Model / Serial No.	Stamfor	rd HCl643J1 / 0270162/002					
Engine Model / Serial no.	16V 200	00G65 / 536 110 785					
Generator Set Running Hours / Date	159	/ 25.03.20					
System Items	Check	Comments					
Notes, comments or recommended work to be que	oted						
Glans on outside at the genset container are loose							
The "Neutral has been earthed in the alternator te							
Documaintation for main cabinet and 400V distru	bution ca	binet is missing					
OK: No action required. PF: Potential failure, shou	ıld be rec	ctified. CF: Critical failure, immediate repair require	ed. <b>NA</b> :				
Not Applicable. * Feedback will be given when and	alised.						
Note: The details appearing in the above record are based on a visual inspection conducted in accordance with recognized technical standards. No liability can be accepted in respect of deficiencies and faults on the components							
inspected which cannot be identified.	accepte	a in respect of deficiencies and faults off the com	ponents				
Helge Breivik og Jan Gunnar Rosseland	25.03.2	0					
Service Technician	Dat	e Customer Representative					