

Checklist Annual Service

		unidai sei vice	Power Solutions
Customer Name / Contact Name	Digiple		/ Alexander Olsen
Generator Set Location / Address		Ellefsensvei 1	/ 0581 Oslo
Generator Set designation / BOS Power project	A-anleg		/ 32069
Generator Model / Serial No.		.3 57-4P	/ 608991/1
Engine Model / Serial no.	16 V 40	000G61	/ 456
Generator Set Running Hours / Date	456		/ 06.10.2020
System Items	Check	Comments	
General			
Visual inspection for general condition	OK		
Visual inspection for leaks	OK		
Check Governor/Connections	OK		
Export engine error logfile *	OK		
Test run at not below 1/3 load and at least until	ОК		
steady-state temperature is reached	OK		
Check for abnormal running noises, exhaust gas	ОК		
color and vibration			
Logg engine operating data	OK		
Logg generator data	OK		
Logg auxilaty data	NA		
Control Panel / LOP			
Control Panel & Wiring, visuell inspection	OK		
Cleanness	OK		
Cable glands, check	OK		
Ground connections	OK		
Wear and tear	OK		
Traces of overheating	OK		
Loose connections	OK		
Emergency stop buttons, check function	OK		
Generator			
Stator	ОК		
Visuel inspection	OK		
Cleanness	OK		
Cable glands, check	OK		
Ground connections	OK		
Wear and tear	OK		
Traces of overheating	OK		
Loose connections	OK		
Armature			
Visuel inspection	OK		
Cleanness	OK		
Cable glands, check	OK		
Ground connections	OK		
Wear and tear	OK		
Traces of overheating	OK		
Loose connections	OK		
Check rotating diodes	OK		

Bertel O. Steen Power Solutions AS



Checklist Annual Service

Customer Name / Contact Name	Digiplex Selma Ellefsensvei 1 A-anlegg LSA 52.3 57-4P 16 V 4000G61		/ Alexander Olsen
Generator Set Location / Address			/ 0581 Oslo
Generator Set designation / BOS Power project			/ 32069
Generator Model / Serial No.			/ 608991/1
Engine Model / Serial no.			/ 456
Generator Set Running Hours / Date	456		/ 06.10.2020
System Items	Check	Comments	



Checklist Annual Service

		dilitual Selvice	Power Solutions	
Customer Name / Contact Name	Digiplex		/ Alexander Olsen	
Generator Set Location / Address		Ellefsensvei 1	/ 0581 Oslo	
Generator Set designation / BOS Power project	A-anleg		/ 32069	
Generator Model / Serial No.		.3 57-4P	/ 608991/1	
Engine Model / Serial no.	16 V 40	000G61	/ 456	
Generator Set Running Hours / Date	456		/ 06.10.2020	
System Items	Check	Comments		
Voltage regulator				
Cleanness	OK			
Traces of overheating	OK			
Loose connections	OK			
Wear and tear	OK			
Auxilary equipment				
Air intake, filter	NA			
Space heater	OK			
Bearing DE, lubricate	OK			
Bearing NDE, lubricate	OK			
Temperature sensors, verify function	OK			
Grounding straps	OK			
Rubber mounts, bolts	OK			
Starting System				
Batteries, visual inspection, cleaness, cracks,	1			
signs of overheating	OK			
Batteries, check battery acid level	NA			
Battery Charger, check connections	ОК			
Starting Motor, check connections	OK			
Starting Motor, insulation condition	OK			
Alternator (dynamo), connections	NA			
Solenoids/valves, visual inspection	NA			
Engine Wiring Harness/Sensors	OK			
Lingine Willing Harriess/Sensors	OK			
Air Intake & Exhaust System				
Air Filters, vacuum indicator	OK			
Air Intake Assembly	OK			
Charge Air Cooler	OK			
Exhaust Assembly	OK			
Turbo Assembly	OK			
Silencer/Muffler	OK			
Hoses & Connections	OK			
Lubrication Custom				
Lubrication System	014	Change delle 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	lia.	
Check oil level	OK	Changed oil and oil fi	ITEF	
Oil Sample for Analysis *	OK			
Oil Pressure	OK			



Checklist Annual Service

	ieckiist <i>F</i>	Annual Service Power Solutions
Customer Name / Contact Name	Digiple	
Generator Set Location / Address	Selma	Ellefsensvei 1 / 0581 Oslo
Generator Set designation / BOS Power project	A-anleg	
Generator Model / Serial No.		.3 57-4P / 608991/1
Engine Model / Serial no.	16 V 40	
Generator Set Running Hours / Date	456	/ 06.10.2020
System Items	Check	Comments
Crankcase Ventilation	OK	Changed ventilation filter
Lube Oil System Gasket Seals	OK	
Hoses & Connections	OK	
Fuel System	1 0	
Fuel Line Connections	OK	
Main Filters	OK	Changed filter
Intermedeate Filters	NA	
Pre Filters	OK	Changed filter
Check service indicator of fuel prefilter	NA	
Transfer system	OK	
Transfer system Filters	OK	
Setling Tank / Day Tank	OK	
Hoses & Connections	OK	
Coolant System		
Radiator	OK	
Heat Exchanger	NA	
Coolant Sample for Analysis *	OK	
Check relief bores of coolant pump(s)	OK	
Inspect intercooler drain system	OK	
Gaskets/Seals	OK	
Hoses & Connections	OK	
Pre Heater, general check	OK	
Fan Drive & Pulley Assembly	OK	
Inspect condition of drive belts. Adjust tension.	NA	
·		
Maintenance		
Replaced engine oil	OK	
Replaced oil filter(s)	OK	
Crank case ventilation filter(s)	OK	
Replaced fuel filter(s)	OK	
Replaced air filter(s)		
Replaced battery(s)		
Replaced coolant filter(s)		
Replaced coolant		
Replaced hoses		
Replaced fan belts		

Bertel O. Steen Power Solutions AS



Checklist Annual Service

Customer Name / Contact Name	Digiplex		/ Alexander Olsen
Generator Set Location / Address	Selma Ellefsensvei 1		/ 0581 Oslo
Generator Set designation / BOS Power project	A-anlegg		/ 32069
Generator Model / Serial No.	LSA 52.3 57-4P		/ 608991/1
Engine Model / Serial no.	16 V 4000G61		/ 456
Generator Set Running Hours / Date	456		/ 06.10.2020
System Items	Check	Comments	

Bertel O. Steen Power Solutions AS



Checklist Annual Service

		Power Solutions
Customer Name / Contact Name	Digiplex	/ Alexander Olsen
Generator Set Location / Address	Selma Ellefsensv	ei 1 / 0581 Oslo
Generator Set designation / BOS Power pro		/ 32069
Generator Model / Serial No.	LSA 52.3 57-4P	/ 608991/1
Engine Model / Serial no.	16 V 4000G61	/ 456
Generator Set Running Hours / Date	456	/ 06.10.2020
System Items	Check Commer	nts
Notes, comments or recommended work to	be quoted	
Missinginsulation at the starter cabel at the	starter	
Cable gland at junction box at theexpansion	n tank should be repaired	
Exhaust mats should be replaced and insul	ationat the end of piping	should be covered
Coolant expansion tank, it is difficult to fill c	ooling water since the tan	k it mounted too high and the cover can
hardly be opened.		
, ,		
OK. No potion required BE. Detectiol failur	a alaa dalla aaastii aal OF a	Original failure in an adiata and in an animal MA. Na
		Critical failure, immediate repair required. NA: No
Applicable. * Feedback will be given when a	analised.	
Note: The details appearing in the above re recognized technical standards. No liability inspected which cannot be identified.		al inspection conducted in accordance with oct of deficiencies and faults on the components
Helge Breivik	8.10.2020	
Service Technician	Date Cus	stomer Representative