



सेंट्रल ट्रान्समिशन यूटिलिटी ऑफ इंडिया लिमिटेड

(पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड के स्वामित्व में)

(भारत सरकार का उद्यम)

CENTRAL TRANSMISSION UTILITY OF INDIA LTD.

(A wholly owned subsidiary of Power Grid Corporation of India Limited)

(A Government of India Enterprise)

Ref: CTU/N/00/CMETS_NR/31

Date: 16-07-2024

As per distribution list

Subject: 31st Consultation Meeting for Evolving Transmission Schemes in Northern Region-Minutes of Meeting

Dear Sir/Ma'am,

Please find enclosed the minutes of the 31st Consultation Meeting for Evolving Transmission Schemes in Northern Region held on 27th June, 2024 (Thursday) through virtual mode.

The minutes are also available at CTU website (www.ctuil.in)

Thanking you,

Yours faithfully,

Kashish Bhambhani
16/07/24

(Kashish Bhambhani)
General Manager (CTU)

Distribution List:

Chief Engineer (PSP&A – I) Central Electricity Authority Sewa Bhawan, R.K.Puram, New Delhi-110 066	Member Secretary Northern Regional Power Committee 18A, Shaheed Jeet Singh Sansanwal Marg, Katwaria Sarai, New Delhi – 110 016
Director (Power System) Solar Energy Corporation of India Ltd. D-3, 1 st Floor, A wing, Religare Building, District Centre, Saket, New Delhi-110017	Director Ministry of New and Renewable Energy, Block 14, CGO Complex, Lodhi Road, New Delhi-110003
Director (SO) Grid Controller of India Limited (erstwhile Power System Operation Corporation Ltd.) 9 th Floor, IFCI Towers, 61, Nehru Place, New Delhi-110 016	Executive Director Northern Regional Load Despatch Centre 18-A, Qutab Institutional Area, Shaheed Jeet Singh Sansanwal Marg, Katwaria Sarai, New Delhi– 110 016
Director (P&C), HPPTCL, Headoffice, Himfed Bhawan,Panjari, Shimla-171005, Himachal Pradesh	Director(W&P) UP Power Transmission Company Ltd. Shakti Bhawan Extn, 3rd floor, 14, Ashok Marg, Lucknow-226 001
Director (Technical) Punjab State Transmission Corporation Ltd. Head Office, The Mall, Patiala 147001, Punjab	Director (Projects) Power Transmission Corporation of Uttarakhand Ltd. Vidyut Bhawan, Near ISBT Crossing, Saharanpur Road, Majra, Dehradun.
Development Commissioner (Power) Power Development Department Grid Substation Complex, Janipur, Jammu	Director (Technical) Rajasthan Rajya Vidyut Prasaran Nigam Ltd. Vidyut Bhawan, Jaipur, Rajasthan-302005.
Member (Power) Bhakra Beas Management Board Sector-19 B, Madhya Marg, Chandigarh - 160019	Superintending Engineer (Operation) Electricity Circle, 5 th Floor, UT Secretariat, Sector-9 D, Chandigarh - 161009
Director (Operations) Delhi Transco Ltd. Shakti Sadan, Kotla Road, New Delhi-110 002	Director (Technical) Haryana Vidyut Prasaran Nigam Ltd. Shakti Bhawan, Sector-6, Panchkula-134109, Haryana

Distribution List:

Shri Ranjan Chhibba Additional Director Sunflag Power Limited D-47, 2 nd Floor Defence Colony, New Delhi-110024 Ph.: 9810172113, 6398668185 Email: rrc@sunflagsteel.com ; rajeev_pandey@sunflagsteel.com ;	Shri Ravindra Shekhawat Senior Manager HHP Two Private Limited 3rd Floor, Jmd Regent Arcade Mall, Haryana Ph.: 9784964606, 9871544211 Email: maharashtra@hygenco.in ; shashank@hygenco.in ;
Shri Amarjeet Singh Joint Vice President (Power Business) Shree Cement Limited SB-187, Bapu Nagar, Opp Rajasthan University JLN Marg, Jaipur, Rajasthan-302015 Ph.: 9116102490, 9214337406 Email: amarjit.singh@shreecement.com shyam.khandelwal@shreecement.com	Shri Pushpinder Hira Manager Greenko UP01 IREP Private Limited 15th Floor, Hindustan Times House, 18-20 KG Marg, Delhi Ph.: 8510967977, 9958355966 Email: pushpinder.h@greenkogroup.com connectivity.lta@greenkogroup.com
Shri Amrik Singh General Manager Chenab Valley Power Projects Pvt Limited Chenab Jal Shakti Bhawan, Opposite Saraswati Dham, Rail Head Complex, Jammu - 180012, J&K (UT) Ph.: 9560455326, 9419792461 Email: amriksingh@cvppindia.com mohanlal.cvpp@nic.in	Shri Ankur Jain Senior Divisional Electrical Engineer Indian Railways DRM Office, near Rail Vihar, Northern Railway, Ambala Cant, Haryana Ph.: 9729539301, 7496939013 Email: srdeetrdumb@gmail.com openaccessumb@gmail.com
Shri Harsha Vishal Kedia Manager- Renewable Power Business Hindustan Zinc Limited Yashad Bhawan, Udaipur, Rajasthan Ph.: 9769410638, 9769410638 Email: harsha.kedia@vedanta.co.in vishnu.khandelwal@vedanta.co.in	Shri Rajeev Thanvi Manager Solarcraft Power India 4 Private Limited 109, First Floor, Rishabh IPEX Mall, IP Extension Patparganj, Delhi – 110092 Ph.: 9462617997, 7838568948 Email: rajeev.thanvi@blupineenergy.com ; ankur.pathak@blupineenergy.com ;
Shri Ajay Kumar Atrea Authorised Signatory Prerak Solar Urja Private Limited L-11, Green Park Extension, New Delhi-110016 Ph.: 9650999982, 8130696120 Email: ajayatrea@arightgreentech.com ; sandeep@arightgreentech.com ;	Shri Kura Ravi Kumar Addl GM PE Electrical NTPC Limited NTPC Bhawan, Scope Complex, 7 Institutional Area, Lodhi Road, Delhi Ph.: 9440909149, 9650996993 Email: kuraravikumar@ntpc.co.in ; abhishekkhanna@ntpc.co.in ;
Shri Vaibhav Kapoor Assistant Vice President ABREL (RJ) Projects Limited Aditya Birla Renewables Subsidiary Limited 8th Floor Parsvnath Capital Towers Bhai Vir Singh Marg, New Delhi Ph.: 9582430361, 9810613998 Email: vaibhav.kapoor@adityabirla.com ; rajuram.choudhary@adityabirla.com ;	Shri Angshuman Rudra GM Avaada Energy Private Limited Avaada Waterbattery Private Limited Avaada Rjbikaner Private Limited C-11, Sector-65, Noida, Uttar Pradesh Ph.: 7835004673, 9818003951, 7835099717 Email: angshuman.rudra@avaada.com ; ashish.shukla@avaada.com ;

	vivek.jain@avaada.com ;
Shri Vikram Malkotia Director Gamma Renewables India Project One Private Limited Pravat Renewables India Project Pvt Ltd B-208 & 209 Pioneer Urban, Square, 2nd Floor, Sector 62, Air Force, Gurgaon, Haryana-122005 Ph.: 8800917799, 9717855521 Email: vikram.malkotia@upcrenewables.com ; alok.nigam@upcrenewables.com ;	Shri Rajesh Sodhi Head Secretarial Acme Cleantech Solutions Private Limited Plot No. 152, Sector-44, Gurugram, Haryana 122002 Ph.: 9811633237, 8744060601 Email: rajesh.sodhi@acme.in ; yogesh@acme.in ;
Shri Radheshyam Goyal Head of Projects Enfinity Global Surya Kiran Private Limited Andhra Pradesh Resco Rooftop Solar Pvt Ltd D.No.8-2-610/68/1,2,3, Accord Blu, 5th Floor, Road.No.10, Banjara Hills, Hyderabad, Telangana Ph.: 9212176421, 9334398618 Email: radhe_goyal@enfinityglobal.com ; sandeep_anand@enfinityglobal.com ;	Shri Ajay Kumar Singh Chief Executive Officer SJVN Green Energy Limited Corporate Headquarters, Shakti Sadan, Shanan, Shimla, Himachal Pradesh-171006 Ph.: 9418480402, 7018402406 Email: business.expansion@sjvn.nic.in ; cs0.sgel@sjvn.nic.in ;
Shri Dhir Singh Senior Manager Green Infra Wind Energy Limited Green Infra Clean Wind Limited Green Infra Clean Solar Farms Limited Green Infra Renewable Projects Limited 5th Floor, Tower C, Building No. 8, DLF Cybercity, Gurugram -122 002, Haryana Ph.: 9993846698, 8700379285, 9810641419 Email: dhir.singh@sembcorp.com ; vivek.hooda@sembcorp.com ; ankur.rajan@sembcorp.com ; connectivity.India@sembcorp.com ;	Shri Vikash Kumar Lead BD Hinduja Renewables Energy Private Limited Unit No. 1, Ground Floor, Boston House, Suren Road, Off Andheri-Kurla Road, Andheri East, Mumbai, Maharashtra-400093 Ph.: 9971879862, 7206156785 Email: vikash.jha@hindujarenewables.com ; arun.kumar@hindujarenewables.com ;
Shri Saurabh Sharadbhai Mehta Authorized Signatory Furies Solren Private Limited B-Block, 6th Floor, Embassy 247, Vikhroli West, Mumbai, Maharashtra – 400083 Ph.: 9930674683, 7838568948 Email: mehta.saurabh2@mahindra.com ; pathak.ankur@mahindra.com ;	Shri Animesh Manna DGM NTPC Renewable Energy Limited NETRA Building, E-3, Ecotech-II, Udyog Vihar, Greater Noida, Uttar Pradesh – 201306 Ph.: 9650997835, 9650991445 Email: amanna@ntpc.co.in ; rajivgupta@ntpc.co.in ;
Shri Naveen Munjal Authorized Signatory Apraava Energy Private Limited 7th Floor, Fulcrum, Sahar Road, Andheri East, Mumbai, Maharashtra – 400099 Ph.: 9867868868, 8433723582 Email: naveen.munjal@apraava.com ; gopal.eti@apraava.com ;	Shri Vinod V Halge Assistant Vice President Saurya Urja Company of Rajasthan Limited R7-A, 3 rd Floor, Crystal Palm Mall, Plot No. 2 Sahkar Circle, Sardar Patel Marg, Jaipur, Rajasthan-302001 Ph.: 9116032104, 9717322665 Email: vinod.halge@sauryaurla.com ; bibhu.biswal@ilfsindia.com ;

Shri Pavan Kumar Gupta Authorized Signatory Juniper Green Energy Private Limited Plot No. 18, 1st Floor, Institutional Area, Sector - 32, Gurgaon, Haryana - 122001 Ph.: 9560540654, 9910509744 Email: pavan.gupta@junipergreenenergy.com ; bd@junipergreenenergy.com ;	Shri Aniket Vyas Director Iraax International (Opc) Private Limited R-3, Tilak Marg, civil Lines, Jaipur, Rajasthan- 302005 Ph.: 9571724543, 9413333984 Email: iraaxinfo@gmail.com ; law.uni.aniketvyas@gmail.com ;
Shri Pradeep Chauhan Director Anboto Solar Private Limited Level 1, Southern Park Building, D-2 District Center Saket, New Delhi- 110017 Ph.: 9870195134, 7303391821 Email: pradeep.chauhan@solarpack.es ; rohit.ahuja@solarpack.es ;	Shri K A Vishwanath General Manager Project Development Solalite Power Private Limited DLF Square, 8th Floor, Jacaranda Marg, DLF Phase 2, Sector 25, Gurugram, Haryana 122002 Ph.: 9911917083, 9711486060 Email: pe@o2power.in ; ka.vishwanath@o2power.in ;
Shri Amit Kumar Authorised Signatory Renew Solar Power Private Limited Renew.Hub, Commercial Block-1, Zone-6, Golf Course Road, DLF City Phase V, Gurugram, Haryana 122009 Ph.: 9717196796, 9873462717 Email: amit.kumar1@renew.com ; mohit.jain@renew.com ; solarbidding.gm@renew.com ;	Smt. Poorva Pitke Senior Manager Sprng Renewable Resources Private Limited Sprng Urja Private Limited Upper Ground, Office A-001, Pentagon 5, Magarpatta City, Hadapsar Pune, Maharashtra 411013 Ph.: 9545659577, 8149855176 Email: poorvapitke@sprngenergy.com ; abhinavbhansali@sprngenergy.com ;
Shri S Sri Murali Chief Operating Officer Axis Energy Ventures India Private Limited 2nd Floor, Plot no. 3, H.No-6-3-680/8/3, PMR Plaza,Thakur Mansion Lane, Somajiguda, Hyderabad-500082,Telangana Ph.: 8008749990, 9502212277 Email: murali.ss@axisenergy.in ; rambabu.m@axisenergy.in ;	Shri Adrit Palchoudhury Vice President CESC LTD Cesc House, Chowringhee Square, Kolkata- West Bengal 700001 Ph.: 9163302198, 9163302164 Email: adrit.palchoudhury@rpsg.in ; sushanta.basumatary@rpsg.in ;
Shri Rajesh Kumar Manager Azure Power India Private Limited Southern Park, 5th Floor, D-II, Saket Place Saket, New Delhi -110017 Ph.: 8769266777, 9599822006 Email: ists@azurepower.com ; wind.pd@azurepower.com ; shashank.gupta@azurepower.com ;	

Minutes of 31st Consultation Meeting for Evolving Transmission Schemes in Northern Region held on 27.06.2024

The 31st Consultation Meeting for Evolving Transmission Schemes in Northern Region (CMETS-NR) was held through VC on 27/06/2024. List of participants is enclosed at Annexure-XII.

A. Application related matters in Northern Region

A1. Resumption of meeting for allocation of connectivity in Northern Region in view of APTEL order dated 28.05.2024 on petition nos. 50, 51, 79, 82 & 160 of 2024

It was informed that CERC vide order dated 19.01.24 on petition no. 268/MP/2023 & 269/MP/2023 had directed CTUIL to carry out fresh reallocation exercise for the meetings held on 20.06.23 and 03.08.23 or any subsequent reallocation meeting held for substations in Rajasthan with stipulated directions. M/s Project Nine had approached the Appellate Tribunal impugning the Hon'ble Commissions Order dated 19.01.2024. Subsequently, CTUIL also preferred it's appeals before the Hon'ble Tribunal impugning the subject Order. Hon'ble Tribunal had directed CTU to not hold allocation/reallocation meetings for the next 10 days pending adjudication on the application which was later extended till further orders. In view of the above, the meetings for allocation of connectivity in Northern Region could not be held.

Recently, Hon'ble APTEL vide order dated 28.05.2024 on petition no. 50, 51, 79, 82 & 160 of 2024, set aside the CERC Order dated 19.01.2024 on petition no. 268/MP/2023 & 269/MP/2023. In view of the above, the meetings for allocation of connectivity in Northern Region are being resumed.

It was also informed that applications for connectivity/GNA/GNA_{RE} received from Dec'23 onwards till May'24 are to be taken up by CTUIL for discussion and grant. Two applications for connectivity received in Nov'23 by ACME are also due for discussion and grant. However, considering the large no. of applications, in the present meeting, applications received till Feb'24 shall be discussed in the present meeting. The subsequent applications received in the month of March'24, April'24 & May'24 shall be taken up for discussion in the subsequent CMETS NR meetings.

B. Conventional Applications for Connectivity/GNA/GNA_{RE}

B1. Connectivity Application for 60 MW Hanol Tuni HEP from M/s Sunflag Power Limited received under GNA Regulations:

S. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
1.	2200000357	Sunflag Power Limited	Dehradun distt., Uttarakhand	15.11.2023	Generating station(s), including REGS(s), without ESS (Hydro)	LOA or PPA	60 MW	25.09.2028	Mori S/s

It was informed that Connectivity application from M/s Sunflag Power Limited (SPL) for 60 MW hydro project in Yamuna basin of Uttarakhand was discussed in the 27th NR-CMETS meeting held on 10/01/2024. Connectivity point requested by the Applicant is Mori substation (earlier planned to be developed under ISTS).

Regarding Mori Substation, it was deliberated that for evacuation of power from various hydro projects including Naitwar Mori HEP in Yamuna Basin of Uttarakhand, Mori Substation along with 220 kV D/c Mori - Dehradun (Twin Zebra) line was planned under UITP scheme for implementation by PTCUL as deemed ISTS scheme. However, during the 3rd NRPC(TP) held on 19/02/2021, it was agreed that Naitwar Mori HEP would be connected to STU system for evacuation of power from their HEP, as no other hydro project in Yamuna basin is expected within next 2-3 years. Therefore, implementation of 220 kV D/c Mori-Dehradun line shall be considered in future under Central sector with materialization of other projects in Yamuna basin.

The present Connectivity application from M/s Sunflag is for the time frame Sep'2028. It was also deliberated that presently, there is no other Connectivity application received from any hydro generators in Yamuna Basin. Accordingly, following transmission system was proposed for Hanol Tuni HEP only in 27th CMETS-NR meeting:

Details of Transmission System required for Connectivity under GNA:

A. Under scope of Applicant:

- Hanol Tuni HEP- Mori Substation 220 kV D/c line along with 220 kV bays at both ends

B. Under ISTS:

- Establishment of 220 kV Switching Station at Mori
- Mori switching station-Dehradun (PG) 220 kV (Twin Zebra#) D/c line

#Line Capacity to be decided based on power transfer requirement as the project capacity is only 60 MW and 220 kV D/c shall not be optimally utilized for the same

However, during the meeting, CEA opined that there may be other hydro generation projects of UJVNL in that basin which may be seeking Connectivity at Mori Substation in future. Further, CEA also confirmed that Hanol Tuni HEP falls under hydro potential area in Yamuna basin in Uttarakhand. However, CTU confirmed that at present, there is no Connectivity application received under GNA Regulations in Yamuna basin. In view of this, substantial investment of a pooling station and 220 kV D/c line may not be justified for only 60 MW of generation. Further 220 kV D/c (considering N-1 scenario) shall also be sub-optimally utilized (30 MW per circuit), till any other generator utilises the same.

During the 27th NR-CMETS meeting, PTCUL informed that Govt. of Uttarakhand has cancelled the allocation of Hanol Tunj HEP to M/s Sunflag and has allotted it to UJVNL. On this, M/s Sunflag informed that, this matter is presently subjudiced and they have applied for the Connectivity under ISTS before the matter went under litigation (in Dec'23). Therefore, in regard to PTCUL comments on the allocation of Hanol Tunj project to UJVNL, M/s Sunflag was required to submit status of litigation associated with this generation project in Uttarakhand. Subsequently, M/s Sunflag vide email dated 07/06/2024 informed that the matter is still under litigation in High court of Uttarakhand and allotment of the project would depend on the petition's outcome.

In view of above, latest status of the Hanol Tunj project was asked from PTCUL, Sunflag & UJVNL. M/s Sunflag updated that Uttarakhand Govt. had cancelled the allocation of their project on 05/12/2023 and subsequently, they had approached High Court and the final order is still awaited. CTUIL highlighted that court proceeding may take some time but the Connectivity application needs to be processed in a time bound manner. In case there is no clarity about the project allocation, M/s Sunflag may withdraw their application and apply again after allocation of the project. M/s Sunflag stated that the next hearing on this petition is scheduled on 30/07/2024 and requested to defer the matter only till then post which final decision may be taken. CTU also indicated that in case of connectivity grant to M/s Sunflag, they will have to submit requisite Con BGs in 1 month period from grant and in view of above project allocation issue & ongoing litigation, whether they will be able to proceed with BG submission. M/s Sunflag submitted that it shall be an issue & they shall have to consult their management in this regard.

UJVNL added that as the project has been allocated to them, they have started the DPR preparation & ground activities for the Hanol Tunj hydro project and they shall apply for Connectivity under ISTS for this project in due course.

CEA and UJVNL also added that Connectivity should not be granted to M/s Sunflag for the Hydro project whose allocation is already cancelled. Further, CEA enquired from UJVNL about any other hydro projects coming up in Yamuna Basin. UJVNL informed that there are two more hydro projects namely Tunai Plaso (72 MW) & Aarakot Tiuni (81 MW) coming up in Yamuna Basin.

Accordingly, in view of above, CTUIL deliberated that all applications received by CTUIL have to be processed in stipulated time lines and cannot be put on hold for indefinite time. Therefore, M/s Sunflag shall update the outcome of hearing scheduled on 30/07/24. Accordingly, the matter shall be deliberated in the CMETS-NR meeting scheduled after 30/07/24, wherein final decision shall be taken up in consultation with all the stakeholders.

B2. Application for Grant of GNA_{RE} to entities other than STU under Regulation 20.1, 20.3 and 20.4 to entities under Regulation 17.1(ii), (iii), (v) & (vi):

SI No.	Application ID	Name of the Applicant	Submission Date	Region	Nature of applicant	GNA _{RE} within Region (MW)	GNA _{RE} outside Region (MW)	Total Quantum (MW) of GNA _{RE} Required	Start date of GNA _{RE}	End date of GNA _{RE}
1	2200000272	HHP Two Pvt. Limited	06.10.2023	NR	Bulk consumer seeking to connect to ISTS at Sonipat (PG)	0.0	110	110	01.05.2026	01.05.2051

It was informed that ,as per the discussion held in the 27th CMETS NR meeting held on 10.01.2024, HHP Two vide email dated 11.01.24 provided the project coordinates near Panipat. Based on the location, it was observed that the project is at a distance of about 50 km from Sonipat (PG) S/s. POWERGRID vide mail 18.12.23 confirmed the space availability for 2 nos. of 220kV line bays at Sonipat(PG). From the studies, it is observed that considering existing and future 220 kV interconnections of HVPN, there is sufficient margin available at 400/220KV Sonipat(PG) ICTs (2x315+1x500 MVA) for grant of GNA_{RE} of 110MW to M/s HHP Two. Accordingly, it was proposed to grant GNA_{RE} of 110 MW (outside the region) through 220 kV D/c line to Sonipat(PG).

M/s HHP Two Pvt. Ltd. Informed that due to unclear status of IOCL Green Hydrogen tender, they are withdrawing the present application. Subsequently, M/s HHP Two Pvt. Limited vide mail dated 28/06/2024 confirmed the application withdrawal.

Accordingly, the application shall be closed as per GNA Regulations.

B3. Applications for Connectivity to ISTS under CERC (Connectivity & General Network Access to the inter-State Transmission System) Regulations, 2022 (Conventional)

SI. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
1.	2200000400	NTPC Limited	Sonebhadra distt., Uttar Pradesh	11.12.2023	Generator (Thermal)	-	1600	01.03.2028	Vindhyachal Pooling Station
2.	2200000494 (Enhancement)	Shree Cement Limited	Beawar, Ajmer distt., Rajasthan	22.01.2024	Generator (Thermal)	-	44	31.03.2024	At Shree Cement Generation plant
3.	2200000527	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	25.01.2024	Standalone ESS (Pumped Storage)	-	672	01.07.2027	-
4.	2200000529	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	-	672	16.12.2027	
5.	2200000524	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	-	672	16.11.2026	
6.	2200000525	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	-	672	01.02.2027	

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
7.	2200000526	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	-	672	16.04.2027	
8.	2200000528	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	-	672	16.04.2027	
9.	2200000553	Avaada Waterbattery Private Limited	Sonbhadra distt., Uttar Pradesh	06.02.2024	Standalone ESS (Pumped Storage)	-	1120	31.03.2028	
10.	2200000496	Chenab Valley Power Projects Private Limited	Kishtwar distt., Jammu and Kashmir	06.02.2024	Generator (Hydro)	-	624	01.11.2025	Kishtwar Pooling Station

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
1.	2200000400	NTPC Limited	Sonebhadra distt., Uttar Pradesh	11.12.2023	Generator (Thermal)	-	1600	01.03.2028	Vindhyachal Pooling Station	NA
It was informed that M/s NTPC Limited has applied for connectivity for 1600 MW (2x800MW) for its power plant Singrauli Stage-III at Singrauli complex(UP). The nearest substation for connectivity indicated by M/s NTPC is Vindhyachal pooling station (WR). The Application along with broad transmission scheme is already discussed in the recent Joint study meetings followed by CMETS WR Meetings. Accordingly, as the above connectivity application is already being processed by Western Region(CTU), the same will be taken up for further discussion only in WR CMETS meetings. NTPC did not attend the meeting.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
2.	2200000494 (Enh.)	Shree Cement Limited	Beawar, Ajmer distt., Rajasthan	22.01.2024	Generator (Thermal)	-	44	31.03.2024 (to be revised as 30.09.24)	At Shree Cement Generation plant	- Conn BG1: Rs. 50 Lakh - Conn BG2: NIL - Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Shree Cement has been granted connectivity of 300 MW through LILO of one circuit of Kota-Merta 400 kV D/c line which is already effective. M/s Shree Cement has applied for enhancement of connectivity for 44 MW for existing captive generation plant (2x19 MW +1x6 MW) situated in close proximity to the above 300 MW power plant at Beawar. At present, 44 MW captive power plant is connected with RVPN system & Shree Cement now intends to disconnect the above 44 MW power plant from RVPN and connect the same with ISTS system. M/s Shree Cement has obtained the necessary NoC from RVPN										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
and the same is also submitted to CTUIL along with the application. RVPN has issued NOC for separating the above 44 MW generation capacity out of 319 MW capacity operating in parallel with RVPN system with the condition that 44 MW generation shall be physically & electrically isolated from balance of 319 MW. M/s Shree Cement has informed that, they shall connect the 11 kV Bus Bar of existing 44 MW captive plant with 300 MW ISTS connected power Plant's auxiliary bus of 6.6kV through already existing 2 numbers of Generation Transformers of Capacity 31.5 MVA each with new 6.6 kV Cables. Status of same may also be provided by M/s Shree Cement. From the studies, it was observed that there is sufficient margin available in the existing corridors interconnected at 400 kV Shree Cement. Accordingly, it was proposed to grant connectivity of 44 MW through the existing system beyond 400 kV Shree Cement generation switchyard. Further, it was also informed that, M/s Shree Cement Limited has requested Start Date of Connectivity under GNA from 31/03/2024. However, as the requested date has already elapsed, M/s Shree Cement may confirm the revised connectivity start date considering time required for regulatory compliances such as intimation issuance, BG submission, issuance of final intimation & signing of connectivity agreement. M/s Shree Cement in the meeting & subsequently vide letter dated 27/06/2024 confirmed 30.09.2024 as the revised start date of connectivity. Accordingly, it was agreed to grant connectivity to M/s Shree Cement with revised start date of connectivity from 30.09.2024. Transmission system for connectivity of M/s Shree Cement Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Interconnection of 11 kV Bus Bar of existing 44 MW captive plant with 300 MW ISTS connected power Plant's auxiliary bus of 6.6kV through already existing 2 numbers of Generation Transformers of Capacity 31.5 MVA each with new 6.6 kV Cables. C. <u>Transmission system for Connectivity under GNA</u> (i). Existing system beyond 400 kV Shree Cement generation switchyard Start Date of Connectivity: 30.09.2024										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
3.	2200000527	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	25.01.2024	Standalone ESS (Pumped Storage)	Connectivity:672 Max Injection: 610 Max Drawl:672	01.07.2027	-	• Conn BG1: Rs. 50 Lakh • Conn BG2: NIL(Bay under Applicant Scope) • Conn BG3; Rs. 2 lakh/MW
It was informed that M/s Greenko UP01 IREP Private Limited has applied for connectivity for 672 MW (Max. Drawl: 672 MW, Max. Injection: 610 MW) for the proposed pumped Storage project in Sonbhadra district(UP). Further, M/s Greenko has also filed additional 5 no. applications of 672 MW each, making the total connectivity quantum of 4032 MW. It was also informed that M/s Greenko vide letter dated 21.05.2024 has mentioned that typically during Peak Solar hours, the Pump Storage Projects shall be drawing power upto the extant of 4032 MW(6x672 MW) & during non solar hours Pump Storage Projects shall be generating upto the maximum extent of 3660 MW(6x610 MW). Accordingly, for evolving the transmission scheme, the above-mentioned maximum values of drawl and Generation may be considered. Further, in order to deliberate on planning of transmission System for evacuation of Power from Pumped Storage Plants, a meeting under Chairmanship of Chairperson, CEA was held on 28.05.2024. In the above meeting, it was decided that CTUIL while granting Connectivity to PSPs shall mention that PSPs shall not operate in generating mode during high RE generation period and if required, PSPs may inject power during high RE generation period based on margin available in the system. CEA in the present meeting confirmed that the Sonbhadra area may be considered as a potential zone for pumped storage projects. Accordingly, the transmission system for connectivity of M/s Greenko at Roberstganj PS shall be considered as common transmission system. CEA also informed that TOR has been issued to M/s Greenko Sonbhadra PSP (3660 MW) and presently under S&I. Considering above, comprehensive transmission scheme is evolved for evacuation of power from Pumped Storage plants in Sonbhadra district. Accordingly, it was proposed to grant connectivity to M/s Greenko at proposed Robertsganj pooling station. M/s Greenko agreed for the same and informed that the 400 kV bays at Roberstganj PS end shall be under their scope. It may be noted that the transmission scheme for Pumped Storage plants in Sonbhadra district is presently under discussion. The scheme is currently tentative, which shall be finalized in subsequent CMETS-NR and other regions (ER & WR) CMETS meeting among CEA, CTUIL, Grid India & Stakeholders. The detailed transmission system shall be informed upon finalization and approval of the scheme. Further, NR-WR inter regional scheme to relieve loading of 765 kV Vindhyachal – Varanasi D/c line shall also be required for connectivity of Pumped Storage Projects in Sonbhadra district. The NR-WR inter regional scheme is already discussed in WR Joint study meeting and to be taken up for stakeholder consultation in subsequent CMETS-NR and CMETS-WR meeting. M/s Greenko informed that for some applications, CTUIL has considered Start date beyond the requested start date. M/s Greenko asked CTUIL to explore implement transmission system in Phases so that some elements can be implemented early matching with the start date requested by M/s Greenko. Regarding this, CTUIL informed that as the scheme is yet to be approved, considering the minimum time required for approval, bidding & implementation (about 35 months),									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
the transmission system for connectivity is expected to be commissioned by 31.05.2027. Therefore, wherever start date earlier than 31.05.2027 is requested, start date of connectivity to M/s Greenko is being granted matching with the expected system commissioning date(31.05.2027). For remaining applications where start date requested is later than 31.05.2027, the requested start date is considered. Regarding phasing of transmission system, CTUIL informed that as per the schedule provided by Greenko 4 out of 6 units of Greenko PSP are coming up on or before expected date of transmission system. Remaining units are scheduled to be commissioned in July'27 & Dec'27. Therefore, considering the short gap between the above schedules, the entire tr. scheme is being taken up together without any phasing . M/s Greenko noted the same. CTUIL informed that for reactive power support, a 400 kV 125 MVAR bus reactor may be considered at Greenko PSP switchyard as part of connectivity. M/s Greenko informed that, as this is a pump storage project, it has inherent capability to provide dynamic as well as static reactive compensation. Therefore, bus reactor will not be required in this case. CEA informed that as per their DPR, all units of M/s Greenko are capable of operating in synchronous condenser mode. Greenko clarified that they had received similar apprehension for their a Pinnapuram project(SR) as well where they have agreed to operate PSP units in synchronous condenser mode as per the reactive power requirement of the grid. On similar lines, M/s Greenko agreed to operate Sonbhadra PSP units in synchronous condenser mode as per the reactive power requirement of the grid. Accordingly, it was agreed to remove the requirement of 1x125 MVAR Bus reactor at Greenko end. However, M/s Greenko shall also keep future provision of Bus Reactor so that in case of future requirement the same can be installed by the applicant.. Consequent to the grant and submission of requisite BGs, any risk related to PSP project (approval/implementation) shall vest with M/s Greenko and treatment of BGs shall be in line with CERC regulations. It was also informed that M/s Greenko UP01 IREP Private Limited has requested Start Date of Connectivity under GNA from 01.07.2027. Considering the same and expected date of commissioning of transmission system (i.e 31.05.2027), it was agreed to grant connectivity with the start date of Connectivity under GNA as 01.07.2027(interim). M/s Greenko noted the same. Transmission system for connectivity of M/s Greenko UP01 IREP Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> <u>A. Transmission System under applicant scope</u> (i). Common Pooling station for Pumped Storage Projects of M/s Greenko UP01 IREP Private Limited (App. No. 220000527-672 MW, 220000529-672 MW, 220000524-672 MW, 220000525-672 MW, 220000526-672 MW & 220000528-672 MW) – Robertsganj Pooling Station 400 kV 2xD/c line(suitable to carry minimum 1400 MW per circuit at nominal voltage)*									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
<i>*Minimum One unit to operate in Synchronous Condenser mode as per the requirement of the grid</i> B. <u>Transmission system for Connectivity under GNA (Tentative):</u> (i). Establishment of 5x1500 MVA 765/400 kV Robertsganj Pooling Station near Robertsganj area in Sonbhadra distt. Uttar Pradesh (ii). LILO of both circuits of 765 kV Varanasi- Gaya 2xSc line at Robertsganj Pooling Station (iii). Establishment of 765/400 kV 2x1500 MVA Prayagraj substation near Prayagraj(Uttar Pradesh) (iv). Prayagraj – Sohawal 400 kV D/c line (Quad) (v). LILO of 765 kV Fatehpur-Varanasi S/c line at Prayagraj S/s (vi). LILO of 765 kV Fatehpur-Sasaram S/c line at Prayagraj S/s (vii). Robertsganj PS – Prayagraj S/s 765 kV D/c line along with 240 MVar line reactor for each circuit at Robertsganj end. <u>Additional Inter regional (WR-NR)Transmission system for Connectivity under GNA (Tentative):</u> (i). 765kV Vindhyachal Pool - Prayagraj D/c line along with 240MVar line reactor (switchable) at Prayagraj end on each ckt of 765kV Vindhyachal Pool - Prayagraj D/c line (ii). Bypassing of both ckts of 765kV Sasan – Vindhyachal Pool 2xS/c line at Vindhyachal Pool and connecting it with 765kV Vindhyachal Pool - Prayagraj D/c line, thus forming 765kV Sasan - Prayagraj D/c line Start Date of Connectivity: 01.07.2027(interim). Final date shall be confirmed upon award of the system									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
4.	2200000529	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	Connectivity:672 Max Injection: 610 Max Drawl:672	16.12.2027	-	• Conn BG1: Rs. 50 Lakh • Conn BG2: NIL(Bay under Applicant Scope) • Conn BG3; Rs. 2 lakh/MW
It was informed that M/s Greenko UP01 IREP Private Limited has applied for connectivity for 672 MW (Max. Drawl: 672 MW, Max. Injection: 610 MW) for the proposed pumped Storage project in Sonbhadra district(UP). As discussed with the previous applications of M/s Greenko, it was proposed to grant connectivity to M/s Greenko at proposed Robertsganj pooling station. For this application, M/s Greenko UP01 IREP Private Limited has requested Start Date of Connectivity under GNA from 16.12.2027. Considering the same and									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
expected date of commissioning of transmission system (i.e 31.05.2027), as well as in line with the discussion as above for Greenko PSP application no.2200000527, it was agreed to grant connectivity with the start date as 16.12.2027(interim). M/s Greenko noted the same. Transmission system for connectivity of M/s Greenko UP01 IREP Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS): NIL</u> B. <u>Transmission System under applicant scope</u> (i). Common Pooling station for Pumped Storage Projects of M/s Greenko UP01 IREP Private Limited (App. No. 220000527-672 MW, 220000529-672 MW, 220000524-672 MW, 220000525-672 MW, 220000526-672 MW & 220000528-672 MW) – Robertsganj Pooling Station 400 kV 2xD/c line(suitable to carry minimum 1400 MW per circuit at nominal voltage)* <i>*Minimum One unit to operate in Synchronous Condenser mode as per the requirement of the grid</i> C. <u>Transmission system for Connectivity under GNA: (Tentative)</u> (i). Establishment of 5x1500 MVA 765/400 kV Robertsganj Pooling Station near Robertsganj area in Sonbhadra distt. Uttar Pradesh (ii). LILO of both circuits of 765 kV Varanasi- Gaya 2xSc line at Robertsganj Pooling Station (iii). Establishment of 765/400 kV 2x1500 MVA Prayagraj substation near Prayagraj(Uttar Pradesh) (iv). Prayagraj – Sohawal 400 kV D/c line(Quad) (v). LILO of 765 kV Fatehpur-Varanasi S/c line at Prayagraj S/s (vi). LILO of 765 kV Fatehpur-Sasaram S/c line at Prayagraj S/s (vii). Robertsganj PS – Prayagraj S/s 765 kV D/c line along with 240 MVar line reactor for each circuit at Robertsganj end. <u>Additional Inter regional (WR-NR)Transmission system for Connectivity under GNA (Tentative):</u> (i). 765kV Vindhyachal Pool - Prayagraj D/c line along with 240MVar line reactor (switchable) at Prayagraj end on each ckt of 765kV Vindhyachal Pool - Prayagraj D/c line (ii). Bypassing of both ckts of 765kV Sasan – Vindhyachal Pool 2xS/c line at Vindhyachal Pool and connecting it with 765kV Vindhyachal Pool - Prayagraj D/c line, thus forming 765kV Sasan - Prayagraj D/c line									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
Start Date of Connectivity: 16.12.2027(interim). Final date shall be confirmed upon award of the system									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
5.	2200000524	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	Connectivity:672 Max Injection: 610 Max Drawl:672	16.11.2026	-	• Conn BG1: Rs. 50 Lakh • Conn BG2: NIL(Bay under Applicant Scope) • Conn BG3; Rs. 2 lakh/MW

It was informed that M/s Greenko UP01 IREP Private Limited has applied for connectivity for 672 MW (Max. Drawl: 672 MW, Max. Injection: 610 MW) for the proposed pumped Storage project in Sonbhadra district(UP). As discussed with the previous applications of M/s Greenko, it was proposed to grant connectivity to M/s Greenko at proposed Robertsganj pooling station.

For this application, M/s Greenko UP01 IREP Private Limited has requested Start Date of Connectivity under GNA from 16.11.2026. Considering the same and expected date of commissioning of transmission system (i.e 31.05.2027), as well as in line with the discussion as above for Greenko PSP application no.2200000527, it was agreed to grant connectivity with the start date as 31.05.2027(interim). M/s Greenko noted the same.

Transmission system for connectivity of M/s Greenko UP01 IREP Private Limited under GNA, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

- (i). Common Pooling station for Pumped Storage Projects of M/s Greenko UP01 IREP Private Limited (App. No. 220000527-672 MW, 220000529-672 MW, 220000524-672 MW, 220000525-672 MW, 220000526-672 MW & 220000528-672 MW) – Robertsganj Pooling Station 400 kV 2xD/c line(suitable to carry minimum 1400 MW per circuit at nominal voltage)*

**Minimum One unit to operate in Synchronous Condenser mode as per the requirement of the grid*

C. Transmission system for Connectivity under GNA : (Tentative)

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
(i). Establishment of 5x1500 MVA 765/400 kV Robertsganj Pooling Station near Robertsganj area in Sonbhadra distt. Uttar Pradesh (ii). LILO of both circuits of 765 kV Varanasi- Gaya 2xSc line at Robertsganj Pooling Station (iii). Establishment of 765/400 kV 2x1500 MVA Prayagraj substation near Prayagraj(Uttar Pradesh) (iv). Prayagraj – Sohawal 400 kV D/c line(Quad) (v). LILO of 765 kV Fatehpur-Varanasi S/c line at Prayagraj S/s (vi). LILO of 765 kV Fatehpur-Sasaram S/c line at Prayagraj S/s (vii). Robertsganj PS – Prayagraj S/s 765 kV D/c line along with 240 MVar line reactor for each circuit at Robertsganj end.									
<u>Additional Inter regional (WR-NR)Transmission system for Connectivity under GNA (Tentative):</u>									
(i). 765kV Vindhyachal Pool - Prayagraj D/c line along with 240MVar line reactor (switchable) at Prayagraj end on each ckt of 765kV Vindhyachal Pool - Prayagraj D/c line (ii). Bypassing of both ckts of 765kV Sasan – Vindhyachal Pool 2xS/c line at Vindhyachal Pool and connecting it with 765kV Vindhyachal Pool - Prayagraj D/c line, thus forming 765kV Sasan - Prayagraj D/c line									
Start Date of Connectivity: 31.05.2027(interim). Final date shall be confirmed upon award of the system									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
6.	2200000525	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	Connectivity:672 Max Injection: 610 Max Drawl:672	01.02.2027	-	• Conn BG1: Rs. 50 Lakh • Conn BG2: NIL (Bay under Applicant Scope) • Conn BG3; Rs. 2 lakh/MW
It was informed that M/s Greenko UP01 IREP Private Limited has applied for connectivity for 672 MW (Max. Drawl: 672 MW, Max. Injection: 610 MW) for the proposed pumped Storage project in Sonbhadra district(UP). As discussed with the previous applications of M/s Greenko, it was proposed to grant connectivity to M/s Greenko at proposed Robertsganj pooling station. For this application, M/s Greenko UP01 IREP Private Limited has requested Start Date of Connectivity under GNA from 01.02.2027. Considering the same and expected date of commissioning of transmission system (i.e 31.05.2027), as well as in line with the discussion as above for Greenko PSP application no.2200000527, it was agreed to grant connectivity with the start date as 31.05.2027(interim). M/s Greenko noted the same. Transmission system for connectivity of M/s Greenko UP01 IREP Private Limited under GNA, as agreed, is as below:									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
<u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Common Pooling station for Pumped Storage Projects of M/s Greenko UP01 IREP Private Limited (App. No. 220000527-672 MW, 220000529-672 MW, 220000524-672 MW, 220000525-672 MW, 220000526-672 MW & 220000528-672 MW) – Robertsganj Pooling Station 400 kV 2xD/c line (suitable to carry minimum 1400 MW per circuit at nominal voltage)* <i>*Minimum One unit to operate in Synchronous Condenser mode as per the requirement of the grid</i> C. <u>Transmission system for Connectivity under GNA: (Tentative)</u> (i). Establishment of 5x1500 MVA 765/400 kV Robertsganj Pooling Station near Robertsganj area in Sonbhadra distt. Uttar Pradesh (ii). LILO of both circuits of 765 kV Varanasi- Gaya 2xSc line at Robertsganj Pooling Station (iii). Establishment of 765/400 kV 2x1500 MVA Prayagraj substation near Prayagraj(Uttar Pradesh) (iv). Prayagraj – Sohawal 400 kV D/c line(Quad) (v). LILO of 765 kV Fatehpur-Varanasi S/c line at Prayagraj S/s (vi). LILO of 765 kV Fatehpur-Sasaram S/c line at Prayagraj S/s (vii). Robertsganj PS – Prayagraj S/s 765 kV D/c line along with 240 MVar line reactor for each circuit at Robertsganj end. <u>Additional Inter regional (WR-NR) Transmission system for Connectivity under GNA (Tentative):</u> (i). 765kV Vindhyachal Pool - Prayagraj D/c line along with 240MVar line reactor (switchable) at Prayagraj end on each ckt of 765kV Vindhyachal Pool - Prayagraj D/c line (ii). Bypassing of both ckts of 765kV Sasan – Vindhyachal Pool 2xS/c line at Vindhyachal Pool and connecting it with 765kV Vindhyachal Pool - Prayagraj D/c line, thus forming 765kV Sasan - Prayagraj D/c line Start Date of Connectivity: 31.05.2027(interim). Final date shall be confirmed upon award of the system									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
7.	2200000526	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	Connectivity:672 Max Injection: 610 Max Drawl:672	16.04.2027	-	• Conn BG1: Rs. 50 Lakh • Conn BG2: NIL (Bay under Applicant Scope) • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Greenko UP01 IREP Private Limited has applied for connectivity for 672 MW (Max. Drawl: 672 MW, Max. Injection: 610 MW) for the proposed pumped Storage project in Sonbhadra district (UP). As discussed with the previous applications of M/s Greenko, it was proposed to grant connectivity to M/s Greenko at proposed Robertsganj pooling station.

For this application, M/s Greenko UP01 IREP Private Limited has requested Start Date of Connectivity under GNA from 16.04.2027. Considering the same and expected date of commissioning of transmission system (i.e 31.05.2027), as well as in line with the discussion as above for Greenko PSP application no.2200000527, it was agreed to grant connectivity with the start date as 31.05.2027 (interim). M/s Greenko noted the same.

Transmission system for connectivity of M/s Greenko UP01 IREP Private Limited under GNA, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

- (i) Common Pooling station for Pumped Storage Projects of M/s Greenko UP01 IREP Private Limited (App. No. 220000527-672 MW, 220000529-672 MW, 220000524-672 MW, 220000525-672 MW, 220000526-672 MW & 220000528-672 MW) – Robertsganj Pooling Station 400 kV 2xD/c line (suitable to carry minimum 1400 MW per circuit at nominal voltage)*

**Minimum One unit to operate in Synchronous Condenser mode as per the requirement of the grid*

C. Transmission system for Connectivity under GNA: (Tentative)

- (i). Establishment of 5x1500 MVA 765/400 kV Robertsganj Pooling Station near Robertsganj area in Sonbhadra distt. Uttar Pradesh
- (ii). LILO of both circuits of 765 kV Varanasi- Gaya 2xSc line at Robertsganj Pooling Station
- (iii). Establishment of 765/400 kV 2x1500 MVA Prayagraj substation near Prayagraj (Uttar Pradesh)
- (iv). Prayagraj – Sohawal 400 kV D/c line (Quad)
- (v). LILO of 765 kV Fatehpur-Varanasi S/c line at Prayagraj S/s
- (vi). LILO of 765 kV Fatehpur-Sasaram S/c line at Prayagraj S/s
- (vii). Robertsganj PS – Prayagraj S/s 765 kV D/c line along with 240 MVar line reactor for each circuit at Robertsganj end.

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
<u>Additional Inter regional (WR-NR) Transmission system for Connectivity under GNA (Tentative):</u> (i). 765kV Vindhyachal Pool - Prayagraj D/c line along with 240MVA line reactor (switchable) at Prayagraj end on each ckt of 765kV Vindhyachal Pool - Prayagraj D/c line (ii). Bypassing of both ckts of 765kV Sasan – Vindhyachal Pool 2xS/c line at Vindhyachal Pool and connecting it with 765kV Vindhyachal Pool - Prayagraj D/c line, thus forming 765kV Sasan - Prayagraj D/c line Start Date of Connectivity: 31.05.2027(interim). Final date shall be confirmed upon award of the system									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
8.	2200000528	Greenko UP01 IREP Private Limited	Sonbhadra distt., Uttar Pradesh	05.02.2024	Standalone ESS (Pumped Storage)	Connectivity:672 Max Injection: 610 Max Drawl:672	16.04.2027	-	• Conn BG1: Rs. 50 Lakh • Conn BG2: NIL(Bay under Applicant Scope) • Conn BG3; Rs. 2 lakh/MW
It was informed that M/s Greenko UP01 IREP Private Limited has applied for connectivity for 672 MW (Max. Drawl: 672 MW, Max. Injection:610 MW) for the proposed pumped Storage project in Sonbhadra district(UP). As discussed with the previous applications of M/s Greenko, it was proposed to grant connectivity to M/s Greenko at proposed Robertsganj pooling station. For this application, M/s Greenko UP01 IREP Private Limited has requested Start Date of Connectivity under GNA from 16.04.2027. Considering the same and expected date of commissioning of transmission system (i.e 31.05.2027), as well as in line with the discussion as above for Greenko PSP application no.2200000527, it was agreed to grant connectivity with the start date as 31.05.2027(interim). M/s Greenko noted the same. Transmission system for connectivity of M/s Greenko UP01 IREP Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u>									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
(i). Common Pooling station for Pumped Storage Projects of M/s Greenko UP01 IREP Private Limited (App. No. 220000527-672 MW, 220000529-672 MW, 220000524-672 MW, 220000525-672 MW, 220000526-672 MW & 220000528-672 MW) – Robertsganj Pooling Station 400 kV 2xD/c line(suitable to carry minimum 1400 MW per circuit at nominal voltage)* <i>*Minimum One unit to operate in Synchronous Condenser mode as per the requirement of the grid</i> C. <u>Transmission system for Connectivity under GNA: (Tentative)</u> (i). Establishment of 5x1500 MVA 765/400 kV Robertsganj Pooling Station near Robertsganj area in Sonbhadra distt. Uttar Pradesh (ii). LILO of both circuits of 765 kV Varanasi- Gaya 2xSc line at Robertsganj Pooling Station (iii). Establishment of 765/400 kV 2x1500 MVA Prayagraj substation near Prayagraj(Uttar Pradesh) (iv). Prayagraj – Sohawal 400 kV D/c line(Quad) (v). LILO of 765 kV Fatehpur-Varanasi S/c line at Prayagraj S/s (vi). LILO of 765 kV Fatehpur-Sasaram S/c line at Prayagraj S/s (vii). Robertsganj PS – Prayagraj S/s 765 kV D/c line along with 240 MVar line reactor for each circuit at Robertsganj end. <u>Additional Inter regional (WR-NR) Transmission system for Connectivity under GNA (Tentative):</u> (i). 765kV Vindhyachal Pool - Prayagraj D/c line along with 240MVar line reactor (switchable) at Prayagraj end on each ckt of 765kV Vindhyachal Pool - Prayagraj D/c line (ii). Bypassing of both ckts of 765kV Sasan – Vindhyachal Pool 2xS/c line at Vindhyachal Pool and connecting it with 765kV Vindhyachal Pool - Prayagraj D/c line, thus forming 765kV Sasan - Prayagraj D/c line Start Date of Connectivity: 31.05.2027(interim). Final date shall be confirmed upon award of the system									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
9.	2200000553	Avaada Waterbattery Private Limited	Sonbhadra distt.,	06.02.2024	Standalone ESS (Pumped Storage)	Connectivity:1120 Max Injection: 900 Max Drawl:1120	31.03.2028 (revised - 31.12.2028)	-	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 12 Cr. • Conn BG3; Rs. 2 lakh/MW

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
			Uttar Pradesh						
It was informed that M/s Avaada Waterbattery Private Limited has applied for connectivity for 1120 MW(Max Injection: 900 MW Max Drawl:1120 MW) for the proposed pumped Storage project in Sonbhadra district(UP). Further, M/s Avaada was asked to confirm, whether they will be following the pattern of drawl of power during peak solar hours and injection during non solar/low solar hours like Greenko PSP Projects. M/s Avaada confirmed that the PSP project shall draw power during RE/Solar peak generation time and inject during low RE generation/non-solar hours. CEA in the meeting confirmed that the Sonbhadra area may be considered as a potential zone for pumped storage projects. Accordingly, the transmission system for connectivity of M/s Avaada Waterbattery at Roberstganj shall be considered as common transmission system. It was also informed that, in order to deliberate on planning of transmission System for evacuation of Power from Pumped Storage Plants, a meeting under Chairmanship of Chairperson, CEA was held on 28.05.2024. In the above meeting, it was decided that CTUIL while granting Connectivity to PSPs shall mention that PSPs shall not operate in generating mode during high RE generation period and if required, PSPs may inject power during high RE generation period based on margin available in the system. However as per the list shared by CEA, HPP&I division, this PSP project of M/s Avaada is not mentioned. Avaada & CEA were asked to clarify regarding the same. M/s Avaada in the meeting informed that the TOR of their project is approved and currently in pre DPR stage & they shall be submitting it to CEA for pre DPR chapter approvals. Regarding the PSP project not mentioned in the CEA list, M/s Avaada informed that they have clarified regarding the same vide letter dated 25.06.2024. M/s Avaada also informed that CEA vide letter dated 08.04.2024 has confirmed that their PSP(Chichlik) is not overlapping with other PSPs whose layouts are submitted in CEA. Further, the measures required, if any, for safety of Chichlik PSP and Shoma PSP due their proximity to one-another will be examined by CEA/CWC after submission of pre-DPR chapters of Chichlik PSP. CTUIL enquired Avaada that in the above CEA letter the PSP installed capacity is mentioned as 1560 MW whereas they have applied for 1120 MW. Regarding this Avaada informed that as per the MoU signed with the UP government & the in principle approval received the installed capacity is 1120 MW. Subsequently, based on the studies conducted at site, they decided to enhance it to 1560 MW. Accordingly, they applied to UP govt for enhancing the capacity to 1560 MW for which they have received approval as well. The same is also shared with CEA. However, at this stage they have applied for connectivity of 1120 MW only. They shall be applying for enhancement in due course of time. CEA optioned that M/s Avaada has applied for connectivity at a very early stage. CEA informed that M/s Avaada has not yet submitted the pre DPR & feasibility report under which various options need to be submitted for PSP. Based on discussions one of the option shall be finalized & the installed capacity of the project will be decided. Therefore, installed capacity is subject to change. M/s Avaada informed that they would like to go ahead with the same proposal they have submitted with TOR. Regarding this, CEA informed that as Avaada has not yet received approval from CEA & neither it is examined or discussed by any appraisal									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
group. Therefore, they cannot be 100% sure of approval of scheme as per TOR. CTUIL informed Avaada that they shall proceed to grant of connectivity to M/s Avaada. M/s Avaada need to submit Conn BGs within 1 month of intimation. As the project is in pre approval stage, in case in future they face any issues with CEA approval, the risk associated with treatment of Conn BGs in case of relinquishment/revocation shall be with M/s Avaada. M/s Avaada agreed for the same. CTUIL asked M/s Avaada whether they would like to continue with the application under above uncertainties. Regarding this, M/s Avaada requested CTUIL to provide one month time so that they can get clarity regarding the project from CEA. CTUIL informed that considering the present status it looks highly unlikely that anything will be clear in such short period of one month. After discussions, it was decided that CTUIL shall process the application and issue intimation. M/s Avaada may decide in the meantime and take a call regarding submission of Conn BGs for further processing of connectivity. In case of non submission of Conn BGs within one month of issuance of intimation, the application shall be closed as per GNA Regulations 2022. M/s Avaada noted the same. Regarding reactive compensation requirement, M/s Avaada shall operate PSP units in synchronous condenser mode as per the reactive power requirement of the grid. Further, M/s Avaada shall also keep future provision of Bus Reactor so that in case of future requirement the same can be installed by the applicant. Accordingly, it was agreed to grant connectivity to M/s Avaada at proposed Robertsganj pooling station with 400 kV D/c line. M/s Avaada agreed for the same and informed that the 400 kV bays at Roberstganj PS end shall be under ISTS. It may be noted that the transmission scheme for Pump Storage plants in Sonbhadra district is presently under discussion. The scheme is currently tentative, which shall be finalized in subsequent CMETS-NR and other regions (ER &WR) CMETS meeting among CEA, CTUIL, Grid India & Stakeholders. The detailed transmission system shall be informed upon finalization and approval of the scheme. Further, NR-WR inter regional scheme to relieve loading of 765 kV Vindhyachal – Varanasi D/c line shall also be required for connectivity of Pumped Storage Projects in Sonbhadra district. The NR-WR inter regional scheme is already discussed in WR Joint study meeting and is to be taken up for stakeholder consultation in subsequent CMETS-NR and CMETS-WR meeting. CTUIL informed that considering expected enhancement in future to 1560 MW, whether DTL capacity to be commensurate to 1560 MW capacity. M/s Avaada confirmed for DTL capacity commensurate to enhancement capacity (Quad moose or equivalent conductors). Same was confirmed vide Avaada mail dated 08/07/24 & 09/07/24 that with future enhancements, maximum drawl for 1560 MW (260 MW X 5 Units + 130 MW X 2 Units) shall be 1716 MW and accordingly DTL shall be designed with quad moose or equivalent conductors, capable of carrying 1716 MW of power per circuit. M/s Avaada Waterbattery has requested revised start date of connectivity under GNA from 31.12.2028. Considering the same and expected date of commissioning of transmission system (i.e 31.05.2027), the start date of Connectivity under GNA shall be 31.12.2028(interim) as requested. M/s Avaada noted the same. Transmission system for connectivity of M/s Avaada Waterbattery Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. Associated Transmission System (ATS): NIL									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
B. Transmission System under applicant scope (i). M/s Avaada Waterbattery Private Limited Pumped Storage Project– Robertsganj Pooling Station 400 kV D/c line (Quad moose or equivalent conductor suitable to carry 1716 MW per circuit at nominal voltage) C. Transmission system for Connectivity under GNA: (Tentative) (i). Establishment of 5x1500 MVA 765/400 kV Robertsganj Pooling Station near Robertsganj area in Sonbhadra distt. Uttar Pradesh (ii). LILO of both circuits of 765 kV Varanasi- Gaya 2xSc line at Robertsganj Pooling Station (iii). Establishment of 765/400 kV 2x1500 MVA Prayagraj substation near Prayagraj(Uttar Pradesh) (iv). Prayagraj – Sohawal 400 kV D/c line (Quad) (v). LILO of 765 kV Fatehpur-Varanasi S/c line at Prayagraj S/s (vi). LILO of 765 kV Fatehpur-Sasaram S/c line at Prayagraj S/s D. Additional Inter regional (WR-NR) Transmission system for Connectivity under GNA (Tentative): (i). 765kV Vindhyachal Pool - Prayagraj D/c line along with 240MVA line reactor (switchable) at Prayagraj end on each ckt of 765kV Vindhyachal Pool - Prayagraj D/c line (ii). Bypassing of both ckts of 765kV Sasan – Vindhyachal Pool 2xS/c line at Vindhyachal Pool and connecting it with 765kV Vindhyachal Pool - Prayagraj D/c line, thus forming 765kV Sasan - Prayagraj D/c line Start Date of Connectivity: 31.12.2028(interim). Final date shall be confirmed upon award of the system									

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
10.	2200000496	Chenab Valley Power Projects Private Limited	Kishtwar distt., Jammu & Kashmir	06.02.2024	Generator (Hydro)	-	624	01.11.2025	Kishtwar Pooling Station	- Conn BG1: Rs. 50 Lakh - Conn BG2: Nil - Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Chenab Valley Power Projects Private Limited(CVPPL) has applied for connectivity for 624 MW for the proposed Kiru Hydropower project in J&K. Chenab Basin is already confirmed as a Hydro Potential Zone by CEA with multiple projects of Pakaldul HEP, Ratle HEP already granted connectivity. Accordingly, transmission system for connectivity shall be considered as a common system for Hydro projects coming in Chenab basin.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
Transmission scheme for evacuation of power from Ratle HEP was discussed and approved in the 72nd NRPC meeting held on 29.03.2024 & 20th NCT meeting recently held on 25.06.2024. From the studies it is observed that with the above scheme along with Ratle HEP, connectivity of Kiru HEP(624 MW) can also be accommodated. No constraints were observed in the studies with Kiru HEP., Accordingly, it is agreed to grant connectivity of 624 MW to CVPPL for Kiru HEP through the already approved Transmission system for Ratle HEP as well as ICT augmentation at Jallandhar & Samba. M/s CVPPL informed that, at the time of application they had requested for start date from 01.11.2025 which they would like to revise to 01.09.2026. CTUIL informed that. CVPPL has applied for connectivity very late as the time left for transmission system implementation is very less even after considering the revised start date requested. As the transmission system is expected to be commissioned by Dec'26, therefore start date of connectivity will be matching with the expected date of transmission system It was also informed that M/s Chenab Valley Power Projects Private Limited has requested Start Date of Connectivity under GNA from 01.09.2026. However, considering the same and expected date of commissioning of transmission system, the start date of Connectivity under GNA shall be 31.12.2026(interim). M/s CVPPL agreed and noted the same. Transmission system for connectivity of M/s Chenab Valley Power Projects Private Limited(Kiru HEP-624 MW) under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Kiru HEP – Pakaldul generation switchyard 400 kV D/c line (Triple HTLS Conductor –Equivalent to about 2400MW-considering 10% overload) along with 400kV bays at Kiru generation switchyard (ii). Bypassing of one ckt of 400kV Kiru- Pakaldul 400kV D/c line (Triple HTLS) at Pakaldul and connecting it with one of the circuit of Pakaladul-Kishtwar 400kV D/c line (Triple HTLS), thus forming 400kV Kishtwar - Kiru (Triple HTLS) direct line (one ckt) (iii). Switchyard Capacity must be able to handle about 2400MW power generated by the generation projects located in downstream of the Kiru HEP. GIS switchyard equipment and XLPE cables provided may be designed for carrying 4000 Amps current. (iv). 420 kV, 1x125 MVAR Bus Reactor at Kiru generation switchyard C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure XI Start Date of Connectivity: 31.12.2026(interim). Final date shall be confirmed upon award of the system										

B4. Application for Grant of GNA to entities other than STU under Regulation 20.1, 20.3 and 20.4 to entities under Regulation 17.1 (ii), (iii), (v) and (vi):

SI No.	Application ID	Name of the Applicant	Submission Date	Nature of applicant	GNA within Region (MW)	GNA outside Region (MW)	Total GNA Required (MW)	Start date of GNA	End date of GNA
1.	2200000576	Indian Railways	19.02.2024	Drawee entity connected to Intra State Transmission System	-	15	15	01.03.2024	23.11.2044

It was informed that Indian Railways has applied for GNA of 15 MW (Outside the region) as a drawee entity connected to Intra State Transmission System of Punjab (PSTCL) at 17 no. of 220 kV & 132 kV Traction substation (TSS). In this regard, Indian Railways has also submitted NOC from PSPCL along with the application.

It was also informed that Punjab has been granted GNA of 5497 MW as per 18.1 of GNA regulation. In addition to that, Tata Steel has been granted GNA_{RE} of 46.12 MW as a drawee entity connected to intra state system. Considering above, it was observed that, there is sufficient margins in the existing transmission system for drawl of additional 15 MW of power by Indian Railways interconnected to intra state (PSTCL) network through ISTS.

Indian Railways in the application has requested for Start date of GNA from 01.03.2024, however, as the date is already elapsed, it was proposed that the GNA shall be granted from 20.07.2024 considering the time required for issuance of intimation. M/s Indian Railways agreed for the same.

Accordingly, it was agreed to grant 15 MW of GNA (outside the region) to Indian Railways for drawl of power from ISTS network through intra state (PSTCL) network with Start Date from 20.07.2024 upto 23.11.2044.

B5. Application for Grant of GNARE to entities other than STU under Regulation 20.1, 20.3 and 20.4 to entities under Regulation 17.1(ii), (iii), (v) & (vi):

SI No.	Application ID	Name of the Applicant	Submission Date	Region	Nature of applicant	GNA _{RE} within Region (MW)	GNA _{RE} outside Region (MW)	Total Quantum of GNA _{RE} Required (MW)	Start date of GNA _{RE}	End date of GNA _{RE}
1	2200000467	Hindustan Zinc Limited	13.02.2024	NR	Bulk consumer seeking to connect to ISTS	5	65	70	30.06.2026	29.06.2051
2	2200000457	Hindustan Zinc Limited	13.02.2024	NR	Bulk consumer seeking to connect to ISTS	5	45	50	30.06.2026	29.06.2051
3	2200000453	Hindustan Zinc Limited	13.02.2024	NR	Bulk consumer seeking to connect to ISTS	5	50	55	30.06.2026	29.06.2051

SI No.	Application ID	Name of the Applicant	Submission Date	Region	Nature of applicant	GNA _{RE} within Region (MW)	GNA _{RE} outside Region (MW)	Total Quantum of GNA Required (MW)	Start date of GNA	End date of GNA
1.	2200000467	Hindustan Zinc Limited	13.02.2024	NR	Bulk consumer seeking to connect to ISTS	5	65	70	30.06.2026	29.06.2051
It was informed that M/s Hindustan Zinc Limited (HZL) has applied for GNA_{RE} of 70 MW for their Rampur Agucha Mining Facility in Bhilwara district, Rajasthan. M/s HZL in the application has mentioned that they are presently connected to RVPN at 220 kV Gulabpura S/s. HZL in the letter submitted with the application informed that they are in the process of obtaining NoC from STU for disconnection from the grid. Regarding the system considered for grant, it was informed that considering the location of the project, it is observed that nearest 220kV ISTS S/s is Kankroli at a long distance of 135 km which is not techno-economical. Accordingly, after evaluating various options, it was proposed that GNA_{RE} of 70 MW (5 MW within the region & 65 MW outside the region) can be granted through LILO of 400 kV Shree Cement – Kota line at HZL switchyard option. As per clause 12.5 of GNA Regulations, the LILO line to connect Hindustan Zinc Limited to the ISTS for providing connection to the ISTS, shall be constructed & maintained by a licensee at the cost of Hindustan Zinc Limited. CTUIL informed that as the Bulk Consumer is presently connected with STU network and seeking direct connectivity to ISTS, it is necessary to submit NoC from STU for disconnection because there is no provision for dual connectivity (both STU & ISTS) to Bulk consumer under Connectivity & GNA Regulations 2022. Therefore, it is necessary that the Bulk consumer before applying for GNA should ensure of obtaining NoC from STU for disconnection. HZL & RVPN were asked to update regarding the NoC. RVPN informed that as on date they have not received any request from Hindustan Zinc Ltd for NoC. Regarding this, HZL informed that they are still in discussion with STU for obtaining NoC in this regard. CTUIL informed that HZL have applied in the month of February'24 and during the application also HZL had informed that they are in the process of obtaining NoC from STU for disconnection from the grid. So even after five months of application, there is no progress regarding the same. As there is no provision to keep application on hold, it is advised that all pending issue should be closed expeditiously by HZL for grant of GNA. HZL informed that they shall update regarding their decision and RVPN NoC by 15.07.24. It was decided that application shall be taken up in next CMETS-NR meeting. In case no NoC is received, based on the discussion with STU, the application shall be closed and HZL may reapply for GNA_{RE} after obtaining necessary NoC from STU.										
2.	2200000453	Hindustan Zinc Limited	13.02.2024	NR	Bulk consumer seeking to connect to ISTS	5	50	55	30.06.2026	29.06.2051
It was informed that M/s Hindustan Zinc Limited(HZL) applied for GNA_{RE} of 55 MW for their Zinc smelter (existing-55 MW) near Debari for drawl of power from Kankroli(PG) S/s. HZL in the letter dated 13.02.2024 submitted along with the application no. 2200000453(55 MW) informed that the project is already connected to STU (RVPN) network and HZL has now applied for direct connectivity to ISTS. M/s HZL informed that they are in the process of obtaining NoC from STU for disconnection from STU network.										

SI No.	Application ID	Name of the Applicant	Submission Date	Region	Nature of applicant	GNA _{RE} within Region (MW)	GNA _{RE} outside Region (MW)	Total Quantum of GNA Required (MW)	Start date of GNA	End date of GNA
CTUIL informed that as the existing Zinc Smelter of HZL is already connected with STU network and is seeking direct connectivity to ISTS, it is necessary to submit NoC from STU for disconnection because there is no provision for dual connectivity (both STU & ISTS) to Bulk consumer under Connectivity & GNA Regulations 2022. Therefore, it is necessary that the Bulk consumer before applying for GNA should ensure obtaining NoC from STU for disconnection. HZL & RVPN were asked to update regarding the NoC. RVPN informed that as on date they have not received any request from Hindustan Zinc Ltd for NoC. Regarding this, HZL informed that they are still in discussion with STU for obtaining NoC in this regard. CTUIL informed that they have applied in the month of February'24 and during the application also HZL had informed that they are in the process of obtaining NoC from STU for disconnection from the grid. So even after five months of application, there is no progress regarding the same. HZL informed that they shall update regarding the same. As there is no provision to keep application on hold, it is advised that all pending issue should be closed expeditiously bu HZL for grant of GNA. HZL informed that they shall update regarding their decision and RVPN NoC by 15.07.24. It was decided that application shall be taken up in next CMETS-NR meeting. In case no NoC is received, based on the discussion with STU, the application shall be closed and HZL may reapply for GNA_{RE} after obtaining necessary NoC from STU.										
3.	2200000457	Hindustan Zinc Limited	13.02.2024	NR	Bulk consumer seeking to connect to ISTS	5	45	50	30.06.2026	29.06.2051
It was informed that M/s Hindustan Zinc Limited(HZL) applied for GNA_{RE} of 50 MW for their under construction Zinc smelter near Debari for drawl of power from Kankroli(PG) S/s. Regarding the transmission system for grant of GNA_{RE}, it was informed that in 23rd CMETS-NR meeting held on 29.08.23, it was decided that as the ICT augmentation at Kankroli(PG) shall cater to load of HZL (200MW) as well as future incremental drawl requirement of RVPN from existing as well as future(Nathdwara)system, the augmentation of ICT shall be considered as common augmentation and shall be under ISTS. Accordingly, M/s HZL was granted GNA_{RE} of 200 MW at Kankroli(PG) S/s through 220 kV D/c line in 24th CMETS-NR meeting. Considering application of 50 MW (application no. 2200000457) & already granted 200 MW GNA_{RE}, total GNA_{RE} to HZL will be 250 MW. The already agreed 220 kV D/c line from HZL(Dariba) to Kankroli(PG) S/s can be utilised by HZL for drawl of additional 50 MW power from Kankroli(PG) S/s. Accordingly, HZL may interconnect their Zinc smelter at Debari with the existing Dariba switchyard. It may be noted that 4th ICT at Kankroli(500 MVA) is already awarded and expected to be commissioned by Sep'25. Considering the additional load of 50 MW of HZL, there is sufficient margin available at Kankroli(PG) S/s for drawl of additional 50 MW as well as requirement of RVPN through Nathdwara system. Accordingly, it was proposed to grant GNA_{RE} of 50 MW with augmentation of 4th ICT at Kankroli(PG) S/s. CTUIL requested RVPN to provide the update regarding the status of implementation of 220kV Nathdwara S/s along with 220kV Nathdwara – Kankroli(PG) D/c line. Regarding this RVPN informed that, earlier bids received for the 220 kV Nathdrawa – Kankroli D/c line were cancelled due to higher tender quotes than estimate. The revised standard bid document is currently under approval & the bidding shall be restarted upon its approval. Regarding the interconnection of Debari with Dariba, HZL informed that they have future expansion plan for both Debari & Dariba units. Therefore, for reliability of connection, HZL requested CTUIL to provide separate bays at Kankroli S/s.										

SI No.	Application ID	Name of the Applicant	Submission Date	Region	Nature of applicant	GNA _{RE} within Region (MW)	GNA _{RE} outside Region (MW)	Total Quantum of GNA Required (MW)	Start date of GNA	End date of GNA
CTUIL informed that as the GNA_{RE} application is only for 50 MW, it is not optimal to grant through separate 220kV bays. The 220 kV D/c line 200 MW GNA_{RE} granted to Dariba has sufficient margins to accommodate additional 50 MW. CTUIL has already considered N-1 reliability (i.e. 220kV D/c) for GNA grant to Dariba(200 MW). If 50 MW is granted through separate bays, then additional 2 no. of 220 kV bays need to be considered for grant of 50 MW which is not techno-economically optimal. Considering the future load growth, ISTS bays at Kankroli S/s may also be required for future drawl requirement of STU(RVPN). Therefore, as Kankroli(PG) is an old substation, it is necessary that the 220 kV bays at Kankroli should be optimally utilised. Being a smelter load, HZL shall ensure the compliance of CEA Standards/regulation regarding the connectivity, Accordingly, after deliberations it was agreed to grant GNA_{RE} of 50 MW through the same 220 kV D/c line allocated to HZL(Dariba) and interconnection of HZL(Dariba) & HZL(Debari). <u>Details of Transmission System for Grant of GNA_{RE} :</u> A. Transmission system for GNA_{RE} (under scope of Applicant and to be constructed and maintained by licensee): (i).Electrical Interconnection of Hindustan Zinc(Debari) [50 MW]– Hindustan Zinc(Dariba) [200 MW] Switchyard* (ii).220 kV Hindustan Zinc(Dariba) Switchyard - Kankroli D/c line along with bays at both ends(Already part of 200 MW GNA_{RE} granted to HZL) B. Transmission system for GNA_{RE} (under ISTS): (i). Augmentation of 1x500 MVA 400/220 kV ICT(4th) at Kankroli (PG) (ii).Shifting of 50MVAr Bus Reactor at future bay to accommodate above ICT. (iii).400 kV bay for termination of Shifting of bus reactor. <i>* Voltage level may be decided & confirmed by M/s HZL after considering all technical aspects which are to be satisfied for technical connection offer.</i> It was also informed that Hindustan Zinc Limited need to submit applicable Conn BGs as per 22.2 (b-i) of GNA Regulations as below: • Conn BG-1: Rs. 50 lakh • Conn BG-3: Rs. 1 Cr.(Rs. 2 lakh/MW) Start Date of GNA_{RE}: 30.06.2026 End Date of GNA_{RE}: 29.06.2051										

C. RE Application Agenda:

C1. Reallocation of Connectivity at Fatehgarh-III PS(Sec-II), Bhadla-II & Bhadla-III agreed in the reallocation meeting held on 12.06.2024

It was informed that, subsequent to APTEL order dated 28.05.2024 on petition nos. 50, 51, 79, 82 & 160 of 2024, a meeting for reallocation of connectivity at Fatehgarh-III PS(Sec-II), Bhadla-II PS & Bhadla-III PS was held on 12.06.2024. In the meeting, reallocation of following entities were agreed:

- Reallocation of connectivity from Bhadla-III PS to Bhadla-II PS
 - a) Solarcraft Power India 4 Pvt. Ltd(App No. 2200000152: 150 MW) – in sharing with Project Nine Renewable Power Pvt. Ltd.(450 MW)
- Reallocation of connectivity from Bhadla-IV PS to Bhadla-III PS
 - a) Prerak Solar Urja Pvt. Ltd – (App. No. 2200000360 : 400 MW)
- Reallocation of connectivity from Fatehgarh-IV PS to Fatehgarh-III PS(Sec-II) at 400kV bay in sharing with M/s Azure
 - a) ABREL (RJ) Projects Limited(App No. 2200000140: 260 MW)
 - b) Aditya Birla Renewables Subsidiary Limited(App .No. 2200000138: 390 MW)
- Reallocation of connectivity from Barmer – I PS to Fatehgarh-IV PS(Sec-II)
 - a) Avaada Energy Pvt. Ltd. – 300 MW (App. No. 2200000077-50 MW & App. No. 2200000290-250 MW)
 - b) Gamma Renewables India Project One Private Limited (App .No. 2200000355: 300 MW)

C2. Remaining Margins after Reallocation

It was informed that after the above reallocation exercise at Fatehgarh-III PS, Fatehgarh-IV PS, Bhadla-II PS & Bhadla-III PS, margins available at RE pooling stations are as below:

- Fatehgarh-III PS(Sec-II) –17 MW (in sharing @400kV) + 50 MW (in sharing @220kV as declared earlier)
- Fatehgarh-IV PS (Sec-II)– 50 MW (in sharing @220kV)
- Bhadla-II PS – 350 MW (in sharing @400kV)
- Bhadla-III PS – 350 MW
 - 150 MW at 220 kV in sharing with M/s Solarcraft
 - 200 MW at 220 kV or 400 kV

It may be noted that after allocation of 650MW capacity to M/s Aditya Birla at Fatehgarh-III PS, only 17MW margin is available at 400kV Fatehgarh-III PS (Section-II). As discussed in the reallocation meeting, 17MW margin is very less quantum to be declared at 400kV, the same will be omitted and Fatehgarh-III PS (Sec-II) shall be closed for further grant except for 50 MW enhancement/sharing at 220 kV bay allocated to M/s Khaba. The remaining margins mentioned above is already uploaded on CTUIL website for allocation to applications already applied for connectivity as per application priority and willingness. Same was agreed.

Based on the above reallocation at Fatehgarh-III (Sec-II), Fatehgarh-IV (Sec-II), Bhadla-II & Bhadla-III, revised transmission system for connectivity for the reallocated entities is as below:

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
1.	2200000077	Avaada Energy Private Limited	Barmer distt., Rajasthan	05.06.2023	Generator (Hybrid)	Land BG Route	50	30.09.2025	Fatehgarh-IV PS(Sec-II)	- Conn BG1: Rs. 50 Lakh - Conn BG2: Nil - Conn BG3: Rs. 2 lakh/MW	- Conn BG1: Rs. 50 Lakh - Conn BG2: Nil - Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Avaada Energy Pvt. Ltd. in the reallocation meeting held on 12.06.2024 opted to shift their connectivity of 300 MW(50+250 MW) granted at er-I PS to Fatehgarh-IV PS (Sec-II). Accordingly, details of revised transmission system for connectivity under GNA for M/s Avaada Energy Private Limited (50 MW) along with the start date of connectivity, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

- (i). Common Pooling station for Avaada Energy Private Limited Solar Power Projects (App No. 220000077(50 MW) & App. No. 2200000290(250 MW)) – Fatehgarh-IV PS(Sec-II) 220 kV S/c line on D/c tower (Suitable to carry minimum 300 MW at nominal voltage)

C. Transmission system for Connectivity under GNA:

1. Augmentation of 1x500 MVA (6th), 400/220kV ICT at Fatehgarh-IV (Section-2) Pooling Station
2. 4x1500 MVA (1st to 4th), 765/400 kV ICTs at Fatehgarh-IV (Section-2) Pooling Station
3. Fatehgarh-IV PS(Sec-II) – Bhinmal (PG) 400 kV D/c line (Twin HTLS*) along with 50 MVAR switchable line reactor on each ckt at each end
4. LILO of both ckts of 765 kV Fatehgarh-III- Beawar D/c line at Fatehgarh-IV (Section-2) PS along with 330 MVAR switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV- Beawar D/c line (formed after LILO)
5. Establishment of 765 kV Mandsaur PS along with 2x330 MVAR (765 kV) Bus Reactors
6. Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end
7. Establishment of 2x1500 MVA, 765/400 kV Substation at suitable location near Sirohi along with 2x240 MVAR (765 kV) & 2x125 MVAR (400 kV) Bus Reactor

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
8.											Fatehgarh-IV (Section-2) PS – Sirohi PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end
9.											Sirohi PS-Chittorgarh (PG) 400 kV D/c line along with 80 MVar switchable line reactor for each circuit at Sirohi PS end (Quad)
10.											Establishment of 3x1500 MVA, 765/400 kV Barmer-I Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor & 2x125 MVAR, 420 kV Bus Reactor
11.											Fatehgarh-III (Section-2) PS – Barmer-I PS 400 kV D/c line (Quad)
12.											Barmer-I PS– Sirohi PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end
13.											Establishment of, 765 kV Substation at suitable location near Rishabdeo (Distt. Udaipur) along with 2x240 MVar (765 kV) Bus Reactor
14.											Sirohi PS- Rishabdeo 765 kV D/c line along with 330 MVar switchable line reactor for each circuit at Sirohi end
15.											Rishabdeo - Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at Rishabdeo end
16.											LILO of one circuit of 765 kV Chittorgarh-Banaskanta D/c line at Rishabdeo S/s
17.											Mandsaur PS–Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS– Indore(PG) 765 kV D/c Line
18.											Establishment of 765/400 kV (2x1500 MVA Kurawar S/s (with 1x500 MVA spare single phase transformer unit) with 2x330 MVar 765 kV bus reactor and 1x125 MVar 420 kV bus reactor (with 1x110 MVar & 1x80 MVar, 765 kV spare single phase reactor unit for line/bus reactor)
19.											Mandsaur – Kurawar 765 kV D/c line along with 240 MVar switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line
20.											LILO of Indore – Bhopal 765 kV S/c line at Kurawar
21.											Kurawar – Ashtha 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
22.											LILO of one circuit of Indore – Itarsi 400 kV D/c line at Astha
23.											Shujalpur – Kurawar 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
* with minimum capacity of 2100 MVA/ckt at nominal voltage											
Revised Start Date of Connectivity under GNA: 28.02.2026(Interim). Final date shall be confirmed upon award of the system											

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
2.	2200000140	ABREL(RJ) Projects Limited	Barmer distt., Rajasthan	29.06.2023	Captive generating plant (Solar)	Land BG Route	260	31.05.2025	Fatehgarh-III PS	- Conn BG1: Rs. 50 Lakh - Conn BG2: Rs. 3 Cr. - Conn BG3: Rs. 2 lakh/MW	- Conn BG1: Rs. 50 Lakh - Conn BG2: Nil(In sharing) - Conn BG3: Rs. 2 lakh/MW
3.	2200000138	Aditya Birla Renewables Subsidiary Limited	Barmer distt., Rajasthan	06.07.2023	Captive generating plant (Hybrid)	Land BG Route	390	31.05.2025	Fatehgarh-III PS	- Conn BG1: Rs. 50 Lakh - Conn BG2: Rs. 3 Cr. - Conn BG3: Rs. 2 lakh/MW	- Conn BG1: Rs. 50 Lakh - Conn BG2: Rs. 6 Cr.[Lead Generator] - Conn BG3: Rs. 2 lakh/MW

It was informed that M/s ABREL(RJ) Projects Limited(260 MW) & M/s Aditya Birla Renewables Subsidiary Limited(390 MW) had been granted connectivity of 650 MW(260+390) at Fatehgarh-IV PS(Sec-II) through 220 kV D/c line. In the reallocation meeting held on 12.06.2024, both ABREL(RJ) & Aditya Birla Renewables opted to shift their connectivity of 650 MW from Fatehgarh-IV PS(Sec-II) to Fatehgarh-III PS(Sec-II) at 400 kV.

It was mentioned that M/s Azure Power India Pvt. Ltd. initially had been granted connectivity of 767 MW(167+500+100) through same bay. In view of revocation of connectivity of 667 MW granted to M/s Azure(167+500), 100 MW connectivity still remains at 400 kV in same bay. M/s Azure in the reallocation meeting informed that they do not wish to be the lead generator for 400 kV bay allocated to them for connectivity of 100 MW and requested CTUIL to make the other entity which opts for reallocation as the lead generator.

M/s Aditya Birla Renewable in the meeting as well as vide mail dated 13.06.2024 informed that Aditya Birla Renewables (App. No. 220000138) shall be the lead generator. It is to mention that lead generator has to submit Conn BG2 of Rs. 6 Cr. for the 400 kV bay and implementation of dedicated transmission system shall be under the scope of lead generator. In view of the above, Aditya Birla Renewables (App. No. 2200000138) has to submit Conn BG2 of Rs. 6 Cr. for the 400 kV line bay. Earlier two no. of Conn BG2 of Rs. 3 Cr. each by M/s ABREJ(RJ) & M/s Aditya Renewables was submitted for 2 no. of 220 kV bays.

Accordingly, details of revised transmission system for connectivity under GNA for M/s M/s ABREL(RJ) Projects Limited (260 MW) & M/s Aditya Birla Renewables Subsidiary Limited (390 MW) along with the start date of connectivity, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
(i). Common Pooling station of M/s ABREL (RJ) Projects Limited Solar Power Project(Appl. Nos. 2200000140 (260 MW)) & Aditya Birla Renewables Subsidiary Limited(Appl. Nos. 2200000138(390 MW)– Fatehgarh-III PS (Section-2) 400 kV S/c line(Suitable to carry minimum 900 MW at nominal voltage) C. Transmission system for Connectivity under GNA: 1. Augmentation of 2x1500 MVA (5th & 6th), 765/400kV ICT at Fatehgarh-III pooling station (Section-II) 2. Establishment of 2x1500 MVA 765/400kV Substation at suitable location near Beawar along with 2x330 MVAR,765kV Bus Reactor & 2x125 MVAR,420kV bus Reactor 3. Fatehgarh-III – Beawar 765 kV D/c (2nd) along with 330 MVAR Switchable line reactor for each circuit at each end of Fatehgarh-III – Beawar 765 kV D/c line (2nd) 4. Fatehgarh-III - Bhadla-III 400kV D/c line (Quad) along with 63 MVAR Switchable line reactor for each circuit at both ends of Fatehgarh-III-Bhadla-III 400kV D/c line 5. LILO of both circuit of Ajmer-Chittorgarh 765 kV D/c line at Beawar substation 6. LILO of 400kV Kota –Merta line at Beawar substation 7. Establishment of 2x1500 MVA 765/400kV substation at suitable location near Dausa along with 2x330 MVAR, 765 kV Bus Reactor & 2x125 MVAR, 420 kV bus Reactor 8. LILO of both circuits of Jaipur (Phagi)- Gwalior 765 kV 2xS/c at Dausa along with 240 MVAR Switchable line reactor for each circuit at Dausa end of Dausa – Gwalior 765 kV D/c line 9. LILO of both circuits of Agra – Jaipur(south) 400kV D/c at Dausa along with 50 MVAR Switchable line reactor for each circuit at Dausa end of Dausa – Agra 400kV D/c line 10. Beawar – Dausa 765 kV D/c line along with 240 MVAR Switchable line reactor for each circuit at each end 11. STATCOM: Fatehgarh – III S/s: STATCOM: $\pm$ 2x300 MVAR, 4x125 MVAR MSC, 2x125 MVAR MSR Additional Transmission system for Inter-regional power transfer: 1) Establishment of 765 kV Mandsaur Pooling Station along with 2x330 MVAR (765 kV) Bus Reactors 2) Beawar – Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end 3a) Mandsaur PS – Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS Indore(PG) 765 kV D/c Line											

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
OR 3b) Establishment of 765kV Kurawar S/s with 2x330 MVAR 765 kV bus reactor 3c) Mandsaur – Kurawar 765 kV D/c line along with 240 MVAR switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line 3d) LILO of Indore – Bhopal 765 kV S/c line at Kurawar Revised Start Date of Connectivity under GNA: 28.02.2026(Interim). Final date shall be confirmed upon award of the system											

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
4.	2200000152	Solarcraft Power India 4 Pvt. Ltd.	Jaisalmer distt., Rajasthan	18.07.2023	Generator (Solar)	Land Route	150	16.06.2025 (Requested revised date 30.09.2026)	Bhadla-III PS	- Conn BG1: Rs. 50 Lakh - Conn BG2: Nil(Bay under applicant scope) - Conn BG3: Rs. 2 lakh/MW	- Conn BG1: Rs. 50 Lakh - Conn BG2: Nil (Bay in sharing) - Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Solarcraft has been granted connectivity of 310 MW (150+110+50) at Bhadla-III PS at 220 kV. In the reallocation meeting held on 12.06.2024, M/s Solarcraft Power opted to shift connectivity of 150 MW from Bhadla-III PS to Bhadla-II PS at 220 kV in sharing with M/s Project Nine Renewable. Accordingly, it is proposed to grant connectivity at Bhadla-II PS in sharing with M/s Project Nine Renewable. Start date of connectivity at Bhadla-III PS was granted matching with Bhadla-Fatehpur HVDC system. However, in view of shifting of connectivity to Bhadla-II PS, the start date of connectivity is to be revised matching with revised transmission system(i.e. Jun'26). In the reallocation meeting held on 12.06.2024, M/s Solarcraft requested for start date of connectivity from 30.09.2026. The same was agreed. Accordingly, the connectivity to M/s Solarcraft shall be revised with Start date of connectivity from 30.09.2026 (interim). However, for other applications of M/s Solarcraft (110+50 MW), intimation will be revised at 220kV Bhadla-III PS by omitting 150 MW reallocated connectivity at 220kV Bhadla-II PS. Further, margin available at 220 kV bay allocated to M/s Solarcraft shall be offered to new applicants for grant of connectivity in sharing. Accordingly, details of revised transmission system for connectivity under GNA for Solarcraft Power India 4 Pvt. Ltd. (150 MW) and revised start date of connectivity as agreed are as below: Details of Transmission system for Connectivity under GNA: A. Associated Transmission System (ATS): NIL											

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
B. Transmission System under applicant scope: (i). Through sharing of dedicated transmission system of M/s Project Nine Renewable Power Private Limited. (450 MW) – Bhadla-II PS 220 kV D/c line (Suitable to carry minimum 300 MW per circuit at nominal voltage). (ii). Infrastructure required for sharing dedicated transmission system - under the scope of M/s Solarcraft Power India 4 Pvt. Ltd C. Transmission system for Connectivity under GNA: - Augmentation of 2x500 MVA, 400/220 kV ICTs (9th & 10th) at Bhadla-II Pooling station (3rd and 4th ICT in 220 kV Section-2) - Augmentation of 2x1500 MVA, 765/400 kV ICT (4th & 5th) at Bhadla-II Pooling station - Establishment of 765/400kV, 2x1500 MVA S/s at suitable location near Sikar (Sikar-II Substation) with 1x125 MVar at 400kV level & 2x330 MVar bus reactors at 765kV level at Sikar -II - Bhadla-II PS – Sikar-II 765kV D/c line (2nd) - Sikar-II – Khetri 765 kV D/c line - Sikar-II – Narela 765 kV D/c line along with 240 MVar Switchable line reactor for each circuit at each end of Sikar-II – Narela 765 kV D/c line - Jhatikara – Dwarka 400kV D/c line (Twin HTLS*) - Augmentation of 1x1500 MVA ICT (3rd), 765/400kV ICT at Jhatikara Substation (Bamnoli/Dwarka section) Additional Transmission system for Inter-regional power transfer: - Establishment of 765 kV Mandsaur Pooling Station along with 2x330 MVAR (765 kV) Bus Reactors - Beawar- Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end 3a) Mandsaur PS – Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS – Indore(PG) 765 kV D/c Line OR 3b) Establishment of 765kV Kurawar S/s with 2x330 MVar 765 kV bus reactor 3c) Mandsaur – Kurawar 765 kV D/c line along with 240 MVar switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line 3d) LILO of Indore – Bhopal 765 kV S/c line at Kurawar <i>* with minimum capacity of 2100MVA on each ckt at nominal voltage</i> Revised Start Date of Connectivity under GNA: 30.09.2026 (Interim). Final date shall be confirmed upon award of the system Further, it was also informed that M/s Solarcraft need to submit sharing agreement with M/s Project Nine Renewables. M/s Solarcraft noted and agreed for the same.											

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
5.	2200000290	Avaada Energy Private Limited	Barmer distt., Rajasthan	17.10.2023	Generator (Hybrid)	Land BG Route	250	30.09.2025	Fatehgarh-IV PS(Sec-II)	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 3 Cr. • Conn BG3: Rs. 2 lakh/MW	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 3 Cr.[Lead] • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Avaada Energy Pvt. Ltd. in the reallocation meeting held on 12.06.2024 opted to shift their connectivity of 300 MW (50+250 MW) granted at Barmer-I PS to Fatehgarh-IV PS (Sec-II). Accordingly, details of revised transmission system for connectivity under GNA for M/s Avaada Energy Private Limited (250 MW) along with the start date of connectivity, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

- (i). Common Pooling station for Avaada Energy Private Limited Solar Power Projects (App No. 220000077(50 MW) & App. No. 2200000290(250 MW)) – Fatehgarh-IV PS(Sec-II) 220 kV S/c line on D/c tower(Suitable to carry minimum 300 MW at nominal voltage)

C. Transmission system for Connectivity under GNA:

1. Augmentation of 2x500 MVA (6th & 7th), 400/220kV ICTs at Fatehgarh-IV (Section-2) Pooling Station
2. 4x1500 MVA (1st to 4th), 765/400 kV ICTs at Fatehgarh-IV (Section-2) Pooling Station
3. Fatehgarh-IV PS(Sec-II) – Bhinmal (PG) 400 kV D/c line (Twin HTLS*) along with 50 MVar switchable line reactor on each ckt at each end
4. LILO of both ckts of 765 kV Fatehgarh-III- Beawar D/c line at Fatehgarh-IV (Section-2) PS along with 330 MVar switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV- Beawar D/c line (formed after LILO)
5. Establishment of 765 kV Mandsaur PS along with 2x330 MVAR (765 kV) Bus Reactors
6. Beawar- Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end
7. Establishment of 2x1500 MVA, 765/400 kV Substation at suitable location near Sirohi along with 2x240 MVar (765 kV) & 2x125 MVar (400 kV) Bus Reactor
8. Fatehgarh-IV (Section-2) PS – Sirohi PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end
9. Sirohi PS-Chittorgarh (PG) 400 kV D/c line along with 80 MVar switchable line reactor for each circuit at Sirohi PS end (Quad)

10. Establishment of 3x1500 MVA, 765/400 kV Barmer-I Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor & 2x125 MVAR, 420 kV Bus Reactor
11. Fatehgarh-III (Section-2) PS – Barmer-I PS 400 kV D/c line (Quad)
12. Barmer-I PS– Sirohi PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end
13. Establishment of, 765 kV Substation at suitable location near Rishabdeo (Distt. Udaipur) along with 2x240 MVAR (765 kV) Bus Reactor
14. Sirohi PS- Rishabdeo 765 kV D/c line along with 330 MVAR switchable line reactor for each circuit at Sirohi end
15. Rishabdeo - Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at Rishabdeo end
16. LILO of one circuit of 765 kV Chittorgarh-Banaskanta D/c line at Rishabdeo S/s
17. Mandsaur PS–Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS–Indore(PG) 765 kV D/c Line
18. Establishment of 765/400 kV (2x1500 MVA Kurawar S/s (with 1x500 MVA spare single phase transformer unit) with 2x330 MVAR 765 kV bus reactor and 1x125 MVAR 420 kV bus reactor (with 1x110 MVAR & 1x80 MVAR, 765 kV spare single phase reactor unit for line/bus reactor)
19. Mandsaur – Kurawar 765 kV D/c line along with 240 MVAR switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line
20. LILO of Indore – Bhopal 765 kV S/c line at Kurawar
21. Kurawar – Ashtha 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
22. LILO of one circuit of Indore – Itarsi 400 kV D/c line at Ashtha
23. Shujalpur – Kurawar 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line

* with minimum capacity of 2100 MVA/ckt at nominal voltage

Revised Start Date of Connectivity under GNA: 28.02.2026(Interim). Final date shall be confirmed upon award of the system

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
6.	2200000355	Gamma Renewables India Project One Pvt. Ltd.	Barmer distt., Rajasthan	31.10.2023	Renewable Power Park Developer (Solar))	Land BG Route	390	01.06.2026	Barmer-I PS	- Conn BG1: Rs. 50 Lakh - Conn BG2: Rs. 3 Cr. - Conn BG3: Rs. 2 lakh/MW	- Conn BG1: Rs. 50 Lakh - Conn BG2: Rs. 3 Cr. - Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Gamma Renewables India Project One Private Limited. in the reallocation meeting held on 12.06.2024 opted to shift their connectivity of 300 MW granted at Barmer-I PS to Fatehgarh-IV PS (Sec-II). Accordingly, details of revised transmission system for connectivity under GNA for M/s Gamma Renewables India Project One Private Limited along with the start date of connectivity, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
A. <u>Associated Transmission System (ATS):</u> NIL											
B. <u>Transmission System under applicant scope</u>											
(i). Gamma Renewables India Project One Private Limited RE Power Park – Fatehgarh-IV PS(Sec-II) 220 kV S/c line on D/c tower (Suitable to carry minimum 300 MW at nominal voltage)											
C. <u>Transmission system for Connectivity under GNA:</u>											
1. Augmentation of 1x500 MVA (7th), 400/220kV ICTs at Fatehgarh-IV (Section-2) Pooling Station 2. 4x1500 MVA (1st to 4th), 765/400 kV ICTs at Fatehgarh-IV (Section-2) Pooling Station 3. Fatehgarh-IV PS(Sec-II) – Bhinmal (PG) 400 kV D/c line (Twin HTLS*) along with 50 MVar switchable line reactor on each ckt at each end 4. LILO of both ckts of 765 kV Fatehgarh-III- Beawar D/c line at Fatehgarh-IV (Section-2) PS along with 330 MVar switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV- Beawar D/c line (formed after LILO) 5. Establishment of 765 kV Mandsaur PS along with 2x330 MVAR (765 kV) Bus Reactors 6. Beawar- Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end 7. Establishment of 2x1500 MVA, 765/400 kV Substation at suitable location near Sirohi along with 2x240 MVar (765 kV) & 2x125 MVar (400 kV) Bus Reactor 8. Fatehgarh-IV (Section-2) PS – Sirohi PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end 9. Sirohi PS-Chittorgarh (PG) 400 kV D/c line along with 80 MVar switchable line reactor for each circuit at Sirohi PS end (Quad) 10. Establishment of 3x1500 MVA, 765/400 kV Barmer-I Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor & 2x125 MVAR, 420 kV Bus Reactor 11. Fatehgarh-III (Section-2) PS – Barmer-I PS 400 kV D/c line (Quad) 12. Barmer-I PS– Sirohi PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end 13. Establishment of, 765 kV Substation at suitable location near Rishabdeo (Distt. Udaipur) along with 2x240 MVar (765 kV) Bus Reactor 14. Sirohi PS- Rishabdeo 765 kV D/c line along with 330 MVar switchable line reactor for each circuit at Sirohi end 15. Rishabdeo - Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at Rishabdeo end 16. LILO of one circuit of 765 kV Chittorgarh-Banaskanta D/c line at Rishabdeo S/s 17. Mandsaur PS–Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS-Indore(PG) 765 kV D/c Line											

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
18. Establishment of 765/400 kV (2x1500 MVA Kurawar S/s (with 1x500 MVA spare single phase transformer unit) with 2x330 MVA 765 kV bus reactor and 1x125 MVA 420 kV bus reactor (with 1x110 MVA & 1x80 MVA, 765 kV spare single phase reactor unit for line/bus reactor) 19. Mandsaur – Kurawar 765 kV D/c line along with 240 MVA switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line 20. LILO of Indore – Bhopal 765 kV S/c line at Kurawar 21. Kurawar – Ashtha 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line 22. LILO of one circuit of Indore – Itarsi 400 kV D/c line at Astha 23. Shujalpur – Kurawar 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line 24. Establishment of 765/400 kV, 2x1500 MVA & 2x500 MVA, 400/220 kV S/s at suitable location near Merta (Merta-II Substation) along with 2x125 MVA & 2x240 MVA bus reactor at Merta-II S/s 25. STATCOM (2x±300MVA) along with MSC (4x125 MVA) & MSR (2x125 MVA) along with 2 nos. 400kV bays at Barmer-I PS 26. 400kV Sectionalizer bay (1 set) at Barmer-I S/s 27. Barmer-I PS – Merta-II 765 kV D/c line along with 330 MVA switchable line reactor for each circuit at each end of Barmer-I PS – Merta-II 765 kV D/c line 28. Merta-II – Beawar 400 kV D/c line (Quad) 29. Merta-II – Dausa 765 kV D/c line along with 240 MVA switchable line reactor for each circuit at each end of Merta-II – Dausa 765 kV D/c line line 30. Establishment of 765/400kV, 2x1500 MVA S/s at suitable location near Ghiror (Distt. Mainpuri) along with 2x125 MVA & 2x240 MVA bus reactor at Ghiror S/s (UP) 31. Dausa - Ghiror 765 kV D/c line along with 330MVA switchable line reactor at Ghiror end and 240 MVA switchable line reactor at Dausa end for each circuit of Dausa - Ghiror 765 kV D/c line 32. LILO of both ckt of 765 kV Aligarh (PG) -Orai (PG) D/c line at Ghiror S/s along with 240 MVA switchable line reactor for each circuit at Ghiror S/s end of 765 kV Ghiror -Orai D/c line 33. LILO of one ckt of 765kV Agra (PG) – Fatehpur(PG) 765kV 2xS/c line at Ghiror along with 240 MVA switchable line reactor at Ghiror S/s end of 765 kV Ghiror -Fatehpur line 34. 400kV Ghiror-Firozabad (UPPTCL) D/c line (Quad) * with minimum capacity of 2100 MVA/ckt at nominal voltage Revised Start Date of Connectivity under GNA: 01.09.2026(Interim). Final date shall be confirmed upon award of the system											

Sl. No.	Application ID	Applicant	Project Location	Application Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location	Conn BG requirement as per earlier intimation	Revised Conn BG requirement
7.	2200000360	Prerak Solar Urja Pvt. Ltd	Bikaner distt., Rajasthan	17.11.2023	Renewable Power Park developer (Solar)	Land Route	400	31.05.2025	Bhadla-III PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 3 Cr. • Conn BG3: Rs. 2 lakh/MW	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 3 Cr. • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Prerak Solar Urja had been granted connectivity of 400 MW at Bhadla-IV PS in the 27th CMETS NR meeting held on 10.01.2024. Subsequently, in the reallocation meeting held on 12.06.2024, M/s Prerak Solar Urja had opted to shift the connectivity of 400 MW from Bhadla-IV PS to Bhadla-III PS. Accordingly, details of revised transmission system for connectivity under GNA for M/s Prerak Solar Urja Pvt. Ltd. (400 MW) and start date of connectivity, as agreed, are as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

- (i). Prerak Solar Urja Private Limited RE Power Park – Bhadla-III PS 220 kV S/c (high capacity) line on D/c tower(suitable to carry minimum 400 MW at nominal voltage)

C. Transmission system for Connectivity under GNA:

1. Augmentation of 2x500 MVA (7th & 8th), 400/220 kV ICT at Bhadla-III PS
2. Augmentation of 2x1500 MVA (3rd & 4th), 765/400kV ICT at Bhadla-III PS
3. 765 kV Bhadla-III – Bikaner-III D/c line along with 240 MVar switchable line reactor for each circuit at Bhadla-III end
4. Bhadla-III – Sikar-II 765 kV D/c line along with 330 MVar Switchable line reactor for each circuit at each end of Bhadla-III – Sikar-II 765 kV D/c line
5. Fatehgarh-III – Bhadla-III 400kV D/c line (Quad) along with 63 MVar Switchable line reactor for each circuit at both ends of Fatehgarh-III – Bhadla-III 400kV D/c line
6. Establishment of 6000 MW, $\pm$ 800 kV Bhadla (HVDC) [LCC] terminal station (4x1500 MW) at a suitable location near Bhadla-III substation
7. Establishment of 6000 MW, $\pm$ 800 kV Fatehpur (HVDC) [LCC] terminal station (4x1500 MW) at suitable location near Fatehpur (UP)
8. Bhadla-III – Bhadla (HVDC) 400 kV 2xD/c quad moose line along with the line bays at both substations
9. $\pm$ 800 kV HVDC line between Bhadla (HVDC) & Fatehpur (HVDC) (with Dedicated Metallic Return)
10. Augmentation of 5x1500 MVA (1st to 5th), 765/400 kV ICTs at Fatehpur (HVDC) along with 2x330 MVar (765kV) bus reactor
11. LILO of both ckts of 765 kV Varanasi – Kanpur (GIS) D/c line at Fatehpur
12. Augmentation by 1x1500 MVA ICT at 765/400kV Kanpur (GIS) substation

Revised Start Date of Connectivity under GNA: 31.12.2028(Interim). Final date shall be confirmed upon award of the system

C3. Revision of Dedicated transmission system for M/s Azure Power India Pvt. Ltd. in view of Reallocation and change in lead generator.

It was informed that, in view of the request for change in lead generator by M/s Azure, dedicated transmission system for connectivity of 100 MW granted to M/s Azure Power India Pvt. Ltd. at Fatehgarh-III PS(Sec-II) shall be modified as below:

Dedicated Transmission system for M/s Azure Power India Pvt. Ltd. (App no. 0412100002 – 100 MW):

- (i). Through sharing of dedicated transmission system of M/s Aditya Birla Renewables Subsidiary Limited (App. No. 2200000138-390 MW) – Fatehgarh-III PS(Sec-II) 400 kV S/c line (suitable to carry minimum 900 MW at nominal voltage).
- (ii). Infrastructure required for sharing of dedicated transmission system shall be under the scope of M/s Azure Power India Pvt. Ltd

Same was agreed. All other aspects including the transmission system for connectivity under GNA related to grant of connectivity of M/s Azure Power India Pvt Ltd shall remain the same. Further, M/s Azure was asked to submit the sharing agreement with lead generator (i.e. Aditya Birla Renewables Subsidiary Ltd). M/s Azure agreed for the same.

C4. Revision of Connectivity transmission system for M/s Anboto Solar Pvt. Ltd.(250 MW App. No. 2200000281)

It was informed that M/s Anboto Solar is granted connectivity of 250 MW at Barmer-I PS based on the discussions in the 27th CMETS NR meeting held on 10.01.2024. In the meeting, M/s Anboto Solar had requested CTUIL to grant connectivity with 5.5 GW scheme (Ph-IV, Part-2). Regarding this, it was informed by CTUIL that, against the transmission system for evacuation of 5.5 GW from Fatehgarh-IV PS(Sec-II) (4 GW) & Barmer-I PS(1.5 GW) (Rajasthan REZ Ph-IV Part-2), total connectivity granted at Fatehgarh-IV (Sec-II) (4080MW) & Barmer-I PS (1350 MW) with 5.5 GW is 5430 MW. As there was only 70 MW margin against application of 250 MW at that point of time, it was decided to grant connectivity of 250 MW with additional system which included Rajasthan REZ Ph-IV Part-4(3.5 GW) scheme which was recently approved in 19th NCT.

Recently, in view of reallocation of connectivity at Fatehgarh-III PS followed by Fatehgarh-IV PS, total connectivity granted with Ph-IV Part-2(5.5 GW) scheme is reduced to about 5030 MW(Fatehgarh-IV PS(Sec-II) – 3730 MW & Barmer-I PS – 1300 MW). Considering the margin available with the above system, as M/s Anboto is having highest priority among applications granted connectivity with Rajasthan REZ Ph-IV Part-4 scheme. It was proposed to revise the transmission system for connectivity with Rajasthan Ph-IV Part-2 scheme. With this, total connectivity granted with Ph-IV Part-2 system shall be 5280 MW(Fatehgarh-IV(Sec-II) – 3730 MW & Barmer-I – 1550 MW). Next application in priority list is 300 MW at Barmer-I PS. However, at Barmer-I PS, total connectivity granted with Ph-IV Part-2 scheme is already crossed 1500 MW. Therefore, as of now, there is no further scope for revision of connectivity system to next applicant. At the time of application, M/s Anboto had requested for start date of connectivity from 30.11.2025. Therefore, with the revised system, start date of connectivity will be 30.06.2026(interim) matching with the transmission system schedule.

Details of revised transmission system & revised start date of connectivity for Anboto Solar, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

----- Same as earlier-----

C. Transmission system for Connectivity under GNA:

1. 2x1500 MVA (2nd & 3rd), 765/400 kV ICTs at Barmer-I Pooling Station
2. 2x500 MVA (3rd & 4th), 400/220 kV ICTs at Barmer-I Pooling Station
3. Fatehgarh-III (Section-2) PS – Barmer-I PS 400 kV D/c line (Quad)
4. Establishment of 2x1500 MVA, 765/400 kV Substation at suitable location near Sirohi along with 2x240 MVar (765 kV) & 2x125 MVar (400 kV) Bus Reactor
5. Barmer-I PS– Sirohi PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end
6. Sirohi PS-Chittorgarh (PG) 400 kV D/c line along with 80 MVar switchable line reactor for each circuit at Sirohi PS end (Quad)
7. Establishment of, 765 kV Substation at suitable location near Rishabdeo (Distt. Udaipur) along with 2x240 MVar (765 kV) Bus Reactor
8. Sirohi PS- Rishabdeo 765 kV D/c line along with 330 MVar switchable line reactor for each circuit at Sirohi end
9. Rishabdeo - Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at Rishabdeo end
10. LILO of one circuit of 765 kV Chittorgarh-Banaskanta D/c line at Rishabdeo S/s
11. Establishment of 765 kV Mandsaur PS along with 2x330 MVAR (765 kV) Bus Reactors
12. Mandsaur PS–Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS – Indore(PG) 765 kV D/c Line
13. Establishment of 765/400 kV (2x1500 MVA Kurawar S/s (with 1x500 MVA spare single phase transformer unit) with 2x330 MVar 765 kV bus reactor and 1x125 MVar 420 kV bus reactor (with 1x110 MVar & 1x80 MVar, 765 kV spare single phase reactor unit for line/bus reactor)
14. Mandsaur – Kurawar 765 kV D/c line along with 240 MVar switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line
15. LILO of Indore – Bhopal 765 kV S/c line at Kurawar
16. Kurawar – Ashtha 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
17. LILO of one circuit of Indore – Itarsi 400 kV D/c line at Astha
18. Shujalpur – Kurawar 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line

Revised Start Date of Connectivity under GNA: 30.06.2026(Interim). Final date shall be confirmed upon award of the system.

C5. Applications for Connectivity to ISTS under CERC (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022 received in Nov'23:

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
1.	2200000387	Acme Cleantech Solutions Private Limited	Jaisalmer distt., Rajasthan	29.11.2023	Generator (Solar)	Land BG route	600	31.03.2026	Fatehgarh-II PS
2.	2200000396	Acme Cleantech Solutions Private Limited	Jaisalmer distt., Rajasthan	30.11.2023	Generator (Hybrid)	LOA (SJVN)	250	31.03.2026	Fatehgarh-II PS

It was informed that in 27th CMETS-NR meeting held on 10.01.2024, connectivity applications of M/s ACME (600+250) were deliberated. In the meeting, it was stated that CTUIL has recently received a request from ABC RJ Land 01 Pvt. Ltd. (380 MW) granted connectivity at Fatehgarh-IV PS(Sec-I) to shift their connectivity from Fatehgarh-IV PS(Sec-II) to Fatehgarh-II PS. The matter was to be examined comprehensively. Accordingly, it was informed in the meeting that the above applications from M/s ACME for grant of connectivity at Fatehgarh-II PS shall be discussed in the next CMETS NR meeting.

Further in the reallocation meeting of Connectivity at Fatehgarh-II PS held on 19.01.2024, it was informed that, in view of not opting for reallocation by any applicant at Fatehgarh-III PS or Fatehgarh-IV PS including ABC RJ (270 MW+110 MW), the margin of 1000 MW connectivity at Fatehgarh-II PS may be offered to new applicants.

In view of the above and APTEL order dated 28.05.2024 on petition nos. 50, 51, 79, 82 & 160 of 2024, the margin available at Fatehgarh-II PS can be allocated to fresh applicants.

One no of 400 kV line bay is in advanced stage of implementation at Fatehgarh-II PS. Accordingly, it was proposed to grant connectivity of 600 MW & 250 MW to M/s ACME at Fatehgarh-II PS through 400 kV S/c line through same 400kV bay.

Further, in view of the issues in implementation of overhead DTL near Fatehgarh-II PS, M/s ACME was asked to confirm the configuration of their DTL (overhead or underground or hybrid). M/s ACME informed that at present they would like to consider overhead transmission line. However, they would comply with the final order of Hon'ble Supreme Court.

M/s Grid India enquired about total connectivity which is granted at Fatehgarh-II PS. Regarding this it was informed that Fatehgarh-II PS was earlier closed with total grant of 5460 MW connectivity. However, during GNA transition , 1000 MW of connectivity was surrendered. Therefore, the margin of 1000 MW was available for grant at Fatehgarh-II PS. With this grant of 850 MW to M/s ACME, total connectivity granted at Fatehgarh-II PS will be 5310 MW and there will be margin of 150 MW at Fatehgarh-II PS.

M/s Axis Energy in the meeting enquired that can CTUIL allow connectivity through overhead line at Fatehgarh-II PS at this stage as it falls under "additional important area (GIB)" and there are no clear directions from Supreme Court. CTUIL clarified that the decision to allow through undergrounding/hybrid or deny overhead line in GIB area vest with the Hon'ble supreme Court constituted committee/any other subsequent direction-order. CTUIL in the agenda itself has already highlighted the GIB issues at Fatehgarh-II PS. However, it is also to note that RE developers are already executed/executing their projects as per the DTL approval of GIB committee. Accordingly, CTUIL in the meeting asked M/s ACME about the configuration of DTL which they are considering. M/s ACME

has already clarified that at this stage they are going ahead with overhead configuration. However, they shall comply with the decision of Hon'ble Supreme court order/committee directions, if any in this regard.

Further, it was also informed that 400 kV Fatehgarh-II – Bhadla-III D/c line which was part of Phase-III scheme has not been ratified for laying of overhead line by supreme court constituted GIB committee. Therefore, for the grant of connectivity of 850 MW to M/s ACME, 765/400 kV 1500 MVA ICT(7th) at Fatehgarh-II PS is required. The 7th 1500 MVA ICT at Fatehgarh-II PS was taken up for approval in the 14th NCT meeting held on 09.06.2023 where the same was deferred and it was decided that the ICT would be taken up for implementation in the matching timeframe of Fatehgarh-II PS- Bhadla III PS 400 kV D/c line, once the transmission line is approved by the GIB Committee constituted by Hon'ble Supreme Court Committee. However, now in view of the requirement of ICT for grant of connectivity to M/s ACME, the 7th 1500 MVA ICT is to be again taken up for approval in the ensuing NCT meeting.

I. Application No. 2200000387(600 MW) & 2200000396(250 MW)

Based on the above, it was proposed to grant connectivity to M/s ACME for App No. 2200000387 (600MW) & 2200000396(250 MW) at Fatehgarh-II PS at 400 kV level through 1 no. of 400kV line bay.

It was also informed that M/s Acme Cleantech Solutions Private Limited has requested start date of Connectivity for 600MW & 250 MW from 31/03/2026. However, considering the same and expected commissioning date of transmission system (i.e. 31.07.2026), the start date of Connectivity under GNA shall be 31.07.2026(interim). Transmission system for connectivity of Acme Cleantech Solutions Private Limited for App. No. 2200000387 & 2200000396 under GNA, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

Common Pooling Station for Acme Cleantech Solutions Pvt Ltd. (App. No. 2200000387(600 MW) & 2200000396(250 MW)) Solar Power Projects
– Fatehgarh-II PS 400 kV S/c line on D/c tower (Suitable to carry minimum 900 MW at nominal voltage)

C. Transmission system for Connectivity under GNA:

1. Augmentation with 765/400kV, 2x1500 MVA Transformer (6th & 7th) at Fatehgarh-II PS
2. Fatehgarh-II PS – Bhadla-II PS 765kV D/c line (2nd)
3. Bhadla-II PS – Sikar-II 765kV D/c line(2nd)
4. Sikar-II – Khetri 765 kV D/c line
5. Sikar-II – Narela 765 kV D/c line along with 240 MVA Switchable line reactor for each circuit at each end of Sikar-II – Narela 765 kV D/c line
6. Jhatikara – Dwarka 400kV D/c line (Twin HTLS*)
7. Augmentation of 1x1500 MVA ICT (3rd), 765/400kV ICT at Jhatikara Substation (Bamnoli/Dwarka section)

* with minimum capacity of 2100 MVA/ckt at nominal voltage

Additional Transmission system for Inter-regional power transfer:

1) Establishment of 765 kV Mandsaur Pooling Station along with 2x330 MVAR (765 kV) Bus Reactors

2) Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end

3a) Mandsaur PS – Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS – Indore(PG) 765 kV D/c Line

OR

3b) Establishment of 765kV Kurawar S/s with 2x330 MVAR 765 kV bus reactor

3c) Mandsaur – Kurawar 765 kV D/c line along with 240 MVAR switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line

3d) LILO of Indore – Bhopal 765 kV S/c line at Kurawar

Start Date of Connectivity under GNA: 31.07.2026(Interim). Final date shall be confirmed upon award of the system

C6. Applications for Connectivity to ISTS under CERC (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022 received in Dec'23:

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
1.	2200000411	Enfinity Global Surya Kiran Private Limited	Barmer distt., Rajasthan	08.12.2023	Renewable Power Park developer (Solar)	Land Route	300	30.06.2026	Barmer-I PS
2.	2200000412	EG Mega Urja Private Limited (erstwhile Andhra Pradesh Resco Rooftop Solar Private Limited)	Barmer distt., Rajasthan	08.12.2023	Renewable Power Park developer (Solar)	Land Route	300	30.06.2026	Barmer-I PS
3.	2200000423	SJVN Green Energy Limited	Bikaner distt., Rajasthan	15.12.2023	Generator (Solar)	PPA PSPCL	1000 (revised to 500)	13.02.2025	Bikaner-IV PS
4.	2200000426* (Enhancement)	Renew Solar (Shakti Six) Private Limited	Bikaner distt., Rajasthan	16.12.2023	Generator (Solar)	Land Route	15	30.06.2026	Bhadla-III PS
5.	2200000436	Green Infra Wind Energy Limited	Barmer distt., Rajasthan	17.12.2023	Generator (Solar)	LOA NHPC	300	01.06.2026	Fatehgarh -II PS
6.	2200000425	Hinduja Renewables Energy Private Limited	Barmer distt., Rajasthan	18.12.2023	Generator (Solar)	LOA NHPC	250	07.03.2026	Barmer-I PS

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
7.	2200000437	Green Infra Clean Wind Limited	Jaisalmer & Bikaner distt., Rajasthan	18.12.2023	Generator (Solar)	Land Route	300	01.06.2027	Fatehgarh -IV PS
8.	2200000408	Green Infra Clean Solar Farms Limited	Barmer distt., Rajasthan	18.12.2023	Generator (Solar)	Land Route	130	01-06-2027	Barmer-I PS
9.	2200000410	Green Infra Renewable Projects Limited	Jaisalmer distt., Rajasthan	19.12.2023	Generator (Solar)	Land Route	683	01.06.2027	Barmer-I PS
10.	2200000419	Furies Solren Private Limited	Bikaner distt., Rajasthan	21.12.2023	Generator (Solar)	Land BG Route	300	31.01.2026	Bikaner-III PS
11.	2200000407	Avaada Energy Private Limited	Bikaner distt., Rajasthan	21.12.2023	Generator (Solar)	LOA NHPC	1000	31.12.2025	Bhadla-III PS
12.	2200000420	NTPC Renewable Energy Limited	Bikaner distt., Rajasthan	22.12.2023	Generator (Solar)	Land Route	1000	30.06.2026	Bikaner-IV PS
13.	2200000452	Pravat Renewables India Project Private Limited	Jaisalmer distt., Rajasthan	27.12.2023	Renewable Power Park developer (Solar)	Land BG Route	300	01.05.2028	Ramgarh PS
14.	2200000459	Apraava Energy Private Limited	Barmer distt., Rajasthan	29.12.2023	Generator (Solar)	LOA NHPC	250	31.03.2026	Fatehgarh -IV PS
15.	2200000469*	Serentica Renewables India 11 Private Limited	Barmer distt., Rajasthan	30.12.2023	Generator (Solar)	Land BG Route	300	31.05.2026	Barmer/ Fatehgarh-IV
16.	2200000482*	Juniper Green Energy Private Limited	Bikaner distt., Rajasthan	30.12.2023	Generator (Solar)	Land BG Route	200	30.09.2027	Bikaner-III PS
17.	2200000475	Saurya Urja Company of Rajasthan Limited	Bikaner distt., Rajasthan	30.12.2023	Renewable Power Park developer (Solar)	Land BG Route	400	31.12.2025	Bikaner PS
18.	2200000485	Juniper Green Energy Private Limited	Barmer distt., Rajasthan	31.12.2023	Generator (Solar)	Land BG Route	50	31.12.2027	Fatehgarh -IV PS

* It was mentioned that the applicants at S. No. 4 by M/s Renew Solar (Shakti Six), S. No. 15 by Serentica & S. No. 16 by M/s Juniper Green has been withdrawn by the respective applicants. Accordingly, the above applications are already closed and therefore shall not be taken up for discussion in the meeting.

CTUIL informed that, in accordance with GNA Regulation, recent CERC Order dated 12.05.2024 in Petition No. 9/MP/2024 and CERC Suo Moto Order dated 22.09.2023 in Petition No. 11/SM/2023, the following requests can be considered only after grant of connectivity:

- Change in fuel (as per Clause 5(xiii) of the Detailed Procedure)
- Change in route of Connectivity (As per Clause (4) of Regulation 11A)
- Change in project location

As explained in the above order, an entity attains the status of Connectivity grantee after signing of Connectivity Agreement in line with Regulation 10.3, before which the entity remains as Applicant. Accordingly, if an entity wants any of the changes referred to above including project location(co-ordinates) communicated at the time of application before signing of Connectivity Agreement, they may withdraw their application and apply afresh in accordance with the Regulations.

It was also informed that, as per the practice, sometimes due to limited margin availability at a pooling station, at the time of grant, applicants (Only RE Generators) may opt for reduction of the connectivity quantum (as well as installed capacity) so that the connectivity may be accommodated at the preferred pooling station. For such cases, RE applicant need to give a formal request along with CEA certificate for reduction of Installed capacity. CTU has already referred the matter of reduction of connectivity quantum in case of availability of limited margin to Hon'ble Commission in Jun'24.

Further, in case of withdrawals of the application, applicant need to confirm the same through letter/mail so that further action may be taken as per the regulation,. In case of non receipt of such withdrawal mail/letter, CTUIL shall proceed to grant connectivity as proposed in the agenda.

Above was noted by the applicants.

With above, deliberations on the applications started as under:

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
1.	2200000411	Enfinity Global Surya Kiran Private Limited	Barmer distt., Rajasthan	08.12.2023	Renewable Power Park developer (Solar)	Land Route	300	30.06.2026	Barmer-I PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: NIL(Bay under applicant scope) • Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Enfinity Global Surya Kiran Private Limited has applied for connectivity of 300 MW at Barmer-I PS. Accordingly, it was proposed to grant connectivity to M/s Enfinity at Barmer-I PS at 220 kV level through 1 no. of 220 kV line bay. M/s Enfinity Global agreed for the same. Applicant was asked to confirm the 220kV bay scope at Barmer-I PS end and the DTL tower configuration. M/s Enfinity Global informed that 220 kV bay at Barmer-I PS end shall be under their scope and the tower configuration shall be S/c on D/c towers. The same was noted. It was also informed that M/s Enfinity Global Surya Kiran Private Limited has requested start Date of Connectivity under GNA from 30.06.2026. Considering the same and expected commissioning date of transmission system(i.e. 30.11.2026), the start date of Connectivity under GNA shall be 30.11.2026(interim). M/s Enfinity global noted the same. Transmission system for connectivity of M/s Enfinity Global Surya Kiran Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u>										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Enfinity Global Surya Kiran Private Limited Renewable Power Park– Barmer-I PS 220 kV S/c line on D/c tower (suitable to carry minimum 300 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-I Start Date of Connectivity under GNA: 30.11.2026(Interim). Final date shall be confirmed upon award of the system										
2.	2200000412	EG Mega Urja Private Limited (erstwhile Andhra Pradesh Resco Rooftop Solar Private Limited)	Barmer distt., Rajasthan	08.12.2023	Renewable Power Park developer (Solar)	Land Route	300	30.06.2026	Barmer-I PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: NIL(Bay under applicant scope) • Conn BG3: Rs. 2 lakh/MW
It was informed that M/s EG Mega Urja Pvt. Ltd. (erstwhile Andhra Pradesh Resco Rooftop Solar Private Limited) has applied for connectivity of 300 MW at Barmer-I PS. Accordingly, it was proposed to grant connectivity at Barmer-I PS at 220 kV level through 1 no. of 220 kV line bay. M/s EG Mega Urja agreed for the same. Applicant was asked to confirm the 220kV bay scope at Barmer-I PS end and the DTL tower configuration. M/s EG Mega Urja informed that 220 kV bay at Barmer-I PS end shall be under their scope and the tower configuration shall be S/c on D/c towers. The same was noted. It was also informed that M/s EG Mega Urja Pvt. Ltd has requested start Date of Connectivity under GNA from 30.06.2026. Considering the same and expected commissioning date of transmission system (i.e. 30.11.2026), the start date of Connectivity under GNA shall be 30.11.2026 (interim). M/s EG Mega Urja noted the same. Transmission system for connectivity of M/s EG Mega Urja Pvt. Ltd Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). M/s EG Mega Urja Private Limited Renewable Power Park – Barmer-I PS 220 kV S/c line on D/c towers (Suitable to carry minimum 300 MW at nominal voltage)										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
C. <u>Transmission system for Connectivity under GNA: As per Annexure-I</u>										
Start Date of Connectivity under GNA: 30.11.2026(Interim). Final date shall be confirmed upon award of the system.										
3.	2200000423	SJVN Green Energy Limited	Bikaner distt., Rajasthan	15.12.2023	Generator (Solar)	PPA PSPCL	1000 (revised to 500 MW)	13.02.2025	Bikaner-IV PS	• Conn BG1:Rs. 50 Lakh • Conn BG2: Rs. 6 Cr. • Conn BG3: Rs. 2 lakh/MW
It was informed that M/s SJVN Green Energy Limited had initially applied for connectivity of 1000 MW at Bikaner-IV PS through PPA route. However, SJVN vide letter dated 22.04.2024 has requested for reduction in connectivity quantum to 500 MW stating that during scrutiny of PPA, it has come to their knowledge that as per Schedule-II of PPA, only 500 MW capacity is to be installed at Bikaner, Rajasthan and 500MW capacity is to be installed at Bhuj-II, Gujarat. Considering above, application was taken up for grant of 500 MW in Bikaner complex. Accordingly, it was proposed to grant connectivity of 500 MW at Bikaner-IV PS at 220 kV level through 2 no. of 220 kV line bay.M/s SJVN agreed for the same. Applicant was asked to confirm the scope of 220kV bays at Bikaner-IV PS end(2 Nos.). M/s SJVN informed that 220 kV bays at Bikaner-IV PS end shall be under ISTS. The same was noted. It was also informed that M/s SJVN Green Energy Limited has requested Start Date of Connectivity under GNA from 13.02.2025. However, considering the same and expected commissioning date of transmission system (i.e. 30.09.2026), the start date of Connectivity under GNA shall be 30.09.2026 (interim). M/s SJVN noted the same. Transmission system for connectivity of M/s SJVN Green Energy Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). SJVN Green Energy Limited Solar Power Project – Bikaner-IV PS 220 kV D/c line (Suitable to carry minimum 300 MW per circuit at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-VI										
Start Date of Connectivity under GNA: 30.09.2026(Interim). Final date shall be confirmed upon award of the system										
4.	2200000436	Green Infra Wind Energy Limited	Barmer distt., Rajasthan	17.12.2023	Generator (Solar)	LOA NHPC	300	01.06.2026	Fatehgarh -II PS	Not Applicable

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
It was informed that M/s Green Infra Wind Energy Limited had applied for connectivity of 300 MW at Fatehgarh-II PS. Subsequently, M/s Green Infra vide letter dated 16.01.2024 has requested to consider application for grant of connectivity at Fatehgarh-IV PS instead of earlier mentioned Fatehgarh-II due to GIB issues near the Fatehgarh-II PS. However, in view of no further margin available for grant at Fatehgarh-IV PS(Sec-II), it was proposed to grant connectivity at next PS in Fatehgarh-Barmer complex i.e. Barmer-I PS. M/s Green Infra in the meeting & subsequently vide mail dated 01.07.2024 informed that they would like to withdraw the present application no. 2200000436. Accordingly, it was decided to close the present application as per GNA Regulations.										
5.	2200000425	Hinduja Renewables Energy Private Limited	Barmer distt., Rajasthan	18.12.2023	Generator (Solar)	LOA NHPC	250	07.03.2026	Barmer-I PS	Conn BG1: Rs. 50 Lakh Conn BG2: Rs. 3 Cr. Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Hinduja Renewables Energy Private Limited has applied for connectivity of 250 MW at Barmer-I PS. Accordingly, it was proposed to grant connectivity at Barmer-I PS at 220 kV level through 1 no. of 220 kV line bay. M/s Hinduja agreed for the same. Applicant was asked to confirm the 220kV bay scope at Barmer-I PS end and the DTL tower configuration. M/s Hinduja informed that 220 kV bay at Barmer-I PS end shall be under ISTS scope and the tower configuration shall be S/c on D/c towers. M/s Hinduja also informed that their project SCoD date as per LoA is 29.04.2026. The same was noted. It was also informed that M/s Hinduja Renewables Energy Private Limited has requested start Date of Connectivity under GNA from 07/03/2026. However, considering the same and expected commissioning date of transmission system(i.e. 30.11.2026), the start date of Connectivity under GNA shall be 30.11.2026(interim). M/s Hinduja noted the same. Transmission system for connectivity of M/s Hinduja Renewables Energy Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Hinduja Renewables Energy Private Ltd Solar Power Project – Barmer-I PS 220 kV S/c line on D/c tower (Suitable to carry minimum 300 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-I Start Date of Connectivity under GNA: 30.11.2026(Interim). Final date shall be confirmed upon award of the system										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
6.	2200000437	Green Infra Clean Wind Limited	Jaisalmer & Bikaner distt., Rajasthan	18.12.2023	Generator (Solar)	Land Route	300	01.06.2027	Fatehgarh -IV PS	- Conn BG1: Rs. 50 Lakh - Conn BG2: Nil(Bay in sharing) - Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Green Infra Clean Wind Limited has applied for connectivity of 300 MW at Fatehgarh-IV PS via Land route. The applicant had mentioned the project location as Jaisalmer & Bikaner district. However, from the coordinates of location of the project as well as Land documents submitted with the application, it was observed that the project is very far from Fatehgarh-IV PS (120-130 miles i.e. about 190 km), also passing through GIB area. Rather, the location of the project is very close to Bhadla complex. M/s Green Infra vide mail dated 13-06-2024 also clarified that the land is near to Bhadla-III PS (~5 km) and requested CTUIL to consider the above application for grant of connectivity at Bhadla-III PS.

CTUIL enquired M/s Green Infra the reason for mentioning Fatehgarh-IV PS as the nearest pooling station when their location is near Bhadla-III. Regarding this, M/s Green Infra informed that at the time of application, Bhadla-III PS was full and there was no visibility of Bhadla-IV PS therefore they mentioned Fatehgarh-IV PS.

CTUIL clarified that just because there was no visibility of Bhadla-IV PS to Green Infra, they cannot get connectivity at Fatehgarh-IV PS even if margin was available at Fatehgarh-IV as their land parcel is near Bhadla-III PS. CTUIL also highlighted that they have observed that recently some developers are mentioning multiple pooling station names in the applications as nearest pooling stations which are far apart from the project location.

As details of nearest ISTS pooling station is an “optional entry” in the application, in case of multiple entries made in the application, CTUIL based on the project location shall identify the nearest pooling station for grant. Accordingly, it was proposed to grant connectivity of 300 MW to M/s Green Infra at Bhadla-III PS at 220 kV in the agenda.

CTUIL requested all applications to note that such a practice of mentioning multiple pooling station or PS in different complex names under “nearest ISTS pooling station” field in application should be avoided as the proposal will only consider based on generation project location mentioned in the application. Applicants noted the same.

M/s Green Infra in the meeting informed that they would like to opt for connectivity at Bhadla-II PS in sharing with M/s Azure. Regarding this, CTUIL informed that after reallocation meeting held on 12.06.2024, margin for connectivity of 350 MW is available at Bhadla-II PS at 400 kV in sharing with M/s Azure. Accordingly, it was agreed to grant connectivity to M/s Azure at Bhadla-II PS in sharing with M/s Azure at 400 kV. It was also informed that M/s Green Infra need to submit sharing agreement with M/s Azure. M/s Green Infra agreed for the same.

M/s Avaada Energy in the meeting raised their protest regarding grant on connectivity to M/s Green Infra at Bhadla-II PS. M/s Avaada informed that as the present application is made for connectivity at Fatehgarh-IV PS, why M/s Green Infra should be allowed to shift from Fatehgarh-IV PS to Bhadla-II PS. Regarding this,

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
CTUIL clarified that this is not a case of connectivity shifting. As per the RE complex vicinity approach, based on their land location in Bhadla complex, Green Infra does not qualify for connectivity at Fatehgarh-IV PS & rather qualify for connectivity at Bhadla-III PS.. Further, CTUIL also need to see technical feasibility & RoW optimization before granting connectivity at any location. Therefore, as Green Infra has applied via land route with land location near Bhadla complex, they are eligible for connectivity at Bhadla complex only not in Fatehgarh-Barmer complex. Accordingly, Green Infra is considered for grant at Bhadla complex. The same was agreed by the stakeholders. Accordingly, it was decided to grant connectivity of 300 MW to M/s Green Infra at Bhadla-II PS at 400 kV in sharing with M/s Azure. It was also informed that M/s Green Infra Clean Wind Limited has requested start Date of Connectivity under GNA from 01/06/2027. Considering the same and expected commissioning date of transmission system (i.e. 31.07.2026), the start date of Connectivity under GNA shall be 01.06.2027(interim). M/s Green Infra noted the same. Transmission system for connectivity of M/s Green Infra Clean Wind Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Through sharing of dedicated transmission system of M/s Azure Power India Pvt. Ltd (650 MW) – Bhadla-II PS 400 kV S/c line (Suitable to carry minimum 1000 MW at nominal voltage). (ii). Infrastructure required for sharing dedicated transmission system - under the scope of M/s Green Infra Clean Wind Ltd C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-III Start Date of Connectivity under GNA: 01.06.2027(Interim). Final date shall be confirmed upon award of the system										
7.	2200000408	Green Infra Clean Solar Farms Limited	Barmer distt., Rajasthan	18.12.2023	Generator (Solar)	Land Route	130	01-06-2027	Barmer-I PS	• Conn BG1: Rs. 50 Lakh • Conn BG2:Rs. 3 Cr. • Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Green Infra Clean Solar Farms Limited has applied for connectivity of 130 MW at Barmer-I PS. Accordingly, it was proposed to grant connectivity of 130 MW at 220 kV Barmer-I PS. M/s Green Infra informed that for the present application, they would like to get connectivity at Barmer-II PS, as they have other applications in que which they										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
want to utilize for Barmer-1 PS as per application priority. The same was agreed. It was also informed that the transmission system for evacuation of power from Barmer-II PS is presently under discussion. The scheme is currently tentative, which shall be finalized in a separate joint study meeting among CEA, CTUIL, Grid India & Stakeholders followed by the subsequent CMETS meeting. The detailed transmission system shall be informed upon finalization and approval of the scheme. Applicant was asked to confirm the 220kV bay scope at Barmer-II PS end and the DTL tower configuration. M/s Green Infra informed that 220 kV bay at Barmer-II PS end shall be under ISTS scope and the tower configuration shall be S/c line. The same was noted. M/s Green Infra Clean Solar Farms Limited has requested start Date of Connectivity under GNA from 01/06/2027. Considering the same and expected commissioning date of transmission system(i.e. 31.12.2029), the start date of Connectivity under GNA shall be 31.12.2029(interim). M/s Green Infra noted the same. Transmission system for connectivity of M/s Green Infra Clean Solar Farms Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Green Infra Clean Solar Farms Limited Solar Power Project – Barmer-II PS 220 kV S/c line (Suitable to carry minimum 300 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-II Start Date of Connectivity under GNA: 31.12.2029 (Interim). Final date shall be confirmed upon award of the system										
8.	2200000410	Green Infra Renewable Projects Limited	Jaisalmer distt., Rajasthan	19.12.2023	Generator (Solar)	Land Route	683 Reduced to 600)	01.06.2027	Barmer-I PS	Conn BG1: Rs. 50 Lakh Conn BG2: Rs. 6 Cr. Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Green Infra Renewable Projects Limited has applied for connectivity of 683 MW at Barmer-I PS. M/s Green Infra requested for grant of 683 MW at Barmer-I PS. CTUIL informed that at Barmer-I PS margin available for fresh grant is only 600 MW excluding enhancement margins of 50 MW in two 220kV bays. Accordingly, Green Infra in the meeting & subsequently vide mail dated 01.07.2024 opted to reduce the connectivity quantum & installed capacity for this application										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
to 600 MW(from 683 MW) so that the entire connectivity can be granted at Barmer-I PS. Accordingly, it was proposed to grant connectivity of 600 MW to M/s Green Infra at Barmer-I PS through 220 kV D/c line. Applicant was asked to confirm the scope of the 220kV bays at Barmer-I PS end (2 no.). M/s Green Infra informed that 220 kV bays at Barmer-I PS end shall be under ISTS scope. The same was noted. M/s Green Infra Renewable Projects Limited has requested start date of Connectivity under GNA from 01/06/2027. Considering the same and expected commissioning date of transmission system (i.e. 30.11.2026), the start date of Connectivity under GNA shall be 01.06.2027(interim). M/s Green Infra noted the same. Transmission system for connectivity of M/s Green Infra Renewable Projects Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Green Infra Renewable Projects Limited Solar Power Project – Barmer-I PS 220 kV D/c line (Suitable to carry minimum 300 MW per circuit at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-I Start Date of Connectivity under GNA: 01.06.2027(interim Final date shall be confirmed upon award of the system It was also informed that, with the present grant of 600 MW to M/s Green Infra, total connectivity granted at Barmer-I PS is 3900 MW. Considering the margins of 100 MW available in already granted 220kV bays (50 MW :Anboto & 50 MW Hinduja), total connectivity will be 4000 MW. Considering the above, as Barmer-I PS was planned for 4000 MW, Barmer-I PS shall be closed for further grant of connectivity except for enhancements/ in sharing through above 220 kV bays allocated to M/s Anboto, Hinduja.										
9.	2200000419	Furies Solren Private Limited	Bikaner distt., Rajasthan	21.12.2023	Generator (Solar)	Land BG Route	300	31.01.2026	Bikaner-III PS	Conn BG1: Rs. 50 Lakh Conn BG2: Rs. 3 Cr. Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Furies Solren Private Limited has applied for connectivity for 300 MW at Bikaner-III PS. However, as there is no margin available for grant at Bikaner-III PS, it was proposed to grant connectivity at Bikaner-IV PS at 220 kV level through 1 no. of 220 kV line bay. M/s Furies Solren noted the same.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
Applicant was asked to confirm the 220kV bay scope at Bikaner-IV PS end and the DTL tower configuration. M/s Furies Solren informed that 220 kV bay at Bikaner-IV PS end shall be under ISTS scope and the tower configuration shall be S/c line on D/c towers. The same was noted. It was also informed that M/s Furies Solren Private Limited has requested Start Date of Connectivity under GNA from 31/01/2026. However, considering the same and expected commissioning date of transmission system (i.e. 30.09.2026), the start date of Connectivity under GNA shall be 30.09.2026 (interim). M/s Furies Solren noted the same. Transmission system for connectivity of M/s Furies Solren Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Furies Solren Private Limited Solar Power Project– Bikaner-IV PS 220 kV S/c line D/c tower (Suitable to carry minimum 300 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA</u> : As per Annexure-VI Start Date of Connectivity under GNA: 30.09.2026(Interim). Final date shall be confirmed upon award of the system										
10.	2200000407	Avaada Energy Private Limited	Bikaner distt., Rajasthan	21.12.2023	Generator (Solar)	LOA NHPC	1000 (Subsequently reduced to 300 MW by Avaada)	31.12.2025	Bhadla-III PS	Conn BG1: Rs. 50 Lakh Conn BG2: Rs. 3 Cr. Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Avaada Energy Private Limited has applied for connectivity for 1000 MW at Bhadla-III PS. However, there is no margin for grant of 1000 MW connectivity at Bhadla-III PS. Therefore, it was proposed to grant connectivity at Bhadla-IV PS at 400 kV level through 1 no. of 400 kV line bay. M/s Avaada informed that vide letter dated 25.06.2024, they have requested to split the connectivity of 1000 MW to avail connectivity of 350 MW at Bhadla-II PS, 350 MW at Bhadla-III PS and remaining capacity of 300 MW at Bhadla-IV PS. M/s Avaada vide letter dated 26.06.2024 had also requested CTUIL to defer the CMETS NR meeting, in view of pendency of Writ Petition filed by M/s Avaada before Hon'ble High Court of Delhi. Regarding above, CTUIL informed that in the present GNA regulations, as of now, there is no provision to split a single application for grant of connectivity at multiple stations. Further, CTU also don't have any direction from the High Court to defer the CMETS-NR meeting based on M/s Avaada petition, therefore the										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
meeting is being continued as scheduled. However, as per the practice, sometimes due to limited margin availability at a pooling station, at the time of grant, applicants (Only RE Generators) may opt for reduction of the connectivity quantum (as well as installed capacity) so that the connectivity may be accommodated at the preferred pooling station. For such cases, RE applicant need to give a formal request along with CEA certificate for reduction of Installed capacity. CTU has already referred the matter of reduction of connectivity quantum in case of availability of limited margin to Hon'ble CERC in Jun'24. Accordingly, in view of limited margin available at Bhadla-III PS, M/s Avaada (1000 MW) may decide suitably. M/s Avaada in the meeting informed that they have also filed a petition with CERC regarding the splitting of connectivity [350 MW at Bhadla-II PS, 350 MW at Bhadla-III & 300 MW at Bhadla-IV] which is going to be heard on 04th July'24. Regarding connectivity at Bhadla-II PS, Avaada informed that even though it is already allocated to Green Infra (300 MW) in this meeting, they have requested to record their protest regarding the grant of connectivity to M/s Green Infra. Same was noted. CTUIL stated that as informed earlier, there is no provision to split connectivity across multiple stations. Therefore, for the present application (1000 MW), connectivity shall be granted at Bhadla-IV PS. M/s Avaada informed that they are ready to downsize their application for grant of connectivity at Bhadla-III PS. CTUIL informed that after reallocation meeting held on 12.06.2024, total margin for connectivity of 350 MW is available at Bhadla-III PS (150 MW in sharing with M/s Solarcraft and additional margin of 200 MW through separate bay). It may be noted that total connectivity granted at Bhadla-III PS is 6150 MW whereas connectivity upto 6500 MW can only be granted. For optimal utilization of 220 kV bay allocated to M/s Solarcraft (160 MW), if margin of 150 MW is kept reserved for enhancement, then remaining margin at Bhadla-III PS shall be only 200 MW. Therefore, only 200 MW can be allocated at new 220 kV line bay. However, in case 300 MW of connectivity is granted at a new 220 kV line bay, then additional connectivity of only 50 MW can be granted through the bay allocated to M/s Solarcraft(i.e.total 210 MW). Therefore, in either case due to limitation of capacity at substation level, one of the two 220 kV bays shall remain underutilized than 300 MW capacity. Considering above, it was decided that connectivity of 300 MW can be granted at Bhadla-III PS on a separate 220 kV bay. Based on above, M/s Avaada accepted to avail 300 MW connectivity at Bhadla-III PS and confirmed to submit reduction of connectivity quantum to 300 MW as well as revised installed capacity CEA certificate shortly. Accordingly, it was agreed to grant connectivity at Bhadla-III PS through 220 kV S/c line. CTUIL asked M/s Avaada to confirm the 220kV bay scope at Bhadla-III PS end and the DTL tower configuration. M/s Avaada informed that 220 kV bay at Bhadla-III PS end shall be under ISTS scope and the tower configuration shall be S/c line on D/c tower. The same was noted. Subsequently, M/s Avaada submitted confirmation on reduction of connectivity quantum to 300 MW (From earlier 1000 MW) vide mail dated 29.06.24 as well as revised installed capacity CEA certificate vide mail dated 02.07.2024.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
It was also informed that M/s Avaada Energy Private Limited has requested Start Date of Connectivity under GNA from 31/12/2025. However, considering the same and expected commissioning date of transmission system (i.e. 31.12.2028), the start date of Connectivity under GNA shall be 31.12.2028 (interim). Transmission system for connectivity of M/s Avaada Energy Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Avaada Energy Private Limited Solar Power Project – Bhadla-III PS 220 kV S/c line on D/c tower (suitable to carry minimum 300 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-V Start Date of Connectivity under GNA: 31.12.2028(Interim). Final date shall be confirmed upon award of the system It was also informed that with the present grant of 300 MW to M/s Avaada, total connectivity granted at Bhadla-III PS is 6450 MW. Considering above, as Bhadla-III PS was planned for 6500 MW, Bhadla-III PS shall be closed for further grant of connectivity except for 50 MW enhancements/in sharing through 220 kV bay allocated to M/s Solarcraft(110+50 MW).										
11.	2200000420	NTPC Renewable Energy Limited	Bikaner distt., Rajasthan	22.12.2023	Generator (Solar)	Land Route	1000 (Reduce to 400 MW)	30.06.2026	Bikaner-IV PS	Conn BG1: Rs. 50 Lakh Conn BG2: Nil(Bay in sharing) Conn BG3: Rs. 2 lakh/MW
It was informed that M/s NTPC Renewable Energy Limited has applied for connectivity for 1000 MW at Bikaner-IV PS. It may be noted that total connectivity granted at Bikaner-IV PS is 5600 MW. As Bikaner-IV was planned for 6000 MW, only 400 MW margin is available for grant connectivity at Bikaner-IV PS. Therefore, in view of no margin for grant of connectivity of 1000 MW at Bikaner-IV PS, it was proposed to grant connectivity at Bikaner-V PS at 400 kV level through 1 no. of 400 kV line bay. M/s NTPC Renewable in the meeting informed that they wish to get connectivity at Bikaner-IV PS. Therefore, they opt to reduce their connectivity quantum & installed capacity for this application to 400 MW so that the connectivity can be granted at Bikaner-IV PS. CTUIL requested to confirm the same through mail & submit the revised CEA installed capacity certificate. NTPC agreed for the same. Subsequently, M/s NTPC vide mail dated 28.06.2024 confirmed reduction of connectivity quantum to 400 MW. Subsequently, NTPC vide mail dated 02.07.2024 also submitted the revised CEA installed capacity certificate for 400 MW.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
CTUIL informed that NTPC has already been granted connectivity of 1500 MW at Bikaner-IV PS through 400 kV D/c line. Accordingly, it was decided to grant connectivity of 400 MW at Bikaner-IV PS through same 400 kV D/c line in sharing with its other applications with revised DTL capacity of 950 MW per circuit (earlier capacity 900 MW per circuit) at nominal voltage. NTPC agreed for the same. M/s NTPC Renewable Energy Limited has requested Start Date of Connectivity under GNA from 30/06/2026. However, considering the same and expected commissioning date of transmission system (i.e. 30.09.2026), the start date of Connectivity under GNA shall be 30.09.2026 (interim). M/s NTPC noted the same. Transmission system for connectivity of M/s NTPC Renewable Energy Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Common pooling station for NTPC Renewable Energy Limited Solar Power Projects (App No. 2200000244(150 MW), 2200000308(700 MW), 2200000373(400 MW), 2200000358(250 MW) & 2200000420(400 MW) – Bikaner-IV PS 400 kV D/c line (Suitable to carry minimum 950 MW per circuit at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-VI Start Date of Connectivity under GNA: 30.09.2026(Interim). Final date shall be confirmed upon award of the system It was also informed that, with the present grant of 400 MW to M/s NTPC Renewable, total connectivity granted at Bikaner-IV PS is 6000 MW. As Bikaner-IV PS was planned for evacuation of 6000 MW, Bikaner-IV PS shall be closed for further grant of connectivity including enhancements. The subsequent applications received at Bikaner complex shall be considered for grant at Bikaner-V PS.										
12.	2200000452	Pravat Renewables India Project Private Limited	Jaisalmer distt., Rajasthan	27.12.2023	Renewable Power Park developer (Solar)	Land BG Route	300	01.05.2028 (revised to 31.01.29)	Ramgarh PS	Conn BG1: Rs. 50 Lakh Conn BG2: Rs. 3 Cr. Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Pravat Renewables India Project Private Limited had applied for connectivity of 300 MW at Ramgarh PS. Accordingly, it was proposed to grant connectivity at Ramgarh PS at 220 kV level through 1 no. of 220 kV line bay. M/s Pravat Renewable agreed for the same. Applicant was asked to confirm the 220kV bay scope at Ramgarh PS end and the DTL tower configuration. M/s Pravat Renewable informed that 220 kV bay at										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
Ramgarh PS end shall be under ISTS scope and the tower configuration shall be S/c line on D/c tower. The same was noted. It was also informed that M/s Pravat Renewables India Project Private Limited has requested start Date of Connectivity under GNA from 01/05/2028. Regarding this M/s Pravat Renewable in the meeting informed that they would like to revise their start date of connectivity to 31.01.2029 from earlier requested date of 01.05.2028. The same was agreed. Accordingly, considering the revised date of 31.01.2029 and expected commissioning date of transmission system (i.e. 31.12.2028), the start date of Connectivity under GNA shall be 31.01.2029(interim) as requested. M/s Pravat Renewable noted and agreed for the same. Transmission system for connectivity of M/s Pravat Renewables India Project Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Pravat Renewables India Project Pvt. Ltd. Renewable Power Park – Ramgarh PS 220 kV S/c line on D/c tower(suitable to carry minimum 300 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-VIII Start Date of Connectivity under GNA: 31.01.2029(Interim). Final date shall be confirmed upon award of the system										
13.	2200000459	Apraava Energy Private Limited	Barmer distt., Rajasthan	29.12.2023	Generator (Solar)	LOA NHPC	250	31.03.2026	Fatehgarh -IV PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 3 Cr. • Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Apraava Energy Private Limited has applied for connectivity of 250 MW at Fatehgarh-IV PS. However, there is no margin available for grant of 250 MW connectivity at Fatehgarh-IV PS as well as at Barmer-I PS. Accordingly, it was proposed to grant connectivity at Barmer-II PS at 220 kV level through 1 no. of 220 kV line bay. M/s Apraava agreed for the same. Applicant was asked to confirm the 220kV bay scope at Barmer-II PS end and the DTL tower configuration. M/s Apraava informed that 220 kV bay at Barmer-II PS end shall be under ISTS scope and the tower configuration shall be S/c line on D/c tower. M/s Apraava also informed that their project SCoD date as per LoA is 17.04.2026. The same was noted.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
It may be noted that the transmission system for evacuation of power from Barmer-II PS is presently under discussion. The scheme is currently tentative, which shall be finalized in a separate joint study meeting among CEA, CTUIL, Grid India & Stakeholders followed by the subsequent CMETS meeting. The detailed transmission system shall be informed upon finalization and approval of the scheme. M/s Apraava Energy Private Limited has requested start date of Connectivity under GNA from 31/03/2026. Considering the same and expected commissioning date of transmission system(i.e. 31.12.2029), the start date of Connectivity under GNA shall be 31.12.2029(interim). Transmission system for connectivity of M/s Apraava Energy Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Apraava Energy Private Limited Solar Power Project – Barmer-II PS 220 kV S/c line on D/c tower (Suitable to carry minimum 300 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-II Start Date of Connectivity under GNA: 31.12.2029(Interim). Final date shall be confirmed upon award of the system										
14.	2200000475	Saurya Urja Company of Rajasthan Limited	Bikaner distt., Rajasthan	30.12.2023	Renewable Power Park developer (Solar)	Land BG Route	400	31.12.2025	Bikaner PS	Conn BG1: Rs. 50 Lakh Conn BG2: Rs. 3 Cr. Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Saurya Urja Company of Rajasthan Limited has applied for connectivity for 400 MW at Bikaner PS. Initially in the agenda, connectivity was proposed to be granted at Bikaner-IV PS as the earlier application of NTPC Renewable (1000 MW) was proposed to be granted at Bikaner-V due to limited margin of 400 MW at Bikaner-IV PS. However, during the meeting, NTPC Renewable opted to reduce their connectivity quantum & installed capacity to 400 MW to get accommodated in Bikaner-IV PS. Therefore, with the grant of total 6000 MW at Bikaner-IV PS, Bikaner-IV PS is already closed for further grant. Accordingly, it was proposed to grant connectivity to M/s Saurya Urja at Bikaner-V PS at 220 kV level through 1 no. of 220 kV line bay. M/s Saurya Urja agreed for the same. Applicant was asked to confirm the 220kV bay scope at Bikaner-V PS end and the DTL tower configuration. M/s Saurya Urja informed that 220 kV bay at Bikaner-V PS end shall be under ISTS scope and the tower configuration shall be S/c line on D/c tower. The same was noted. It was also informed that the transmission system for evacuation of power from Bikaner-V PS is presently under discussion. The scheme is currently tentative, which shall be finalized in a separate joint study meeting among CEA, CTUIL, Grid India & Stakeholders followed by the subsequent CMETS meeting. The										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
detailed transmission system shall be informed upon finalization and approval of the scheme. A meeting was held under the chairmanship of Joint Secretary, MNRE on 31.05.2024 to discuss the additional potential Renewable Energy Zones (REZ) in the states of Madhya Pradesh, Rajasthan, and Gujarat. In the meeting, CTUIL informed that there are REZ in which they are receiving connectivity applications beyond the identified capacity & requested SECI and MNRE to provide their comments and declare the additional capacity as REZ. In this regard, MNRE advised that those RE developers who are coming with land acquisition route should be allowed to connect under REZ criteria (even beyond the identified capacity). However, with above minutes, there was no clarity on treatment of applications received in other routes like LoA/PPA or Land BG route. As the present application is through Land BG route, suitable clarifications from MNRE was required regarding consideration of RE Potential for transmission system consideration (ATS/Common). CTU also sought clarification from MNRE in this regard, which is still awaited. CTUIL also requested SECI to take up matter with MNRE and resolve the matter as the Conn BG requirement depends on the clarifications in this regard. SECI in the meeting informed that there is some ambiguity regarding the applications received in other routes in the minutes of MNRE meeting due to communication gap and they will take up the matter with MNRE. CTUIL also requested developers to take up matter with MNRE so that the issue can be resolved. Subsequently, MNRE vide mail dated 05.07.2024 clarified that <i>“since there is no difference between connectivity applications based on LoA route, Land BG route/ Land route, all the connectivity applications may be considered equally. The minutes of the meeting would be amended and re-issued accordingly.”</i> In view of the above clarification by MNRE, connectivity transmission system for the relevant applications including present one shall be considered as common transmission system and Conn BGs shall be considered accordingly. It was also informed that M/s Saurya Urja Company of Rajasthan Limited has requested Start Date of Connectivity under GNA from 31/12/2025. However, considering the same and expected commissioning date of transmission system (i.e. 31.12.2029), the start date of Connectivity under GNA shall be 31.12.2029 (interim). M/s Saurya Urja noted the same. Transmission system for connectivity of M/s Saurya Urja Company of Rajasthan Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS): NIL</u> B. <u>Transmission System under applicant scope</u> (i). Saurya Urja Company of Rajasthan Limited Renewable Power Park– Bikaner-V PS 220 kV S/c (high capacity) line on D/c tower(Suitable to carry minimum 400 MW at nominal voltage)										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
C. <u>Transmission system for Connectivity under GNA</u> As per Annexure-VII Start Date of Connectivity under GNA: 31.12.2029(Interim). Final date shall be confirmed upon award of the system										
15.	2200000485	Juniper Green Energy Private Limited	Barmer distt., Rajasthan	31.12.2023	Generator (Solar)	Land BG Route	50	31.12.2027	Fatehgarh -IV PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Nil(Bay in sharing) • Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Juniper Green Energy Private Limited has applied for enhancement of connectivity of 50 MW at Fatehgarh-IV PS. As informed earlier, after reallocation, there is 50 MW enhancement margin available at Fatehgarh-IV PS(Sec-II). Further, M/s Juniper Green is already granted connectivity of 300 MW at Fatehgarh-IV PS(Sec-II). Accordingly, it was proposed to grant connectivity at Fatehgarh-IV PS(Sec-II) through the same 220 kV bay earlier allocated to M/s Juniper Green for connectivity of 300 MW(App. No. 220000063). M/s Juniper agreed for the same. It was also informed that M/s Juniper Green Energy Private Limited has requested start date of Connectivity under GNA from 31/12/2027. Considering the same and expected commissioning date of transmission system (i.e. 30.11.2026), the start date of Connectivity under GNA shall be 31.12.2027(interim). Transmission system for connectivity of M/s Juniper Green Energy Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Common Pooling Station for Juniper Green Steller Pvt. Ltd. Renewable Power Park(App. No. 2200000063-300 MW) & Juniper Green Energy Pvt. Ltd. Solar Power Project(App. No. 2200000485-50 MW)– Fatehgarh-IV PS(Sec-II) 220 kV S/c line on D/c tower (Suitable to carry minimum 350 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-X Start Date of Connectivity under GNA: 31.12.2027(Interim). Final date shall be confirmed upon award of the system With this grant of 50 MW to M/s Juniper, total connectivity granted at Fatehgarh-IV PS(Sec-II) shall be 4980 MW. As Fatehgarh-IV PS(Sec-II) was planned for 5 GW(4 GW with Rajasthan REZ Ph-IV Part-2 scheme & 1 GW with Rajasthan REZ Ph-4 scheme), Fatehgarh-IV(Sec-II) shall be closed for further grant of connectivity including enhancements.										

C7. Applications for Connectivity to ISTS under CERC (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022 received in Jan'24:

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
1.	2200000484	Iraax International (OPC) Private Limited	Bikaner distt., Rajasthan	10.01.2024	Generator (Solar)	Land Route	100	31.03.2026	Bikaner-III PS
2.	2200000495	Juniper Green Energy Private Limited	Barmer distt., Rajasthan	11.01.2024	Generator (Hybrid Solar-150MW Wind-80MW)	NTPC LOA	230	31.03.2026	Fatehgarh -IV PS
3.	2200000499	Juniper Green Energy Private Limited	Jaisalmer distt., Rajasthan	11.01.2024	Generator (Solar)	Land BG route	150	30.06.2028	Ramgarh PS
4.	2200000492 (Enhancement)	Anboto Solar Private Limited	Barmer distt., Rajasthan	18.01.2024	Generator (Solar)	Land Route	50	30.11.2025	Barmer-I PS
5.	2200000507	Solalite Power Private Limited	Barmer distt., Rajasthan	19.01.2024	Generator (Solar)	NTPC LOA	250	31.03.2026	Barmer-I PS
6.	2200000516	Renew Solar Power Private Limited	Jodhpur distt., Rajasthan	25.01.2024	Generator (Solar)	SECI LOA	300	30.09.2026	Bhadla-III PS
7.	2200000521	Renew Solar Power Private Limited	Jodhpur distt., Rajasthan	25.01.2024	Generator (Solar) with ESS	SJVN LOA	Solar:200 ESS: 46	31.05.2026	Bhadla-III PS
8.	2200000522	Renew Solar Power Private Limited	Jodhpur distt., Rajasthan	25.01.2024	Generator (Solar)	SJVN LOA	300	31.05.2026	Bhadla-III PS
9.	2200000531	Sprng Renewable Resources Private Limited	Jaisalmer distt., Rajasthan	25.01.2024	Generator (Solar)	Land BG route	200	30.06.2027	Barmer-I PS
10.	2200000539	Sprng Urja Private Limited	Jaisalmer distt., Rajasthan	30.01.2024	Generator (Solar)	Land BG route	200	30.06.2029	Barmer-I PS
11.	2200000541	Green Infra Wind Energy Limited	Jaisalmer distt., Rajasthan	30.01.2024	Generator (Solar)	SECI LOA	300	01.06.2027	Barmer-I PS
12.	2200000510	Axis Energy Ventures India Private Limited	Jodhpur distt., Rajasthan	31.01.2024	Generator (Solar)	Land Route	320	30.06.2025	Fatehgarh-II PS

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
1.	2200000484	Iraax International (OPC) Private Limited	Bikaner distt., Rajasthan	10.01.2024	Generator (Solar)	Land Route	100	31.03.2026	Bikaner-III PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Nil(Bay under applicant scope) • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Iraax International (OPC) Private Limited has applied for connectivity for 100 MW at Bikaner-III PS. However, as mentioned above, in view of no margin available at Bikaner-III PS & Bikaner-IV PS, the connectivity can be granted at Bikaner-V PS. M/s Iraax International has filed another application for connectivity of 150 MW at Bikaner-III PS (App. No. 2200000540-150 MW) which is also being discussed in the same meeting for grant at Bikaner-V PS. Accordingly, it was proposed to grant connectivity at Bikaner-V PS at 220 kV level through 1 no. of 220 kV line bay. M/s Iraax agreed for the same.

Applicant was asked to confirm the 220kV bay scope at Bikaner-V PS end and the DTL tower configuration. M/s Iraax informed that 220 kV bay at Bikaner-V PS end shall be under their scope and the tower configuration shall be S/c line on D/c tower. The same was noted.

It may be noted that the transmission system for evacuation of power from Bikaner-V PS is presently under discussion. The scheme is currently tentative, which shall be finalized in a separate joint study meeting among CEA, CTUIL, Grid India & Stakeholders followed by the subsequent CMETS meeting. The detailed transmission system shall be informed upon finalization and approval of the scheme.

In line with MNRE meeting/subsequent clarification as stated earlier, , the application is being considered in the RE potential zone and Conn BGs shall be applicable accordingly.

It was also informed that M/s Iraax International (OPC) Private Limited has requested Start Date of Connectivity under GNA from 31/03/2026. However, considering the same and expected commissioning date of transmission system (i.e. 31.12.2029), the start date of Connectivity under GNA shall be 31.12.2029 (interim). M/s Iraax noted the same.

Transmission system for connectivity of M/s Iraax International (OPC) Private Limited under GNA, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

(i). Common Pooling station for Iraax International (OPC) Private Ltd Solar Power Projects(App. No. 2200000484-100 MW & App. No. 2200000540-150 MW) – Bikaner-V PS 220 kV S/c line on D/c tower(Suitable to carry minimum 300 MW at nominal voltage)

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
C. <u>Transmission system for Connectivity under GNA</u> : As per Annexure VII										
Start Date of Connectivity under GNA: 31.12.2029(Interim). Final date shall be confirmed upon award of the system										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
2.	2200000495	Juniper Green Energy Private Limited	Barmer distt., Rajasthan	11.01.2024	Generator (Hybrid Solar-150MW Wind-80MW)	NTPC LOA	230	31.03.2026	Fatehgarh -IV PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs 3 Cr • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Juniper Green Energy Private Limited has applied for connectivity for 230 MW at Fatehgarh -IV PS. As informed earlier, there is no margin available at Fatehgarh-IV PS & Barmer-I PS. Accordingly, it was proposed to grant connectivity at Barmer-II PS at 220 kV level through 1 no. of 220 kV line bay. M/s Juniper Green agreed for the same.

Applicant was asked to confirm the 220kV bay scope at Barmer-II PS end and the DTL tower configuration. M/s Juniper Green informed that 220 kV bay at Barmer-II PS end shall be under ISTS and the tower configuration shall be S/c line on D/c tower. The same was noted.

It may be noted that the transmission system for evacuation of power from Barmer-II PS is presently under discussion. The scheme is currently tentative, which shall be finalized in a separate joint study meeting among CEA, CTUIL, Grid India & Stakeholders followed by the subsequent CMETS meeting. The detailed transmission system shall be informed upon finalization and approval of the scheme.

It was also informed that M/s Juniper Green Energy Private Limited has requested start Date of Connectivity under GNA from 31/03/2026. However, considering the same and expected commissioning date of transmission system (i.e.31.12.2029), the start date of Connectivity under GNA shall be 31.12.2029 (interim). M/s Juniper Green noted the same.

Transmission system for connectivity of M/s Juniper Green Energy Private Limited under GNA, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

- (i). Juniper Green Energy Private Limited Hybrid Power Project – Barmer-II PS 220 kV S/c line on D/c tower(Suitable to carry minimum 300 MW at nominal voltage)

C. Transmission system for Connectivity under GNA: As per Annexure II

Start Date of Connectivity under GNA: 31.12.2029(Interim). Final date shall be confirmed upon award of the system

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
3.	2200000499	Juniper Green Energy Private Limited	Jaisalmer distt., Rajasthan	11.01.2024	Generator (Solar)	Land BG route	150	30.06.2028	Ramgarh PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs.3 Cr. • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Juniper Green Energy Private Limited has applied for connectivity for 150 MW at Ramgarh PS. M/s Juniper has filed another application for connectivity of 150 MW at Ramgarh PS(App. No. 2200000550-150 MW) which is also being discussed in the same meeting for grant at Ramgarh PS. Accordingly, it was proposed to grant connectivity at Ramgarh PS at 220 kV level through 1 no. of 220 kV line bay. M/s Juniper Green agreed for the same.

Applicant was asked to confirm the 220kV bay scope at Ramgarh PS end and the DTL tower configuration. M/s Juniper Green informed that 220 kV bay at Ramgarh PS end shall be under ISTS and the tower configuration shall be S/c line on D/c towers. The same was noted.

It was also informed that M/s Juniper Green Energy Private Limited has requested Start Date of Connectivity under GNA from 30/06/2028. However, considering the same and expected commissioning date of transmission system (i.e. 31.12.2028), the start date of Connectivity under GNA shall be 31.12.2028 (interim). M/s Juniper Green noted the same.

Transmission system for connectivity of M/ Juniper Green Energy Private Limited under GNA, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

- (i). Common Pooling station for Juniper Green Energy Private Limited (App. No. 2200000499(150 MW) & 2200000550(150 MW)) Solar Power Projects — Ramgarh PS 220 kV S/c line on D/c tower(Suitable to carry minimum 300 MW at nominal voltage)

C. Transmission system for Connectivity under GNA: As per Annexure VIII**Start Date of Connectivity under GNA: 31.12.2028(Interim).** Final date shall be confirmed upon award of the system

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
4.	2200000492 (Enhancement)	Anboto Solar Private Limited	Barmer distt., Rajasthan	18.01.2024	Generator (Solar)	Land Route	50	30.11.2025	Barmer-I PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Nil (Bay in sharing) • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Anboto Solar Private Limited has applied for enhancement of connectivity for 50 MW at Barmer-I PS. As mentioned earlier, 50 MW margin available at Barmer-I PS in sharing with Anboto Solar(250 MW). Accordingly, it was proposed to grant connectivity at Barmer-I PS through the same 220 kV bay allocated to M/s Anboto Solar(250 MW). M/s Anboto Solar agreed for the same.

It was also informed that M/s Anboto Solar Private Limited has requested start Date of Connectivity under GNA from 30/11/2025. However, considering the same and expected commissioning date of transmission system (i.e. 30.11.2026), the start date of Connectivity under GNA shall be 30.11.2026(interim). M/s Anboto Solar noted the same.

M/s Anboto Solar informed that as per their PPA, SCoD date is 30.06.2026 and therefore requested to give connectivity matching with the PPA date. Regarding this CTUIL informed that as the transmission system requirement is necessary for grant of connectivity, connectivity can be granted matching with the transmission system (i.e. 30.11.2026(interim)).M/s Anboto Solar noted and agreed for the same.

Transmission system for connectivity of M/s Anboto Solar Private Limited under GNA, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:**A. Associated Transmission System (ATS):** NIL**B. Transmission System under applicant scope**

- (i). Common Pooling Station for Anboto Solar Private Limited Solar Power Projects(App. No. 2200000281-250 MW & 2200000492-50 MW)– Barmer-I PS 220 kV S/c line on D/c tower(Suitable to carry minimum 300 MW at nominal voltage)

C. Transmission system for Connectivity under GNA: As per Annexure I**Start Date of Connectivity under GNA: 30.11.2026(Interim).** Final date shall be confirmed upon award of the system

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
5.	2200000507	Solalite Power Private Limited	Barmer distt., Rajasthan	19.01.2024	Generator (Solar)	NTPC LOA	250	31.03.2026	Barmer-I PS	Not Applicable

It was informed that M/s Solalite Power Private Limited has applied for connectivity for 250 MW at Barmer-I PS. However, in view of no further margins available at Barmer-I PS except enhancements, it was proposed to grant connectivity at Barmer-II PS at 220 kV level through 1 no. of 220 kV line bay.

M/s Solalite Power in the meeting informed that they are withdrawing the present application. Subsequently vide mail dated 28.06.2024 M/s Solalite Power confirmed the withdrawal of the present application. Accordingly, it was decided to close the above application as per GNA Regulations.

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
6.	2200000516	Renew Solar Power Private Limited	Jodhpur distt., Rajasthan	25.01.2024	Generator (Solar)	SECI LOA	300	30.09.2026	Bhadla-III PS	To be decided in subsequent CMETS NR meeting

It was informed that M/s Renew Solar Power Private Limited has applied for connectivity for 300 MW at Bhadla-III PS. However, Bhadla-III PS is already closed for further grant of connectivity except enhancement of 50 MW (in sharing with Solarcraft). Renew Solar has also filed additional applications of 200MW & 300 MW at Bhadla-III PS which are also being discussed in the same meeting. Accordingly, it was proposed to grant connectivity at Bhadla-IV PS at 400 kV level through 1 no. of 400 kV line bay.

M/s Renew in the meeting informed that they are withdrawing the remaining two applications (2200000521(200 MW) & 2200000522(300 MW)). M/s Renew was asked to confirm the same through mail/letter. In view of the withdrawal of two other applications, for the present application of 300 MW, it was proposed to grant connectivity at 220 kV through S/c line. M/s Renew agreed for the same.

Applicant was asked to confirm the 220kV bay scope at Bhadla-IV PS end and the DTL tower configuration. M/s Renew Solar informed that 220 kV bay at Bhadla-IV PS end shall be under ISTS and the tower configuration shall be S/c line on D/c tower. The same was noted.

Subsequent to the mail confirming withdrawal dated 28.06.2024, M/s Renew vide mail dated 30.06.2024 again informed that they are not withdrawing the applications (2200000521(200 MW) & 2200000522(300 MW)) as informed in the meeting and they agree for the grant of connectivity as originally proposed by CTUIL at 400 kV Bhadla-IV PS.

M/s Renew may note that such frequent change in decisions will not be entertained in future and authorized representative should bring their management firm

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
decision before any communication in the meeting/mail. In view of the above developments, it is being decided that the present application along with other two applications (2200000521: 200 MW & 2200000522:300 MW) shall be again taken up for stakeholders discussion in the subsequent CMETS NR meeting for grant.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
7.	2200000521	Renew Solar Power Private Limited	Jodhpur distt., Rajasthan	25.01.2024	Generator (Solar) with ESS	SJVN LOA	Connectivity:200 (Solar:200 ESS: 46)	31.05.2026	Bhadla-III PS	To be decided in subsequent CMETS NR
It was informed that M/s Renew Solar Power Private Limited has applied for connectivity for 200 MW at Bhadla-III PS. As discussed with the previous application of M/s Renew, earlier it was proposed to grant connectivity at Bhadla-IV PS at 400 kV level through 1 no. of 400 kV line bay in sharing with previous application of M/s Renew(2200000516). M/s Renew in the meeting opted to withdraw the present application. M/s Renew was asked to confirm the same through mail/letter. M/s Renew agreed for the same. Subsequent to the mail confirming withdrawal dated 28.06.2024, M/s Renew vide mail dated 30.06.2024 again informed that they are not withdrawing the applications (2200000521(200 MW) & 2200000522(300 MW)) as informed in the meeting and they agree for the grant of connectivity as originally proposed by CTUIL at 400 kV Bhadla-IV PS. M/s Renew may note that such frequent change in decisions will not be entertained in future and authorized representative should bring their management firm decision before any communication in the meeting/mail. In view of the above, it was decided that the present application along with other two applications (2200000516: 300 MW & 2200000522:300 MW) shall be again taken up for discussion in the subsequent CMETS NR meeting for grant.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
8.	2200000522	Renew Solar Power Private	Jodhpur distt.,	25.01.2024	Generator (Solar)	SJVN LOA	300	31.05.2026	Bhadla-III PS	To be decided in subsequent CMETS NR

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
		Limited	Rajasthan							
It was informed that M/s Renew Solar Power Private Limited has applied for connectivity for 300 MW at Bhadla-III PS. As discussed with the previous application of M/s Renew, it was proposed to grant connectivity at Bhadla-IV PS at 400 kV level through 1 no. of 400 kV line bay in sharing with previous application of M/s Renew(2200000516 & 2200000521). M/s Renew in the meeting opted to withdraw the present application. M/s Renew was asked to confirm the same through mail/letter. M/s Renew agreed for the same. Subsequent to the mail confirming withdrawal dated 28.06.2024, M/s Renew vide mail dated 30.06.2024 again informed that they are not withdrawing the applications (2200000521(200 MW) & 2200000522(300 MW)) as informed in the meeting and they agree for the grant of connectivity as originally proposed by CTUIL at 400 kV Bhadla-IV PS. M/s Renew may note that such frequent change in decisions will not be entertained in future and authorized representative should bring their management firm decision before any communication in the meeting/mail. In view of the above, it was decided that the present application along with other two applications (2200000516: 300 MW & 2200000521:300 MW) shall be again taken up for discussion in the subsequent CMETS NR meeting for grant.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
9.	2200000531	Sprng Renewable Resources Private Limited	Jaisalmer distt., Rajasthan	25.01.2024	Generator (Solar)	Land BG route	200	30.06.2027	Barmer-I PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 3 Cr. • Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Sprng Renewable Resources Private Limited has applied for connectivity for 200 MW at Barmer-I PS. However, in view of no margin available at Barmer-I PS connectivity can be granted at Barmer-II PS. Further, another application from M/s Sprng Urja Private Limited for connectivity of 200 MW at Barmer-I PS is also being discussed in the present meeting for grant at Barmer-II PS. Accordingly, it was proposed to grant connectivity at Barmer-II PS at 220 kV level through 1 no. of 220 kV line bay for both the applications (200MW+200MW). M/s Sprng agreed for the same. Applicant was asked to confirm the 220kV bay scope at Barmer-II PS end and the DTL tower configuration. M/s Sprng Renewable informed that 220 kV bay at Barmer-II PS end shall be under ISTS and the tower configuration shall be S/c line on D/c tower. The same was noted. It may be noted that the transmission system for evacuation of power from Barmer-II PS is presently under discussion. The scheme is currently tentative, which shall be finalized in a separate joint study meeting among CEA, CTUIL, Grid India & Stakeholders followed by the subsequent CMETS meeting. The transmission										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
system shall be informed upon finalization and approval of the scheme. It was also informed that M/s Sprng Renewable Resources Private Limited has requested Start Date of Connectivity under GNA from 30/06/2027. However, considering the same and expected commissioning date of transmission system (i.e. 31.12.2029), the start date of Connectivity under GNA shall be 31.12.2029 (interim). M/s Sprng Renewable noted the same. Transmission system for connectivity of M/s Sprng Renewable Resources Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Common pooling station for Sprng Renewable Resources Private Limited(App. No. 2200000531(200 MW) & Sprng Urja Private Limited(App. No. 2200000539(200 MW) Solar Power Projects– Barmer-II PS 220 kV S/c (high capacity) line on D/c tower (Suitable to carry minimum 400 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-II Start Date of Connectivity under GNA: 31.12.2029(Interim). Final date shall be confirmed upon award of the system										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
10.	2200000539	Sprng Urja Private Limited	Jaisalmer distt., Rajasthan	30.01.2024	Generator (Solar)	Land BG route	200	30.06.2029	Barmer-I PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Nil(Bay in sharing) • Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Sprng Urja Private Limited has applied for connectivity for 200 MW at Barmer-I PS. As informed with the previous application of M/s Sprng Renewable, it was proposed to grant connectivity at Barmer-II PS at 220 kV level in sharing with the previous application of M/s Sprng Renewable (App. No. 2200000531). M/s Sprng Urja agreed for the same.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
It may be noted that the transmission system for evacuation of power from Barmer-II PS is presently under discussion. The scheme is currently tentative, which shall be finalized in a separate joint study meeting among CEA, CTUIL, Grid India & Stakeholders followed by the subsequent CMETS meeting. The detailed transmission system shall be informed upon finalization and approval of the scheme. It was also informed that M/s Sprng Urja Private Limited has requested Start Date of Connectivity under GNA from 30/06/2029. However, considering the same and expected commissioning date of transmission system (i.e. 31.12.2029), the start date of Connectivity under GNA shall be 31.12.2029 (interim). M/s Sprng Urja noted the same. Transmission system for connectivity of M/s Sprng Urja Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Common pooling station for Sprng Renewable Resources Private Limited(App. No. 2200000531(200 MW) & Sprng Urja Private Limited(App. No. 2200000539(200 MW) Solar Power Projects– Barmer-II PS 220 kV S/c (high capacity) line on D/c tower(suitable to carry minimum 400 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-II Start Date of Connectivity under GNA: 31.12.2029(Interim). Final date shall be confirmed upon award of the system										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
11.	2200000541	Green Infra Wind Energy Limited (Withdraw)	Jaisalmer distt., Rajasthan	30.01.2024	Generator (Solar)	SECI LOA	300	01.06.2027	Barmer-I PS	Not Applicable

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
It was informed that M/s Green Infra Wind Energy Limited has applied for connectivity of 300 MW at Barmer-I PS. Accordingly, it was proposed to grant connectivity at Barmer-II PS at 220 kV level. M/s Green Infra in the meeting requested that considering LOA timeline, whether they can shift the application to other RE complex in Rajasthan. CTUIL mentioned that change in location is not allowed as per Hon'ble CERC orders on Petition No. 9/MP/2024 and CERC Suo Moto Order dated 22.09.2023 in Petition No. 11/SM/2023, M/s Green Infra vide mail dated 01.07.2024 informed that they would like to withdraw the present application no. 2200000541. Accordingly, it was decided to close the present application as per GNA Regulations.										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
12.	2200000510	Axis Energy Ventures India Private Limited (Withdraw)	Jodhpur distt., Rajasthan	31.01.2024	Generator (Solar)	Land Route	320	30.06.2025	Fatehgarh-II PS	Not Applicable
It was informed that M/s Axis Energy Ventures India Private Limited has applied for connectivity of 320 MW at Fatehgarh-II PS on land route. It may be noted that out of 1000 MW margin available at Fatehgarh-II PS, 850 MW connectivity is already agreed for grant to M/s ACME for its applications of 600 MW & 250 MW in the same meeting as per application priority. Remaining margin at Fatehgarh-II PS is only 150 MW. Therefore, margin for 320 MW connectivity to M/s Axis Energy is not available at Fatehgarh-II PS. Further, from the coordinates of location of the Axis Energy project as well as Land documents submitted along with the application, it was observed that the project is far away from Fatehgarh-II PS (i.e. about 190 km) also passing through GIB area. Rather, location of the project is very close to Bhadla complex (15 km from Bhadla-III PS). In view of the above, it was proposed to grant connectivity of 320 MW to M/s Axis Energy Ventures at Bhadla-IV PS through 220 kV S/c line. M/s Axis Energy informed that they are willing to get connectivity at Fatehgarh-II PS not at Bhadla-IV PS. They have land near Fatehgarh-II PS which they wish to use for the present connectivity. CTU enquired that if M/s Axis had land near Fatehgarh-II PS, they should have submitted the same in the application. Instead, land documents submitted by M/s Axis in the present application are in Bhadla complex. CTUIL asked Axis Energy to clarify regarding the same. Regarding this, M/s Axis Energy clarified that the land documents submitted with the present application are near Bhadla complex and their land near Fatehgarh-II PS is already used in other application granted connectivity at Fatehgarh-IV PS. CTUIL informed that as the land is near Bhadla complex, it can grant connectivity in Bhadla complex. For grant of connectivity at Fatehgarh-II PS having balance margin of 150 MW, the applicant may submit a new application which will be processed as per the application priority. Further, if the application is filed via land										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
route, the applicant must ensure that the land should be in Fatehgarh complex preferably near to Fatehgarh-II to avoid ROW issues.										
M/s Axis Energy informed that as they are not willing to obtain connectivity at Bhadla-IV PS, they would like to withdraw the present application. M/s Axis Energy vide mail dated 03.07.2024 confirmed the withdrawal of the application.										
Accordingly, it was decided to close the above application as per GNA Regulations.										

C8. Applications for Connectivity to ISTS under CERC (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022 received in Feb'24:

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
1.	2200000518	CESC Ltd.	Sirohi distt., Rajasthan	01.02.2024	Generator (Solar)	Land BG Route	300	01.02.2026	Sirohi
2.	2200000550 (Enhancement)	Juniper Green Energy Private Limited	Jaisalmer distt., Rajasthan	05.02.2024	Generator (Solar)	Land BG Route	150	31.12.2028	Ramgarh PS
3.	2200000551	Renew Solar Power Private Limited	Sirohi distt., Rajasthan	05.02.2024	Generator (Solar)	NTPC LOA	400	01.08.2026	Sirohi
4.	2200000540	Iraax International (Op) Private Limited	Bikaner distt., Rajasthan	08.02.2024	Generator (Solar)	Land Route	150	31.03.2026	Bikaner-III PS
5.	2200000561 (Enhancement)	Avaada RJBikaner Private Limited	Bikaner distt., Rajasthan	13.02.2024	Generator (Solar)	Land Route	136	31.03.2025	Bikaner-III PS
6.	2200000564 (Enhancement)	NTPC Renewable Energy Limited	Jaisalmer distt., Rajasthan	15.02.2024	Generator (Solar)	SECI LOA	200	16.04.2026	Fatehgarh-IV PS

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
1.	2200000518	CESC Ltd.	Sirohi distt., Rajasthan	01.02.2024	Generator (Solar)	Land BG Route	300	01.02.2026	Sirohi	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 3 Cr. • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s CESC Ltd. has applied for connectivity for 300 MW at Sirohi PS. Accordingly, it was proposed to grant connectivity at Sirohi PS at 220 kV level through 1 no. of 220 kV line bay. M/s CESC Ltd. agreed for the same.

Applicant was asked to confirm the 220kV bay scope at Sirohi PS end and the DTL tower configuration. M/s CESC Ltd informed that 220 kV bay at Sirohi PS end shall be under ISTS and the tower configuration shall be S/c line on D/c towers. The same was noted.

It may be noted that the transmission system for evacuation of power from Sirohi was recently approved in the 30th CMETS NR meeting held on 18.06.2024 as well as in the 74th NRPC meeting recently held on 28.06.2024. The scheme is yet to be approved in NCT meeting.

It was also informed that M/s CESC Ltd. has requested Start Date of Connectivity under GNA from 01.02.2026. However, considering the same and expected commissioning date of transmission system (i.e. 31.03.2027), the start date of Connectivity under GNA shall be 31.03.2027 (interim). M/s CESC Ltd. noted the same.

Transmission system for connectivity of M/s CESC Ltd. under GNA, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

(ii). CESC Ltd. Solar Power Project– Sirohi PS 220 kV S/c line on D/c tower (Suitable to carry minimum 300 MW at nominal voltage)

C. Transmission system for Connectivity under GNA: As per Annexure-IX

Start Date of Connectivity under GNA: 31.03.2027(Interim). Final date shall be confirmed upon award of the system

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity(As per Application)	Connectivity Location(As per Application)	Conn BGs requirement
2.	2200000550 (Enh.)	Juniper Green Energy Private Limited	Jaisalmer distt., Rajasthan	05.02.2024	Generator (Solar)	Land BG Route	150	31.12.2028	Ramgarh PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Nil (in sharing) • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Juniper Green Energy Private Limited has applied for enhancement of connectivity for 150 MW at Ramgarh PS. It may be noted that Connectivity of 150 MW to M/s Juniper Green Energy Private Limited is already agreed for grant at Ramgarh PS in the same meeting (App. No. 2200000499). Accordingly, it was proposed to grant connectivity of 150 MW(Enhancement)at Ramgarh PS at 220 kV level through the same 220 kV line bay. M/s Juniper Green agreed for the same.

It was also informed that M/s Juniper Green Energy Private Limited has requested Start Date of Connectivity under GNA from 31.12.2028. Considering the same and expected commissioning date of transmission system (i.e. 31.12.2028), the start date of Connectivity under GNA shall be 31.12.2028 (interim). M/s Juniper Green noted the same.

Transmission system for connectivity of M/s Juniper Green Energy Private Limited under GNA, as agreed, is as below:

Details of Transmission system for Connectivity under GNA:

A. Associated Transmission System (ATS): NIL

B. Transmission System under applicant scope

- (i). Common Pooling station for Juniper Green Energy Private Limited (App. No. 2200000499(150 MW) & 2200000550(150 MW)) Solar Power Projects — Ramgarh PS 220 kV S/c line on D/c tower(Suitable to carry minimum 300 MW at nominal voltage)

C. Transmission system for Connectivity under GNA: As per Annexure-VIII

Start Date of Connectivity under GNA: 31.12.2028(Interim). Final date shall be confirmed upon award of the system

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BGs requirement
3.	2200000551	Renew Solar Power Private Limited	Sirohi distt., Rajasthan	05.02.2024	Generator (Solar)	NTPC LOA	400	01.08.2026	Sirohi	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 3 Cr. • Conn BG3: Rs. 2 lakh/MW

It was informed that M/s Renew Solar Power Private Limited has applied for connectivity for 400 MW at Sirohi PS. Accordingly, it was proposed to grant connectivity at Sirohi PS at 220 kV level through 1 no. of 220 kV line bay. M/s Renew agreed for the same.

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)	Conn BGs requirement
Applicant was asked to confirm the 220kV bay scope at Sirohi PS end and the DTL tower configuration. M/s Renew Solar informed that 220 kV bay at Sirohi PS end shall be under ISTS and the tower configuration shall be S/c line on D/c towers. The same was noted. It may be noted that the transmission system for evacuation of power from Sirohi was recently approved in the 30th CMETS NR meeting held on 18.06.2024 as well as in the 74th NRPC meeting recently held on 28.06.2024. The scheme is yet to be approved in NCT meeting. It was also informed that M/s Renew Solar Power Private Limited has requested Start Date of Connectivity under GNA from 01.08.2026. However, considering the same and expected commissioning date of transmission system (i.e. 31.03.2027), the start date of Connectivity under GNA shall be 31.03.2027 (interim). M/s Renew noted the same. Transmission system for connectivity of M/s Renew Solar Power Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Renew Solar Power Private Limited Solar Power Project– Sirohi PS 220 kV S/c (high capacity) line on D/c tower (suitable to carry minimum 400 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure-IX Start Date of Connectivity under GNA: 31.03.2027(Interim). Final date shall be confirmed upon award of the system										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
4.	2200000540	Iraax International (Opc) Private Limited	Bikaner distt., Rajasthan	08.02.2024	Generator (Solar)	Land Route	150	31.03.2026	Bikaner-III PS	- Conn BG1: Rs. 50 Lakh - Conn BG2: Nil (in sharing) - Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Iraax International (OPC) Private Limited has applied for connectivity for 150 MW at Bikaner-III PS. However, as mentioned earlier, in view of no margin available at Bikaner-III & Bikaner-IV PS, the connectivity can be granted at Bikaner-V PS. Further, Connectivity of 100 MW to M/s Iraax International										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
(OPC) Private Limited at Bikaner-V PS is already agreed for grant in the same meeting (App. No. 2200000484). Accordingly, it was proposed to grant connectivity at Bikaner-V PS at 220 kV level through same 220 kV S/c line graded with app no. 2200000484. M/s Iraax agreed for the same. It may be noted that the transmission system for evacuation of power from Bikaner-V PS is presently under discussion. The scheme is currently tentative, which shall be finalized in a separate joint study meeting among CEA, CTUIL, Grid India & Stakeholders followed by the subsequent CMETS meeting. The detailed transmission system shall be informed upon finalization and approval of the scheme. In line with MNRE meeting/subsequent clarification as stated earlier, the application is being considered in the RE potential zone and Conn BGs shall be applicable accordingly. M/s Iraax International (OPC) Private Limited has requested Start Date of Connectivity under GNA from 31/03/2026. However, considering the same and expected commissioning date of transmission system (i.e. 31.12.2029), the start date of Connectivity under GNA shall be 31.12.2029 (interim). M/s Iraax International noted the same. Transmission system for connectivity of M/s Iraax International (OPC) Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Common Pooling station for Iraax International (OPC) Private Ltd Solar Power Projects(App. No. 2200000484-100 MW & App. No. 2200000540-150 MW) – Bikaner-V PS 220 kV S/c line on D/c tower (Suitable to carry minimum 300 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA :</u> As per Annexure VII Start Date of Connectivity under GNA: 31.12.2029(Interim). Final date shall be confirmed upon award of the system										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
5.	2200000561 (Enhancement)	Avaada RJBikaner	Bikaner distt.,	13.02.2024	Generator (Solar)	Land Route	136	31.03.2025	Bikaner-III PS	• Conn BG1: Rs. 50 Lakh • Conn BG2: Rs. 3 Cr.

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
		Private Limited	Rajasthan							• Conn BG3: Rs. 2 lakh/MW
It was informed that M/s Avaada RJBikaner Private Limited has applied for connectivity for 136 MW at Bikaner-III PS. However, as mentioned earlier, in view of no margins available at Bikaner-III PS & Bikaner-IV PS, connectivity can be granted at Bikaner-V PS. Further, there is no margin available in other 220kV bays to accommodate 136 MW. Accordingly, it was proposed to grant connectivity at Bikaner-V PS at 220 kV level through 1 no. of 220 kV line bay. However it was also indicated that remaining margin (about 165 MW) may be granted to other applications in sharing. M/s Avaada RJBikaner agreed for the same. Applicant was asked to confirm the 220kV bay scope at Bikaner-V PS end and the DTL tower configuration. M/s Avaada RJBikaner informed that 220 kV bay at Bikaner-V PS end shall be under ISTS and the tower configuration shall be S/c line on D/c towers. The same was noted. It may be noted that the transmission system for evacuation of power from Bikaner-V PS is presently under discussion. The scheme is currently tentative, which shall be finalized in a separate joint study meeting among CEA, CTUIL, Grid India & Stakeholders followed by the subsequent CMETS meeting. The detailed transmission system shall be informed upon finalization and approval of the scheme. In line with MNRE meeting/subsequent clarification as stated earlier, the application is being considered in the RE potential zone and Conn BGs shall be applicable accordingly. M/s Avaada RJBikaner Private Limited has requested Start Date of Connectivity under GNA from 31/03/2025. However, considering the same and expected commissioning date of transmission system (i.e. 31.12.2029), the start date of Connectivity under GNA shall be 31.12.2029 (interim). M/s Avaada RJBikaner noted the same. Transmission system for connectivity of M/s Avaada RJBikaner Private Limited under GNA, as agreed, is as below: <u>Details of Transmission system for Connectivity under GNA:</u> A. <u>Associated Transmission System (ATS):</u> NIL B. <u>Transmission System under applicant scope</u> (i). Avaada RJBikaner Private Limited Solar Power Project – Bikaner-V PS 220 kV S/c line on D/c tower(Suitable to carry minimum 300 MW at nominal voltage) C. <u>Transmission system for Connectivity under GNA:</u> As per Annexure VII										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
Start Date of Connectivity under GNA: 31.12.2029(Interim). Final date shall be confirmed upon award of the system										

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)	Conn BGs requirement
6.	2200000564 (Enhancement)	NTPC Renewable Energy Limited	Jaisalmer distt., Rajasthan	15.02.2024	Generator (Solar)	SECI LOA	200	16.04.2026	Fatehgarh-IV PS	To be decided in subsequent CMETS NR meeting
It was informed that M/s NTPC Renewable Energy Limited has applied for connectivity for 200 MW at Fatehgarh-IV PS. However, as mentioned earlier, in view of no further margins for connectivity at Fatehgarh-IV & Barmer-I PS, it was proposed to grant connectivity at Barmer-II PS at 220 kV level through S/c line. NTPC was asked to confirm the 220kV bay scope at Barmer-II PS end and the DTL tower configuration. M/s NTPC informed that they have filed additional applications for about 900 MW in last two months at Fatehgarh-IV PS. M/s NTPC requested CTUIL to grant connectivity at 400 kV combinedly for all applications. Regarding this, CTUIL clarified that, as the present application is for 200 MW, connectivity cannot be granted at 400 kV at this stage. However, when the future applications come up for discussion in the subsequent CMETS meetings for grant & if those applications can be accommodated to Barmer-II PS, as per application priority, then the connectivity can be granted at 400 kV based on total connectivity quantum at Barmer-II PS. Therefore, at this stage connectivity shall be considered for grant at 220 kV. NTPC requested to take up all applications together in next CMETS meeting for optimization of DTL. After deliberations, it was decided that the present application shall be again taken up for discussion in the subsequent CMETS NR meeting along with the other applications of NTPC in Fatehgarh-Barmer complex.										

It was informed that applications received in the month of March'24, April-24 & May-24 shall be taken up for discussion and grant in the subsequent CMETS NR meetings. The list of applications received in the month of March'24, April'24 & May'24 are as below:

C9. Application for Grant of GNA/GNARE to entities other than STU under Regulation 20.1, 20.3 and 20.4 to entities under Regulation 17.1(ii), (iii), (v) and (vi) received in Mar'24:

Sl No.	Application ID	Name of the Applicant	Submission Date	Nature of applicant	GNA _{RE} within Region (MW)	GNA _{RE} outside Region (MW)	Total Quantum of GNA _{RE} Required (MW)	Start date of GNA _{RE}	End date of GNA _{RE}
1.	2200000627	Hindalco Industries Limited	21.03.2024	Bulk consumer seeking to connect to ISTS	50	50	100	01.04.2026	31.03.2061

C10. Applications for Connectivity to ISTS under CERC (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022 received in Mar'24:

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)
1.	2200000567	NTPC Renewable Energy Limited	Jaisalmer distt., Rajasthan	01.03.2024	Generator (Solar)	Land Route	300	31.03.2026	Fatehgarh-IV PS
2.	2200000580 (Enhancement)	Avaada Energy Private Limited	Barmer distt., Rajasthan	02.03.2024	Generator (Solar)	NTPC LOA	200	26.03.2026	Barmer-I PS
3.	2200000616	Jade Hybren Private Limited	Bikaner distt., Rajasthan	06.03.2024	Generator (Solar)	Land BG Route	300	30.06.2026	Bikaner-IV PS
4.	2200000618	Migos Hybren Private Limited	Jaisalmer distt., Rajasthan	06.03.2024	Generator (Solar)	Land BG Route	600	31.12.2026	Ramgarh PS
5.	2200000624	Kyros Hybren Private Limited	Bikaner distt., Rajasthan	07.03.2024	Generator (Solar)	Land BG Route	100	30.06.2025	Bhadla-II PS
6.	2200000605	Aravalli Surya (Project 1) Private Limited	Jodhpur distt., Rajasthan	07.03.2024	Generator (Solar)	Land Route	335	31.12.2027	Bhadla-II PS
7.	2200000598	Adani Renewable Energy Holding Four Limited	Jaisalmer distt., Rajasthan	13.03.2024	Generator (Solar)	Land Route	500	15.06.2025	Ramgarh PS
8.	2200000599	Adani Renewable Energy Holding Four Limited	Jaisalmer distt., Rajasthan	13.03.2024	Generator (Solar)	Land Route	500	15.06.2025	Ramgarh PS
9.	2200000644	Serentica Renewables India Private Limited	Jalor distt., Rajasthan	14.03.2024	Generator (Solar)	Land BG Route	300	30.06.2026	Sirohi PS
10.	2200000600	Adani Renewable Energy Park Rajasthan Limited	Jaisalmer distt., Rajasthan	14.03.2024	Renewable Power Park developer (Solar)	Land Route	1000	15.06.2025	Ramgarh PS
11.	2200000601	Adani Renewable Energy Park Rajasthan Limited	Jaisalmer distt., Rajasthan	14.03.2024	Renewable Power Park developer (Solar)	Land Route	1000	15.06.2025	Ramgarh PS
12.	2200000646	Illuminate Hybren Private Limited	Sirohi distt., Rajasthan	15.03.2024	Generator (Solar)	Land BG Route	300	30.06.2026	Sirohi PS
13.	2200000636	Avaada Energy	Barmer distt.,	19.03.2024	Generator (Solar)	SJVN LOA	450	30.09.2026	Barmer-I PS

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity Location (As per Application)
		Private Limited	Rajasthan						
14.	2200000654	Green Infra Wind Energy Limited	Barmer distt., Rajasthan	27.03.2024	Generator (Solar)	SJVN LOA	300	30.06.2027	Barmer-I PS
15.	2200000661 (Enhancement)	Adani Renewable Energy Holding Four Limited	Ramgarh, Jaisalmer distt. Rajasthan	28.03.2024	Generator (Solar)	SECI LOA	250	01.10.2025	Ramgarh PS
16.	2200000662 (Enhancement)	Adani Renewable Energy Holding Four Limited	Ramgarh, Jaisalmer distt. Rajasthan	28.03.2024	Generator (Solar)	SECI LOA	284	01.10.2026	Ramgarh PS
17.	2200000668	Juniper Green Energy Private Limited	Barmer distt., Rajasthan	28.03.2024	Generator (Hybrid)	SJVN LOA	180 (Solar-130 Wind-50)	30.06.2026	Barmer-I PS
18.	2200000672	Tata Power Renewable Energy Limited	Ramgarh, Jaisalmer distt., Rajasthan	29.03.2024	Generator (Solar)	Land BG Route	600	30.06.2028	Ramgarh PS
19.	2200000681	Sprng Urja Private Limited	Barmer distt., Rajasthan	30.03.2024	Renewable Power Park developer (Solar)	Land BG Route	1000	30.06.2029	Barmer-I PS

C11. Applications for Connectivity to ISTS under CERC (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022 received in Apr'24:

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
1.	2200000706	JSW Neo Energy Limited	Jaisalmer distt., Rajasthan	12.04.2024	Generator (Solar)	SJVN LOA	700	01.09.2025	Ramgarh PS
2.	2200000689	JSW Neo Energy Limited	Jaisalmer distt., Rajasthan	12.04.2024	Generator (Solar)	SJVN LOA	700	01.03.2027	Ramgarh PS
3.	2200000715	Amaresha Renewables India Project Private Limited	Barmer distt., Rajasthan	15.04.2024	Renewable Power Park Developer (Solar)	Land BG Route	300	01.04.2027	Barmer-I PS
4.	2200000726	NTPC Renewable Energy Limited	Bikaner distt., Rajasthan	23.04.2024	Generator (Solar)	Land Route	1000	31.12.2026	Bikaner-IV PS
5.	2200000756	Juniper Green Energy Private Limited	Jaisalmer distt., Rajasthan	25.04.2024	Generator (Hybrid)	NTPC LOA	360 (Solar-260, Wind-100)	30.06.2026	Ramgarh PS

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
6.	2200000758	Vayuna Renewables India Project Private Limited	Sirohi distt. Rajasthan	25.04.2024	Renewable Power Park Developer (Solar)	Land BG	300	01.04.2027	Sirohi PS
7.	2200000761	Kantida Renewables India Project Private Limited	Phalodi distt., Rajasthan	25.04.2024	Renewable Power Park Developer (Solar)	Land BG Route	300	01.04.2028	Bhadla IV/Bikaner V PS
8.	2200000743	Izhma Solar Private Limited	Sirohi distt., Rajasthan	26.04.2024	Generator (Solar)	Land BG Route	200	31.03.2028	Sirohi PS
9.	2200000777	Renew Solar Power Private Limited	Jaisalmer distt., Rajasthan	30.04.2024	Generator (Solar)	NTPC LOA	400	30.06.2027	Ramgarh PS
10.	2200000778	Renew Solar Power Private Limited	Barmer distt., Rajasthan	30.04.2024	Generator (Solar)	SECI LOA	300	31.12.2026	Barmer-I PS
11.	2200000779	Renew Solar Power Private Limited	Sirohi distt., Rajasthan	30.04.2024	Generator (Solar)	NTPC LOA	300	30.06.2027	Sirohi PS

C12. Application for Grant of GNA/GNA_{RE} to entities other than STU under Regulation 20.1, 20.3 and 20.4 to entities under Regulation 17.1(ii), (iii), (v) and (vi) received in April'24:

Sl No.	Application ID	Name of the Applicant	Submission Date	Nature of applicant	GNA _{RE} within Region (MW)	GNA _{RE} Outside Region (MW)	Total GNA _{RE} Required (MW)	Start date of GNA _{RE}	End date of GNA _{RE}
1	2200000691	Linde India Limited	05.04.2024	Drawee entity connected to Intra state Transmission System	0	8	8	16.07.2024	30.06.2039

Sl No.	Application ID	Name of the Applicant	Submission Date	Nature of applicant	GNA within Region (MW)	GNA outside Region (MW)	Total GNA Required (MW)	Start date of GNA	End date of GNA
1	2200000721	Cosmos Hydro Power Private Limited	26.04.2024	Injecting entity connected to intra state transmission system	19.53	0	19.53	01.07.2024	19.09.2033

C13. Applications for Connectivity to ISTS under CERC (Connectivity & General Network Access to the inter-State Transmission System) Regulations, 2022 (Conventional)

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
---------	----------------	-----------	------------------	-----------------	---------------------	------------------------------	---	--

1	2200000685	Greenko RJ01 IREP Private Limited	Baran, Rajasthan	04.04.2024	Standalone ESS (Pumped Storage)	880	15.10.2026	-
---	------------	-----------------------------------	------------------	------------	---------------------------------	-----	------------	---

C14. Applications for Connectivity to ISTS under CERC (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022 received in May'24:

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
1.	2200000755	SA Renewable Infra Private Limited	Bikaner distt., Rajasthan	04.05.2024	Generator (Solar)	Land Route	100	31.03.2026	Bikaner-III PS
2.	2200000796	Vena Energy Vindhya Wind Power Private Limited	Bikaner distt., Rajasthan	06.05.2024	Generator (Solar)	Land BG Route	300	01.10.2027	Bikaner-IV PS
3.	2200000788	ACME Solar Holdings Private Limited	Sirohi distt., Rajasthan	07.05.2024	Generator (Solar)	Land BG Route	300	31.03.2027	Sirohi PS
4.	2200000793	SAEL Industries Limited	Sirohi distt., Rajasthan	10.05.2024	Generator (Solar)	Land BG Route	300	30.05.2026	Sirohi PS
5.	2200000794	SAEL Industries Limited	Sirohi distt., Rajasthan	10.05.2024	Generator (Solar)	Land BG Route	300	30.05.2026	Sirohi PS
6.	2200000811	Adani Renewable Energy Holding Four Limited	Jaisalmer distt., Rajasthan	10.05.2024	Generator (Solar)	SECI LOA	765	31.03.2025	Bhadla-II PS
7.	2200000810	Adani Renewable Energy Holding Four Limited	Jaisalmer distt., Rajasthan	10.05.2024	Generator (Solar)	SECI LOA	717	31.03.2025	Fatehgarh-III PS
8.	2200000782	RJS Renewables Private Limited	Jaisalmer distt., Rajasthan	12.05.2024	Generator (Wind)	Land Route	150	20.04.2028	Ramgarh PS
9.	2200000797	JSW Neo Energy Limited	Jaisalmer distt., Rajasthan	13.05.2024	Generator (Solar)	NTPC LOA	700	01.05.2027	Ramgarh PS
10.	2200000812	Green Infra Wind Energy Private Limited	Nagaur distt., Rajasthan	14.05.2024	Generator (Solar)	Land BG Route	300	31.05.2027	Nagaur PS
11.	2200000813	Green Infra Wind Energy Private Limited	Nagaur distt., Rajasthan	14.05.2024	Generator (Solar)	Land BG Route	300	31.05.2027	Nagaur PS
12.	2200000823	Banyan Energy Private Limited	Nagaur distt., Rajasthan	18.05.2024	Generator (Solar)	Land BG Route	300	30.06.2026	Merta PS
13.	2200000827	Amplus Centaur Solar Private Limited	Sirohi distt., Rajasthan	20.05.2024	Generator (Solar)	Land BG Route	350	30.04.2027	Sirohi PS
14.	2200000807	Adani Renewable Energy Two Limited	Barmer distt.,	21.05.2024	Generator (Wind)	Land Route	600	31.03.2025	Barmer-I PS

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
			Rajasthan						
15.	2200000809	Adani Renewable Energy Two Limited	Barmer & Jaisalmer distt., Rajasthan	21.05.2024	Generator (Wind)	Land Route	595	31.03.2025	Barmer-I PS
16.	2200000840	Acme Solar Holdings Private Limited	Jodhpur distt., Rajasthan	25.05.2024	Generator (Solar)	Land BG Route	300	31.03.2027	Nagaur (MERTA-II) PS
17.	2200000842	Purvah Green Power Private Limited	Nagaur distt., Rajasthan	25.05.2024	Generator (Solar)	Land BG Route	300	01.06.2027	Nagaur PS
18.	2200000848	Hexa Climate Solutions Private Limited	Nagaur distt., Rajasthan	25.05.2024	Generator (Solar with ESS)	Land BG Route	300	31.03.2027	Merta-II PS
19.	2200000850	Renew Solar Power Private Limited	Jalore distt., Rajasthan	27.05.2024	Generator (Solar)	NTPC LOA	300	30.11.2026	Jalore PS
20.	2200000854	Hexa Climate Solutions Private Limited	Bikaner distt., Rajasthan	27.05.2024	Generator (Solar with ESS)	Land BG Route	50	30.06.2025	Bikaner PS
21.	2200000856	Serentica Renewables India 11 Private Limited	Barmer distt., Rajasthan	28.05.2024	Generator (Solar with ESS)	NTPC LOA	250	31.12.2027	Barmer PS
22.	2200000866	Solarcraft Power India 8 Private Limited	Bikaner distt., Rajasthan	30.05.2024	Generator (Solar)	LOA or PPA	300	29.06.2026	Bikaner PS
23.	2200000875	Demeter Sun Power Private Limited	Phalodi distt., Rajasthan	30.05.2024	Generator (Solar)	Land Route	300	31.12.2027	Bhadla IV PS
24.	2200000879	Juniper Green Energy Private Limited	Nagaur distt., Rajasthan	30.05.2024	Generator (Solar)	Land BG Route	300	31.12.2027	Merta-II PS
25.	2200000841	Acme Solar Holdings Private Limited	Jodhpur distt., Rajasthan	31.05.2024	Generator (Solar)	Land BG Route	100	31.03.2027	Nagaur (MERTA-II) PS
26.	2200000891	Serentica Renewables India Private Limited	Udaipur distt., Rajasthan	31.05.2024	Generator (Solar)	Land BG Route	400	30.06.2026	Rishabhdeo PS
27.	2200000886	Renew Solar Power Private Limited	Jalore distt., Rajasthan	31.05.2024	Generator (Solar)	Land BG Route	100	31.12.2027	Jalore PS
28.	2200000887	Renew Solar Power Private Limited	Jalore distt., Rajasthan	31.05.2024	Generator (Solar)	Land BG Route	200	31.07.2027	Jalore PS
29.	2200000888	Renew Solar Power Private Limited	Jalore distt., Rajasthan	31.05.2024	Generator (Solar)	Land BG Route	200	30.09.2027	Jalore PS

Sl. No.	Application ID	Applicant	Project Location	Submission Date	Nature of Applicant	Criterion for applying	Injection at ISTS point (MW)	Start Date of Connectivity (As per Application)	Connectivity location (As per Application)
30.	2200000889	Renew Solar Power Private Limited	Jalore distt., Rajasthan	31.05.2024	Generator (Solar)	Land BG Route	100	31.10.2027	Jalore PS
31.	2200000890	Renew Solar Power Private Limited	Jalore distt., Rajasthan	31.05.2024	Generator (Solar)	Land BG Route	100	30.11.2027	Jalore PS
32.	2200000860	Enren-III Energy Private Limited	Nagaur distt., Rajasthan	31.05.2024	Generator (Solar)	Land BG Route	300	31.01.2027	Nagaur (Merta-II) PS
33.	2200000894	Sindhari Solar Power Private Limited	Nagaur distt., Rajasthan	31.05.2024	Renewable Power Park developer (Solar)	Land BG Route	300	30.06.2027	Nagaur

C.15. Application for Grant of GNA to entities other than STU under Regulation 20.1, 20.3 and 20.4 to entities under Regulation 17.1(ii), (iii), (v) and (vi) received in May'24:

SI No.	Application ID	Name of the Applicant	Submission Date	Nature of applicant	GNA within Region (MW)	GNA outside Region (MW)	Total GNA Required (MW)	Start date of GNA	End date of GNA
1	2200000375	Indian Railways	07.05.2024	Bulk consumer seeking to connect to ISTS	0	50	50	01.04.2024	31.03.2054
2	2200000829	Noida Power Company Limited	21.05.2024	Drawee entity connected to Intra State Transmission System	0	100	100	01.06.2024	31.03.2026

C16. Application for Grant of GNA_{RE} to entities other than STU under Regulation 20.1, 20.3 and 20.4 to entities under Regulation 17.1(ii), (iii), (v) and (vi) received in May'24:

SI No.	Application ID	Name of the Applicant	Submission Date	Nature of applicant	GNA _{RE} within Region (MW)	GNA _{RE} outside Region (MW)	Total GNA _{RE} Required (MW)	Start date of GNA _{RE}	End date of GNA _{RE}
1	2200000740	Ambuja Cements Limited	03.05.2024	Drawee entity connected to Intra State Transmission System	0	25	25	01.06.2024	30.06.2025
2	2200000739	Ambuja Cements Limited	03.05.2024	Drawee entity connected to Intra State Transmission System	0	7	7	01.06.2024	30.06.2025
3	2200000770	Ambuja Cements Limited	07.05.2024	Drawee entity connected to Intra State Transmission System	0	15	15	01.06.2024	30.06.2025
4	2200000768	Ambuja Cements Limited	07.05.2024	Drawee entity connected to Intra State Transmission System	0	8.5	8.5	01.06.2024	30.06.2025
5	2200000769	Ambuja Cements Limited	07.05.2024	Drawee entity connected to Intra State Transmission System	0	7.5	7.5	01.06.2024	30.06.2025

SI No.	Application ID	Name of the Applicant	Submission Date	Nature of applicant	GNA _{RE} within Region (MW)	GNA _{RE} outside Region (MW)	Total GNA _{RE} Required (MW)	Start date of GNA _{RE}	End date of GNA _{RE}
6	2200000772	ACC Limited	07.05.2024	Drawee entity connected to Intra state transmission system	0	27	27	01.06.2024	30.06.2025

Annexure-I

Transmission system for Connectivity under GNA at Barmer-I PS

1. Augmentation of 5x500 MVA (5th to 9th), 400/220 kV ICTs at Barmer-I PS
2. Augmentation with 765/400 kV, 3x1500 MVA Transformer (3rd, 4th & 5th) at Barmer-I PS
3. Fatehgarh-III (Section-2) PS – Barmer-I PS 400 kV D/c line (Quad)
4. Establishment of 2x1500 MVA, 765/400 kV Substation at suitable location near Sirohi along with 2x240 MVar (765 kV) & 2x125 MVar (400 kV) Bus Reactor
5. Barmer-I PS– Sirohi PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end
6. Sirohi PS-Chittorgarh (PG) 400 kV D/c line along with 80 MVar switchable line reactor for each circuit at Sirohi PS end (Quad)
7. Establishment of 765 kV Substation at suitable location near Rishabdeo (Distt. Udaipur) along with 2x240 MVar (765 kV) Bus Reactor
8. Sirohi PS- Rishabdeo 765 kV D/c line along with 330 MVar switchable line reactor for each circuit at Sirohi end
9. Rishabdeo - Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at Rishabdeo end
10. LILO of one circuit of 765 kV Chittorgarh-Banaskantha D/c line at Rishabdeo S/s
11. Establishment of 765 kV Mandsaur PS along with 2x330 MVAR (765 kV) Bus Reactors
12. Mandsaur PS–Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS – Indore(PG) 765 kV D/c Line
13. Establishment of 765/400 kV 2x1500 MVA Kurawar S/s with 2x330 MVar 765 kV bus reactor and 1x125 MVar 420 kV bus reactor
14. Mandsaur – Kurawar 765 kV D/c line along with 240 MVar switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line
15. Kurawar – Ashtha 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
16. LILO of Indore – Bhopal 765 kV S/c line at Kurawar
17. LILO of one circuit of Indore – Itarsi 400 kV D/c line at Ashtha
18. Shujalpur – Kurawar 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
19. Establishment of 765/400 kV, 2x1500 MVA & 2x500 MVA, 400/220 kV S/s at suitable location near Merta (Merta-II Substation) along with 2x125 MVar & 2x240 MVar bus reactor at Merta-II S/s
20. STATCOM (2x±300MVar) along with MSC (4x125 MVar) & MSR (2x125 MVar) along with 2 nos. 400kV bays at Barmer-I PS
21. 400kV Sectionalizer bay (1 set) at Barmer-I S/s

22. Barmer-I PS – Merta-II 765 kV D/c line along with 330 MVar switchable line reactor for each circuit at each end of Barmer-I PS – Merta-II 765 kV D/c line
23. Merta-II – Beawar 400 kV D/c line (Quad)
24. Merta-II – Dausa 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end of Merta-II – Dausa 765 kV D/c line
25. Establishment of 765/400kV, 2x1500 MVA S/s at suitable location near Ghiror (Distt. Mainpuri) along with 2x125 MVar & 2x240 MVar bus reactor at Ghiror S/s (UP)
26. Dausa - Ghiror 765 kV D/c line along with 330MVar switchable line reactor at Ghiror end and 240 MVar switchable line reactor at Dausa end for each circuit of Dausa - Ghiror 765 kV D/c line
27. LILO of both ckt of 765 kV Aligarh (PG) -Orai (PG) D/c line at Ghiror S/s along with 240 MVar switchable line reactor for each circuit at Ghiror S/s end of 765 kV Ghiror -Orai D/c line
28. LILO of one ckt of 765kV Agra (PG) – Fatehpur(PG) 765kV 2xS/c line at Ghiror along with 240 MVar switchable line reactor at Ghiror S/s end of 765 kV Ghiror -Fatehpur line
29. 400kV Ghiror-Firozabad (UPPTCL) D/c line (Quad)

Annexure-II

Transmission system for Connectivity under GNA at Barmer-II PS(Tentative)

For connectivity at 220kV or 400kV level of Barmer-II PS

1. Establishment of 400/220kV Pooling Station at suitable location near Barmer (Barmer-II PS) along with 2x125 MVar bus reactor
2. LILO of both ckts of 400kV Fatehgarh-IV PS – Barmer-I PS at Barmer-II PS
3. Establishment of 6000 MW, ± 800 kV Barmer-II (HVDC) terminal station (4x1500 MW) at a suitable location near Barmer-II substation
4. Establishment of 6000 MW, ± 800 kV South Kalamb S/s (HVDC) terminal station (4x1500 MW) at a suitable location near South of Kalamb (WR)
5. Establishment 2x1500 MVA, 765/400kV Substation near South of Kalamb with 2x330 MVAR, 765 kV bus reactor and 2x125 MVAR, 420 kV bus reactor
6. LILO of Pune-III – Boisar-II 765kV D/c line at South Kalamb with associated bays at South Kalamb S/s
7. ± 800 kV HVDC line between Barmer-II (HVDC) & South Kalamb (HVDC) (with Dedicated Metallic Return)

Additional system for connectivity at 220kV level only of Barmer-II PS

1. 400/220kV, 6x500 MVA ICTs at Barmer-II PS

Annexure-III

Transmission system for Connectivity under GNA at Bhadla-II PS (at 400 kV in sharing)

1. Augmentation of 2x1500 MVA, 765/400 kV ICT (4th & 5th) at Bhadla-II Pooling station
2. Establishment of 765/400kV, 2x1500 MVA S/s at suitable location near Sikar (Sikar-II Substation) with 1x125 MVAR at 400kV level & 2x330 MVAR bus reactors at 765kV level at Sikar -II
3. Bhadla-II PS – Sikar-II 765kV D/c line (2nd)
4. Sikar-II – Khetri 765 kV D/c line
5. Sikar-II – Narela 765 kV D/c line along with 240 MVAR Switchable line reactor for each circuit at each end of Sikar-II – Narela 765 kV D/c line
6. Jhatikara – Dwarka 400kV D/c line (Twin HTLS*)
7. Augmentation of 1x1500 MVA ICT (3rd), 765/400kV ICT at Jhatikara Substation (Bamnoli/Dwarka section)

*minimum 2100 MVA per ckt at nominal voltage

Additional Transmission system for Inter-regional power transfer:

- 1) Establishment of 765 kV Mandsaur Pooling Station along with 2x330 MVAR (765 kV) Bus Reactors
- 2) Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end
- 3a) Mandsaur PS – Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS – Indore(PG) 765 kV D/c Line
- OR
- 3b) Establishment of 765kV Kurawar S/s with 2x330 MVAR 765 kV bus reactor
- 3c) Mandsaur – Kurawar 765 kV D/c line along with 240 MVAR switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line
- 3d) LILO of Indore – Bhopal 765 kV S/c line at Kurawar

Annexure-IV

Transmission system for Connectivity under GNA at Bhadla-III PS

1. Augmentation of 2x500 MVA (8th & 9th), 400/220 kV ICT at Bhadla-III PS
2. Augmentation of 2x1500 MVA (3rd & 4th), 765/400kV ICT at Bhadla-III PS
3. 765 kV Bhadla-III – Bikaner-III D/c line along with 240 MVar switchable line reactor for each circuit at Bhadla-III end
4. Bhadla-III – Sikar-II 765 kV D/c line along with 330 MVar Switchable line reactor for each circuit at each end of Bhadla-III – Sikar-II 765 kV D/c line
5. Fatehgarh-III – Bhadla-III 400kV D/c line (Quad) along with 63 MVar Switchable line reactor for each circuit at both ends of Fatehgarh-III – Bhadla-III 400kV D/c line
6. Establishment of 6000 MW, ± 800 kV Bhadla (HVDC) [LCC] terminal station (4x1500 MW) at a suitable location near Bhadla-III substation
7. Establishment of 6000 MW, ± 800 kV Fatehpur (HVDC) [LCC] terminal station (4x1500 MW) at suitable location near Fatehpur (UP)
8. Bhadla-III – Bhadla (HVDC) 400 kV 2xD/c quad moose line along with the line bays at both substations
9. ± 800 kV HVDC line between Bhadla (HVDC) & Fatehpur (HVDC) (with Dedicated Metallic Return)
10. Augmentation of 5x1500 MVA (1st to 5th), 765/400 kV ICTs at Fatehpur (HVDC) along with 2x330 MVar (765kV) bus reactor
11. LILO of both ckts of 765 kV Varanasi – Kanpur (GIS) D/c line at Fatehpur
12. Augmentation by 1x1500 MVA ICT at 765/400kV Kanpur (GIS) substation

Annexure-V

Transmission system for Connectivity under GNA at Bhadla-IV PS(Tentative)

For connectivity at 220kV or 400kV level of Bhadla-IV PS

1. Establishment of 765/400kV, 4x1500 MVA pooling station at suitable location near Bhadla (Bhadla-IV PS) along with 2x125 MVar & 2x240 MVar bus reactor along with 2x125 MVar & 2x240 MVar bus reactor
2. Bhadla-IV PS – Bhadla-III PS 400kV D/c line (Quad)
3. Establishment of 6000 MW, ± 800 kV Bhadla-IV (HVDC) terminal station (4x1500 MW) at suitable location near Bhadla
4. Establishment of 6000 MW, ± 800 kV terminal station (4x1500 MW) at suitable location in WR/ER
5. ± 800 kV HVDC line between Bhadla-IV (HVDC) & Suitable location in WR/ER (with Dedicated Metallic Return)
6. Establishment of 765/400kV, 2x1500 MVA S/s substation station at Suitable location in WR/ER along with 2x125 MVar & 2x240 MVar bus reactor
7. Associated transmission system in WR/ER for onwards dispersal of power

Additional system for connectivity at 220kV level only of Bhadla-IV PS

1. 400/220kV, 4x500 MVA ICTs at Bhadla-IV PS

Annexure-VI

Transmission system for Connectivity under GNA at Bikaner-IV PS (For M/s SJVN & NTPC)

1. Establishment of 6x1500 MVA, 765/400 kV & 6x500 MVA, 400/220 kV Bikaner-IV Pooling Station along with 2x240 MVar (765kV) & 2x125 MVar (420kV) Bus Reactors at a suitable location near Bikaner
2. 400kV Sectionalizer bay (1 set) at Bikaner-IV PS
3. STATCOM (2x±300MVar) along with MSC (4x125 MVar) & MSR (2x125 MVar) along with 2 nos. 400kV bays at Bikaner-IV PS
4. LILO of both ckts of 400kV Bikaner II PS- Bikaner III PS (Quad) direct line at Bikaner-IV PS
5. Establishment of 765/400 kV, 6x1500 MVA S/s at suitable location near Siwani (Distt. Bhiwani) along with 2x240 MVar (765kV) Bus Reactor & 2x125 MVar (420kV) Bus Reactor
6. Bikaner-IV PS – Siwani 765 kV 2xD/c line along with 240 MVar switchable line reactor for each circuit at each end
7. Siwani – Jind (PG) 400 kV D/c line (Quad)
8. Siwani – Patran (Indi Grid) 400 kV D/c line (Quad) along with 80 MVar switchable line reactor for each circuit at Siwani S/s end
9. Siwani – Fatehabad (PG) 400 kV D/c line (Quad)
10. Siwani – Sonipat (PG) 400 kV D/c line (Quad) along with 63 MVar switchable line reactor for each circuit at Siwani S/s end
11. STATCOM (2x±300MVar) along with MSC (4x125 MVar) & MSR (2x125 MVar) along with 2 nos. 400kV bays at Siwani S/s
12. 400kV Sectionalizer bay (1 set) at at Siwani S/s

Additional Transmission system for Inter-regional power transfer:

- 1) Establishment of 765 kV Mandsaur Pooling Station along with 2x330 MVar (765 kV) Bus Reactors
- 2) Beawar- Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end

3a) Mandsaur PS – Indore(PG) 765 kV D/c Line along with 1x330 MVar switchable line reactor on each ckt at Mandsaur end of Mandsaur PS – Indore(PG) 765 kV D/c Line

OR

3b) Establishment of 765kV Kurawar S/s with 2x330 MVar 765 kV bus reactor

3c) Mandsaur – Kurawar 765 kV D/c line along with 240 MVar switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line

3d) LILO of Indore – Bhopal 765 kV S/c line at Kurawar

Transmission system for Connectivity under GNA at Bikaner-IV PS (For M/s Furies)

1. Establishment of 6x1500 MVA, 765/400 kV & 6x500 MVA, 400/220 kV Bikaner-IV Pooling Station along with 2x240 MVar (765kV) & 2x125 MVar (420kV) Bus Reactors at a suitable location near Bikaner
2. 400/220kV, 2x500 MVA ICTs (7th & 8th) ICTs at Bikaner-IV PS
3. 400kV Sectionalizer bay (1 set) at Bikaner-IV PS
4. STATCOM (2x±300MVar) along with MSC (4x125 MVar) & MSR (2x125 MVar) along with 2 nos. 400kV bays at Bikaner-IV PS
5. LILO of both ckts of 400kV Bikaner II PS- Bikaner III PS (Quad) direct line at Bikaner-IV PS
6. Establishment of 765/400 kV, 6x1500 MVA S/s at suitable location near Siwani (Distt. Bhiwani) along with 2x240 MVar (765kV) Bus Reactor & 2x125 MVar (420kV) Bus Reactor
7. Bikaner-IV PS – Siwani 765 kV 2xD/c line along with 240 MVar switchable line reactor for each circuit at each end
8. Siwani – Jind (PG) 400 kV D/c line (Quad)
9. Siwani – Patran (Indi Grid) 400 kV D/c line (Quad) along with 80 MVar switchable line reactor for each circuit at Siwani S/s end
10. Siwani – Fatehabad (PG) 400 kV D/c line (Quad)
11. Siwani – Sonipat (PG) 400 kV D/c line (Quad) along with 63 MVar switchable line reactor for each circuit at Siwani S/s end
12. STATCOM (2x±300MVar) along with MSC (4x125 MVar) & MSR (2x125 MVar) along with 2 nos. 400kV bays at Siwani S/s
13. 400kV Sectionalizer bay (1 set) at at Siwani S/s

Additional Transmission system for Inter-regional power transfer:

- 1) Establishment of 765 kV Mandsaur Pooling Station along with 2x330 MVar (765 kV) Bus Reactors
- 2) Beawar- Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end

3a) Mandsaur PS – Indore(PG) 765 kV D/c Line along with 1x330 MVar switchable line reactor on each ckt at Mandsaur end of Mandsaur PS – Indore(PG) 765 kV D/c Line

OR

3b) Establishment of 765kV Kurawar S/s with 2x330 MVar 765 kV bus reactor

3c) Mandsaur – Kurawar 765 kV D/c line along with 240 MVar switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line

3d) LILO of Indore – Bhopal 765 kV S/c line at Kurawar

Annexure-VII

Transmission system for Connectivity under GNA at Bikaner-V PS(Tentative)

For connectivity at 220kV or 400kV level of Bikaner-V PS

1. Establishment of 765/400kV, 4x1500 MVA pooling station at suitable location near Bikaner (Bikaner-V PS) along with 2x125 MVar & 2x240 MVar bus reactor
2. LILO of both ckts of 400kV Bikaner-II PS- Khetri D/c line at Bikaner-V PS
3. Establishment of 6000 MW, ± 800 kV Bikaner-V (HVDC) terminal station (4x1500 MW) at suitable location near Bikaner
4. Establishment of 6000 MW, ± 800 kV Begunia (HVDC) terminal station (4x1500 MW) at Begunia (Distt. Khordha), Orissa (ER)
5. ± 800 kV HVDC line between Bikaner-V (HVDC) & Begunia (HVDC) (with Dedicated Metallic Return)
6. Establishment of 765/400kV, 5x1500 MVA S/s substation station at Begunia along with 2x125 MVar & 2x240 MVar bus reactor
7. Begunia – Paradeep (ISTS) 765kV D/c line along with associated bays at both ends
8. Begunia – Gopalpur (ISTS) 765kV D/c line along with associated bays at both ends along with 240MVar switchable line reactor for each circuit at Begunia end of Begunia –Gopalpur (ISTS) 765kV D/c line
9. Begunia – Khuntuni (OPTCL) 765kV D/c line

Additional system for connectivity at 220kV level only of Bikaner-V PS

1. 400/220kV, 5x500 MVA ICTs at Bikaner-V PS

Annexure-VIII

Transmission system for Connectivity under GNA at Ramgarh PS

For connectivity at 220kV or 400kV level of Ramgarh PS

1. Augmentation of 2x1500 MVA (1st & 2nd), 765/400kV ICT at Ramgarh PS
2. Ramgarh PS – Bhadla-III PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at Ramgarh end
3. Augmentation of 2x1500 MVA (3rd & 4th), 765/400kV ICT at Bhadla-III
4. 765 kV Bhadla-III – Bikaner-III D/c line along with 240 MVar switchable line reactor for each circuit at Bhadla-III end
5. Bhadla-III – Sikar-II 765 kV D/c line along with 330 MVar Switchable line reactor for each circuit at each end of Bhadla-III – Sikar-II 765 kV D/c line
6. Fatehgarh-III – Bhadla-III 400kV D/c line(Quad) along with 63 MVar Switchable line reactor for each circuit at both ends of Fatehgarh-III–Bhadla-III 400kV D/c line
7. Establishment of 6000 MW, ± 800 kV Bhadla (HVDC) [LCC] terminal station (4x1500 MW) at a suitable location near Bhadla-III substation
8. Establishment of 6000 MW, ± 800 kV Fatehpur (HVDC) [LCC] terminal station (4x1500 MW) at suitable location near Fatehpur (UP)
9. Bhadla-III – Bhadla (HVDC) 400 kV 2xD/c line(Quad) along with the line bays at both substations
10. ± 800 kV HVDC line between Bhadla (HVDC) & Fatehpur (HVDC) (with Dedicated Metallic Return)
11. Augmentation of 5x1500 MVA (1st to 5th), 765/400 kV ICTs at Fatehpur (HVDC) along with 2x330 MVar (765kV) bus reactor
12. LILO of both ckts of 765 kV Varanasi – Kanpur (GIS) D/c line at Fatehpur
13. Augmentation by 1x1500 MVA ICT at 765/400kV Kanpur (GIS) substation

Additional system for connectivity at 220kV level only of Ramgarh PS

1. 400/220kV, 2x500 MVA ICTs (1st & 2nd) at Ramgarh PS

Annexure-IX

Transmission system for Connectivity under GNA at Sirohi PS

1. Establishment of 2x1500 MVA, 765/400 kV Substation at suitable location near Sirohi along with 2x240 MVar (765 kV) & 2x125 MVar (400 kV) Bus Reactor
2. Augmentation of 5x500 MVA, 400/220kV ICTs at Sirohi PS
3. Sirohi PS-Chittorgarh (PG) 400 kV D/c line along with 80 MVar switchable line reactor for each circuit at Sirohi PS end (Quad)
4. Establishment of, 765 kV Substation at suitable location near Rishabdeo (Distt. Udaipur) along with 2x240 MVar (765 kV) Bus Reactor
5. Sirohi PS- Rishabdeo 765 kV D/c line along with 330 MVar switchable line reactor for each circuit at Sirohi end
6. Rishabdeo - Mandsaur PS 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at Rishabdeo end
7. LILO of one circuit of 765 kV Chittorgarh-Banaskanta D/c line at Rishabdeo S/s
8. Establishment of 765 kV Mandsaur PS along with 2x330 MVAR (765 kV) Bus Reactors
9. Mandsaur PS–Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS – Indore(PG) 765 kV D/c Line
10. Establishment of 765/400 kV (2x1500 MVA Kurawar S/s with 2x330 MVar 765 kV bus reactor and 1x125 MVar 420 kV bus reactor
11. Mandsaur – Kurawar 765 kV D/c line along with 240 MVar switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c line
12. Kurawar – Ashtha 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
13. LILO of Indore – Bhopal 765 kV S/c line at Kurawar
14. LILO of one circuit of Indore – Itarsi 400 kV D/c line at Astha
15. Shujalpur – Kurawar 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
16. Sirohi – Mandsaur PS 765KV D/c line along with 240 MVar switchable line reactor at Sirohi S/s end 330MVar switchable line reactor at Mandsaur PS end for each circuit of Sirohi – Mandsaur PS 765KV D/c line
17. Mandsaur PS – Khandwa (New) 765kV D/c line along with 240MVar switchable line reactor for each circuit at each end of Mandsaur PS – Khandwa (New) 765kV D/c line

Annexure-X

Transmission system for Connectivity under GNA at Fatehgarh-IV PS(Sec-II)

1. Augmentation of 1x500 MVA (7th), 400/220kV ICTs at Fatehgarh-IV (Section-2) Pooling Station
2. 4x1500 MVA (1st to 4th), 765/400 kV ICTs at Fatehgarh-IV (Section-2) Pooling Station
3. Fatehgarh-IV PS(Sec-II) – Bhinmal (PG) 400 kV D/c line (Twin HTLS*) along with 50 MVAr switchable line reactor on each ckt at each end
4. LILO of both ckts of 765 kV Fatehgarh-III- Beawar D/c line at Fatehgarh-IV (Section-2) PS along with 330 MVAr switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV- Beawar D/c line (formed after LILO)
5. Establishment of 765 kV Mandsaur PS along with 2x330 MVAR (765 kV) Bus Reactors
6. Beawar- Mandsaur PS 765 kV D/c line along with 240 MVAr switchable line reactor for each circuit at each end
7. Establishment of 2x1500 MVA, 765/400 kV Substation at suitable location near Sirohi along with 2x240 MVAr (765 kV) & 2x125 MVAr (400 kV) Bus Reactor
8. Fatehgarh-IV (Section-2) PS – Sirohi PS 765 kV D/c line along with 240 MVAr switchable line reactor for each circuit at each end
9. Sirohi PS-Chittorgarh (PG) 400 kV D/c line along with 80 MVAr switchable line reactor for each circuit at Sirohi PS end (Quad)
10. Establishment of 3x1500 MVA, 765/400 kV Barmer-I Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor & 2x125 MVAR, 420 kV Bus Reactor
11. Fatehgarh-III (Section-2) PS – Barmer-I PS 400 kV D/c line (Quad)
12. Barmer-I PS– Sirohi PS 765 kV D/c line along with 240 MVAR switchable line reactor for each circuit at each end
13. Establishment of, 765 kV Substation at suitable location near Rishabdeo (Distt. Udaipur) along with 2x240 MVAr (765 kV) Bus Reactor
14. Sirohi PS- Rishabdeo 765 kV D/c line along with 330 MVAr switchable line reactor for each circuit at Sirohi end
15. Rishabdeo - Mandsaur PS 765 kV D/c line along with 240 MVAr switchable line reactor for each circuit at Rishabdeo end
16. LILO of one circuit of 765 kV Chittorgarh-Banaskanta D/c line at Rishabdeo S/s
17. Mandsaur PS–Indore(PG) 765 kV D/c Line along with 1x330 MVAR switchable line reactor on each ckt at Mandsaur end of Mandsaur PS-Indore(PG) 765 kV D/c Line
18. Establishment of 765/400 kV (2x1500 MVA Kurawar S/s (with 1x500 MVA spare single phase transformer unit) with 2x330 MVAr 765 kVbus reactor and 1x125 MVAr 420 kV bus reactor (with 1x110 MVAr & 1x80 MVAr, 765 kV spare single phase reactor unit for line/bus reactor)
19. Mandsaur – Kurawar 765 kV D/c line along with 240 MVAr switchable line reactors on each ckt at both ends of Mandsaur – Kurawar 765 kV D/c Line
20. LILO of Indore – Bhopal 765 kV S/c line at Kurawar
21. Kurawar – Ashtha 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
22. LILO of one circuit of Indore – Itarsi 400 kV D/c line at Ashtha
23. Shujalpur – Kurawar 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line
24. Establishment of 765/400 kV, 2x1500 MVA & 2x500 MVA, 400/220 kV S/s at suitable location near Merta (Merta-II Substation) along with 2x125 MVAr & 2x240 MVAr bus reactor at Merta-II S/s
25. STATCOM (2x±300MVAr) along with MSC (4x125 MVAr) & MSR (2x125 MVAr) along with 2 nos. 400kV bays at Barmer-I PS

26. 400kV Sectionalizer bay (1 set) at Barmer-I S/s
27. Barmer-I PS – Merta-II 765 kV D/c line along with 330 MVar switchable line reactor for each circuit at each end of Barmer-I PS–Merta-II 765 kV D/c line
28. Merta-II – Beawar 400 kV D/c line (Quad)
29. Merta-II – Dausa 765 kV D/c line along with 240 MVar switchable line reactor for each circuit at each end of Merta-II – Dausa 765 kV D/c line line
30. Establishment of 765/400kV, 2x1500 MVA S/s at suitable location near Ghiror (Distt. Mainpuri) along with 2x125 MVar & 2x240 MVar bus reactor at Ghiror S/s (UP)
31. Dausa - Ghiror 765 kV D/c line along with 330MVar switchable line reactor at Ghiror end and 240 MVar switchable line reactor at Dausa end for each circuit of Dausa - Ghiror 765 kV D/c line
32. LILO of both ckt of 765 kV Aligarh (PG) -Orai (PG) D/c line at Ghiror S/s along with 240 MVar switchable line reactor for each circuit at Ghiror S/s end of 765 kV Ghiror -Orai D/c line
33. LILO of one ckt of 765kV Agra (PG) – Fatehpur(PG) 765kV 2xS/c line at Ghiror along with 240 MVar switchable line reactor at Ghiror S/s end of 765 kV Ghiror -Fatehpur line
34. 400kV Ghiror-Firozabad (UPPTCL) D/c line (Quad)

Annexure-XI

Transmission scheme for connectivity of Kiru HEP (624MW)

S. No.	Description of Transmission Element
1	LILO of 400 kV Kishenpur- Dulhasti line (Twin) at Kishtwar S/s along with associated bays at Kishtwar S/s
2	Reconductoring of 400 kV Kishenpur-Kishtwar section with Twin HTLS (minimum 2100 MVA capacity) (formed after LILO of Kishenpur-Dulhasti line at Kishtwar S/s) along with bay upgradation works (2000A to 3150A) at Kishenpur end for above line.
3	400 kV Kishenpur-Samba D/c line (Quad) (only one circuit is to be terminated at Kishenpur utilizing 1 no. of 400kV vacated line bay at Kishenpur S/s (formed with bypassing of one ckt of 400kV Kishtwar – Kishenpur 400kV D/c line (Quad) at Kishenpur) while second circuit would be connected to bypassed circuit of 400kV Kishtwar – Kishenpur line (Quad))
4	Bypassing of one ckt of 400kV Kishtwar – Kishenpur 400kV D/c line (Quad) at Kishenpur and connecting it with one of the circuit of Kishenpur-Samba 400kV D/c line(Quad), thus forming 400kV Kishtwar - Samba (Quad) direct line (one ckt)
5	1x80 MVar Switchable line reactor at Samba end of 400kV Kishtwar-Samba 400kV line-165km (Quad) [formed after bypassing of 400kV Kishtwar – Kishenpur line (Quad) at Kishenpur and connecting it with one of the circuit of Kishenpur-Samba 400kV D/c line(Quad)]
6	Bypassing both ckts of 400kV Kishenpur – Samba D/c line (Twin) & 400 kV Samba – Jalandhar D/c line (Twin) at Samba and connecting them together to form 400kV Kishenpur– Jalandhar D/c direct line (Twin) (4 nos. of vacated 400kV line bays at Samba S/s will be utilized for 400 kV Kishenpur-Samba D/c line (Quad) & 400kV Samba- Jalandhar D/c line(Quad))
7	Bays upgradation works (2000A to 3150A) at Samba end (4 nos. bays vacated after bypassing of Kishenpur – Samba D/c line (Twin) & 400 kV Samba – Jalandhar D/c line (Twin))
8	1x63 MVar Switchable line reactor on each ckt at Jalandhar end of Kishenpur– Jalandhar D/c direct line -171km(Twin) (formed after bypassing both ckts of 400kV Kishenpur – Samba D/c line (Twin) & 400 kV Samba – Jalandhar D/c line (Twin) at Samba and connecting them together to form Kishenpur– Jalandhar D/c direct line (Twin))
9	400kV Samba- Jalandhar D/c line(Quad) (only one circuit is to be terminated at Jalandhar utilizing 1 no. of 400kV vacated line bay at Jalandhar S/s (formed with bypassing of 400kV Jalandhar – Nakodar line (Quad) at Jalandhar) while second circuit would be connected to bypassed circuit of Jalandhar –Nakodar 400kV line (Quad))
10	1x80 MVar Switchable line reactor at Samba end of Samba –Nakodar direct line (Quad) formed after bypassing of 400kV Jalandhar – Nakodar line-187km (Quad) at Jalandhar and connecting it with one of the circuit of Samba-Jalandhar 400kV D/c line(Quad Moose), thus forming Samba –Nakodar line (Quad)
11	Bypassing 400kV Jalandhar – Nakodar line (Quad) at Jalandhar and connecting it with one of the circuit of Samba-Jalandhar 400kV D/c line(Quad Moose), thus forming 400kV Samba –Nakodar (Quad) direct line
12	Augmentation of 500 MVA ICT (4 th) at Jalandhar(PG) S/s along with associated transformer bays - space confirmation by POWERGRID is awaited
13.	Augmentation of 500 MVA ICT (4 th) ICT at Samba(PG) S/s along with associated transformer bays

List of Participants of 31st Consultation meeting for Evolving Transmission Schemes in NR held on 27.06.2024**CEA**

Shri Nitin Deswal Deputy Director

Grid India

Mr. Ibtesam Asif Dy. Manager

Shri Shri Gaurab Dash Dy. Manager

Shri Raj Kishan Assistant Manager

SECI

Shri R.K.Agarwal Consultant

CTU

Shri V Thiagarajan Sr. GM (CTU)

Shri Kashish Bhambhani GM (CTUIL)

Shri Sandeep Kumawat DGM (CTU)

Shri Ganeswara Rao Jada DGM on deputation (CEA)

Smt. Ankita Singh Ch. Manager (CTU)

Shri Narendra Sathvik R Ch. Manager (CTU)

Shri Yatin Sharma Manager (CTU)

Shri Madhusudan Meena Engineer (CTU)

RVPNL

Shri Dr. Om Prakash Mahela XEN(PP&D)

PSTCL

Shri Nitin Kumar Sr. EE

PTCUL

Shri Lalit Kumar SE

HVPNL

Shri Vinay Jain XEN

Sanjay verma SE

JKTPCT

Shri K. K. Thappa SE

HPPTCL

Shri Harmanjeet Singh AE

Connectivity/GNA Applicants

Shri IMS Karasi GM (UJVNL)

Shri Yogesh Kumar Sanklecha Acme Solar Holdings Ltd.

Shri Ajay Kumar Pradhan Acme Solar Holdings Ltd.

Shri Rambabu M Axis Energy Ventures India Private Limited

Shri S Sri Murali Axis Energy Ventures India Private Limited

Shri T R Kishor Nair Avaada Energy Private Limited

Shri Angshuman Rudra Avaada Energy Private Limited

Shri Atulesh Parasar Avaada Energy Private Limited

Shri Jasmine P. Singh Acme Cleantech Solutions Private Limited

Mr. Md Sharique Afzal Apraava Energy Private Limited

Shri Gopal Eti Apraava Energy Private Limited

Shri Shashank Gupta Azure Power India Private Limited

Shri Vaibhav Kapoor Aditya Birla Renewables Subsidiary Limited

Shri Rohit Ahuja Anboto Solar Private Limited

Shri Ayush Jain Anboto Solar Private Limited

Shri Mohan Lal Thakur	Chenab Valley Power Projects Pvt Limited
Shri Amrik Singh	Chenab Valley Power Projects Pvt Limited
Shri Sushanta Basumatary	CESC Limited
Mr. Farrukh Aamir	CESC Limited
Shri Sachin Jindal	Enfinity Global Surya Kiran & EG Saur Urja Private Limited
Shri Ankur Pathak	Furies Solren Private Limited
Shri Vivek Hooda	Green Infra Wind Energy Limited
Shri Pushpinder Hira	Greenko Up01 Irep Private Limited
Shri Manish Kumar	Greenko Up01 Irep Private Limited
Shri Om Prakash Meena	Greenko Up01 Irep Private Limited
Shri Vikash Kumar	Hinduja Renewables Energy Private Limited
Shri Aniket Vyas	Iraax International (Opc) Private Limited
Shri Vinod Kumar Jaroli	Hindustan Zinc Limited
Shri Ravindra Shekhawat	HHP Two Private Limited
Shri Pavan Kumar Gupta	Juniper Green Energy Private Limited
Smt. Priyanka Raj	Juniper Green Energy Private Limited
Shri Animesh Manna	NTPC Renewable Energy Limited
Shri Ankur Jain	Indian Railways
Shri Gurbachan Singh	Indian Railways
Shri Ajay Peri	Prerak Solar Urja Private Limited
Shri Vikram Malkotia	Pravat Renewables & Gamma Renewables
Shri Alok Kumar Nigam	Pravat Renewables & Gamma Renewables
Shri Mohit Jain	Renew Solar Power Private Limited
Shri Rajiv Pandey	Sunflag Power Ltd
Shri Vinod V Halge	Saurya Urja Company of Rajasthan Limited
Shri Chinmay Sirdeshmukh	Sprng Renewable Resources Private Limited
Smt. Poorva Pitke	Sprng Renewable Resources Private Limited
Shri K A Vishwanath	Solalite Power Private Limited
Shri Abhishek Bhardwaj	SJVN Green Energy Limited
Shri Amarjeet Singh	Shree Cement Limited
Shri Dhir Singh	Solarcraft Power India 4 Private Limited