



CORE MATERIAL TESTING SERVICES LLP

ACCREDITED CIVIL ENGG. MATERIAL TESTING LABORATORY



TC - 15516

TEST REPORT

Discipline : Mechanical
Group : Building Material

COMPRESSIVE STRENGTH OF CONCRETE CUBE

ULR No. : TC1551626000016003F
Report No. : CMTS/DDSR/LAB/2026-27/JULY 27/13

Name of Project : Ahilya Bhavan Kalamboli.

Name of Client : DDSR Reality
Name of Contractor : A.V.N. Infra

Sample Id : 8586
Location : 2nd Slab

Date of Sample Received : 22.07.2026
Date of Report : 27.07.2026
Age of Cubes : 14 Days
Grade of Cube : M-45
Description of Sample : Concrete Cube
Condition of Sample : Satisfactory
Nos. of Sample : 03 Nos.

Test Method : As Per IS 516 (Part 1/Sec 1) : 2021

Sr. No.	Cube ID Mark	Date of Casting	Date of Testing	Weight (Kg)	Dimension in mm x mm x mm			C/S Area of Cube (m ²)	Failure Load in (KN)	Comp. Strength of Concrete cube (N/mm ²) {Load/Area}	Average comp. Strength (N/mm ²)	Type of Failure
					L	W	H					
1	1	13-07-26	27-07-26	8.520	150.0	150.0	150.0	0.02250	515.0	22.89	24.28	Satisfactory
2	2	13-07-26	27-07-26	8.090	150.0	150.0	150.0	0.02250	598.0	26.58		Satisfactory
3	3	13-07-26	27-07-26	8.400	150.0	150.0	150.0	0.02250	526.0	23.38		Satisfactory

- Note: 1. Sample were not drawn by the laboratory.
2. This report refers only to the sample submitted for testing.
3. This report is valid at the time of and under the conditions specified there in.
4. This report may not be reproduced in part or full, without the permission of "CMTS LLP", Navi Mumbai.
5. Any correction invalidates this report.

Prepared By

Shruti Naik

QC Engineer
(Shruti Naik)



Reviewed & Checked By

S. Rahamansab

Authorized Signatory
(S. Rahamansab)

Document No.: CMTS/F4/TRF/88, Rev.: 01 Dated: 17/06/2024

-----End of Report-----





CORE MATERIAL TESTING SERVICES LLP

ACCREDITED CIVIL ENGG. MATERIAL TESTING LABORATORY



TC - 15516

TEST REPORT

Discipline : Mechanical
Group : Building Material

COMPRESSIVE STRENGTH OF CONCRETE CUBE

ULR No. : TC1551626000016004F
Report No. : CMTS/DDSR/LAB/2026-27/JULY 27/14

Name of Project : Ahilya Bhavan Kalamboli.

Name of Client : DDSR Reality
Name of Contractor : A.V.N. Infra

Sample Id : 8587
Location : 2nd Slab

Date of Sample Received : 22.07.2026
Date of Report : 27.07.2026
Age of Cubes : 14 Days
Grade of Cube : M-45
Description of Sample : Concrete Cube
Condition of Sample : Satisfactory
Nos. of Sample : 03 Nos.

Test Method : As Per IS 516 (Part 1/Sec 1) : 2021

Sr. No.	Cube ID Mark	Date of Casting	Date of Testing	Weight (Kg)	Dimension in mm x mm x mm			C/S Area of Cube (m ²)	Failure Load in (KN)	Comp. Strength of Concrete cube (N/mm ²) {Load/Area}	Average comp. Strength (N/mm ²)	Type of Failure
					L	W	H					
1	1	13-07-26	27-07-26	8.857	150.0	150.0	150.0	0.02250	400.0	17.78	19.17	Satisfactory
2	2	13-07-26	27-07-26	8.365	150.0	150.0	150.0	0.02250	414.0	18.40		Satisfactory
3	3	13-07-26	27-07-26	8.600	150.0	150.0	150.0	0.02250	480.0	21.33		Satisfactory

- Note: 1. Sample were not drawn by the laboratory.
2. This report refers only to the sample submitted for testing.
3. This report is valid at the time of and under the conditions specified there in.
4. This report may not be reproduced in part or full, without the permission of "CMTS LLP", Navi Mumbai.
5. Any correction invalidates this report.

Prepared By

[Signature]

QC Engineer
(Shruti Naik)



Reviewed & Checked By

[Signature]

Authorized Signatory
(S. Rahamansab)

Document No.: CMTS/F4/TRF/88, Rev.: 01 Dated: 17/06/2024

End of Report





CORE MATERIAL TESTING SERVICES LLP

ACCREDITED CIVIL ENGG. MATERIAL TESTING LABORATORY



TC - 15516

TEST REPORT

Discipline : Mechanical
Group : Building Material

COMPRESSIVE STRENGTH OF CONCRETE CUBE

ULR No. : TC1551626000016005F
Report No. : CMTS/DDSR/LAB/2026-27/JULY 27/15

Name of Project : Ahilya Bhavan Kalamboli.

Name of Client : DDSR Reality
Name of Contractor : A.V.N. Infra

Sample Id : 8588
Location : 2nd Slab

Date of Sample Received : 22.07.2026
Date of Report : 27.07.2026
Age of Cubes : 14 Days
Grade of Cube : M-45
Description of Sample : Concrete Cube
Condition of Sample : Satisfactory
Nos. of Sample : 03 Nos.

Test Method : As Per IS 516 (Part 1/Sec 1) : 2021

Sr. No.	Cube ID Mark	Date of Casting	Date of Testing	Weight (Kg)	Dimension in mm x mm x mm			C/S Area of Cube (m ²)	Failure Load in (KN)	Comp. Strength of Concrete cube (N/mm ²) {Load/Area}	Average comp. Strength (N/mm ²)	Type of Failure
					L	W	H					
1	1	13-07-26	27-07-26	8.390	150.0	150.0	150.0	0.02250	370.0	16.44	18.80	Satisfactory
2	2	13-07-26	27-07-26	8.500	150.0	150.0	150.0	0.02250	442.0	19.64		Satisfactory
3	3	13-07-26	27-07-26	8.590	150.0	150.0	150.0	0.02250	457.0	20.31		Satisfactory

- Note: 1. Sample were not drawn by the laboratory.
2. This report refers only to the sample submitted for testing.
3. This report is valid at the time of and under the conditions specified there in.
4. This report may not be reproduced in part or full, without the permission of "CMTS LLP", Navi Mumbai.
5. Any correction invalidates this report.

Prepared By

Shruti Naik

QC Engineer
(Shruti Naik)



Reviewed & Checked By

S. Rahamansab

Authorized Signatory
(S. Rahamansab)

Document No.: CMTS/F4/TRF/88, Rev.: 01 Dated: 17/06/2024

-----End of Report-----

