

Bayesian Dictionary Learning for EEG Source Identification

Trine Nyholm Kragh & Laura Nyrup Mogensen
Mathematical Engineering, MATTEK

Master's Thesis





Mathematical Engineering
Aalborg University
<http://www.aau.dk>

AALBORG UNIVERSITY

STUDENT REPORT

Title:

Bayesian Dictionary Learning for EEG
Source Identification

Abstract:

Here is the abstract

Theme:

Project Period:

Fall Semester 2019

Project Group:

Mattek9

Participant(s):

Trine Nyholm Kragh
Laura Nyrup Mogensen

Supervisor(s):

Jan Østergaard
Rasmus Waagepetersen

Copies: 1

Page Numbers: 15

Date of Completion:

September 23, 2019

The content of this report is freely available, but publication (with reference) may only be pursued due to agreement with the author.



AALBORG UNIVERSITET
STUDENTERRAPPORT

Matematik-Teknologi
Aalborg Universitet
<http://www.aau.dk>

Titel:

Bayesian Bibliotek Læring for EEG Kilde
Identifikation

Abstract:

Her er resuméet

Tema:

Projektperiode:

Efterårssemestret 2019

Projektgruppe:

Mattek9

Deltager(e):

Trine Nyholm Kragh
Laura Nyrup Mogensen

Vejleder(e):

Jan Østergaard
Rasmus Waagepetersen

Oplagstal: 1

Sidetæl: 15

Afleveringsdato:

23. september 2019

Rapportens indhold er frit tilgængeligt, men offentliggørelse (med kildeangivelse) må kun ske efter aftale med forfatterne.

Preface

Here is the preface. You should put your signatures at the end of the preface.

Aalborg University, September 23, 2019

Trine Nyholm Kragh
<trijen15@student.aau.dk>

Laura Nyrup Mogensen
<lmogen15@student.aau.dk>

Danish Summary

Dansk resume ?

Contents

Preface	vii
Danish Summary	ix
Introduction	3
1 Problem Analysis	5
1.1 Motivation	5
1.2 Related Work and Our Contribution	7
2 Sparse Signal Recovery	9
2.1 Compressive Sensing	9
2.2 ICA	11
2.3 Cov-DL	12
2.4 MSB	12
Bibliography	13
A Appendix A	15

Introduction

Introduktion til hele projektet, skal kunne læses som en appetitvækker til resten af rapporten, det vi skriver her skal så uddybes senere. Brug dog stadigvæk kilder.

- kort intro a EEG og den brede anvendelse, anvendelse indenfor høreapparat.
- intro af model, problem med overbestemt system
- Seneste forslag til at løse dette
- vi vil efterviser dette og udvide til realtime tracking
- opbygningen af rapporten

Chapter 1

Problem Analysis

This chapter examines existing literature concerning source localisation from EEG measurements. At first a motivation for the problem is given, considering especially the application within the hearing aid industry. Further, the state of the art methods are presented followed by a description of the contribution proposed in this thesis.

1.1 Motivation

(Hvad er EEG)

EEG recordings or measurements are used within medicine as an imaging technique measuring electric signals on the scalp, caused by brain activity.

The brain consist of an enormous amounts of cells, called neurons. These neurons are mutually connected in neural nets and when a neuron is activated, for instance by some physical stimuli, local current flows are produced[4]. As such the neurons are somehow communicating(?).

The EEG measurements are provided by a varies number of metal electrodes referred to as sensors, placed on the scalp of a human reading electrical signals which are massively amplified and displayed on the computer as a sum of sinusoidal waves relative to time.

It takes a large amount of active neurons to generate an electrical signal that is recordable on the scalp as the current then have to penetrate the skull, skin and several other thin layers.

From this it is clear that the measurements from a single sensor do not correspond to the activity of a single neuron in the brain, but rather a collection of many activities. Here the same neuron activities can be measured by two or more sensors. Furthermore, interfering signals can occur resulting from physical movement of e.g. eyes and jawbone[4].

The waves resulting from EEG have been classified into four groups according to the dominant frequency. The delta wave (0.5 – 4 Hz) is observed from infants and sleeping adults, the Theta wave (4 – 8 Hz) is observed from children and sleeping adults, the alpha wave (8 – 13 Hz) is the most extensively studied brain rhythm, which is induced by an adult laying down with closed eyes. Lastly the beta wave (13 – 30 Hz) is considered the normal brain rhythm for normal adults, associated with active thinking, active attention or solving concrete problems[1, p. 11]. An example of EEG measurement within the four categories are illustrated by figure 1.1. Evoked




Figure 1.1: Example of time dependent EEG measurements within the four defined categories alpha, beta, theta and delta. Image source: [1]

potential

(Hvad bruges det til)

EEG is widely used within medicine and research of the cognitive processes in the brain. Diagnosis and Management of neurological disorders such as epilepsy is one example.

A great advantage of EEG is the speed. Neural activity can be measured within fractions of a second after a stimuli has been provided[4, p. 3]. When a person is exposed to certain stimuli, e.g. visual or audible, the measured activity is said to result from evoked potential.

noter - den skal drejes hen på connectivity som et ønsket område, og dermed source lokalisation

- study of dynamical behaviour of the brain, now big research field because of EEG and others → many data analysis tools (Van artikel)
- lately functional integration is of interest that is interplay between functionally segregate brain areas

(Hvad er problemet, localisation)

Due to EEG being non-invasive and fast it is widely used to study of the dynamical behaviour of the brain. Over the past two decades especially functional integration has become an area of interest, that is the interplay between functionally segregate brain areas [3] (evt. Friston 2011).

This concerns the localization of the single cortical sources causing the united signal measured by a EEG sensor.

(Anvendelse i praksis)

The hearing aid industry is one example of the use of this research. At Eriksholm research center which is a part of the hearing aid manufacture Oticon is cognitive hearing science an important research area. The main goal is to make it possible to the hearing aid to identify the attended speaker by reading the signal from the brain, which is where the EEG measurements are used (<https://www.eriksholm.com/research/cognitive-hearing-science>).

evt. lave subsections her..

1.2 Related Work and Our Contribution

indhold

nb. husk at dette kapitel skal vise et helt system og hvorhenne i det system vi kigger nærmere og kommer ind med vores bidrag. Det skal gøres klar hvilke områder vi vælger at ligge vores kræfter i.

Chapter 2

Problem Statement

forslag:

how can sources of activation within the brain be localized from EEG measurement, in the cases of less sensors than sources.

From EEG measurements how do one localize activated sources within the brain and can this be done in real time with the possibility to include feedback

Vi skal have styr på hvad det er vi vil dem vores realtime implementering: - måle om der er støj, så vi kan skrue ned for den støj, jeg tror det var det Jan snakked om i første omgang - kæde støjen sammen med locationerne for de aktive sources, måske det man gør i forhold til at retningsbestemme støj? - er første del blot at localisere sources

Chapter 3

Sparse Signal Recovery

Through this chapter an introduction to the concept compressive sensing is described with associated theory which later on will be used in the development of the algorithm with used methods known from compressive sensing to estimate the mixing matrix A and the sparse source matrix X .

3.1 Compressive Sensing

Compressive sensing is the theory of efficient recover/reconstruct a signal from minimal measurements. This recovery is often described as a linear model/system

$$\mathbf{y} = \mathbf{A}\mathbf{x},$$

which consist of observed data $\mathbf{y} \in \mathbb{R}^M$, a matrix $\mathbf{A} \in \mathbb{R}^{M \times N}$ which models the linear measurements and signal $\mathbf{x} \in \mathbb{R}^N$. In compressive sensing terminology, \mathbf{y} is the signal of interest that is wish recovered from minimal measurements meaning that the signal \mathbf{x} must be sparse.

A signal is said to be k -sparse if the signal has at most k non-zeros coefficient

$$\|\mathbf{x}\|_0 = \text{card}(\text{supp}(\mathbf{x})) \leq k,$$

where the ℓ_0 -norm is used. The function card is the cardinality of the support of \mathbf{x} . The support of \mathbf{x} is giving as

$$\text{supp}(\mathbf{x}) = \{j \in [N] : x_j \neq 0\},$$

where $[N]$ a set [2, p. 41]. The set of all k -sparse signals is denoted as

$$\Sigma_k = \{\mathbf{x} : \|\mathbf{x}\|_0 \leq k\}.$$

It is of interest to recover the signal \mathbf{y} when $M \ll N$ and $k < M$ [5, p. 8]. This lead to that the matrix \mathbf{A} becomes rank-deficient and therefore have a non-empty

null-space [5, p. ix].

The linear model and finding the sparse signal \mathbf{x} can be written as an optimisation problem

$$\min_{\mathbf{z}} \|\mathbf{z}\|_0 \quad \text{s.t.} \quad \mathbf{y} = \mathbf{Az},$$

where \mathbf{z} is all possible candidates to an k -sparse signal \mathbf{x} .

Unfortunately, this optimisation problem is non-convex because of ℓ_0 -norm and is therefore difficult to solve – it is a NP-hard problem. Instead by replacing the ℓ_0 -norm with its convex approximation, the ℓ_1 -norm, the optimisation problem become computational feasible [5, p. 27]

$$\min_{\mathbf{z}} \|\mathbf{z}\|_1 \quad \text{s.t.} \quad \mathbf{y} = \mathbf{Az}, \quad (3.1)$$

and instead we find the best k -term approximation of the signal \mathbf{x} .

3.1.1 Conditions on the Mixing Matrix

To ensure an exact or an approximate reconstruction of the sparse signal \mathbf{x} some conditions associated on the matrix \mathbf{A} must be satisfied.

Null Space Conditions

The null space property (NSP) is some necessary and sufficient condition for exact recovery. The null space of the matrix A is defined as

$$\mathcal{N}(A) = \{z : Az = 0\}.$$

Restricted Isometry Conditions

NSP do not take account for noise and we must therefore look at some stronger conditions which incorporate noise, the following restricted isometry property (RIP)

Definition 3.1 (Restricted Isometry Property)

A matrix A satisfies the RIP of order k if there exists a $\delta_k \in (0, 1)$ such that

$$(1 - \delta_k) \|x\|_2^2 \leq \|Ax\|_2^2 \leq (1 + \delta_k) \|x\|_2^2,$$

holds for all $x \in \Sigma_k$

If a matrix A satisfy RIP then it will also satisfy the NSP as RIP is strictly stronger than NSP.

Theorem 3.1.1

If A satisfies the RIP of order $2k$ with the constant $\delta_{2k} < \sqrt{2} - 1$. Then

$$C = \frac{2}{1 - (1 + \sqrt{2})\delta_{2k}}$$

Coherence

The NSP provide a unique solution to the optimisation problem, (2.1), but is unfortunately complicated to investigate. Instead an alternative measure used for sparsity is presented.

Coherence is a measure of quality and determine if the matrix A is a good choice for the optimisation problem (2.1). A small coherence describe the performance of a recovery algorithm as good with that choice of \mathbf{A} .

Definition 3.2 (Coherence)

Coherence of the matrix $A \in \mathbb{R}^{M \times N}$, denoted as $\mu(A)$, with columns $\mathbf{a}_1, \dots, \mathbf{a}_N$ for all $i \in [N]$ is given as

$$\mu(A) = \max_{1 \leq i < j \leq n} \frac{|\langle a_i, a_j \rangle|}{\|a_i\|_2 \|a_j\|_2}.$$

3.2 ICA

Through this section the mathematical concepts of Independent Component Analysis (ICA) will be explained and defined.

Lets set up an situations. We have some measurements that has been affect by some surrounding noise or "sideløbende" measurements such as different conversations in a room. The measurements can be described by a vector \mathbf{y} if we look at the one-dimensional case. \mathbf{y} consist of the measurement from the original signal, a vector \mathbf{x} and surrounding measurements, a matrix \mathbf{A} . This situation can be described as the linear model

$$\mathbf{y} = \mathbf{A}\mathbf{x} = \sum_{i=1}^n \mathbf{a}_i x_i$$

We known the measurements \mathbf{y} but if also knew the mixing parameter in \mathbf{A} then by inverting the linear model we could solve the system and find the original signal. But this is not the case as the mixing matrix also is unknown.

If we used the statistical properties of \mathbf{x} then it would be possible to estimate both the mixing matrix and then the original signal. What ICA do is to assume statistical independence

Lets define the ICA model which is a generative model meaning that the observed data is generated by a process of mixing components which are latent component. Let n be the observed random variables such that y_1, \dots, y_n are model as a linear combination of the random variables x_1, \dots, x_n :

$$y_i = a_{i1}x_1 + a_{i2}x_2 + \dots + a_{in}x_n, \quad i = 1, \dots, n$$

$$\mathbf{y} = \begin{bmatrix} a_{11} & a_{12} & \dots & a_{1n} \\ a_{21} & a_{22} & \dots & a_{2n} \\ \vdots & \vdots & \dots & \vdots \\ a_{n1} & a_{n2} & \dots & a_{nn} \end{bmatrix} \mathbf{x}$$

where $\mathbf{y} = \{y_i\}_{i \in [1, n]}$ and $\mathbf{x} = \{x_t\}_{t \in [1, n]}$. Furthermore, \mathbf{x} is statistically mutually independent.

Notes: ICA can be used on Gaussian variables as little is done in addition to decorrelate for Gaussian variable

Whiting is useful to be done beore ICA

3.3 Cov-DL

3.4 MSB

Bibliography

- [1] Saeid Sanei, J.A. Chambers. *EEG Signal Processing*. John Wiley and sons, Ltd, 2007.
- [2] Simon Foucart, Hoyer Rauhut. *A Mathematical Introduction to Compressive Sensing*. Springer Science+Business Media New York, 2013.
- [3] Steen Luca Faes, Esin Karahan Jitkomut Songsiri Pedro A. Valdes-Sosa Daniele Marinazzo1 Frederik Van de. “Critical Comments on EEG Sensor Space Dynamical Connectivity Analysis”. In: *Brain Topography* 32 (2019).
- [4] Teplan, M. “Fundamentals of EEG”. In: *Measurement science review* 2 (2002).
- [5] Yonina C. Eldar, Gitta Kutyniok. *Compressed Sensing: Theory and Application*. Cambridge University Presse, New York, 2012.

Appendix A

Appendix A