

Nepal Import Review Draft - Grid-Connected PV Inverter

For SunBridge Trading, to share with the Nepal import agent. Checked against NEPQA-2025 §1.4. Draft for review.

1. Important: the two documents describe different products

Verdict: DIFFERENT_PRODUCT

Records do not share any model number and/or differ in phase. Their specifications are not comparable.

Field Document A Document B

Document type Certificate of Conformity Test Report

Phase three single

DC voltage class 1100V 60V

These two documents share a factory but are different product lines. They cannot be treated as one filing. Each is scored separately against NEPQA below.

2. NEPQA §1.4 document scorecard - Product 1 - Deye (three-phase)

Models: SUN-3K-G06P3-EU-AM2, SUN-4K-G06P3-EU-AM2, SUN-5K-G06P3-EU-AM2,
SUN-6K-G06P3-EU-AM2, SUN-7K-G06P3-EU-AM2, SUN-8K-G06P3-EU-AM2, SUN-9K-G06P3-EU-AM2,
SUN-10K-G06P3-EU-AM2, SUN-12K-G06P3-EU-AM2, SUN-15K-G06P3-EU-AM2,
SUN-3K-G06P3-EU-AM2-P1, SUN-4K-G06P3-EU-AM2-P1, SUN-5K-G06P3-EU-AM2-P1,
SUN-6K-G06P3-EU-AM2-P1, SUN-7K-G06P3-EU-AM2-P1, SUN-8K-G06P3-EU-AM2-P1,
SUN-9K-G06P3-EU-AM2-P1, SUN-10K-G06P3-EU-AM2-P1, SUN-12K-G06P3-EU-AM2-P1,
SUN-15K-G06P3-EU-AM2-P1

- MET - DOC-1: Test certificate to IEC 61727:2004 (utility interface characteristics), from an IECCEE/IECRE-listed body
- MET - DOC-2: Test certificate to IEC 62116:2014 (islanding prevention test procedure), from an IECCEE/IECRE-listed body
- MISSING - DOC-3: Test certificate to IEC 62891:2020 (MPPT efficiency of grid-connected inverters), from an IECCEE/IECRE-listed body
- MISSING - DOC-4: Test certificate to IEC 62109-1:2010 AND IEC 62109-2:2011 (safety: general + inverter-particular), from an IECCEE/IECRE-listed body
- ASK_FACTORY - DOC-5: Importer-manufacturer agreement, signed and stamped, stating the PV inverter warranty period
- ASK_FACTORY - DOC-6: Catalogue and technical datasheet of the PV inverter

2. NEPQA §1.4 document scorecard - Product 2 - CHISAGE (single-phase)

Models: CE-1P3001G-230-EU, CE-1P5001G-230-EU, CE-1P6001G-230-EU, CE-1P8001G-230-EU,
CE-1P10001G-230-EU, CE-1P13001G-230-EU, CE-1P16001G-230-EU, CE-1P18001G-230-EU,
CE-1P20001G-230-EU

- MISSING - DOC-1: Test certificate to IEC 61727:2004 (utility interface characteristics), from an

IECEE/IECRE-listed body

- MISSING - DOC-2: Test certificate to IEC 62116:2014 (islanding prevention test procedure), from an IECEE/IECRE-listed body
- MISSING - DOC-3: Test certificate to IEC 62891:2020 (MPPT efficiency of grid-connected inverters), from an IECEE/IECRE-listed body
- MISSING - DOC-4: Test certificate to IEC 62109-1:2010 AND IEC 62109-2:2011 (safety: general + inverter-particular), from an IECEE/IECRE-listed body
- ASK_FACTORY - DOC-5: Importer-manufacturer agreement, signed and stamped, stating the PV inverter warranty period
- ASK_FACTORY - DOC-6: Catalogue and technical datasheet of the PV inverter

3. To clarify with the factory

- Catalogue and technical datasheet of the PV inverter
- Importer-manufacturer agreement, signed and stamped, stating the PV inverter warranty period
- Test certificate to IEC 61727:2004 (utility interface characteristics), from an IECEE/IECRE-listed body
- Test certificate to IEC 62109-1:2010 AND IEC 62109-2:2011 (safety: general + inverter-particular), from an IECEE/IECRE-listed body
- Test certificate to IEC 62116:2014 (islanding prevention test procedure), from an IECEE/IECRE-listed body
- Test certificate to IEC 62891:2020 (MPPT efficiency of grid-connected inverters), from an IECEE/IECRE-listed body

Statuses: MET = standard found in the document. MISSING = required standard not present.
ASK_FACTORY = cannot be shown by this document type.