

Which issue should be investigated first?

La Haute Borne wind farm, 2015 assessment year. Independent analysis of public data. 30 September 2026.

Question. After validating the data, which issue should be investigated first, what is the potential exposure, how confident are we, and what operational information is required before anyone acts?

FIRST INVESTIGATION	DECISION EVIDENCE
R80711 42.5 hours 26 July 15:10 to 28 July 09:30 UTC	Potential shortfall 36.8-37.6 MWh Illustrative exposure EUR 1,842-4,513 at EUR 50-120/MWh All three analytical methods flag the event. Confidence is medium because no operational record exists.

The next step is a request for event codes and work orders covering that interval.

Potential shortfall is not confirmed recoverable energy. It is the gap between observed output and a statistical reference built from the same machines' own past. No cause has been established.

Validated energy accounting, 2015

Composition of gross positive residual shortfall



Persistent reviewable events

Non-persistent short dips

Potential shortfall is not confirmed recoverable energy.

Quantity	Value
Gross positive residual shortfall	671.6 MWh
Shortfall inside persistent reviewable events	380.8 MWh
Non-persistent shortfall (short dips)	290.8 MWh
Energy lost during missing data	unknown, not zero
Records that cannot be assessed	2,771

Only 57% of the gross figure sits inside reviewable events. Treating the headline as actionable would be the easiest mistake available here.

What changed after validation

Three things, none of which were visible in the raw data.

The timestamps were confidently wrong

They carry proper daylight-saving offsets, which makes them look reliable. Every local day held exactly 144 ten-minute records, including both clock-change days - which a daylight-saving logger cannot produce. The logger's clock never moved, so **every summer record sat one hour early**, about seven months of each year. Correcting it removed all 48 duplicate and all 48 absent intervals and closed a one-hour seasonal gap against independent reanalysis data.


The meter series is synthetic

The data publisher derived it from SCADA. That removed the one external cross-check normally available, so every check here is internal. It is a real limitation, not a presentational one.

Comparing each turbine against itself was hiding the fleet picture

R80711's own reference sits 11-19 kW below its neighbours, so judging it against its own history flattered it. Under a pooled fleet reference it moves from apparently well-behaved to the largest shortfall on the site. An earlier version of this analysis named R80790 as the turbine with the shallower curve. Measuring it directly showed the opposite, and the correction is recorded in the project history rather than edited away.

Figure 4: evidence for and against the timestamp correction (P-11)



Timestamp validation evidence: the one-hour correction closes the seasonal alignment gap and removes holes in the ten-minute sequence.

Recommended first investigation


R80711 produced almost nothing for 42.5 hours - **97.6% of records at or below zero, against an expected 901 kW** - while all three neighbouring turbines produced continuously at 724-840 kW in the same 5-12 m/s wind. In the preceding 48 hours R80711 was operating in line with expectation.

It is ranked first because it is large, corroborated by all three methods, discrete enough to investigate, carries no data-quality qualifications, and **one record request can resolve it**.

An important qualification

Removing this single event drops R80711 from 5.35% to 4.46% of potential, below R80790's 5.10%. R80711 leads the fleet-relative ranking largely because of this event, not because of a persistent pattern. R80790's more diffuse gap is a separate second line of enquiry.

Gross shortfall by turbine and method (% of potential)



Required next evidence

Turbine event and alarm codes for the interval; work orders and maintenance records; curtailment or grid instructions; operator logs. The site operations team normally holds the operating records, with curtailment records from the commercial team.

Five possible explanations fit the evidence equally well - planned maintenance, an unplanned fault stop, grid curtailment, a controller lockout awaiting manual reset, or a communications loss while the turbine was in fact running. **Nothing in this dataset can choose between them.** If the records show a planned outage, the item closes.

The three most important limitations

- 01 No event codes, work orders or curtailment records exist.** Every operational explanation is a hypothesis. No finding reaches validated on the project's evidence hierarchy.
- 02 No independent meter validation.** The supplied meter series is synthetic, so all verification is internal.
- 03 Four turbines, and 2015 data.** A pooled reference built from four machines is weak, a site-wide problem affecting all of them would remain invisible, and nothing here describes the site today.

[Open the full analysis, source tables and application instructions](#)

Data: ENGIE La Haute Borne, Etalab Open Licence 2.0, via the OpenOA repository (NatLabRockies/OpenOA). Independent project. No Clir Renewables data, software or methodology was used, and nothing here describes Clir, its platform or its customers. Prices are illustrative; no tariff, PPA or market price is known for this site.