TYPE TEST REPORT

Testing laboratory: Central Power Research Institute, Bhopal
NABL accreditation certificate no. TC-7741
Report no. CPRI/STDS/2023/4471 dated 08-09-2023

Equipment under test: 11kV Vacuum Circuit Breaker, type VCB-11-630-25

Short circuit breaking current test ? 25 kA for 3 seconds ? PASSED
Lightning impulse withstand test ? 75 kVp ? PASSED
Power frequency withstand test ? 28 kV for 1 minute ? PASSED
Temperature rise test ? within limits ? PASSED

The equipment complies with IS 13118 and IEC 62271-100.

For Central Power Research Institute
Authorised Signatory

FOR ABC SWITCHGEAR PVT LTD