TYPE TEST REPORT

Report No. PQR/TT/2023/0881
Tested at: Central Power Research Institute, Bhopal

NABL Accreditation Certificate No. TC-6612
Valid from 01-04-2021 to 31-03-2024

Report dated 14-11-2023

Tests carried out:

Short circuit breaking current test	25 kA, 1 sec
Lightning impulse withstand voltage test	75 kVp
Temperature rise test	within limits

Authorised Signatory
Laboratory Seal



FOR ABC SWITCHGEAR PVT LTD