DEVIATION SHEET

NIT No. BSES/EE/2026/014

The following deviation from the technical specification is recorded:

Clause 3.4 Table Sl. No. 2 Rated short circuit breaking current

Specification requirement : 25 kA for 3 seconds

Offered : 20 kA for 3 seconds

Justification : standard product range

All other clauses of the specification are complied with.

For and on behalf of XYZ Electricals Ltd

Authorised Signatory

Company Seal

FOR ABC SWITCHGEAR PVT LTD