TYPE TEST REPORT

Testing laboratory: Electrical Research and Development Association, Vadodara
NABL accreditation certificate no. TC-5588
Valid from 01-07-2022 to 30-06-2027
Report no. ERDA/TT/2024/1192 dated 22-02-2024

Equipment under test: 11kV Vacuum Circuit Breaker, type XE-11-800-20

Short circuit breaking current test ? 20 kA for 3 seconds ? PASSED
Lightning impulse withstand test ? 75 kVp ? PASSED
Power frequency withstand test ? 28 kV for 1 minute ? PASSED
Temperature rise test ? within limits ? PASSED

The equipment complies with IS 13118 and IEC 62271-100.

For Electrical Research and Development Association
Authorised Signatory

FOR ABC SWITCHGEAR PVT LTD