NOTICE INVITING TENDER

Supply of 11kV Vacuum Circuit Breaker Panels

Bidders are advised that the qualification requirements of this tender are strict, and that any bidder who fails to satisfy the qualification requirements stated elsewhere in this document shall not be considered for further technical evaluation by the purchaser. This paragraph is explanatory only and does not itself impose any requirement on the bidder.

Documents to be submitted with the offer:

a) Technical Offer, being this specification signed and stamped

b) Deviation Sheet

c) Guaranteed Technical Particulars

d) Type test reports from a NABL accredited laboratory

e) Audited balance sheets for the last three financial years

SECTION 2 ? QUALIFICATION REQUIREMENTS

2.1 The bidder shall have designed, manufactured and supplied not less than 200 numbers of 11kV Vacuum Circuit Breakers to any State Electricity Board or Distribution Licensee in India during the last five years.

2.2 The bidder shall have an average annual turnover of not less than Rs. 10 crore during the last three financial years.

2.3 The bidder shall own and operate an in-house routine testing facility at the manufacturing works, and shall furnish

photographic evidence and a list of test equipment with valid calibration certificates.

2.4 The bidder shall not have been blacklisted or debarred by any utility in India during the last three years, and shall furnish a self-declaration to that effect on company letterhead.

SECTION 3 ? TECHNICAL REQUIREMENTS

3.1 The circuit breaker shall conform in all respects to IS 13118 and IEC 62271-100, and to the latest amendments thereof.

3.2 The operating mechanism shall be of the motor wound spring charged type, suitable for both local and remote operation.

3.3 All type test reports submitted shall be not older than five years from the date of bid opening.

3.4 The following type tests shall have been carried out on the offered equipment: short circuit breaking current test, lightning impulse withstand test, power frequency withstand test and temperature rise test.

3.4 The equipment shall comply with the following technical parameters:

Sl. No.	Parameter	Required value
1	Rated voltage	11 kV
2	Rated short circuit breaking current	25 kA for 3 seconds
3	Rated frequency	50 Hz
4	Degree of protection of enclosure	IP 4X or better
5	Auxiliary supply voltage	110 V DC

Any deviation from the above parameters shall be listed in the Deviation Sheet. A Deviation Sheet marked NIL shall be taken to mean full compliance.

SECTION 4 ? TESTS

4.1 Routine tests shall be carried out on each circuit breaker in the presence of the purchaser's representative, and test certificates shall be submitted for approval before despatch.

4.2 The bidder shall submit a Quality Assurance Plan for approval within fifteen days of the date of the purchase order.

4.3 Any equipment failing a routine test shall be replaced at the bidder's cost.

SECTION 5 ? GUARANTEE

5.1 The equipment shall be guaranteed against defective design, material and workmanship for a period of 18 months from the date of commissioning or 24 months from the date of despatch, whichever is earlier.

5.2 The bidder shall furnish a performance bank guarantee for 10 percent of the order value, valid for the full guarantee period.