

GAS TURBINE GT-01 - MAINTENANCE MANUAL

Equipment Information

Equipment ID: GT-01

Equipment Type: Industrial Gas Turbine

Location: Process Area A

Manufacturer Reference: Synthetic Industrial Equipment

Normal Operating Conditions

Normal operating temperature range: 520°C to 560°C.

Warning temperature range: 561°C to 580°C.

Critical temperature: Above 580°C.

Normal vibration level: below 5 mm/s.

Maintenance Schedule

Routine inspection must be performed every 500 operating hours.

Intermediate maintenance must be performed every 2,000 operating hours.

Major maintenance must be performed every 4,000 operating hours.

Vibration Limits

Vibration below 5 mm/s is considered normal.

Vibration between 5 mm/s and 7 mm/s requires monitoring.

Vibration above 7 mm/s requires inspection of the bearings and rotor assembly.

Temperature Response

When temperature enters the warning range, the operator should increase monitoring frequency.

When temperature exceeds 580°C, the equipment is considered to be in a critical temperature condition.

A critical temperature condition requires controlled shutdown according to the safety procedure.

Maintenance Recommendation

If abnormal temperature and vibration are observed together, maintenance personnel should inspect the bearing system, rotor assembly, lubrication system, and relevant temperature sensors.

All maintenance actions must be recorded in the equipment maintenance log.