

# SIFY TECHNOCRAFT — DCIM EXECUTIVE REPORT

Generated Timestamp: 2026-07-07 05:32:13 | System Status: OPERATIONAL

## 1. Core Infrastructure Performance Metrics

| Metric KPI Identifier           | Current Telemetry Value |
|---------------------------------|-------------------------|
| Average Airflow Temperature     | 25.7 °C                 |
| Total Facility Grid Load        | 305.4 kW                |
| Power Usage Effectiveness (PUE) | 1.51                    |

## 2. Active Thermal Critical Hotspots (>28.0 °C)

| Target Rack ID | Triggered Core Temp |
|----------------|---------------------|
| 8H             | 30.9 °C             |
| 8A             | 28.5 °C             |
| 7C             | 30.3 °C             |
| 7B             | 30.4 °C             |