OpenDSS Type Library Documentation

June 24, 2014

Version 7.6.3.31

Enumerations

enum MonitorModes

Enum: dssVI = 0,

Monitor records Voltage and Current at the terminal (Default

Enum: **dssPower = 1,**

Monitor records kW, kvar or kVA, angle values, etc. at the terminal to which it is connected.

Enum: dssSequence = 16,

Reports the monitored quantities as sequence quantities

Enum: dssMagnitude = 32,

Reports the monitored quantities in Magnitude Only

Enum: dssPosOnly = 64,

Reports the Positive Seq only or avg of all phases

Enum: dssTaps = 2,

For monitoring Regulator and Transformer taps

Enum: dssStates = 3

For monitoring State Variables (for PC Elements only

enum SolveModes

Enum: dssSnapShot = 0,

Solve a single snapshot power flow

Enum: dssDutyCycle = 6,

Solve following Duty Cycle load shapes

Enum: dssDirect = 7,

Solve direct (forced admittance model

Enum: dssDaily = 1,

Solve following Daily load shapes

Enum: dssMonte1 = 3,

Monte Carlo Mode 1

Enum: dssMonte2 = 10,

Monte Carlo Mode 2

Enum: dssMonte3 = 11,

Monte Carlo Mode 3

Enum: dssFaultStudy = 9,

Fault study at all buses

Enum: dssYearly = 2,

Solve following Yearly load shapes

Enum: dssMonteFault = 8,

Monte carlo Fault Study

Enum: dssPeakDay = 5,

Solves for Peak Day using Daily load curve

Enum: **dssLD1 = 4**,

Load-duration Mode 1

Enum: **dssLD2 = 12**,

Load-Duration Mode 2

Enum: dssAutoAdd = 13,

Auto add generators or capacitors

Enum: dssHarmonic = 15,

(no Help string available)

Enum: dssDynamic = 14

(no Help string available)

enum Options

Enum: dssPowerFlow = 1,

Power Flow load model option

Enum: dssAdmittance = 2,

Admittance load model option

Enum: dssNormalSolve = 0,

Solution algorithm option - Normal solution mode

Enum: dssNewtonSolve = 1,

Solution algorithm option - Newton solution

Enum: dssStatic = 0,

Control Mode option - Static

Enum: **dssEvent = 1**,

Control Mode Option - Event driven solution mode

Enum: **dssTime = 2**,

Control mode option - Time driven mode

Enum: dssMultiphase = 0,

Circuit model is multiphase (default

Enum: dssPositiveSeq = 1,

Circuit model is positive sequence model only

Enum: **dssGaussian = 1,**

Random mode = Gaussian

Enum: **dssUniform = 2**,

Random mode = Uniform

Enum: dssLogNormal = 3,

Random Mode = Log normal

Enum: dssAddGen = 1,

Add generators in AutoAdd mode (AddType

Enum: dssAddCap = 2

Add capacitors in AutoAdd mode (Addtype

enum CapControlModes

Enum: dssCapControlVoltage = 1,

voltage control, ON and OFF settings on the PT secondary base

Enum: dssCapControlKVAR = 2,

kVAR control, ON and OFF settings on PT / CT base

Enum: dssCapControlCurrent = 0,

Current control, ON and OFF settings on CT secondary

Enum: dssCapControlPF = 4,

ON and OFF settings are power factor, negative for leading

Enum: dssCapControlTime = 3

Time control, ON and OFF settings are seconds from midnight

enum ActionCodes

Enum: dssActionNone = 0,

No action

Enum: dssActionOpen = 1,

Open a switch

Enum: **dssActionClose = 2,**

Close a switch

Enum: dssActionReset = 3,

Reset to the shelf state (unlocked, closed for a switch

Enum: dssActionLock = 4,

Lock a switch, prventing both manual and automatic operation

Enum: dssActionUnlock = 5,

Unlock a switch, permitting both manual and automatic operation

Enum: dssActionTapUp = 6,

Move a regulator tap up

Enum: dssActionTapDown = 7

Move a regulator tap down

enum LoadStatus

Enum: dssLoadVariable = 0,

(no Help string available)

Enum: **dssLoadFixed = 1**,

(no Help string available)

Enum: **dssLoadExempt = 2** (no Help string available)

enum LoadModels

Enum: **dssLoadConstPQ = 1,** (no Help string available)

Enum: **dssLoadConstZ = 2,** (no Help string available)

Enum: **dssLoadMotor = 3,** (no Help string available)

Enum: **dssLoadCVR = 4,** (no Help string available)

Enum: **dssLoadConstl = 5,** (no Help string available)

Enum: **dssLoadConstPFixedQ = 6,** (no Help string available)

Enum: **dssLoadConstPFixedX = 7,** (no Help string available)

Enum: **dssLoadZIPV** = **8** (no Help string available)

enum LineUnits

Enum: **dssLineUnitsNone = 0,** *No line length unit.*

Enum: **dssLineUnitsMiles = 1,** Line length units in miles.

Enum: **dssLineUnitskFt = 2,**Line length units are in thousand feet.

Enum: **dssLineUnitskm = 3**,

Line length units are km.

Enum: **dssLineUnitsmeter = 4,** *Line length units are meters.*

Enum: **dssLineUnitsft = 5,** *Line units in feet.*

Enum: **dssLineUnitsinch = 6,** *Line length units are inches.*

Enum: **dssLineUnitscm = 7,** *Line units are cm.*

Enum: **dssLineUnitsmm = 8,** *Line length units are mm.*

Enum: **dssLineUnitsMaxnum = 9** *Maximum number of line units constants.*

Interfaces

Text Interface

Property (get): **value = Command** [out, retval] Type: BSTR* Command Input command string for the DSS.

Property (put): **Command = value [in] Type: BSTR Command** *Input command string for the DSS.*

Property (get): **value = Result [out, retval] Type: BSTR* Result**Result string for the last command.

DSSProperty Interface

Property (get): value = Name [out, retval] Type: BSTR* Name Name of Property

Property (get): value = Description [out, retval] Type: BSTR* Description Description of the property.

Property (get): value = Val [out, retval] Type: BSTR* Value (no Help string available)

Property (put): Val = value [in] Type: BSTR Value (no Help string available)

CktElement Interface

Property (get): value = Name [out, retval] Type: BSTR* Value Full Name of Active Circuit Element

Property (get): value = NumTerminals [out, retval] Type: long* Value Number of Terminals this Circuit Element

Property (get): value = NumConductors [out, retval] Type: long* Value Number of Conductors per Terminal

Property (get): value = NumPhases [out, retval] Type: long* Value Number of Phases

Property (get): value = BusNames [out, retval] Type: VARIANT* Value

Variant array of strings. Get Bus definitions to which each terminal is connected. 0-based array.

Property (put): **BusNames = value [in] Type: VARIANT Value**Variant array of strings. Set Bus definitions for each terminal is connected.

Property (get): value = Properties [in] Type: VARIANT Indx, [out, retval] Type: IDSSProperty** Value

Collection of Properties for this Circuit Element (0 based index, if numeric

Property (get): value = Voltages [out, retval] Type: VARIANT* Value Complex array of voltages at terminals

Property (get): value = Currents [out, retval] Type: VARIANT* Value Complex array of currents into each conductor of each terminal

Property (get): value = Powers [out, retval] Type: VARIANT* Value Complex array of powers into each conductor of each terminal

Property (get): value = Losses [out, retval] Type: VARIANT* Value Total losses in the element: two-element complex array

Property (get): value = PhaseLosses [out, retval] Type: VARIANT* Value Complex array of losses by phase

Property (get): value = SeqVoltages [out, retval] Type: VARIANT* Value

Double array of symmetrical component voltages at each 3-phase terminal

Property (get): **value = SeqCurrents** [out, retval] Type: VARIANT* Value

Double array of symmetrical component currents into each 3-phase terminal

Property (get): value = SeqPowers [out, retval] Type: VARIANT* Value Double array of sequence powers into each 3-phase teminal

Property (get): **value = Enabled** [out, retval] Type: VARIANT_BOOL* Value Boolean indicating that element is currently in the circuit.

Property (put): **Enabled = value [in] Type: VARIANT_BOOL Value**Boolean indicating that element is currently in the circuit.

Property (get): value = NormalAmps [out, retval] Type: double* Value
Normal ampere rating for PD Elements

Property (put): **NormalAmps = value [in] Type: double Value** *Normal ampere rating*

Property (get): value = EmergAmps [out, retval] Type: double* Value

Emergency Ampere Rating for PD elements

Property (put): EmergAmps = value [in] Type: double Value

Emergency Ampere Rating

Method: Open [in] Type: long Term, [in] Type: long Phs

Open the specified terminal and phase, if non-zero. Else all conductors at terminal.

Method: Close [in] Type: long Term, [in] Type: long Phs

Close the specified terminal and phase, if non-zero. Else all conductors at terminal.

Method: IsOpen [in] Type: long Term, [in] Type: long Phs, [out, retval] Type:

VARIANT_BOOL* Value

Boolean indicating if the specified terminal and, optionally, phase is open.

Property (get): value = NumProperties [out, retval] Type: long* Value

Number of Properties this Circuit Element.

Property (get): value = AllPropertyNames [out, retval] Type: VARIANT* Value

Variant array containing all property names of the active device.

Property (get): value = Residuals [out, retval] Type: VARIANT* Value

Residual currents for each terminal: (mag, angle

Property (get): value = Yprim [out, retval] Type: VARIANT* Value

YPrim matrix, column order, complex numbers (paired

Property (get): value = DisplayName [out, retval] Type: BSTR* Value

Display name of the object (not necessarily unique

Property (put): DisplayName = value [in] Type: BSTR Value

Display name of the object (not necessarily unique

Property (get): value = Handle [out, retval] Type: long* Value

Pointer to this object

Property (get): value = GUID [out, retval] Type: BSTR* Value

globally unique identifier for this object

Property (get): value = HasSwitchControl [out, retval] Type: VARIANT_BOOL* Value

This element has a SwtControl attached.

Property (get): value = HasVoltControl [out, retval] Type: VARIANT_BOOL* Value

This element has a CapControl or RegControl attached.

Property (get): value = EnergyMeter [out, retval] Type: BSTR* Value Name of the Energy Meter this element is assigned to.

Property (get): value = Controller [in] Type: long idx, [out, retval] Type: BSTR* Value Full name of the i-th controller attached to this element. Ex: str = Controller(2

Property (get): value = CplxSeqVoltages [out, retval] Type: VARIANT* Value

Complex double array of Sequence Voltage for all terminals of active circuit element.

Property (get): value = CplxSeqCurrents [out, retval] Type: VARIANT* Value

Complex double array of Sequence Currents for all conductors of all terminals of active circuit element.

Property (get): **value = AllVariableNames** [out, retval] Type: VARIANT* Value

Variant array of strings listing all the published variable names, if a PCElement. Otherwise, null string.

Property (get): value = AllVariableValues [out, retval] Type: VARIANT* Value Variant array of doubles. Values of state variables of active element if PC element.

Property (get): value = Variable [in] Type: BSTR MyVarName, [out] Type: long* Code, [out, retval] Type: double* Value

For PCElement, get the value of a variable by name. If Code>0 Then no variable by this name or not a PCelement.

Property (get): value = Variablei [in] Type: long ldx, [out] Type: long* Code, [out, retval] Type: double* Value

For PCElement, get the value of a variable by integer index.

Property (get): value = NodeOrder [out, retval] Type: VARIANT* Value

Variant array of integer containing the node numbers (representing phases, for example

Property (get): value = HasOCPDevice [out, retval] Type: VARIANT_BOOL* Value

True if a recloser, relay, or fuse controlling this ckt element. OCP = Overcurrent Protection

Property (get): value = NumControls [out, retval] Type: long* Value

Number of controls connected to this device. Use to determine valid range for index into

Controller array.

Property (get): value = OCPDevIndex [out, retval] Type: long* Value Index into Controller list of OCP Device controlling this CktElement

Property (get): **value = OCPDevType** [out, retval] Type: long* Value 0=None; 1=Fuse; 2=Recloser; 3=Relay; Type of OCP controller device

Property (get): **value = CurrentsMagAng** [out, retval] Type: VARIANT* Value Currents in magnitude, angle format as a variant array of doubles.

Property (get): value = VoltagesMagAng [out, retval] Type: VARIANT* Value Voltages at each conductor in magnitude, angle form as variant array of doubles.

Error Interface

Property (get): value = Number [out, retval] Type: long* Number Error Number

Property (get): value = Description [out, retval] Type: BSTR* Description Description of error for last operation

Circuit Interface

Property (get): value = Name [out, retval] Type: BSTR* Value Name of the active circuit.

Property (get): value = NumCktElements [out, retval] Type: long* Value Number of CktElements in the circuit.

Property (get): value = NumBuses [out, retval] Type: long* Value Total number of Buses in the circuit.

Property (get): value = NumNodes [out, retval] Type: long* Value Total number of nodes in the circuit.

Property (get): value = Buses [in] Type: VARIANT Index, [out, retval] Type: IBus** Value Collection of Buses in the circuit. Index may be string or integer index (0 based

Property (get): value = CktElements [in] Type: VARIANT Idx, [out, retval] Type: ICktElement**
Value

Collection of CktElements in Circuit

Property (get): value = Losses [out, retval] Type: VARIANT* Value

Total losses in active circuit, complex number (two-element array of double

Property (get): value = LineLosses [out, retval] Type: VARIANT* Value Complex total line losses in the circuit

Property (get): value = SubstationLosses [out, retval] Type: VARIANT* Value Complex losses in all transformers designated to substations.

Property (get): value = TotalPower [out, retval] Type: VARIANT* Value Total power, watts delivered to the circuit

Property (get): value = AllBusVolts [out, retval] Type: VARIANT* Value Complex array of all bus, node voltages from most recent solution

Property (get): value = AllBusVmag [out, retval] Type: VARIANT* Value Array of magnitudes (doubles

Property (get): value = AllElementNames [out, retval] Type: VARIANT* Value Vaiant array of strings containing Full Name of all elements.

Property (get): value = ActiveElement [out, retval] Type: ICktElement** Value Return an interface to the active circuit element

Method: **Disable [in] Type: BSTR Name**Disable a circuit element by name (removes from circuit but leave in database

Method: **Enable** [in] Type: BSTR Name *Activate* (enable

Property (get): **value = Solution** [out, retval] Type: ISolution** Value Return an interface to the Solution object.

Property (get): value = ActiveBus [out, retval] Type: IBus** Value Return an interface to the active bus.

Method: FirstPCElement [out, retval] Type: long* Value Sets the first Power Conversion (PC

Method: **NextPCElement** [out, retval] Type: long* Value Gets next PC Element. Returns 0 if no more.

Method: FirstPDElement [out, retval] Type: long* Value Sets the first Power Delivery (PD

Method: **NextPDElement** [out, retval] Type: long* Value Gets next PD Element. Returns 0 if no more.

Property (get): value = AllBusNames [out, retval] Type: VARIANT* Value Array of strings containing names of all buses in circuit (see AllNodeNames

Property (get): value = AllElementLosses [out, retval] Type: VARIANT* Value

Array of total losses (complex

Method: Sample [void

Force all Meters and Monitors to take a sample.

Method: SaveSample [void

Force all meters and monitors to save their current buffers.

Property (get): value = Monitors [out, retval] Type: IMonitors** Value

Returns interface to Monitors collection.

Property (get): value = Meters [out, retval] Type: IMeters** Value

Returns interface to Meters (EnergyMeter

Property (get): value = Generators [out, retval] Type: IGenerators** Value

Returns a Generators Object interface

Property (get): value = Settings [out, retval] Type: ISettings** Value

Returns interface to Settings interface.

Property (get): value = Lines [out, retval] Type: ILines** Value

Returns Interface to Lines collection.

Method: SetActiveElement [in] Type: BSTR FullName, [out, retval] Type: long* Value

Sets the Active Circuit Element using the full object name (e.g. \i0

Method: Capacity [in] Type: double Start, [in] Type: double Increment, [out, retval] Type:

double* Value

(no Help string available)

Method: SetActiveBus [in] Type: BSTR BusName, [out, retval] Type: long* Value

Sets Active bus by name. Ignores node list. Returns bus index (zero based

Method: SetActiveBusi [in] Type: long BusIndex, [out, retval] Type: long* Value

Sets ActiveBus by Integer value. 0-based index compatible with SetActiveBus return value and

AllBusNames indexing. Returns 0 if OK.

Property (get): value = AllBusVmagPu [out, retval] Type: VARIANT* Value

Double Array of all bus voltages (each node

Property (get): value = AllNodeNames [out, retval] Type: VARIANT* Value

Variant array of strings containing full name of each node in system in same order as returned by

AllBusVolts, etc.

Property (get): value = SystemY [out, retval] Type: VARIANT* Value System Y matrix (after a solution has been performed

Property (get): value = CtrlQueue [out, retval] Type: ICtrlQueue** Value Interface to the main Control Queue

Property (get): value = AllBusDistances [out, retval] Type: VARIANT* Value
Returns distance from each bus to parent EnergyMeter. Corresponds to sequence in
AllBusNames.

Property (get): **value = AllNodeDistances** [out, retval] Type: VARIANT* Value
Returns an array of distances from parent EnergyMeter for each Node. Corresponds to
AllBusVMag sequence.

Property (get): value = AllNodeVmagByPhase [in] Type: long Phase, [out, retval] Type: VARIANT* Value

Returns Array of doubles represent voltage magnitudes for nodes on the specified phase.

Property (get): value = AllNodeVmagPUByPhase [in] Type: long Phase, [out, retval] Type: VARIANT* Value

Returns array of per unit voltage magnitudes for each node by phase

Property (get): value = AllNodeDistancesByPhase [in] Type: long Phase, [out, retval] Type: VARIANT* Value

Returns an array of doubles representing the distances to parent EnergyMeter. Sequence of array corresponds to other node ByPhase properties.

Property (get): value = AllNodeNamesByPhase [in] Type: long Phase, [out, retval] Type: VARIANT* Value

Return variant array of strings of the node names for the By Phase criteria. Sequence corresponds to other ByPhase properties.

Property (get): value = Loads [out, retval] Type: ILoads** Value Returns interface to Load element interface

Method: FirstElement [out, retval] Type: long* Value

Sets First element of active class to be the Active element in the active circuit. Returns 0 if none.

Method: NextElement [out, retval] Type: long* Value

Sets the next element of the active class to be the active element in the active circuit. Returns 0 if

no more elements.

Method: **SetActiveClass** [in] **Type: BSTR ClassName, [out, retval] Type: long* Value**Sets the active class by name. Use FirstElement, NextElement to iterate through the class.
Returns -1 if fails.

Property (get): value = ActiveDSSElement [out, retval] Type: IDSSElement** Value
Returns Interface to the Active DSS object, which could be either a circuit element or a general
DSS element.

Property (get): value = ActiveCktElement [out, retval] Type: ICktElement** Value Returns interface to the Active Circuit element (same as ActiveElement

Property (get): value = ActiveClass [out, retval] Type: IActiveClass** Value Returns interface to active class.

Property (get): value = Transformers [out, retval] Type: ITransformers** Value Returns interface to Transformers collection

Property (get): **value = SwtControls** [out, retval] Type: ISwtControls** Value Returns interface to SwtControls collection.

Property (get): value = CapControls [out, retval] Type: ICapControls** Value Returns interface to CapControls collection

Property (get): value = RegControls [out, retval] Type: IRegControls** Value Returns interfact to RegControls collection

Property (get): value = Capacitors [out, retval] Type: ICapacitors** Value Interface to the active circuit's Capacitors collection.

Property (get): value = Topology [out, retval] Type: ITopology** Value Interface to the active circuit's topology object.

Property (get): value = Sensors [out, retval] Type: ISensors** Value Interface to Sensors in the Active Circuit.

Method: UpdateStorage [void

Forces update to all storage classes. Typically done after a solution. Done automatically in intrinsic solution modes.

Property (get): value = ParentPDElement [out, retval] Type: long* Value

Sets Parent PD element, if any, to be the active circuit element and returns index>0; Returns 0 if it

fails or not applicable.

Property (get): value = XYCurves [out, retval] Type: IXYCurves** Value Interface to XYCurves in active circuit.

Property (get): value = PDElements [out, retval] Type: IPDElements** Value Interface to PDElements collection

Property (get): value = Reclosers [out, retval] Type: IReclosers** Value (no Help string available)

Property (get): value = Relays [out, retval] Type: IRelays** Value (no Help string available)

Property (get): value = LoadShapes [out, retval] Type: ILoadShapes** Value Interface to OpenDSS Load shapes currently defined.

Property (get): value = Fuses [out, retval] Type: Fuses** Value Return interface to Fuses

Property (get): value = Isources [out, retval] Type: IlSources** Value Interface to ISOURCE devices

Bus Interface

Property (get): value = Name [out, retval] Type: BSTR* Name Name of Bus

Property (get): value = NumNodes [out, retval] Type: long* NumNodes Number of Nodes this bus.

Property (get): value = Voltages [out, retval] Type: VARIANT* Voltages Complex array of voltages at this bus.

Property (get): **value = SeqVoltages** [out, retval] Type: VARIANT* SeqVoltages Double Array of sequence voltages at this bus.

Property (get): value = Nodes [out, retval] Type: VARIANT* Nodes
Integer Array of Node Numbers defined at the bus in same order as the voltages.

Property (get): value = Voc [out, retval] Type: VARIANT* Voc Open circuit voltage; Complex array.

Property (get): value = Isc [out, retval] Type: VARIANT* Isc

Short circuit currents at bus; Complex Array.

Property (get): value = puVoltages [out, retval] Type: VARIANT* Value Complex Array of pu voltages at the bus.

Property (get): value = kVBase [out, retval] Type: double* Value Base voltage at bus in kV

Property (get): value = ZscMatrix [out, retval] Type: VARIANT* Value Complex array of Zsc matrix at bus. Column by column.

Property (get): value = Zsc1 [out, retval] Type: VARIANT* Value Complex Positive-Sequence short circuit impedance at bus..

Property (get): value = Zsc0 [out, retval] Type: VARIANT* Value Complex Zero-Sequence short circuit impedance at bus.

Method: **ZscRefresh** [out, retval] Type: VARIANT_BOOL* Value Recomputes Zsc for active bus for present circuit configuration.

Property (get): value = YscMatrix [out, retval] Type: VARIANT* Value Complex array of Ysc matrix at bus. Column by column.

Property (get): value = Coorddefined [out, retval] Type: VARIANT_BOOL* Value False=0 else True. Indicates whether a coordinate has been defined for this bus

Property (get): value = x [out, retval] Type: double* Value X Coordinate for bus (double

Property (put): **x = value [in] Type: double Value** *X Coordinate for bus (double*

Property (get): value = y [out, retval] Type: double* Value Y coordinate for bus(double

Property (put): **y = value [in] Type: double Value** *Y coordinate for bus(double*

Property (get): value = Distance [out, retval] Type: double* Value Distance from energymeter (if non-zero

Method: GetUniqueNodeNumber [in] Type: long StartNumber, [out, retval] Type: long* Value

Returns a unique node number at the active bus to avoid node collisions and adds it to the node

list for the bus.

Property (get): value = CplxSeqVoltages [out, retval] Type: VARIANT* Value Complex Double array of Sequence Voltages (0, 1, 2

Property (get): value = Lambda [out, retval] Type: double* Value Accumulated failure rate downstream from this bus; faults per year

Property (get): value = N_interrupts [out, retval] Type: double* Value Number of interruptions this bus per year

Property (get): **value = Int_Duration** [out, retval] Type: double* Value Average interruption duration, hr.

Property (get): value = Cust_Interrupts [out, retval] Type: double* Value Annual number of customer-interruptions from this bus

Property (get): value = Cust_Duration [out, retval] Type: double* Value Accumulated customer outage durations

Property (get): value = N_Customers [out, retval] Type: long* Value Total numbers of customers served downline from this bus

Property (get): **value = VLL [out, retval] Type: VARIANT* Value**For 2- and 3-phase buses, returns variant array of complex numbers represetin L-L voltages in volts. Returns -1.0 for 1-phase bus. If more than 3 phases, returns only first 3.

Property (get): value = puVLL [out, retval] Type: VARIANT* Value

Returns Complex array of pu L-L voltages for 2- and 3-phase buses. Returns -1.0 for 1-phase bus.

If more than 3 phases, returns only 3 phases.

Property (get): value = VMagAngle [out, retval] Type: VARIANT* Value Variant Array of doubles containing voltages in Magnitude (VLN

Property (get): value = puVmagAngle [out, retval] Type: VARIANT* Value Variant array of doubles containig voltage magnitude, angle pairs in per unit

DSS Interface

Property (get): value = NumCircuits [out, retval] Type: long* Value Number of Circuits currently defined

Property (get): value = Circuits [in] Type: VARIANT Idx, [out, retval] Type: ICircuit** Value

Collection of Circuit objects

Property (get): value = ActiveCircuit [out, retval] Type: ICircuit** Value Returns interface to the active circuit.

Property (get): value = Text [out, retval] Type: IText** Value Returns the DSS Text (command-result

Property (get): value = Error [out, retval] Type: IError** Value Returns Error interface.

Method: NewCircuit [in] Type: BSTR Name, [out, retval] Type: ICircuit** Value Make a new circuit and return interface to active circuit.

Method: **ClearAll [void** Clears all circuit definitions.

Method: **ShowPanel [void**Shows non-MDI child form of the Main DSS Edit Form

Method: **Start** [in] Type: long code, [out, retval] Type: VARIANT_BOOL* Value Validate the user and start the DSS. Returns TRUE if successful.

Property (get): value = Version [out, retval] Type: BSTR* Value Get version string for the DSS.

Property (get): value = DSSProgress [out, retval] Type: IDSSProgress** Value Gets interface to the DSS Progress Meter

Property (get): value = Classes [out, retval] Type: VARIANT* Value List of DSS intrinsic classes (names of the classes

Property (get): value = UserClasses [out, retval] Type: VARIANT* Value List of user-defined classes

Property (get): value = NumClasses [out, retval] Type: long* Value Number of DSS intrinsic classes

Property (get): value = NumUserClasses [out, retval] Type: long* Value Number of user-defined classes

Property (get): value = DataPath [out, retval] Type: BSTR* Value DSS Data File Path. Default path for reports, etc. from DSS

Property (put): DataPath = value [in] Type: BSTR Value

DSS Data File Path. Default path for reports, etc. from DSS

Method: Reset [void

Resets DSS Initialization for restarts, etc from applets

Property (get): value = AllowForms [out, retval] Type: VARIANT_BOOL* Value

Default is TRUE. Use this to set to FALSE; Cannot reset to TRUE;

Property (put): AllowForms = value [in] Type: VARIANT_BOOL Value

Default is TRUE. Use this to set to FALSE; Cannot reset to TRUE;

Property (get): value = DefaultEditor [out, retval] Type: BSTR* Value

Returns the path name for the default text editor.

Property (get): value = ActiveClass [out, retval] Type: IActiveClass** Value

Returns interface to the active class.

Method: SetActiveClass [in] Type: BSTR ClassName, [out, retval] Type: long* Value

Sets the Active DSS Class for use with ActiveClass interface. Same as SetActiveClass in Circuit

interface.

Property (get): value = Executive [out, retval] Type: IDSS_Executive** Value

Interface to DSS Executive commands and options

Property (get): value = Events [out, retval] Type: IDSSEvents** Value

Interface to the DSS Events

Property (get): value = CmathLib [out, retval] Type: ICmathLib** Value

Returns an interface to the complex math library.

Property (get): value = Parser [out, retval] Type: IParser** Value

Returns interface to the OpenDSS Parser library for use by user-written programs.

Solution Interface

Method: Solve [void

Execute solution for present solution mode.

Property (get): value = Mode [out, retval] Type: long* Mode

Set present solution mode (by a text code - see DSS Help

Property (put): Mode = value [in] Type: long Mode

Set present solution mode (by a text code - see DSS Help

Property (get): value = Frequency [out, retval] Type: double* Frequency Set the Frequency for next solution

Property (put): **Frequency = value [in] Type: double Frequency**Set the Frequency for next solution

Property (get): value = Hour [out, retval] Type: long* Hour Set Hour for time series solutions.

Property (put): **Hour = value [in] Type: long Hour** *Set Hour for time series solutions.*

Property (get): **value = Seconds** [out, retval] Type: double* Seconds Seconds from top of the hour.

Property (put): **Seconds = value [in] Type: double Seconds** *Seconds from top of the hour.*

Property (get): value = StepSize [out, retval] Type: double* StepSize Time step size in sec

Property (put): **StepSize = value [in] Type: double StepSize** *Time step size in sec*

Property (get): value = Year [out, retval] Type: long* Year Set year for planning studies

Property (put): **Year = value [in] Type: long Year**Set year for planning studies

Property (get): value = LoadMult [out, retval] Type: double* LoadMult Default load multiplier applied to all non-fixed loads

Property (put): **LoadMult = value [in] Type: double LoadMult**Default load multiplier applied to all non-fixed loads

Property (get): value = Iterations [out, retval] Type: long* Iterations Number of iterations taken for last solution. (Same as TotalIterations

Property (get): value = MaxIterations [out, retval] Type: long* MaxIterations Max allowable iterations.

Property (put): **MaxIterations = value [in] Type: long MaxIterations** *Max allowable iterations.*

Property (get): value = Tolerance [out, retval] Type: double* Tolerance Solution convergence tolerance.

Property (put): **Tolerance = value [in] Type: double Tolerance** *Solution convergence tolerance.*

Property (get): value = Number [out, retval] Type: long* Number

Number of solutions to perform for Monte Carlo and time series simulations

Property (put): **Number = value [in] Type: long Number**Number of solutions to perform for Monte Carlo and time series simulations

Property (get): value = Random [out, retval] Type: long* Random Randomization mode for random variables \i0

Property (put): Random = value [in] Type: long Random Randomization mode for random variables \iO

Property (get): value = ModeID [out, retval] Type: BSTR* Value ID (text

Property (get): value = LoadModel [out, retval] Type: long* Value Load Model: dssPowerFlow (default

Property (put): LoadModel = value [in] Type: long Value Load Model: dssPowerFlow (default

Property (get): value = LDCurve [out, retval] Type: BSTR* Value Load-Duration Curve name for LD modes

Property (put): **LDCurve = value [in] Type: BSTR Value**Load-Duration Curve name for LD modes

Property (get): value = pctGrowth [out, retval] Type: double* Value Percent default annual load growth rate

Property (put): **pctGrowth = value [in] Type: double Value**Percent default annual load growth rate

Property (get): value = AddType [out, retval] Type: long* Value
Type of device to add in AutoAdd Mode: dssGen (Default

Property (put): AddType = value [in] Type: long Value Type of device to add in AutoAdd Mode: dssGen (Default

Property (get): value = GenkW [out, retval] Type: double* Value Generator kW for AutoAdd mode

Property (put): **GenkW = value [in] Type: double Value** *Generator kW for AutoAdd mode*

Property (get): value = GenPF [out, retval] Type: double* Value PF for generators in AutoAdd mode

Property (put): **GenPF = value [in] Type: double Value**PF for generators in AutoAdd mode

Property (get): value = Capkvar [out, retval] Type: double* Value Capacitor kvar for adding capacitors in AutoAdd mode

Property (put): **Capkvar = value [in] Type: double Value**Capacitor kvar for adding capacitors in AutoAdd mode

Property (get): value = Algorithm [out, retval] Type: long* Value
Base Solution algorithm: dssNormalSolve | dssNewtonSolve

Property (put): Algorithm = value [in] Type: long Value

Base Solution algorithm: dssNormalSolve | dssNewtonSolve

Property (get): value = ControlMode [out, retval] Type: long* Value dssStatic* | dssEvent | dssTime Modes for control devices

Property (put): **ControlMode = value [in] Type: long Value** dssStatic* | dssEvent | dssTime Modes for control devices

Property (get): value = GenMult [out, retval] Type: double* Value
Default Multiplier applied to generators (like LoadMult

Property (put): **GenMult = value [in] Type: double Value**Default Multiplier applied to generators (like LoadMult

Property (get): value = DefaultDaily [out, retval] Type: BSTR* Value Default daily load shape (defaults to \i0

Property (put): **DefaultDaily = value [in] Type: BSTR Value**Default daily load shape (defaults to \i0

Property (get): value = DefaultYearly [out, retval] Type: BSTR* Value
Default Yearly load shape (defaults to \i0

Property (put): DefaultYearly = value [in] Type: BSTR Value

Default Yearly load shape (defaults to \i0

Property (get): value = EventLog [out, retval] Type: VARIANT* Value

Array of strings containing the Event Log

Property (get): value = dblHour [out, retval] Type: double* Value

Hour as a double, including fractional part

Property (put): dblHour = value [in] Type: double Value

Hour as a double, including fractional part

Property (put): StepsizeMin = value [in] Type: double Param1

Set Stepsize in minutes

Property (put): StepsizeHr = value [in] Type: double Param1

Set Stepsize in Hr

Property (get): value = Controllterations [out, retval] Type: long* Value

Value of the control iteration counter

Property (put): Controllterations = value [in] Type: long Value

Value of the control iteration counter

Property (get): value = MaxControllterations [out, retval] Type: long* Value

Maximum allowable control iterations

Property (put): MaxControllterations = value [in] Type: long Value

Maximum allowable control iterations

Method: Sample_DoControlActions [void

Sample controls and then process the control queue for present control mode and dispatch

control actions

Method: CheckFaultStatus [void

Executes status check on all fault objects defined in the circuit.

Method: SolveSnap [void

Execute the snapshot power flow routine in the DSS that solves at the present state with control

actions

Method: SolveDirect [void

Executes a direct solution from the system Y matrix, ignoring compensation currents of loads,

generators (includes Yprim only

Method: SolvePflow [void

Solves using present power flow method. Iterative solution rather than direct solution.

Method: SolveNoControl [void

Similar to SolveSnap except no control actions are checked or executed

Method: SolvePlusControl [void

Executes a power flow solution (SolveNoControl

Method: InitSnap [void

Initializes some variables for snap shot power flow. SolveSnap does this automatically.

Method: CheckControls [void

The normal process for sampling and executing Control Actions and Fault Status and rebuilds Y if necessary.

Method: SampleControlDevices [void

Executes a sampling of all intrinsic control devices, which push control actions onto the control queue.

Method: DoControlActions [void

Pops control actions off the control queue and dispatches to the proper control element

Method: **BuildYMatrix** [in] Type: long BuildOption, [in] Type: long AllocateVI Force building of the System Y matrix

Property (get): value = SystemYChanged [out, retval] Type: VARIANT_BOOL* Value Flag that indicates if elements of the System Y have been changed by recent activity.

Property (get): value = Converged [out, retval] Type: VARIANT_BOOL* Value Flag to indicate whether the circuit solution converged

Property (put): **Converged = value [in] Type: VARIANT_BOOL Value**Flag to indicate whether the circuit solution converged

Property (get): value = Totaliterations [out, retval] Type: long* Value Total iterations including control iterations for most recent solution.

Property (get): value = MostIterationsDone [out, retval] Type: long* Value

Max number of iterations required to converge at any control iteration of the most recent solution.

Property (get): **value = ControlActionsDone** [out, retval] Type: VARIANT_BOOL* Value Flag indicating the control actions are done.

Property (put): **ControlActionsDone = value [in] Type: VARIANT_BOOL Value** (no Help string available)

Monitors Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Array of all Monitor Names

Property (get): value = First [out, retval] Type: long* Value Sets the first Monitor active. Returns 0 if no monitors.

Property (get): value = Next [out, retval] Type: long* Value Sets next monitor active. Returns 0 if no more.

Method: **Reset [void** *Resets active Monitor object.*

Method: **ResetAll [void** *Resets all Monitor Objects*

Method: Sample [void

Causes active Monitor to take a sample.

Method: Save [void

Causes active monitor to save its current sample buffer to its monitor stream. Then you can access the Bytestream or channel data. Most standard solution modes do this automatically.

Method: Show [void

Converts monitor file to text and displays with text editor

Property (get): value = FileName [out, retval] Type: BSTR* Value

Name of CSV file associated with active Monitor.

Property (get): value = Mode [out, retval] Type: long* Value

Set Monitor mode (bitmask integer - see DSS Help

Property (put): **Mode = value [in] Type: long Value**Set Monitor mode (bitmask integer - see DSS Help

Property (get): value = Name [out, retval] Type: BSTR* Value

Sets the active Monitor object by name

Property (put): Name = value [in] Type: BSTR Value

Sets the active Monitor object by name

Property (get): value = ByteStream [out, retval] Type: VARIANT* Value

Byte Array containing monitor stream values. Make sure a \i0

Property (get): value = SampleCount [out, retval] Type: long* Value

Number of Samples in Monitor at Present

Method: SampleAll [void

Causes all Monitors to take a sample of the present state

Method: SaveAll [void

Save all Monitor buffers to their respective file streams.

Property (get): value = Count [out, retval] Type: long* Value

Number of Monitors

Method: Process [void

Post-process monitor samples taken so far, e.g., Pst for mode=4

Method: ProcessAll [void

All monitors post-process the data taken so far.

Property (get): value = FileVersion [out, retval] Type: long* Value

Monitor File Version (integer

Property (get): value = RecordSize [out, retval] Type: long* Value

Size of each record in ByteStream (Integer

Property (get): value = Header [out, retval] Type: VARIANT* Value

Header string; Variant array of strings containing Channel names

Property (get): value = dblHour [out, retval] Type: VARIANT* Value

Variant array of doubles containgin time value in hours for time-sampled monitor values; Empty

if frequency-sampled values for harmonics solution (see dblFreq

Property (get): value = dblFreq [out, retval] Type: VARIANT* Value

Variant array of doubles containing frequency values for harmonics mode solutions; Empty for

time mode solutions (use dblHour

Property (get): value = Channel [in] Type: long Index, [out, retval] Type: VARIANT* Value

Variant array of doubles for the specified channel (usage: MyArray = DSSMonitor.Channel(i

Property (get): value = NumChannels [out, retval] Type: long* Value Number of Channels in the active Monitor

Meters Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Array of all energy Meter names

Property (get): value = First [out, retval] Type: long* Value Set the first energy Meter active. Returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value Sets the next energy Meter active. Returns 0 if no more.

Property (get): value = RegisterNames [out, retval] Type: VARIANT* Value Array of strings containing the names of the registers.

Property (get): value = RegisterValues [out, retval] Type: VARIANT* Value Array of all the values contained in the Meter registers for the active Meter.

Method: **Reset [void** Resets registers of active Meter.

Method: ResetAll [void

Resets registers of all Meter objects.

Method: Sample [void

Forces active Meter to take a sample.

Method: Save [void

Saves meter register values.

Property (get): value = Name [out, retval] Type: BSTR* Value Get/Set the active meter name.

Property (put): **Name = value [in] Type: BSTR Value** Set a meter to be active by name.

Property (get): value = Totals [out, retval] Type: VARIANT* Value Totals of all registers of all meters

Property (get): value = Peakcurrent [out, retval] Type: VARIANT* Value

Array of doubles to set values of Peak Current property

Property (put): Peakcurrent = value [in] Type: VARIANT Value

Array of doubles to set values of Peak Current property

Property (get): value = CalcCurrent [out, retval] Type: VARIANT* Value

Set the magnitude of the real part of the Calculated Current (normally determined by solution

Property (put): CalcCurrent = value [in] Type: VARIANT Value

Set the magnitude of the real part of the Calculated Current (normally determined by solution

Property (get): value = AllocFactors [out, retval] Type: VARIANT* Value

Array of doubles: set the phase allocation factors for the active meter.

Property (put): AllocFactors = value [in] Type: VARIANT Value

Array of doubles: set the phase allocation factors for the active meter.

Property (get): value = MeteredElement [out, retval] Type: BSTR* Value

Set Name of metered element

Property (put): MeteredElement = value [in] Type: BSTR Value

Set Name of metered element

Property (get): value = MeteredTerminal [out, retval] Type: long* Value

set Number of Metered Terminal

Property (put): MeteredTerminal = value [in] Type: long Value

set Number of Metered Terminal

Property (get): value = DIFilesAreOpen [out, retval] Type: VARIANT_BOOL* Value

Global Flag in the DSS to indicate if Demand Interval (DI

Method: SampleAll [void

Causes all EnergyMeter objects to take a sample at the present time

Method: SaveAll [void

Save All EnergyMeter objects

Method: OpenAllDIFiles [void

Open Demand Interval (DI

Method: CloseAllDIFiles [void

Close All Demand Interval Files (Necessary at the end of a run

Property (get): value = CountEndElements [out, retval] Type: long* Value

Number of zone end elements in the active meter zone.

Property (get): value = AllEndElements [out, retval] Type: VARIANT* Value Variant array of names of all zone end elements.

Property (get): value = Count [out, retval] Type: long* Value
Number of Energy Meters in the Active Circuit

Property (get): value = AllBranchesInZone [out, retval] Type: VARIANT* Value Wide string list of all branches in zone of the active energymeter object.

Property (get): value = CountBranches [out, retval] Type: long* Value
Number of branches in Active energymeter zone. (Same as sequencelist size

Property (get): value = SAIFI [out, retval] Type: double* Value
Returns SAIFI for this meter's Zone. Execute Reliability Calc method first.

Property (get): value = SequenceIndex [out, retval] Type: long* Value

Get/set Index into Meter's SequenceList that contains branch pointers in lexical order. Earlier index quaranteed to be upline from later index. Sets PDelement active.

Property (put): **SequenceIndex = value [in] Type: long Value**Get/set Index into Meter's SequenceList that contains branch pointers in lexical order. Earlier index guaranteed to be upline from later index. Sets PDelement active.

Property (get): value = SAIFIKW [out, retval] Type: double* Value
SAIFI based on kW rather than number of customers. Get after reliability calcs.

Method: **DoReliabilityCalc** [void Calculate SAIFI, etc.

Property (get): value = SeqListSize [out, retval] Type: long* Value Size of Sequence List

Generators Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Array of names of all Generator objects.

Property (get): value = RegisterNames [out, retval] Type: VARIANT* Value Array of Names of all generator energy meter registers

Property (get): value = RegisterValues [out, retval] Type: VARIANT* Value

Array of valus in generator energy meter registers.

Property (get): value = First [out, retval] Type: long* Value Sets first Generator to be active. Returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value Sets next Generator to be active. Returns 0 if no more.

Property (get): value = ForcedON [out, retval] Type: VARIANT_BOOL* Value Indicates whether the generator is forced ON regardles of other dispatch criteria.

Property (put): **ForcedON = value [in] Type: VARIANT_BOOL Value** *Indicates whether the generator is forced ON regardles of other dispatch criteria.*

Property (get): value = Name [out, retval] Type: BSTR* Value Sets a generator active by name.

Property (put): **Name = value [in] Type: BSTR Value**Sets a generator active by name.

Property (get): value = kV [out, retval] Type: double* Value Voltage base for the active generator, kV

Property (put): **kV = value [in] Type: double Value**Voltage base for the active generator, kV

Property (get): **value = kW [out, retval] Type: double* Value** *kW output for the active generator. kvar is updated for current power factor.*

Property (put): **kW = value [in] Type: double Value** *kW output for the active generator. kvar is updated for current power factor*

Property (get): value = kvar [out, retval] Type: double* Value kvar output for the active generator. Updates power factor based on present kW value.

Property (put): **kvar = value [in] Type: double Value** kvar output for the active generator. Updates power factor based on present kW.

Property (get): value = PF [out, retval] Type: double* Value Power factor (pos. = producing vars

Property (put): **PF = value [in] Type: double Value**Power factor (pos. = producing vars

Property (get): value = Phases [out, retval] Type: long* Value

Number of phases

Property (put): Phases = value [in] Type: long Value

Number of phases

Property (get): value = Count [out, retval] Type: long* Value

Number of Generator Objects in Active Circuit

Property (put): idx = value [in] Type: long Value

Property (get): value = idx [out, retval] Type: long* Value

Get/Set active Generator by index into generators list. 1..Count

Get/Set active Generator by index into generators list. 1..Count

DSSProgress Interface

Property (put): PctProgress = value [in] Type: long Param1

Percent progress to indicate [0..100]

Property (put): **Caption = value [in] Type: BSTR Param1**Caption to appear on the bottom of the DSS Progress form.

Method: Show [void

Shows progress form with null caption and progress set to zero.

Method: Close [void

Closes (hides

Settings Interface

Property (get): value = AllowDuplicates [out, retval] Type: VARIANT_BOOL* Value

True | False* Designates whether to allow duplicate names of objects

Property (put): AllowDuplicates = value [in] Type: VARIANT_BOOL Value

True | False* Designates whether to allow duplicate names of objects

Property (get): value = ZoneLock [out, retval] Type: VARIANT_BOOL* Value

True | False* Locks Zones on energy meters to prevent rebuilding if a circuit change occurs.

Property (put): ZoneLock = value [in] Type: VARIANT_BOOL Value

True | False* Locks Zones on energy meters to prevent rebuilding if a circuit change occurs.

Property (put): AllocationFactors = value [in] Type: double Param1

Sets all load allocation factors for all loads defined by XFKVA property to this value.

Property (get): value = AutoBusList [out, retval] Type: BSTR* Value List of Buses or (File=xxxx

Property (put): AutoBusList = value [in] Type: BSTR Value List of Buses or (File=xxxx

Property (get): value = CktModel [out, retval] Type: long* Value dssMultiphase * | dssPositiveSeq IIndicate if the circuit model is positive sequence.

Property (put): **CktModel = value [in] Type: long Value**dssMultiphase * | dssPositiveSeq IIndicate if the circuit model is positive sequence.

Property (get): value = NormVminpu [out, retval] Type: double* Value Per Unit minimum voltage for Normal conditions.

Property (put): **NormVminpu = value [in] Type: double Value**Per Unit minimum voltage for Normal conditions.

Property (get): value = NormVmaxpu [out, retval] Type: double* Value

Per Unit maximum voltage for Normal conditions.

Property (put): **NormVmaxpu = value [in] Type: double Value**Per Unit maximum voltage for Normal conditions.

Property (get): value = EmergVminpu [out, retval] Type: double* Value Per Unit minimum voltage for Emergency conditions.

Property (put): **EmergVminpu = value [in] Type: double Value**Per Unit minimum voltage for Emergency conditions.

Property (get): value = EmergVmaxpu [out, retval] Type: double* Value Per Unit maximum voltage for Emergency conditions.

Property (put): **EmergVmaxpu = value [in] Type: double Value**Per Unit maximum voltage for Emergency conditions.

Property (get): value = UEweight [out, retval] Type: double* Value Weighting factor applied to UE register values.

Property (put): **UEweight = value [in] Type: double Value** *Weighting factor applied to UE register values.*

Property (get): value = LossWeight [out, retval] Type: double* Value

Weighting factor applied to Loss register values.

Property (put): LossWeight = value [in] Type: double Value Weighting factor applied to Loss register values.

Property (get): value = UEregs [out, retval] Type: VARIANT* Value

Array of Integers defining energy meter registers to use for computing UE

Property (put): **UEregs = value [in] Type: VARIANT Value**Array of Integers defining energy meter registers to use for computing UE

Property (get): value = LossRegs [out, retval] Type: VARIANT* Value
Integer array defining which energy meter registers to use for computing losses

Property (put): LossRegs = value [in] Type: VARIANT Value
Integer array defining which energy meter registers to use for computing losses

Property (get): value = Trapezoidal [out, retval] Type: VARIANT_BOOL* Value True | False * Gets value of trapezoidal integration flag in energy meters.

Property (put): **Trapezoidal = value [in] Type: VARIANT_BOOL Value**True | False * Gets value of trapezoidal integration flag in energy meters.

Property (get): value = VoltageBases [out, retval] Type: VARIANT* Value

Array of doubles defining the legal voltage bases in kV L-L

Property (put): **VoltageBases = value [in] Type: VARIANT Value**Array of doubles defining the legal voltage bases in kV L-L

Property (get): value = ControlTrace [out, retval] Type: VARIANT_BOOL* Value True | False* Denotes whether to trace the control actions to a file.

Property (put): **ControlTrace = value [in] Type: VARIANT_BOOL Value**True | False* Denotes whether to trace the control actions to a file.

Property (get): value = PriceSignal [out, retval] Type: double* Value Price Signal for the Circuit

Property (put): **PriceSignal = value [in] Type: double Value**Price Signal for the Circuit

Property (get): value = PriceCurve [out, retval] Type: BSTR* Value

Name of LoadShape object that serves as the source of price signal data for yearly simulations, etc.

Property (put): PriceCurve = value [in] Type: BSTR Value

Name of LoadShape object that serves as the source of price signal data for yearly simulations, etc.

Lines Interface

Property (get): value = Name [out, retval] Type: BSTR* Value

Specify the name of the Line element to set it active.

Property (put): Name = value [in] Type: BSTR Value

Specify the name of the Line element to set it active.

Property (get): value = AllNames [out, retval] Type: VARIANT* Value

Names of all Line Objects

Property (get): value = First [out, retval] Type: long* Value

Invoking this property sets the first element active. Returns 0 if no lines. Otherwise, index of the line element.

Property (get): value = Next [out, retval] Type: long* Value

Invoking this property advances to the next Line element active. Returns 0 if no more lines.

Otherwise, index of the line element.

Method: New [in] Type: BSTR Name, [out, retval] Type: long* Value

Creates a new Line and makes it the Active Circuit Element.

Property (get): value = Bus1 [out, retval] Type: BSTR* Value

Name of bus for terminal 1.

Property (put): Bus1 = value [in] Type: BSTR Value

Name of bus for terminal 1.

Property (get): value = Bus2 [out, retval] Type: BSTR* Value

Name of bus for terminal 2.

Property (put): Bus2 = value [in] Type: BSTR Value

Name of bus for terminal 2.

Property (get): value = LineCode [out, retval] Type: BSTR* Value

Name of LineCode object that defines the impedances.

Property (put): LineCode = value [in] Type: BSTR Value

Name of LineCode object that defines the impedances.

Property (get): value = Length [out, retval] Type: double* Value
Length of line section in units compatible with the LineCode definition.

Property (put): **Length = value [in] Type: double Value**Length of line section in units compatible with the LineCode definition.

Property (get): value = Phases [out, retval] Type: long* Value Number of Phases, this Line element.

Property (put): **Phases = value [in] Type: long Value**Number of Phases, this Line element.

Property (get): value = R1 [out, retval] Type: double* Value Positive Sequence resistance, ohms per unit length.

Property (put): **R1 = value [in] Type: double Value**Positive Sequence resistance, ohms per unit length.

Property (get): **value = X1 [out, retval] Type: double* Value**Positive Sequence reactance, ohms per unit length.

Property (put): **X1 = value [in] Type: double Value**Positive Sequence reactance, ohms per unit length.

Property (get): value = R0 [out, retval] Type: double* Value Zero Sequence resistance, ohms per unit length.

Property (put): **R0 = value [in] Type: double Value**Zero Sequence resistance, ohms per unit length.

Property (get): value = X0 [out, retval] Type: double* Value Zero Sequence reactance ohms per unit length.

Property (put): **X0 = value [in] Type: double Value** *Zero Sequence reactance ohms per unit length.*

Property (get): **value = C1 [out, retval] Type: double* Value**Positive Sequence capacitance, nanofarads per unit length.

Property (put): **C1 = value [in] Type: double Value**Positive Sequence capacitance, nanofarads per unit length.

Property (get): value = C0 [out, retval] Type: double* Value Zero Sequence capacitance, nanofarads per unit length.

Property (put): **C0 = value [in] Type: double Value**Zero Sequence capacitance, nanofarads per unit length.

Property (get): value = Rmatrix [out, retval] Type: VARIANT* Value Resistance matrix (full

Property (put): **Rmatrix = value [in] Type: VARIANT Value**Resistance matrix (full

Property (get): value = Xmatrix [out, retval] Type: VARIANT* Value (no Help string available)

Property (put): **Xmatrix = value [in] Type: VARIANT Value** (no Help string available)

Property (get): value = Cmatrix [out, retval] Type: VARIANT* Value (no Help string available)

Property (put): **Cmatrix = value [in] Type: VARIANT Value** (no Help string available)

Property (get): value = NormAmps [out, retval] Type: double* Value Normal ampere rating of Line.

Property (put): **NormAmps = value [in] Type: double Value**Normal ampere rating of Line.

Property (get): value = EmergAmps [out, retval] Type: double* Value Emergency (maximum

Property (put): **EmergAmps = value [in] Type: double Value** *Emergency (maximum*

Property (get): value = Geometry [out, retval] Type: BSTR* Value Line geometry code

Property (put): **Geometry = value [in] Type: BSTR Value**Line geometry code

Property (get): value = Rg [out, retval] Type: double* Value

Earth return resistance value used to compute line impedances at power frequency

Property (put): **Rg = value [in] Type: double Value**Earth return resistance value used to compute line impedances at power frequency

Property (get): value = Xg [out, retval] Type: double* Value

Earth return reactance value used to compute line impedances at power frequency

Property (put): Xg = value [in] Type: double Value

Earth return reactance value used to compute line impedances at power frequency

Property (get): value = Rho [out, retval] Type: double* Value

Earth Resistivity, m-ohms

Property (put): Rho = value [in] Type: double Value

Earth Resistivity, m-ohms

Property (get): value = Yprim [out, retval] Type: VARIANT* Value

Yprimitive: Does Nothing at present on Put; Dangerous

Property (put): **Yprim = value [in] Type: VARIANT Value**

Yprimitive: Does Nothing at present on Put; Dangerous

Property (get): value = NumCust [out, retval] Type: long* Value

Number of customers on this line section.

Property (get): value = TotalCust [out, retval] Type: long* Value

Total Number of customers served from this line section.

Property (get): value = Parent [out, retval] Type: long* Value

Sets Parent of the active Line to be the active line. Returns 0 if no parent or action fails.

Property (get): value = Count [out, retval] Type: long* Value

Number of Line objects in Active Circuit.

Property (get): value = Spacing [out, retval] Type: BSTR* Value

Line spacing code

Property (put): Spacing = value [in] Type: BSTR Value

Line spacing code

Property (get): value = Units [out, retval] Type: long* Value

(no Help string available)

Property (put): Units = value [in] Type: long Value

(no Help string available)

CtrlQueue Interface

Method: ClearQueue [void

Clear control queue

Method: Delete [in] Type: long ActionHandle

Delete a control action from the DSS control queue by referencing the handle of the action

Property (get): value = NumActions [out, retval] Type: long* Value

Number of Actions on the current actionlist (that have been popped off the control queue by

CheckControlActions

Property (put): Action = value [in] Type: long Param1

Set the active action by index

Property (get): value = ActionCode [out, retval] Type: long* Value

Code for the active action. Long integer code to tell the control device what to do

Property (get): value = DeviceHandle [out, retval] Type: long* Value

Handle (User defined

Method: Push [in] Type: long Hour, [in] Type: double Seconds, [in] Type: long ActionCode,

[in] Type: long DeviceHandle, [out, retval] Type: long* Value

Push a control action onto the DSS control queue by time, action code, and device handle (user

defined

Method: Show [void

Show entire control queue in CSV format

Method: ClearActions [void

Clear the Action list.

Property (get): value = PopAction [out, retval] Type: long* Value

Pops next action off the action list and makes it the active action. Returns Number of actions

remaining.

Loads Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value

Variant array of strings containing all Load names

Property (get): value = First [out, retval] Type: long* Value

Set first Load element to be active; returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value

Sets next Load element to be active; returns 0 of none else index of active load.

Property (get): value = Name [out, retval] Type: BSTR* Value Set active load by name.

Property (put): Name = value [in] Type: BSTR Value Set active load by name.

Property (get): value = Idx [out, retval] Type: long* Value Sets active load by index into load list. 1..Count

Property (put): Idx = value [in] Type: long Value Sets active load by index into load list. 1..Count

Property (get): value = kW [out, retval] Type: double* Value Set kW for active Load. Updates kvar based on present PF.

Property (put): **kW = value [in] Type: double Value**Set kW for active Load. Updates kvar based on present PF.

Property (get): **value = kV** [**out, retval**] **Type: double* Value**Set kV rating for active Load. For 2 or more phases set Line-Line kV. Else actual kV across terminals.

Property (put): **kV = value [in] Type: double Value**Set kV rating for active Load. For 2 or more phases set Line-Line kV. Else actual kV across terminals.

Property (get): value = kvar [out, retval] Type: double* Value Set kvar for active Load. Updates PF based in present kW.

Property (put): **kvar = value [in] Type: double Value**Set kvar for active Load. Updates PF based on present kW.

Property (get): value = PF [out, retval] Type: double* Value

Set Power Factor for Active Load. Specify leading PF as negative. Updates kvar based on kW value

Property (put): **PF = value [in] Type: double Value**Set Power Factor for Active Load. Specify leading PF as negative. Updates kvar based on present value of kW.

Property (get): value = Count [out, retval] Type: long* Value

Number of Load objects in active circuit.

Property (get): value = PctMean [out, retval] Type: double* Value

Average percent of nominal load in Monte Carlo studies; only if no loadshape defined for this load.

Property (put): **PctMean = value [in] Type: double Value** (no Help string available)

Property (get): value = PctStdDev [out, retval] Type: double* Value

Percent standard deviation for Monte Carlo load studies; if there is no loadshape assigned to this load.

Property (put): PctStdDev = value [in] Type: double Value (no Help string available)

Property (get): value = AllocationFactor [out, retval] Type: double* Value Factor for allocating loads by connected xfkva

Property (put): AllocationFactor = value [in] Type: double Value (no Help string available)

Property (get): value = Cfactor [out, retval] Type: double* Value
Factor relates average to peak kw. Used for allocation with kwh and kwhdays/

Property (put): **Cfactor = value [in] Type: double Value** (no Help string available)

Property (get): value = Class [out, retval] Type: long* Value

A code number used to separate loads by class or group. No effect on the solution.

Property (put): Class = value [in] Type: long Value (no Help string available)

Property (get): value = IsDelta [out, retval] Type: VARIANT_BOOL* Value Delta loads are connected line-to-line.

Property (put): IsDelta = value [in] Type: VARIANT_BOOL Value (no Help string available)

Property (get): value = CVRcurve [out, retval] Type: BSTR* Value

Name of a loadshape with both Mult and Qmult, for CVR factors as a function of time.

Property (put): CVRcurve = value [in] Type: BSTR Value

Property (get): value = CVRwatts [out, retval] Type: double* Value

Percent reduction in P for percent reduction in V. Must be used with dssLoadModelCVR.

Property (put): CVRwatts = value [in] Type: double Value

(no Help string available)

Property (get): value = CVRvars [out, retval] Type: double* Value

Percent reduction in Q for percent reduction in V. Must be used with dssLoadModelCVR.

Property (put): CVRvars = value [in] Type: double Value

(no Help string available)

Property (get): value = daily [out, retval] Type: BSTR* Value

Name of the loadshape for a daily load profile.

Property (put): daily = value [in] Type: BSTR Value

(no Help string available)

Property (get): value = duty [out, retval] Type: BSTR* Value

Name of the loadshape for a duty cycle simulation.

Property (put): duty = value [in] Type: BSTR Value

(no Help string available)

Property (get): value = kva [out, retval] Type: double* Value

Base load kva. Also defined kw and kvar or pf input, or load allocation by kwh or xfkva.

Property (put): kva = value [in] Type: double Value

(no Help string available)

Property (get): value = kwh [out, retval] Type: double* Value

kwh billed for this period. Can be used with Cfactor for load allocation.

Property (put): kwh = value [in] Type: double Value

(no Help string available)

Property (get): value = kwhdays [out, retval] Type: double* Value

Length of kwh billing period for average demand calculation. Default 30.

Property (put): kwhdays = value [in] Type: double Value

(no Help string available)

Property (get): value = Model [out, retval] Type: enum LoadModels*, [Value

The Load Model defines variation of P and Q with voltage.

Property (put): **Model = value [in] Type: enum LoadModels, [Value** (no Help string available)

Property (get): value = NumCust [out, retval] Type: long* Value Number of customers in this load, defaults to one.

Property (put): **NumCust = value [in] Type: long Value** (no Help string available)

Property (get): value = Rneut [out, retval] Type: double* Value Neutral resistance for wye-connected loads.

Property (put): **Rneut = value [in] Type: double Value** (no Help string available)

Property (get): value = Spectrum [out, retval] Type: BSTR* Value Name of harmonic current spectrrum shape.

Property (put): **Spectrum = value [in] Type: BSTR Value** (no Help string available)

Property (get): value = Vmaxpu [out, retval] Type: double* Value

Maximum per-unit voltage to use the load model. Above this, constant Z applies.

Property (put): Vmaxpu = value [in] Type: double Value (no Help string available)

Property (get): value = Vminemerg [out, retval] Type: double* Value Minimum voltage for unserved energy (UE

Property (put): **Vminemerg = value [in] Type: double Value** (no Help string available)

Property (get): value = Vminnorm [out, retval] Type: double* Value Minimum voltage for energy exceeding normal (EEN

Property (put): Vminnorm = value [in] Type: double Value (no Help string available)

Property (get): value = Vminpu [out, retval] Type: double* Value

Minimum voltage to apply the load model. Below this, constant Z is used.

Property (put): Vminpu = value [in] Type: double Value

Property (get): value = xfkVA [out, retval] Type: double* Value

Rated service transformer kVA for load allocation, using AllocationFactor. Affects kW, kvar, and pf.

Property (put): xfkVA = value [in] Type: double Value (no Help string available)

Property (get): value = Xneut [out, retval] Type: double* Value Neutral reactance for wye-connected loads.

Property (put): **Xneut = value [in] Type: double Value** (no Help string available)

Property (get): value = Yearly [out, retval] Type: BSTR* Value
Name of yearly duration loadshape

Property (put): **Yearly = value [in] Type: BSTR Value** (no Help string available)

Property (get): value = Status [out, retval] Type: enum LoadStatus*, [Value Response to load multipliers: Fixed (growth only

Property (put): **Status = value [in] Type: enum LoadStatus, [Value** (no Help string available)

Property (get): value = Growth [out, retval] Type: BSTR* Value Name of the growthshape curve for yearly load growth factors.

Property (put): **Growth = value [in] Type: BSTR Value** (no Help string available)

Property (get): **value = ZIPV** [out, retval] Type: VARIANT* Value

Array of 7 doubles with values for ZIPV property of the LOAD object

Property (put): **ZIPV = value [in] Type: VARIANT Value** (no Help string available)

Property (get): value = pctSeriesRL [out, retval] Type: double* Value (no Help string available)

Property (put): pctSeriesRL = value [in] Type: double Value
Percent of Load that is modeled as series R-L for harmonics studies

Property (get): value = RelWeight [out, retval] Type: double* Value

Relative Weighting factor for the active LOAD

Property (put): RelWeight = value [in] Type: double Value

Relative Weighting factor for the active LOAD

DSSElement Interface

Property (get): value = Name [out, retval] Type: BSTR* Value
Full Name of Active DSS Object (general element or circuit element

Property (get): value = Properties [in] Type: VARIANT Indx, [out, retval] Type: IDSSProperty** Value

Collection of properties for Active DSS object (general element or circuit element

Property (get): value = NumProperties [out, retval] Type: long* Value Number of Properties for the active DSS object.

Property (get): value = AllPropertyNames [out, retval] Type: VARIANT* Value

Variant array of strings containing the names of all properties for the active DSS object.

ActiveClass Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Variant array of strings consisting of all element names in the active class.

Property (get): value = First [out, retval] Type: long* Value

Sets first element in the active class to be the active DSS object. If object is a CktElement,

ActiveCktELment also points to this element. Returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value

Sets next element in active class to be the active DSS object. If object is a CktElement,

ActiveCktElement also points to this element. Returns 0 if no more.

Property (get): value = Name [out, retval] Type: BSTR* Value Name of the Active Element of the Active Class

Property (put): Name = value [in] Type: BSTR Value (no Help string available)

Property (get): value = NumElements [out, retval] Type: long* Value Number of elements in this class. Same as Count property.

Property (get): value = ActiveClassName [out, retval] Type: BSTR* Value

Returns name of active class.

Property (get): value = Count [out, retval] Type: long* Value

Number of elements in Active Class. Same as NumElements Property.

Capacitors Interface

Property (get): value = kV [out, retval] Type: double* Value
Bank kV rating. Use LL for 2 or 3 phases, or actual can rating for 1 phase.

Property (put): **kV = value [in] Type: double Value**Bank kV rating. Use LL for 2 or 3 phases, or actual can rating for 1 phase.

Property (get): value = kvar [out, retval] Type: double* Value Total bank KVAR, distributed equally among phases and steps.

Property (put): **kvar = value [in] Type: double Value**Total bank KVAR, distributed equally among phases and steps.

Property (get): value = NumSteps [out, retval] Type: long* Value Number of steps (default 1

Property (put): **NumSteps = value [in] Type: long Value**Number of steps (default 1

Property (get): value = IsDelta [out, retval] Type: VARIANT_BOOL* Value Delta connection or wye?

Property (put): IsDelta = value [in] Type: VARIANT_BOOL Value Delta connection or wye?

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Variant array of strings with all Capacitor names in the circuit.

Property (get): value = First [out, retval] Type: long* Value Sets the first Capacitor active. Returns 0 if no more.

Property (get): value = Next [out, retval] Type: long* Value Sets the next Capacitor active. Returns 0 if no more.

Property (get): value = Name [out, retval] Type: BSTR* Value Sets the acitve Capacitor by Name.

Property (put): Name = value [in] Type: BSTR Value

Sets the acitve Capacitor by Name.

Property (get): value = Count [out, retval] Type: long* Value

Number of Capacitor objects in active circuit.

Transformers Interface

Property (get): value = NumWindings [out, retval] Type: long* Value

Number of windings on this transformer. Allocates memory; set or change this property first.

Property (put): NumWindings = value [in] Type: long Value

Number of windings on this transformer. Allocates memory; set or change this property first.

Property (get): value = XfmrCode [out, retval] Type: BSTR* Value

Name of an XfrmCode that supplies electircal parameters for this Transformer.

Property (put): XfmrCode = value [in] Type: BSTR Value

Name of an XfrmCode that supplies electircal parameters for this Transformer.

Property (get): value = Wdg [out, retval] Type: long* Value

Active Winding Number from 1..NumWindings. Update this before reading or setting a sequence of winding properties (R, Tap, kV, kVA, etc.

Property (put): Wdg = value [in] Type: long Value

Active Winding Number from 1..NumWindings. Update this before reading or setting a sequence of winding properties (R, Tap, kV, kVA, etc.

Property (get): value = R [out, retval] Type: double* Value

Active Winding resistance in %

Property (put): R = value [in] Type: double Value

Active Winding resistance in %

Property (get): value = Tap [out, retval] Type: double* Value

Active Winding tap in per-unit.

Property (put): **Tap = value [in] Type: double Value**

Active Winding tap in per-unit.

Property (get): value = MinTap [out, retval] Type: double* Value

Active Winding minimum tap in per-unit.

Property (put): MinTap = value [in] Type: double Value

Active Winding minimum tap in per-unit.

Property (get): value = MaxTap [out, retval] Type: double* Value

Active Winding maximum tap in per-unit.

Property (put): MaxTap = value [in] Type: double Value

Active Winding maximum tap in per-unit.

Property (get): value = NumTaps [out, retval] Type: long* Value

Active Winding number of tap steps betwein MinTap and MaxTap.

Property (put): NumTaps = value [in] Type: long Value

Active Winding number of tap steps betwein MinTap and MaxTap.

Property (get): value = kV [out, retval] Type: double* Value

Active Winding kV rating. Phase-phase for 2 or 3 phases, actual winding kV for 1 phase transformer.

Property (put): **kV = value [in] Type: double Value**

Active Winding kV rating. Phase-phase for 2 or 3 phases, actual winding kV for 1 phase transformer.

Property (get): value = kVA [out, retval] Type: double* Value

Active Winding kVA rating. On winding 1, this also determines normal and emergency current ratings for all windings.

Property (put): kVA = value [in] Type: double Value

Active Winding kVA rating. On winding 1, this also determines normal and emergency current ratings for all windings.

Property (get): value = Xneut [out, retval] Type: double* Value

Active Winding neutral reactance [ohms] for wye connections.

Property (put): Xneut = value [in] Type: double Value

Active Winding neutral reactance [ohms] for wye connections.

Property (get): value = Rneut [out, retval] Type: double* Value

Active Winding neutral resistance [ohms] for wye connections. Set less than zero for ungrounded wye.

Property (put): Rneut = value [in] Type: double Value

Active Winding neutral resistance [ohms] for wye connections. Set less than zero for ungrounded wye.

Property (get): value = IsDelta [out, retval] Type: VARIANT_BOOL* Value

Active Winding delta or wye connection?

Property (put): IsDelta = value [in] Type: VARIANT_BOOL Value

Active Winding delta or wye connection?

Property (get): value = Xhl [out, retval] Type: double* Value

Percent reactance between windings 1 and 2, on winding 1 kVA base. Use for 2-winding or 3-winding transformers.

Property (put): Xhl = value [in] Type: double Value

Percent reactance between windings 1 and 2, on winding 1 kVA base. Use for 2-winding or 3-winding transformers.

Property (get): value = Xht [out, retval] Type: double* Value

Percent reactance between windigns 1 and 3, on winding 1 kVA base. Use for 3-winding transformers only.

Property (put): Xht = value [in] Type: double Value

Percent reactance between windigns 1 and 3, on winding 1 kVA base. Use for 3-winding transformers only.

Property (get): value = XIt [out, retval] Type: double* Value

Percent reactance between windings 2 and 3, on winding _1_ kVA base. Use for 3-winding transformers only.

Property (put): XIt = value [in] Type: double Value

Percent reactance between windings 2 and 3, on winding _1_ kVA base. Use for 3-winding transformers only.

Property (get): value = Name [out, retval] Type: BSTR* Value

Sets a Transformer active by Name.and 3, on winding _1_ kVA base. Use for 3-winding transformers only.

Property (put): Name = value [in] Type: BSTR Value

Sets a Transformer active by Name.and 3, on winding _1_ kVA base. Use for 3-winding transformers only.

Property (get): value = First [out, retval] Type: long* Value

Sets the first Transformer active. Returns 0 if no more.

Property (get): value = Next [out, retval] Type: long* Value

Sets the next Transformer active. Returns 0 if no more.

Property (get): **value = AllNames** [out, retval] Type: VARIANT* Value Variant array of strings with all Transformer names in the active circuit.

Property (get): value = Count [out, retval] Type: long* Value (no Help string available)

SwtControls Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Variant array of strings with all SwtControl names in the active circuit.

Property (get): value = Name [out, retval] Type: BSTR* Value Sets a SwtControl active by Name.

Property (put): Name = value [in] Type: BSTR Value Sets a SwtControl active by Name.

Property (get): value = First [out, retval] Type: long* Value Sets the first SwtControl active. Returns 0 if no more.

Property (get): value = Next [out, retval] Type: long* Value Sets the next SwtControl active. Returns 0 if no more.

Property (get): value = Action [out, retval] Type: enum ActionCodes*, [Value Open or Close the switch. No effect if switch is locked. However, Reset removes any lock and then closes the switch (shelf state

Property (put): **Action = value [in] Type: enum ActionCodes, [Value**Open or Close the switch. No effect if switch is locked. However, Reset removes any lock and then closes the switch (shelf state

Property (get): value = IsLocked [out, retval] Type: VARIANT_BOOL* Value The lock prevents both manual and automatic switch operation.

Property (put): **IsLocked = value [in] Type: VARIANT_BOOL Value**The lock prevents both manual and automatic switch operation.

Property (get): **value = Delay [out, retval] Type: double* Value**Time delay [s] betwen arming and opening or closing the switch. Control may reset before actually operating the switch.

Property (put): **Delay = value [in] Type: double Value**

Time delay [s] betwen arming and opening or closing the switch. Control may reset before actually operating the switch.

Property (get): value = SwitchedObj [out, retval] Type: BSTR* Value Full name of the switched element.

Property (put): **SwitchedObj = value [in] Type: BSTR Value** *Full name of the switched element.*

Property (get): value = SwitchedTerm [out, retval] Type: long* Value Terminal number where the switch is located on the SwitchedObj

Property (put): **SwitchedTerm = value [in] Type: long Value** *Terminal number where the switch is located on the SwitchedObj*

Property (get): value = Count [out, retval] Type: long* Value (no Help string available)

CapControls Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Variant array of strings with all CapControl names.

Property (get): value = Name [out, retval] Type: BSTR* Value Sets a CapControl active by name.

Property (put): **Name = value [in] Type: BSTR Value** Sets a CapControl active by name.

Property (get): value = First [out, retval] Type: long* Value Sets the first CapControl as active. Return 0 if none.

Property (get): value = Next [out, retval] Type: long* Value Gets the next CapControl in the circut. Returns 0 if none.

Property (get): value = Mode [out, retval] Type: enum CapControlModes*, [Value Type of automatic controller.

Property (put): **Mode = value [in] Type: enum CapControlModes, [Value** *Type of automatic controller.*

Property (get): value = Capacitor [out, retval] Type: BSTR* Value Name of the Capacitor that is controlled.

Property (put): **Capacitor = value [in] Type: BSTR Value**Name of the Capacitor that is controlled.

Property (get): value = MonitoredObj [out, retval] Type: BSTR* Value Full name of the element that PT and CT are connected to.

Property (put): **MonitoredObj = value [in] Type: BSTR Value**Full name of the element that PT and CT are connected to.

Property (get): value = MonitoredTerm [out, retval] Type: long* Value Terminal number on the element that PT and CT are connected to.

Property (put): **MonitoredTerm = value [in] Type: long Value** *Terminal number on the element that PT and CT are connected to.*

Property (get): value = CTratio [out, retval] Type: double* Value Transducer ratio from pirmary current to control current.

Property (put): **CTratio = value [in] Type: double Value** *Transducer ratio from pirmary current to control current.*

Property (get): value = PTratio [out, retval] Type: double* Value Transducer ratio from primary feeder to control voltage.

Property (put): **PTratio = value [in] Type: double Value** *Transducer ratio from primary feeder to control voltage.*

Property (get): value = ONSetting [out, retval] Type: double* Value Threshold to arm or switch on a step. See Mode for units.

Property (put): **ONSetting = value [in] Type: double Value**Threshold to arm or switch on a step. See Mode for units.

Property (get): value = OFFSetting [out, retval] Type: double* Value Threshold to switch off a step. See Mode for units.

Property (put): **OFFSetting = value [in] Type: double Value** *Threshold to switch off a step. See Mode for units.*

Property (get): value = Vmax [out, retval] Type: double* Value

With VoltOverride, swtich off whenever PT voltage exceeds this level.

Property (put): Vmax = value [in] Type: double Value
With VoltOverride, swtich off whenever PT voltage exceeds this level.

Property (get): value = Vmin [out, retval] Type: double* Value

With VoltOverride, switch ON whenever PT voltage drops below this level.

Property (put): Vmin = value [in] Type: double Value

With VoltOverride, switch ON whenever PT voltage drops below this level.

Property (get): value = UseVoltOverride [out, retval] Type: VARIANT_BOOL* Value

Enables Vmin and Vmax to override the control Mode

Property (put): UseVoltOverride = value [in] Type: VARIANT_BOOL Value

Enables Vmin and Vmax to override the control Mode

Property (get): value = Delay [out, retval] Type: double* Value

Time delay [s] to switch on after arming. Control may reset before actually switching.

Property (put): **Delay = value [in] Type: double Value**

Time delay [s] to switch on after arming. Control may reset before actually switching.

Property (get): value = DelayOff [out, retval] Type: double* Value

Time delay [s] before swithcing off a step. Control may reset before actually switching.

Property (put): DelayOff = value [in] Type: double Value

Time delay [s] before swithcing off a step. Control may reset before actually switching.

Property (get): value = DeadTime [out, retval] Type: double* Value

(no Help string available)

Property (put): **DeadTime = value [in] Type: double Value**

(no Help string available)

Property (get): value = Count [out, retval] Type: long* Value

Number of CapControls in Active Circuit

RegControls Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value

Variant array of strings containing all RegControl names

Property (get): value = Name [out, retval] Type: BSTR* Value

Get/set Active RegControl name

Property (put): Name = value [in] Type: BSTR Value

Sets a RegControl active by name

Property (get): value = First [out, retval] Type: long* Value Sets the first RegControl active. Returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value Sets the next RegControl active. Returns 0 if none.

Property (get): **value = MonitoredBus** [out, retval] Type: BSTR* Value Name of a remote regulated bus, in lieu of LDC settings

Property (put): **MonitoredBus = value [in] Type: BSTR Value**Name of a remote regulated bus, in lieu of LDC settings

Property (get): value = Transformer [out, retval] Type: BSTR* Value Name of the transformer this regulator controls

Property (put): **Transformer = value [in] Type: BSTR Value** *Name of the transformer this regulator controls*

Property (get): value = TapWinding [out, retval] Type: long* Value Tapped winding number

Property (put): **TapWinding = value [in] Type: long Value** *Tapped winding number*

Property (get): value = Winding [out, retval] Type: long* Value Winding number for PT and CT connections

Property (put): **Winding = value [in] Type: long Value**Winding number for PT and CT connections

Property (get): value = CTPrimary [out, retval] Type: double* Value CT primary ampere rating (secondary is 0.2 amperes

Property (put): **CTPrimary = value [in] Type: double Value** *CT primary ampere rating (secondary is 0.2 amperes*

Property (get): value = PTratio [out, retval] Type: double* Value PT ratio for voltage control settings

Property (put): **PTratio = value [in] Type: double Value**PT ratio for voltage control settings

Property (get): value = ForwardR [out, retval] Type: double* Value LDC R setting in Volts

Property (put): ForwardR = value [in] Type: double Value

LDC R setting in Volts

Property (get): value = ForwardX [out, retval] Type: double* Value

LDC X setting in Volts

Property (put): ForwardX = value [in] Type: double Value

LDC X setting in Volts

Property (get): value = ReverseR [out, retval] Type: double* Value

Reverse LDC R setting in Volts.

Property (put): ReverseR = value [in] Type: double Value

Reverse LDC R setting in Volts.

Property (get): value = ReverseX [out, retval] Type: double* Value

Reverse LDC X setting in volts.

Property (put): ReverseX = value [in] Type: double Value

Reverse LDC X setting in volts.

Property (get): value = IsReversible [out, retval] Type: VARIANT BOOL* Value

Regulator can use different settings in the reverse direction. Usually not applicable to substation transformers.

Property (put): IsReversible = value [in] Type: VARIANT_BOOL Value

Regulator can use different settings in the reverse direction. Usually not applicable to substation transformers.

Property (get): value = IsInverseTime [out, retval] Type: VARIANT_BOOL* Value

Time delay is inversely adjusted, proportinal to the amount of voltage outside the regulating band.

Property (put): IsInverseTime = value [in] Type: VARIANT_BOOL Value

Time delay is inversely adjusted, proportinal to the amount of voltage outside the regulating band.

Property (get): value = Delay [out, retval] Type: double* Value

Time delay [s] after arming before the first tap change. Control may reset before actually changing taps.

Property (put): Delay = value [in] Type: double Value

Time delay [s] after arming before the first tap change. Control may reset before actually

changing taps.

Property (get): value = TapDelay [out, retval] Type: double* Value

Time delay [s] for subsequent tap changes in a set. Control may reset before actually changing taps.

Property (put): TapDelay = value [in] Type: double Value

Time delay [s] for subsequent tap changes in a set. Control may reset before actually changing taps.

Property (get): value = MaxTapChange [out, retval] Type: long* Value

Maximum tap change per iteration in STATIC solution mode. 1 is more realistic, 16 is the default for a faster soluiton.

Property (put): MaxTapChange = value [in] Type: long Value

Maximum tap change per iteration in STATIC solution mode. 1 is more realistic, 16 is the default for a faster soluiton.

Property (get): value = VoltageLimit [out, retval] Type: double* Value

First house voltage limit on PT secondary base. Setting to 0 disables this function.

Property (put): VoltageLimit = value [in] Type: double Value

First house voltage limit on PT secondary base. Setting to 0 disables this function.

Property (get): value = ForwardBand [out, retval] Type: double* Value

Regulation bandwidth in forward direction, centered on Vrea

Property (put): ForwardBand = value [in] Type: double Value

Regulation bandwidth in forward direciton, centered on Vreg

Property (get): value = ForwardVreg [out, retval] Type: double* Value

Target voltage in the forward direction, on PT secondary base.

Property (put): ForwardVreg = value [in] Type: double Value

Target voltage in the forward direction, on PT secondary base.

Property (get): value = ReverseBand [out, retval] Type: double* Value

Bandwidth in reverse direction, centered on reverse Vreg.

Property (put): ReverseBand = value [in] Type: double Value

Bandwidth in reverse direction, centered on reverse Vreg.

Property (get): value = ReverseVreg [out, retval] Type: double* Value

Target voltage in the revese direction, on PT secondary base.

Property (put): **ReverseVreg = value [in] Type: double Value** *Target voltage in the revese direction, on PT secondary base.*

Property (get): value = Count [out, retval] Type: long* Value
Number of RegControl objects in Active Circuit

Property (get): value = TapNumber [out, retval] Type: long* Value (no Help string available)

Property (put): **TapNumber = value [in] Type: long Value**Integer number of the tap that the controlled transformer winding is currently on.

Topology Interface

Property (get): value = NumLoops [out, retval] Type: long* Value Number of loops

Property (get): value = NumIsolatedBranches [out, retval] Type: long* Value Number of isolated branches (PD elements and capacitors

Property (get): value = AllLoopedPairs [out, retval] Type: VARIANT* Value Variant array of all looped element names, by pairs.

Property (get): value = AllisolatedBranches [out, retval] Type: VARIANT* Value Variant array of all isolated branch names.

Property (get): value = NumIsolatedLoads [out, retval] Type: long* Value Number of isolated loads

Property (get): value = AllisolatedLoads [out, retval] Type: VARIANT* Value Variant array of all isolated load names.

Property (get): value = BranchName [out, retval] Type: BSTR* Value Name of the active branch.

Property (put): **BranchName = value [in] Type: BSTR Value** (no Help string available)

Property (get): value = First [out, retval] Type: long* Value Sets the first branch active, returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value

Sets the next branch active, returns 0 if no more.

Property (get): value = ActiveBranch [out, retval] Type: long* Value Returns index of the active branch

Property (get): value = ForwardBranch [out, retval] Type: long* Value

Move forward in the tree, return index of new active branch or 0 if no more

Property (get): value = BackwardBranch [out, retval] Type: long* Value

MOve back toward the source, return index of new active branch, or 0 if no more.

Property (get): value = LoopedBranch [out, retval] Type: long* Value Move to looped branch, return index or 0 if none.

Property (get): value = ParallelBranch [out, retval] Type: long* Value Move to directly parallel branch, return index or 0 if none.

Property (get): value = FirstLoad [out, retval] Type: long* Value First load at the active branch, return index or 0 if none.

Property (get): value = NextLoad [out, retval] Type: long* Value Next load at the active branch, return index or 0 if no more.

Property (get): value = ActiveLevel [out, retval] Type: long* Value Topological depth of the active branch

Property (get): value = BusName [out, retval] Type: BSTR* Value (no Help string available)

Property (put): **BusName = value [in] Type: BSTR Value**Set the active branch to one containing this bus, return index or 0 if not found

DSS_Executive Interface

Property (get): value = NumCommands [out, retval] Type: long* Value Number of DSS Executive Commands

Property (get): value = NumOptions [out, retval] Type: long* Value Number of DSS Executive Options

Property (get): value = Command [in] Type: long i, [out, retval] Type: BSTR* Value Get i-th command

Property (get): value = Option [in] Type: long i, [out, retval] Type: BSTR* Value

Get i-th option

Property (get): value = CommandHelp [in] Type: long i, [out, retval] Type: BSTR* Value Get help string for i-th command

Property (get): value = OptionHelp [in] Type: long i, [out, retval] Type: BSTR* Value Get help string for i-th option

Property (get): value = OptionValue [in] Type: long i, [out, retval] Type: BSTR* Value Get present value of i-th option

DSSEvents Interface

Sensors Interface

Property (get): value = Name [out, retval] Type: BSTR* Value Name of the active sensor.

Property (put): **Name = value [in] Type: BSTR Value** Set the active Sensor by name.

Property (get): value = Count [out, retval] Type: long* Value Number of Sensors in Active Circuit.

Property (get): value = First [out, retval] Type: long* Value Sets the first sensor active. Returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value Sets the next Sensor active. Returns 0 if no more.

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Variant array of Sensor names.

Property (get): value = IsDelta [out, retval] Type: VARIANT_BOOL* Value True if measured voltages are line-line. Currents are always line currents.

Property (put): IsDelta = value [in] Type: VARIANT_BOOL Value (no Help string available)

Property (get): value = ReverseDelta [out, retval] Type: VARIANT_BOOL* Value True if voltage measurements are 1-3, 3-2, 2-1.

Property (put): ReverseDelta = value [in] Type: VARIANT_BOOL Value

Property (get): value = PctError [out, retval] Type: double* Value

Assumed percent error in the Sensor measurement. Default is 1.

Property (put): PctError = value [in] Type: double Value

(no Help string available)

Property (get): value = Weight [out, retval] Type: double* Value

Weighting factor for this Sensor measurement with respect to other Sensors. Default is 1.

Property (put): Weight = value [in] Type: double Value

(no Help string available)

Property (get): value = MeteredElement [out, retval] Type: BSTR* Value

Full Name of the measured element

Property (put): MeteredElement = value [in] Type: BSTR Value

(no Help string available)

Property (get): value = MeteredTerminal [out, retval] Type: long* Value

Number of the measured terminal in the measured element.

Property (put): MeteredTerminal = value [in] Type: long Value

(no Help string available)

Method: Reset [void

Clear the active Sensor.

Method: ResetAll [void

Clear all Sensors in the Active Circuit.

Property (get): value = kVbase [out, retval] Type: double* Value

Voltage base for the sensor measurements. LL for 2 and 3-phase sensors, LN for 1-phase sensors.

Property (put): kVbase = value [in] Type: double Value

(no Help string available)

Property (get): value = Currents [out, retval] Type: VARIANT* Value

Array of doubles for the line current measurements; don't use with kWS and kVARS.

Property (put): Currents = value [in] Type: VARIANT Value

(no Help string available)

Property (get): value = kVS [out, retval] Type: VARIANT* Value

Array of doubles for the LL or LN (depending on Delta connection

Property (put): **kVS = value [in] Type: VARIANT Value** (no Help string available)

Property (get): value = kVARS [out, retval] Type: VARIANT* Value

Array of doubles for Q measurements. Overwrites Currents with a new estimate using kWS.

Property (put): **kVARS = value [in] Type: VARIANT Value** (no Help string available)

Property (get): value = kWS [out, retval] Type: VARIANT* Value

Array of doubles for P measurements. Overwrites Currents with a new estimate using kVARS.

Property (put): **kWS = value [in] Type: VARIANT Value** (no Help string available)

XYCurves Interface

Property (get): value = Count [out, retval] Type: long* Value

Number of XYCurve Objects

Property (get): value = First [out, retval] Type: long* Value

Sets first XYcurve object active; returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value

Advances to next XYCurve object; returns 0 if no more objects of this class

Property (get): value = Name [out, retval] Type: BSTR* Value

Name of active XYCurve Object

Property (put): Name = value [in] Type: BSTR Value

Get Name of active XYCurve Object

Property (get): value = Npts [out, retval] Type: long* Value

Get/Set Number of points in X-Y curve

Property (put): Npts = value [in] Type: long Value

Get/Set Number of Points in X-Y curve

Property (get): value = Xarray [out, retval] Type: VARIANT* Value

Get/Set X values as a Variant array of doubles. Set Npts to max number expected if setting

Property (put): Xarray = value [in] Type: VARIANT Value

Get/Set X values as a Variant array of doubles. Set Npts to max number expected if setting

Property (get): value = Yarray [out, retval] Type: VARIANT* Value Get/Set Y values in curve; Set Npts to max number expected if setting

Property (put): **Yarray = value [in] Type: VARIANT Value**Get/Set Y values in curve; Set Npts to max number expected if setting

Property (get): value = x [out, retval] Type: double* Value
Set X value or get interpolated value after setting Y

Property (put): x = value [in] Type: double Value (no Help string available)

Property (get): **value = y [out, retval] Type: double* Value**Y value for present X or set this value then get corresponding X

Property (put): **y = value [in] Type: double Value**Set Y value or get interpolated Y value after setting X

Property (get): **value = Xshift** [out, retval] Type: double* Value Amount to shift X value from original curve

Property (put): **Xshift = value [in] Type: double Value** (no Help string available)

Property (get): **value = Yshift** [out, retval] Type: double* Value amount to shift Y value from original curve

Property (put): **Yshift = value [in] Type: double Value** (no Help string available)

Property (get): value = Xscale [out, retval] Type: double* Value Factor to scale X values from original curve

Property (put): **Xscale = value [in] Type: double Value** Factor to scale X values from original curve

Property (get): value = Yscale [out, retval] Type: double* Value Factor to scale Y values from original curve

Property (put): **Yscale = value [in] Type: double Value**Amount to scale Y values from original curve. Represents a curve shift.

PDElements Interface

Property (get): value = Count [out, retval] Type: long* Value

Number of PD elements (including disabled elements

Property (get): value = First [out, retval] Type: long* Value

Set the first enabled PD element to be the active element. Returns 0 if none found.

Property (get): value = Next [out, retval] Type: long* Value

Advance to the next PD element in the circuit. Enabled elements only. Returns 0 when no more elements.

Property (get): value = IsShunt [out, retval] Type: VARIANT_BOOL* Value

Variant boolean indicating of PD element should be treated as a shunt element rather than a series element. Applies to Capacitor and Reactor elements in particular.

Property (get): value = FaultRate [out, retval] Type: double* Value

Get/Set Number of failures per year. For LINE elements: Number of failures per unit length per year.

Property (put): **FaultRate = value [in] Type: double Value** (no Help string available)

Property (get): value = pctPermanent [out, retval] Type: double* Value Get/Set percent of faults that are permanent (require repair

Property (put): **pctPermanent = value [in] Type: double Value** (no Help string available)

Property (get): value = Name [out, retval] Type: BSTR* Value

Get/Set name of active PD Element. Returns null string if active element is not PDElement type.

Property (put): Name = value [in] Type: BSTR Value (no Help string available)

Property (get): value = Lambda [out, retval] Type: double* Value Failure rate for this branch. Faults per year including length of line.

Property (get): value = AccumulatedL [out, retval] Type: double* Value accumulated failure rate for this branch on downline

Property (get): value = RepairTime [out, retval] Type: double* Value Average time to repair a permanent fault on this branch, hours.

Property (get): value = Numcustomers [out, retval] Type: long* Value Number of customers, this branch

Property (get): value = Totalcustomers [out, retval] Type: long* Value Total number of customers from this branch to the end of the zone

Property (get): value = ParentPDElement [out, retval] Type: long* Value

Sets the parent PD element to be the active circuit element. Returns 0 if no more elements upline.

Property (get): value = FromTerminal [out, retval] Type: long* Value Number of the terminal of active PD element that is on the \i0

Reclosers Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Variant array of strings with names of all Reclosers in Active Circuit

Property (get): value = Count [out, retval] Type: long* Value Number of Reclosers in active circuit.

Property (get): value = First [out, retval] Type: long* Value Set First Recloser to be Active Ckt Element. Returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value
Iterate to the next recloser in the circuit. Returns zero if no more.

Property (get): value = Name [out, retval] Type: BSTR* Value Get Name of active Recloser or set the active Recloser by name.

Property (put): Name = value [in] Type: BSTR Value (no Help string available)

Property (get): **value = MonitoredObj** [out, retval] Type: BSTR* Value Full name of object this Recloser is monitoring.

Property (put): **MonitoredObj = value [in] Type: BSTR Value**Set monitored object by full name.

Property (get): value = MonitoredTerm [out, retval] Type: long* Value Terminal number of Monitored object for the Recloser

Property (put): MonitoredTerm = value [in] Type: long Value

Property (get): value = SwitchedObj [out, retval] Type: BSTR* Value Full name of the circuit element that is being switched by the Recloser.

Property (put): **SwitchedObj = value [in] Type: BSTR Value** (no Help string available)

Property (get): value = SwitchedTerm [out, retval] Type: long* Value
Terminal number of the controlled device being switched by the Recloser

Property (put): **SwitchedTerm = value [in] Type: long Value** (no Help string available)

Property (get): value = NumFast [out, retval] Type: long* Value Number of fast shots

Property (put): **NumFast = value [in] Type: long Value** (no Help string available)

Property (get): value = Shots [out, retval] Type: long* Value

Number of shots to lockout (fast + delayed

Property (put): **Shots = value [in] Type: long Value** (no Help string available)

Property (get): value = RecloseIntervals [out, retval] Type: VARIANT* Value Variant Array of Doubles: reclose intervals, s, between shots.

Property (get): value = PhaseTrip [out, retval] Type: double* Value Phase trip curve multiplier or actual amps

Property (put): **PhaseTrip = value [in] Type: double Value** *Phase Trip multiplier or actual amps*

Property (get): value = PhaseInst [out, retval] Type: double* Value Phase instantaneous curve multipler or actual amps

Property (put): **PhaseInst = value [in] Type: double Value** (no Help string available)

Property (get): value = GroundTrip [out, retval] Type: double* Value Ground (310

Property (put): GroundTrip = value [in] Type: double Value

Property (get): value = Groundinst [out, retval] Type: double* Value

Ground (310

Property (put): GroundInst = value [in] Type: double Value

Ground (310

Method: Open [void

Open recloser's controlled element and lock out the recloser

Method: Close [void

Close the switched object controlled by the recloser. Resets recloser to first operation.

Property (get): value = idx [out, retval] Type: long* Value

Get/Set the active Recloser by index into the recloser list. 1..Count

Property (put): idx = value [in] Type: long Value

Get/Set the Active Recloser by index into the recloser list. 1.. Count

Relays Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value

Variant array of strings containing names of all Relay elements

Property (get): value = Count [out, retval] Type: long* Value

Number of Relays in circuit

Property (get): value = First [out, retval] Type: long* Value

Set First Relay active. If none, returns 0.

Property (get): value = Next [out, retval] Type: long* Value

Advance to next Relay object. Returns 0 when no more relays.

Property (get): value = Name [out, retval] Type: BSTR* Value

Get name of active relay.

Property (put): Name = value [in] Type: BSTR Value

Set Relay active by name

Property (get): value = MonitoredObj [out, retval] Type: BSTR* Value

Full name of object this Relay is monitoring.

Property (put): MonitoredObj = value [in] Type: BSTR Value

Property (get): value = MonitoredTerm [out, retval] Type: long* Value Number of terminal of monitored element that this Relay is monitoring.

Property (put): **MonitoredTerm = value [in] Type: long Value** (no Help string available)

Property (get): value = SwitchedObj [out, retval] Type: BSTR* Value Full name of element that will be switched when relay trips.

Property (put): **SwitchedObj = value [in] Type: BSTR Value** (no Help string available)

Property (get): value = SwitchedTerm [out, retval] Type: long* Value (no Help string available)

Property (put): **SwitchedTerm = value [in] Type: long Value**Terminal number of the switched object that will be opened when the relay trips.

Property (get): value = idx [out, retval] Type: long* Value Get/Set active Relay by index into the Relay list. 1..Count

Property (put): idx = value [in] Type: long Value Get/Set Relay active by index into relay list. 1..Count

CmathLib Interface

Property (get): value = cmplx [in] Type: double RealPart, [in] Type: double ImagPart, [out, retval] Type: VARIANT* Value

Convert real and imaginary doubles to Variant array of doubles

Property (get): value = cabs [in] Type: double realpart, [in] Type: double imagpart, [out, retval] Type: double* Value

Return abs value of complex number given in real and imag doubles

Property (get): value = cdang [in] Type: double RealPart, [in] Type: double ImagPart, [out, retval] Type: double* Value

Returns the angle, in degrees, of a complex number specified as two doubles: Realpart and imagpart.

Property (get): value = ctopolardeg [in] Type: double RealPart, [in] Type: double ImagPart, [out, retval] Type: VARIANT* Value

Convert complex number to magnitude and angle, degrees. Returns variant array of two doubles.

Property (get): value = pdegtocomplex [in] Type: double magnitude, [in] Type: double angle, [out, retval] Type: VARIANT* Value

Convert magnitude, angle in degrees to a complex number. Returns Variant array of two doubles.

Property (get): value = cmul [in] Type: double a1, [in] Type: double b1, [in] Type: double a2, [in] Type: double b2, [out, retval] Type: VARIANT* Value

Multiply two complex numbers: (a1, b1

Property (get): value = cdiv [in] Type: double a1, [in] Type: double b1, [in] Type: double a2, [in] Type: double b2, [out, retval] Type: VARIANT* Value

Divide two complex number: (a1, b1

Parser Interface

Property (get): value = CmdString [out, retval] Type: BSTR* Value

String to be parsed. Loading this string resets the Parser to the beginning of the line. Then parse off the tokens in sequence.

Property (put): CmdString = value [in] Type: BSTR Value

String to be parsed. Loading this string resets the Parser to the beginning of the line. Then parse off the tokens in sequence.

Property (get): value = NextParam [out, retval] Type: BSTR* Value

Get next token and return tag name (before = sign

Property (get): value = AutoIncrement [out, retval] Type: VARIANT_BOOL* Value

Default is FALSE. If TRUE parser automatically advances to next token after DblValue, IntValue, or StrValue. Simpler when you don't need to check for parameter names.

Property (put): AutoIncrement = value [in] Type: VARIANT_BOOL Value

Default is FALSE. If TRUE parser automatically advances to next token after DblValue, IntValue, or StrValue. Simpler when you don't need to check for parameter names.

Property (get): value = DblValue [out, retval] Type: double* Value Return next parameter as a double.

Property (get): value = IntValue [out, retval] Type: long* Value Return next parameter as a long integer.

Property (get): value = StrValue [out, retval] Type: BSTR* Value Return next parameter as a string

Property (get): value = WhiteSpace [out, retval] Type: BSTR* Value

Get the characters used for White space in the command string. Default is blank and Tab.

Property (put): WhiteSpace = value [in] Type: BSTR Value

Set the characters used for White space in the command string. Default is blank and Tab.

Property (get): value = BeginQuote [out, retval] Type: BSTR* Value

Get String containing the the characters for Quoting in OpenDSS scripts. Matching pairs defined in EndQuote. Default is \i0

Property (put): **BeginQuote = value [in] Type: BSTR Value**

Set String containing the the characters for Quoting in OpenDSS scripts. Matching pairs defined in EndQuote. Default is \i0

Property (get): value = EndQuote [out, retval] Type: BSTR* Value

String containing characters, in order, that match the beginning quote characters in BeginQuote. Default is \iO

Property (put): EndQuote = value [in] Type: BSTR Value

String containing characters, in order, that match the beginning quote characters in BeginQuote.

Default is \i0

Property (get): value = Delimiters [out, retval] Type: BSTR* Value

String defining hard delimiters used to separate token on the command string. Default is , and =.

The = separates token name from token value. These override whitesspace to separate tokens.

Property (put): Delimiters = value [in] Type: BSTR Value

String defining hard delimiters used to separate token on the command string. Default is , and =.

The = separates token name from token value. These override whitesspace to separate tokens.

Method: ResetDelimiters [void

Reset delimiters to their default values.

Property (get): value = Vector [in] Type: long ExpectedSize, [out, retval] Type: VARIANT* Value

Returns token as variant array of doubles. For parsing quoted array syntax.

Property (get): value = Matrix [in] Type: long ExpectedOrder, [out, retval] Type: VARIANT* Value

Use this property to parse a Matrix token in OpenDSS format. Returns square matrix of order specified. Order same as default Fortran order: column by column.

Property (get): value = SymMatrix [in] Type: long ExpectedOrder, [out, retval] Type:

VARIANT* Value

Use this property to parse a matrix token specified in lower triangle form. Symmetry is forced.

LoadShapes Interface

Property (get): value = Name [out, retval] Type: BSTR* Value

Get the Name of the active Loadshape

Property (put): Name = value [in] Type: BSTR Value

Set the active Loadshape by name

Property (get): value = Count [out, retval] Type: long* Value

Number of Loadshape objects currently defined in Loadshape collection

Property (get): value = First [out, retval] Type: long* Value

Set the first loadshape active and return integer index of the loadshape. Returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value

Advance active Loadshape to the next on in the collection. Returns 0 if no more loadshapes.

Property (get): value = AllNames [out, retval] Type: VARIANT* Value

Variant array of strings containing names of all Loadshape objects currently defined.

Property (get): value = Npts [out, retval] Type: long* Value

Get Number of points in active Loadshape.

Property (put): Npts = value [in] Type: long Value

Set number of points to allocate for active Loadshape.

Property (get): value = Pmult [out, retval] Type: VARIANT* Value

Variant array of Doubles for the P multiplier in the Loadshape.

Property (put): Pmult = value [in] Type: VARIANT Value

Variant array of doubles containing the P array for the Loadshape.

Property (get): value = Qmult [out, retval] Type: VARIANT* Value

Variant array of doubles containing the Q multipliers.

Property (put): Qmult = value [in] Type: VARIANT Value

Variant array of doubles containing the Q multipliers.

Method: Normalize [void

Normalize the P and Q curves based on either Pbase, Qbase or simply the peak value of the curve.

Property (get): value = TimeArray [out, retval] Type: VARIANT* Value

Time array in hours correscponding to P and Q multipliers when the Interval=0.

Property (put): TimeArray = value [in] Type: VARIANT Value

Time array in hours correscponding to P and Q multipliers when the Interval=0.

Property (get): value = HrInterval [out, retval] Type: double* Value

Fixed interval time value, hours

Property (put): HrInterval = value [in] Type: double Value

Fixed interval time value, hours.

Property (get): value = MinInterval [out, retval] Type: double* Value

Fixed Interval time value, in minutes

Property (put): MinInterval = value [in] Type: double Value

Fixed Interval time value, in minutes

Method: New [in] Type: BSTR Name

Make a new Loadshape

Property (get): value = Pbase [out, retval] Type: double* Value

Base for normalizing P curve. If left at zero, the peak value is used.

Property (put): Pbase = value [in] Type: double Value

Base for normalizing P curve. If left at zero, the peak value is used.

Property (get): value = Qbase [out, retval] Type: double* Value

Base for normalizing Q curve. If left at zero, the peak value is used.

Property (put): Qbase = value [in] Type: double Value

Base for normalizing Q curve. If left at zero, the peak value is used.

Property (get): value = UseActual [out, retval] Type: VARIANT_BOOL* Value

T/F flag to let Loads know to use the actual value in the curve rather than use the value as a multiplier.

Property (put): UseActual = value [in] Type: VARIANT_BOOL Value

T/F flag to let Loads know to use the actual value in the curve rather than use the value as a multiplier.

Property (get): value = Sinterval [out, retval] Type: double* Value

Fixed interval data time interval, seconds

Property (put): Sinterval = value [in] Type: double Value

Fixed interval data time interval, seconds

Fuses Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value

Variant array of strings containing names of all Fuses in the circuit

Property (get): value = Count [out, retval] Type: long* Value

Number of Fuse elements in the circuit

Property (get): value = First [out, retval] Type: long* Value

Set the first Fuse to be the active fuse. Returns 0 if none.

Property (get): value = Next [out, retval] Type: long* Value

Advance the active Fuse element pointer to the next fuse. Returns 0 if no more fuses.

Property (get): value = Name [out, retval] Type: BSTR* Value

Get the name of the active Fuse element

Property (put): Name = value [in] Type: BSTR Value

Set the active Fuse element by name.

Property (get): value = MonitoredObj [out, retval] Type: BSTR* Value

Full name of the circuit element to which the fuse is connected.

Property (put): MonitoredObj = value [in] Type: BSTR Value

Full name of the circuit element to which the fuse is connected.

Property (get): value = MonitoredTerm [out, retval] Type: long* Value

Terminal number to which the fuse is connected.

Property (put): MonitoredTerm = value [in] Type: long Value

Number of the terminal to which the fuse is connected

Property (get): value = SwitchedObj [out, retval] Type: BSTR* Value

Full name of the circuit element switch that the fuse controls. Defaults to the MonitoredObj.

Property (put): SwitchedObj = value [in] Type: BSTR Value

Full name of the circuit element switch that the fuse controls. Defaults to MonitoredObj.

Property (get): value = SwitchedTerm [out, retval] Type: long* Value

Number of the terminal containing the switch controlled by the fuse.

Property (put): SwitchedTerm = value [in] Type: long Value

Number of the terminal of the controlled element containing the switch controlled by the fuse.

Property (get): value = TCCcurve [out, retval] Type: BSTR* Value

Name of the TCCcurve object that determines fuse blowing.

Property (put): TCCcurve = value [in] Type: BSTR Value

Name of the TCCcurve object that determines fuse blowing.

Property (get): value = RatedCurrent [out, retval] Type: double* Value

Multiplier or actual amps for the TCCcurve object. Defaults to 1.0. Multipliy current values of TCC curve by this to get actual amps.

Property (put): RatedCurrent = value [in] Type: double Value

Multiplier or actual fuse amps for the TCC curve. Defaults to 1.0. Has to correspond to the Current axis of TCCcurve object.

Property (get): value = Delay [out, retval] Type: double* Value

A fixed delay time in seconds added to the fuse blowing time determined by the TCC curve. Default is 0.

Property (put): **Delay = value [in] Type: double Value**

Fixed delay time in seconds added to the fuse blowing time to represent fuse clear or other delay.

Method: **Open [void** *Manual opening of fuse*

Method: Close [void

Close the fuse back in and reset.

Method: IsBlown [void

Current state of the fuses. TRUE if any fuse on any phase is blown. Else FALSE.

Property (get): value = idx [out, retval] Type: long* Value

Get/set active fuse by index into the list of fuses. 1 based: 1..count

Property (put): **idx = value [in] Type: long Value**Set Fuse active by index into the list of fuses. 1..count

Property (get): value = NumPhases [out, retval] Type: long* Value

Number of phases, this fuse.

ISources Interface

Property (get): value = AllNames [out, retval] Type: VARIANT* Value Variant array of strings containing names of all ISOURCE elements.

Property (get): value = Count [out, retval] Type: long* Value Count: Number of ISOURCE elements.

Property (get): value = First [out, retval] Type: long* Value Set the First ISOURCE to be active; returns Zero if none.

Property (get): value = Next [out, retval] Type: long* Value

Sets the next ISOURCE element to be the active one. Returns Zero if no more.

Property (get): value = Name [out, retval] Type: BSTR* Value Get name of active ISOURCE

Property (put): Name = value [in] Type: BSTR Value Set Active ISOURCE by name

Property (get): value = Amps [out, retval] Type: double* Value Get the magnitude of the ISOURCE in amps

Property (put): **Amps = value [in] Type: double Value**Set the magnitude of the ISOURCE, amps

Property (get): value = AngleDeg [out, retval] Type: double* Value Phase angle for ISOURCE, degrees

Property (put): **AngleDeg = value [in] Type: double Value**Phase angle for ISOURCE, degrees

Property (get): value = Frequency [out, retval] Type: double* Value
The present frequency of the ISOURCE, Hz

Property (put): **Frequency = value [in] Type: double Value**Set the present frequency for the ISOURCE