



# SHEET KEYNOTES

1. FURNACE #5 IS A DOWN FLOW UNIT. DISCONNECT AND REMOVE EXISTING FURNACE #5 WITH ASSOCIATED DX COOLING COIL AND FLUE TO CHIMNEY. REMOVE ASSOCIATED FUEL OIL INLINE FILTER AND PIPING BACK TO ABOVE BATHROOM CEILING. REMOVE CONDENSATE PIPING BACK TO EXTERIOR OF EXTERIOR WALL. EXISTING FLOOR SUPPLY DUCTWORK SHALL REMAIN. CONTRACTOR SHALL CLEAN ALL BELOW GROUND DUCTWORK COMPLETE. PREPARE DUCT TO RECEIVE NEW CONNECTION.
2. REMOVE EXISTING RETURN DUCT AND ASSOCIATED FILTER GRILLE.
3. DISCONNECT AND REMOVE EXISTING FURNACE #6. REMOVE EXISTING ASSOCIATED DX COOLING COIL AND FLUE TO CHIMNEY. REMOVE ASSOCIATED FUEL OIL INLINE FILTER AND PIPING BACK TO ABOVE GROUND FUEL OIL TANK. REMOVE RETURN DUCTWORK BETWEEN FURNACES AND SUPPLY DUCT UP TO DEMOLITION LIMIT LINE.
4. DISCONNECT AND REMOVE REFRIGERANT PIPING FROM EXISTING FURNACE #5 AND #6 BACK TO ROOF MOUNTED CONDENSING UNITS. REMOVE REMOTE ROOF MOUNTED CONDENSING UNITS COMPLETE TO INCLUDE ROOF SUPPORTS. CONTRACTOR SHALL EVACUATE AND RETAIN REFRIGERANT FROM SYSTEMS PER EPA REGULATIONS AND STORE IN EPA APPROVED CONTANERS. REMOVE REFRIGERANT PIPING FROM ABOVE CORRIDOR CEILING BACK TO FURNANCES TO INCLUDE ALL HANGERS AND SUPPORTS.



| Revisions | Date        |  |
|-----------|-------------|--|
|           | Description |  |
| No.       |             |  |

COMMUNITY UNITED METHODIST CHURCH  
CLASSROOM HVAC REPLACEMENT

1072 OLD KEMPSVILLE RD  
VIRGINIA BEACH, VA 23464

MECHANICAL ENLARGED AND SECOND FLOOR PLAN - DEMOLITION

|                  |          |
|------------------|----------|
| Project #:       | 23041    |
| Date:            | 08/18/23 |
| Project Manager: | PCS      |
| Designed By:     | PCS      |
| Drawn By:        | BAC      |
| Checked By:      | PCS      |