



The manufacturer
may use the mark:



Revision 1.6, September 3, 2020
Surveillance Audit Due
May 1, 2023



ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#1004

Certificate / Certificat Zertifikat / 合格証

FRS 1103091 C001

exida hereby confirms that the:

DeltaV SIS with Electronic Marshalling
Emerson Automation Solutions
Fisher Rosemount Systems, Inc.
Austin, TX - USA

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7
Logic Solver Requirements: NFPA 72:2016,
NFPA 85:2015, NFPA86:2019, NFPA87:2018,
EN50156-1:2015, EN54-2-A1:2006,
EN50402-1-A1:2004, EN298:2012

and meets requirements providing a level of integrity to:

Systematic Capability: SC3 (SIL 3 Capable)
Random Capability: Type B Element
SIL 3 @ HFT=0 or HFT=1

**Therefore can be used as part of a safety instrumented
system as per IEC 61511.**

**PFH/PFD_{AVG} and Architecture Constraints must be verified
for each application.**

Safety Function: DeltaV SIS will perform the configured safety logic and execute the automatic diagnostics in the specified time period.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



John C. Yozallinas
Evaluating Assessor

[Signature]
Certifying Assessor

FRS 1103091 C001

Systematic Capability: SC3 (SIL 3 Capable)

Random Capability: Type B Element

SIL 3 @ HFT=0 or HFT=1

Therefore can be used as part of a safety instrumented system as per IEC 61511.

PFH/PFD_{AVG} and Architecture Constraints must be verified for each application

DeltaV SIS with
Electronic Marshalling

Systematic Capability :

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated without further "prior use" justification by end user per IEC 61511.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. **For detailed information on failure rates of the DeltaV SIS with Electronic Marshalling, contact the manufacturer.**

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{AVG} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: FRS 11-03-091 R002 V2 R1 or later

Safety Manual for DeltaV SIS: D800058X032, Jan 2020 or later

Application Standards: NFPA 72:2016, NFPA 85:2015, NFPA86:2019, NFPA87:2018, EN50156-1:2015, EN54-2-A1:2006, EN50402-1-A1:2004, EN298:2012

The DeltaV SIS Logic Solver was evaluated as the logic solver portion of a System per the relevant requirements of the listed application standards. All requirements of any Application Standard and the Authority Having Jurisdiction must be met for any particular application. Any additional regulatory requirements that exist must be followed.



80 N Main St
Sellersville, PA 18960