

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085DO0039**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Distributor <i>Vertreiber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Product Category <i>Produktart</i>	Gas fittings: Pressure regulator for LPG (4302)
Product description <i>Produktbezeichnung</i>	Pressure regulator for LPG
Model <i>Modell</i>	902-904-908-954
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CY, CZ, DE, DK, EE, ES, FI, FR, GR, HR, HU, IE, IT, LT, LU, LV, MT, NL, PL, PT, RO, SE, SI, SK
Test reports <i>Prüfberichte</i>	Type testing: 22-1282-00-00 from 12.01.2023 (FGL)
Test basis <i>Prüfgrundlagen</i>	DIN EN 16129 (01.08.2013) EU/2016/426 A III D (09.03.2016)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	12.01.2033 / 22-0469-GEE

10.03.2023 Kir A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der ZertifizierungsstelleDVGW CERT GmbH - notified by the government of the Federal Republic of
Germany and officially registered by the European Commission for conformity
assessment of gas appliancesDVGW CERT GmbH – von der Deutschen Bundesregierung benannte und von
der Europäischen Kommission offiziell registrierte Stelle für die
Konformitätsbewertung von GasgerätenDVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
902	Outlet pressure: 0,1...1; 0,2...2; 0,5...2; 0,5...3 bar Inlet pressure range: 1...16 (P); 0,7...16 (LPG) bar Nominal flow rate: 15...25; 15...40; 20...40 kg/h	First stage high pressure variable regulator
904	Outlet pressure: 0,75; 1,0; 1,5; 3,0 bar Inlet pressure range: 1,25...16 (P); 1,5...16 (P); 2...16 (P); 3,5...16 (P) bar Nominal flow rate: 25; 40 kg/h	First stage high pressure fixed regulator
908	Outlet pressure: 0,75; 1,0; 1,5; 3,0 bar Inlet pressure range: 1,25...16 (P); 1,5...16 (P); 2...16 (P); 3,5...16 (P) bar Nominal flow rate: 25; 40 kg/h	First stage high pressure fixed regulator with PRV
954	Outlet pressure: 0,75; 1,5; 3,0 bar Inlet pressure range: 1,25...16 (P); 2...16 (P); 3,5...16 (P) bar Nominal flow rate: 25; 40 kg/h	High pressure limiter, limiting pressure 1,15/1,8/4,0 bar

Hints of Utilization /Remarks**Verwendungshinweise / Bemerkungen**

Nominal pressure rating: PN 16

Allowable ambient temperature: -20...+50 °C (P, LPG)

Connections at the inlet side: G.1, G.2, G.4, G.5, G.6, G.7, G.9, G.10, G.12, G.13, G.14, G.17, G.18, G.23

Connections at the outlet side: H.1, H.7, H.11, H.19

Type 908 optionally with pressure relief valve (A.1)

DVGW