

ELEVATIONS DRAWING NOTES

SN03 | Part-cantilevered canopy
Structural engineer to design the canopy, its supported outer edge and cantilevered inner end, including wind uplift, deflection, connections and foundations. Provide a designed loadbearing frame at the slatted screen. Decorative slats are non-loadbearing unless expressly designed otherwise by the engineer.

SN05 | Foundations and roof framing
Confirm ground conditions, trees, drains and adjacent foundations before foundation design. Do not reuse conservatory foundations without the engineer's verification. Design roof joists and rooflight trimmers for the complete warm-roof build-up, parapets and imposed loads; coordinate openings before fabrication.

EX01 | Existing external walls
Existing house: mixed buff facing brickwork above a blue engineering-brick plinth to DPC level. Retain outside the indicated alterations; make good disturbed areas with matching bricks and mortar. Confirm brick types and DPC level on site.

EX02 | Existing pitched roof
Existing brown small-format tiles to pitched roof; clay or concrete composition to be confirmed on site. Retain roof covering outside the works. Match replacement tiles where disturbed and weather extension abutments without obstructing existing roof ventilation.

EX03 | Existing windows and doors
Existing windows and external doors comprise mixed white and brown frames, including uPVC, with varied glazing patterns. Retain except where removal or replacement is indicated. Confirm frame materials, opening arrangements and finishes on site.

EX04 | Existing WC flat roof
Existing felt-covered flat roof over the WC is reported to be at the end of its service life. Remove with the WC structure; inspect and make good retained abutments. Do not incorporate the existing covering into the new roof.

EX05 | Conservatory and WC removal
Remove existing conservatory and adjoining flat-roof WC, approximately 3,100 mm projection x 4,350 mm overall width. Isolate services and seal redundant drain connections. Protect retained walls and roof; make good exposed junctions. Confirm demolition extent and any retained foundations on site.

WF01 | Monocouche render
Proprietary monocouche render to indicated walls above DPC; colour Chalk or Silver Pearl, subject to final manufacturer and sample approval. Apply the complete compatible system to the specified substrate, with beads and movement joints. Terminate above DPC; do not bridge the damp-proof course.

WF02 | Blue brick plinth
Blue engineering-brick plinth up to DPC, matching the original house in colour, size, bond and pointing. Coordinate DPC with the floor membrane and external levels; maintain 150 mm clearance above finished ground except at separately detailed accessible thresholds.

WF03 | Horizontal composite cladding
Horizontal composite cladding to the rear canopy surround as indicated. Manufacturer, profile and colour to be agreed from samples. Provide compatible support battens, drained and ventilated cavity, trims and movement allowances.

PD04 | Parapet coping level
Parapet coping: 3,000 mm above proposed terrace, equivalent to 2,850 mm above GFFL. Coping is included in overall extension height, not eaves height. Terrace-relative dimensions are distinct from planning heights; use the ground datum described in PD05.

RF02 | Parapet and copings
Parapet conceals the warm-roof edge; coping level to PD04. Provide weathered copings with drips, secure fixings and sealed joints; turn roof waterproofing up the inner face beneath the coping system. Maintain insulation continuity at the roof edge.

RF03 | Flat rooflights
Three flat rooflights, nominally 1,500 x 1,000 mm each; two over the dining/occasional seating area and one over the bedroom. Confirm whether dimensions refer to the opening or overall unit before ordering. Provide insulated upstands at least 150 mm above the adjacent finished roof surface.

RF05 | Rainwater drainage
Form positive falls to sized roof outlets and rainwater pipes. Provide accessible outlets and an emergency overflow to the parapet-enclosed roof. Confirm discharge route and capacity before construction; keep all roof drainage within the site and clear of door thresholds.

OP01 | East-facing sliding doors
Large glazed sliding doors to the east, garden-facing elevation. Frame material, colour, panel arrangement and opening direction to be confirmed. Coordinate structural opening and deflection tolerances with the supplier. Provide safety glazing, weather seals and a drained threshold; confirm thermal performance and ventilation in the construction specification.

OP02 | East-facing bedroom window
New uPVC window to the bedroom on the east, garden-facing elevation. Colour and opening arrangement to be agreed. Coordinate glazing, ventilation and any required escape opening with the Building Regulations design; confirm clear opening dimensions and sill height before ordering.

PR01 | Entrance canopy
Flat-roof canopy outside the sliding doors; top 2,710 mm above proposed terrace (2,560 mm above GFFL). Provide weatherproof covering, falls, edge trims and drainage clear of the entrance. Structural support and cantilever to SN03; terrace and threshold levels to PR03.

PR02 | Vertical metal screen
Open screen of vertical powder-coated metal slats to one side of the canopy; metal type, section, spacing and colour to be agreed. Fix to a corrosion-protected supporting frame. Retain open gaps between slats. Canopy loads to be carried by the engineer-designed structure, not decorative infill.

GN01 | Drawing scope
Drawings describe the proposed development for planning assessment. They are not construction drawings or a complete Building Regulations specification. Obtain coordinated construction details, structural calculations and Building Control approval before relevant work starts. Refer discrepancies to Noble Architecture before proceeding.

GN02 | Survey and dimensions
Prepared from client-supplied photographs and measurements; Noble Architecture has not undertaken a measured site survey. Verify dimensions, levels, boundaries and existing construction on site before design, ordering or setting out. Use stated dimensions; do not scale for construction. Report discrepancies before work proceeds.

NAVIGATE THIS BUILDING IN 3D

Scan this drawing to enter the 3D model and view the building in full 3D, and to freely navigate and take a tour:

