



Inspection Offer List

Date: 17/09/2026

No of valves Offered: 2

SO No : CD13E
Cust Name : ARCHIRODON CONSTRUCTION (OVERSEAS) COMPANY LIMITED
Cust Ref : 4108-PM-INST-008 Dt. 12/09/2025
Project : ARCHIRODON_ADNOC SE AIP5 PROJECT-ASAB/SAHIL(PKG 1)

Job Number	Po Sln	Valve Sln	Tag No	Model No	Description	Body Sln	BML Test		Seat Leakage Test				Calibration	
							Pressure/ Duration	Test Status	Pressure	Test Medium	SL Class/ Allowable	Test Status	Stroke / Supply	Test Staus
CD13E085	79	25009567	14-01-FCV-1601-01A	58-41611	24", #600 RF, RF Cv: 4500,Ch:L	1102544	117 KSC 10 Min		3.5 KSC	WAT	Class : IV 17.1 NLM		8" 65 PSI	
CD13E086	80	25009568	14-01-FCV-1601-01B	58-41611	24", #600 RF, RF Cv: 4500,Ch:L	1104484	117 KSC 10 Min		3.5 KSC	WAT	Class : IV 17.1 NLM		8" 65 PSI	